

Feasibility Study

Copper Valley Intertie

**State of Alaska, Department of
Community and Regional Affairs,
Division of Energy**

Volume 1

April 1994



Section I

SUMMARY AND CONCLUSIONS

| | |
|--|------|
| A. INTRODUCTION..... | I-1 |
| B. PURPOSE OF STUDY | I-2 |
| C. STUDY METHODOLOGY | I-3 |
| D. PROJECT DESCRIPTION | I-4 |
| 1. Route | I-4 |
| 2. Design and Estimated Cost | I-5 |
| 3. Schedule..... | I-6 |
| 4. Impacts on Railbelt and CVEA Electric Systems..... | I-9 |
| E. ECONOMIC ANALYSIS..... | I-9 |
| 1. Load Forecast..... | I-9 |
| 2. Comparison of Alternatives - Present Value of Future Costs..... | I-14 |
| 3. Comparison of Alternatives - Cost of Power..... | I-16 |
| F. ENVIRONMENTAL REVIEW | I-18 |

| | |
|-------------|--|
| Table I-1: | Unit Cost Estimate Comparison - Transmission Line Construction Only |
| Table I-2: | Intertie Cost Estimate Summary - Apparent Preferred Route Alternative D |
| Table I-3: | Historical and Projected CVEA Energy Requirements (MWh) |
| Table I-4: | Description of Power Supply Scenarios |
| Table I-5: | Summary of Economic Analysis Results - Cumulative Present Value of Comparable System Costs and Benefit/Cost Ratios |
| Table I-6: | Estimated Cost of Power |
| Figure I-1: | Historical and Projected Energy Requirements |
| Figure I-2: | Historical and Projected Energy Sales by Customer Class - Medium Load Growth Scenario |

Section II

INTRODUCTION

| | |
|----------------------------|------|
| A. BACKGROUND..... | II-1 |
| B. PURPOSE OF STUDY | II-2 |
| C. STUDY METHODOLOGY | II-3 |
| D. FORMAT OF REPORT..... | II-4 |

Section III

ROUTE SELECTION

| | |
|---|-------|
| A. BACKGROUND..... | III-1 |
| 1. Cordova Power Supply Study..... | III-1 |
| 2. Northeast Transmission Intertie Project..... | III-1 |
| 3. Sutton to Glennallen 138-kV Transmission Intertie Project..... | III-2 |

Section III

ROUTE SELECTION *(continued)*

- B. METHODOLOGY III-3
 - 1. General III-3
 - 2. Public Meetings III-3
 - 3. Route Reconnaissance Flyovers III-4
 - 4. Ground Reconnaissance III-5
 - 5. Route Selection Methodology III-5
- C. PUBLIC COMMENT SUMMARY III-6
 - 1. Visual Impacts III-6
 - 2. EMF Effects III-7
 - 3. Right-of-Way and Land Ownership III-7
 - 4. State Mental Health Trust Lands III-8
- D. INTERTIE CORRIDOR CHARACTERISTICS III-9
 - 1. Soil Conditions III-9
 - 2. Wetlands III-9
 - 3. Forest Cover III-10
 - 4. Wildlife Habitat III-10
- E. ROUTE SELECTION CRITERIA III-11
- F. DESCRIPTION OF ROUTE SEGMENTS III-12
- G. DESCRIPTION OF ROUTE ALTERNATIVES III-29
 - 1. Route Alternative A, The Northern Route III-29
 - 2. Route Alternative B, The Southern Route III-29
 - 3. Route Alternative C III-30
 - 4. Route Alternative D III-30
- H. ROUTE ALTERNATIVE COMPARISON III-30
 - 1. Methodology III-30
 - 2. A First Comparison III-31
 - 3. Sensitivity Analysis III-31
 - 4. Route Alternative Comparison III-31
 - 5. Apparent Preferred Route Alternative III-33

- Table III-1: Segment Data Tabulation and Route Alternatives
- Table III-2: Preliminary Comparison of Impacts Uniform Category Weights
- Table III-3: Route Alternative Comparison Sensitivity Analysis

Figure III-1: Study Route Alternative Maps

Section IV

FEASIBILITY DESIGN - TRANSMISSION LINE

- A. SYSTEM CONFIGURATION OPTIONS IV-1
 - 1. Voltage Selection for the Intertie IV-1
 - 2. Location of the Autotransformer on MEA System IV-1
 - 3. Substation Switching Arrangements IV-2
 - 4. Future Regional Grid Concerns IV-3

Section IV

FEASIBILITY DESIGN - TRANSMISSION LINE (continued)

| | | |
|-----|--|-------|
| B. | SUMMARY OF PTI SYSTEM STUDIES..... | IV-3 |
| 1. | Original Study Conclusions | IV-3 |
| 2. | Supplemental Study | IV-4 |
| 3. | Discussion of Intertie Operation and SVC..... | IV-4 |
| C. | DESIGN CRITERIA | IV-6 |
| 1. | Background..... | IV-6 |
| 2. | Project Location | IV-7 |
| 3. | Electric Loading | IV-7 |
| 4. | Ampacity..... | IV-8 |
| 5. | Weather Data | IV-9 |
| 6. | Design Loadings and Loading Zones..... | IV-16 |
| 7. | Overload Capacity Factors and Safety Factors | IV-17 |
| 8. | Conductor Sag-Tension Limits..... | IV-18 |
| 9. | Failure Containment and Sequence..... | IV-19 |
| 10. | Electrical Clearances | IV-20 |
| 11. | Foundations, Guys and Anchors..... | IV-22 |
| 12. | Insulator Assemblies..... | IV-22 |
| 13. | ROW Width..... | IV-22 |
| D. | FEASIBILITY DESIGN ALTERNATIVES | IV-23 |
| 1. | Background..... | IV-23 |
| 2. | Methodology | IV-23 |
| 3. | Conductor Selection..... | IV-24 |
| 4. | Structure Selection | IV-31 |
| 5. | Foundation and Anchor Selection..... | IV-39 |
| 6. | Anchorage-Fairbanks Intertie Structure Study | IV-43 |
| 7. | Construction Plan | IV-44 |

Table IV-1: Conductor Operating Temperatures

Table IV-2: Average of Annual Minimum of Monthly Average of Daily Minimum Temperatures

Table IV-3a: Extreme Ice Assumptions in the Absence of Statistical Data

Table IV-3b: Probability of Occurrence of 1-SD and 2-SD Ice Loadings

Table IV-4: Reduction of MRI 50-Year Data for Intertie Study

Table IV-5: Assumed Study Design Criteria

Table IV-6: Overload Capacity Factors

Table IV-7: Conductor Tension Limits

Table IV-8: Electrical Clearances

Table IV-9: Maximum Sag Comparison

Table IV-10: Horizontal Phase Spacing Comparison

Table IV-11: ROW Width for Same Given Maximum Span

Table IV-12: Maximum Spans for 125-ft Right-of-Way

Table IV-13: ROW Width Requirements Based on Conductor Blowout and Maximum Spans - Loading Zones 1 and 2

Table IV-14: Comparison of Wood H-Frame Spans

Table IV-15: Comparison of Steel H-Frame Spans

Section IV

FEASIBILITY DESIGN - TRANSMISSION LINE *(continued)*

- Table IV-16: Comparison of X-Frame Spans
- Table IV-17: Single Pole Comparison

- Figure IV-1: Tangent X-Frame Structure
- Figure IV-2: Tangent Wood H-Frame Structure
- Figure IV-3: Tangent Single Wood Pole
- Figure IV-4: Tangent Single Steel Pole
- Figure IV-5: Running Angle Three Pole Structure
- Figure IV-6: Typical Steel A-Frame Structure Long Span Crossings
- Figure IV-7: Right-of-Way Cross Section - Heavy Forest
- Figure IV-8: Right-of-Way Cross Section - Sparse / Low Forest

Section V

FEASIBILITY DESIGN - SUBSTATIONS

- A. BACKGROUND V-1
- B. NEW SUBSTATION NEAR O'NEILL SUBSTATION V-1
- C. PUMP STATION NO. 11 SUBSTATION EXPANSION V-2

- Figure V-1: System One-Line Diagram
- Figure V-2: Layout New Sutton Substation
- Figure V-3: Pump Station No. 11 Substation Layout

Section VI

PROJECT COST ESTIMATES

- A. INTRODUCTION AND BACKGROUND VI-1
 - 1. Introduction VI-1
 - 2. Final Report Cost Estimate Adjustments - A Discussion VI-1
- B. TRANSMISSION LINE CONSTRUCTION COST ESTIMATES VI-2
 - 1. Methodology VI-2
 - 2. Cost Assumptions VI-7
 - 3. Feasibility Cost Estimates - Transmission Line Construction VI-10
 - 4. Transmission Line Cost Estimate Reasonableness VI-11
- C. SUBSTATION CONSTRUCTION COST ESTIMATES VI-13
 - 1. Methodology VI-13
 - 2. Cost Assumptions VI-14
 - 3. Feasibility Cost Estimates - Substation Construction VI-15
- D. ENGINEERING COSTS VI-18
- E. CONSTRUCTION MANAGEMENT COSTS VI-18
- F. PERMITTING COSTS VI-19
- G. OWNER COSTS VI-19
- H. TOTAL PROJECT DEVELOPMENT COST ESTIMATES VI-19
- I. OPERATION AND MAINTENANCE COSTS VI-20
 - 1. Basic O&M Cost Estimate VI-20
 - 2. Impact of Using Steel X-Frames on O&M Costs VI-21

Section VI

PROJECT COST ESTIMATES *(continued)*

| | |
|--------------|---|
| Table VI-1: | Right-of-Way Clearing Cost Assumptions |
| Table VI-2: | Unit Cost Estimate Comparison Transmission Line Construction Only |
| Table VI-3: | Mobilization Costs |
| Table VI-4: | Transmission Line Feasibility Level Construction Cost Estimates - Least Cost Option - All Route Alternatives |
| Table VI-5: | Construction Cost Comparison - Swan Lake, Tyee Lake and Intertie |
| Table VI-6: | Tabulation of Historical Transmission Line Construction Costs |
| Table VI-7: | Total Intertie Development Cost Estimates - All Alternatives |
| Table VI-8: | Annual Operation and Maintenance Costs - Steel H-Frame Construction Alternative |
| Table VI-9: | Annual Operation and Maintenance Costs - Wood Construction Alternative |
| Table VI-10: | Annual Operation and Maintenance Costs - Steel X-Frame Construction Alternative |

Section VII

PROJECT SCHEDULE

| | | |
|----|--|-------|
| A. | PROJECT DEVELOPMENT ORGANIZATION | VII-1 |
| 1. | CVEA Acts as Project Manager..... | VII-1 |
| 2. | CVEA Contracts Externally for Project Manager | VII-2 |
| 3. | Turnkey (Design/Build) | VII-2 |
| 4. | Hybrid - CVEA as Project Manager & Turnkey (Design/Build)..... | VII-2 |
| B. | SCHEDULE ASSUMPTIONS | VII-3 |
| 1. | Project Financing..... | VII-3 |
| 2. | Environmental Assessment..... | VII-3 |
| 3. | Permitting..... | VII-3 |
| 4. | Right-of-Way Easement Acquisition | VII-4 |
| 5. | Preliminary Design | VII-4 |
| 6. | Final Design | VII-4 |
| 7. | Contracts..... | VII-5 |
| 8. | Energization Date | VII-6 |
| C. | PROJECT SCHEDULE COMPARISONS | VII-6 |

Figure VII-1: Project Schedule

Section VIII

ELECTRIC LOAD FORECAST

| | | |
|----|--|---------|
| A. | INTRODUCTION..... | VIII-1 |
| B. | METHODOLOGY | VIII-1 |
| C. | ASSUMPTIONS OF THE LOAD FORECAST..... | VIII-4 |
| D. | LARGE COMMERCIAL CUSTOMERS | VIII-9 |
| 1. | Petro Star Refinery | VIII-9 |
| 2. | Seafood Processors..... | VIII-10 |
| 3. | Alyeska Pipeline Service Company | VIII-11 |

Section VIII

ELECTRIC LOAD FORECAST *(continued)*

- 4. State of Alaska Department of Mental Health..... VIII-11
- 5. City of Valdez VIII-12
- 6. Other Large Commercial Customers VIII-12
- 7. Potential New Large Loads VIII-12
- E. LOAD FORECAST PROJECTIONS VIII-13
 - 1. Medium Case Scenarios..... VIII-13
 - 2. High Case Scenario VIII-19
 - 3. Low Case Scenario..... VIII-21
- F. CONSIDERATIONS AND LIMITATIONS..... VIII-22
- G. CONCLUSIONS VIII-22

Table VIII-1: Load Forecast Assumptions for High, Medium, and Low Case Scenarios

Table VIII-2: Historical and Projected CVEA Energy Requirements

Table VIII-3: Historical and Projected CVEA Peak Demand

Figure VIII-1: Copper Valley Electric Association - Population

Figure VIII-2: DOR-Alaska North Slope Production

Figure VIII-3: Energy Sales by Class - Medium Cases

Figure VIII-4: Residential Usage per Customer

Figure VIII-5: Energy Requirements

Figure VIII-6: Peak Demand

Section IX

POWER SUPPLY EVALUATION

- A. OVERVIEW..... IX-1
- B. CVEA'S EXISTING POWER SUPPLY SYSTEM IX-2
 - 1. Solomon Gulch Project IX-2
 - 2. Existing Diesel Generation Capacity IX-3
- C. PLANNING RESERVE CRITERIA..... IX-5
- D. PROJECTED POWER SUPPLY REQUIREMENTS IX-6
- E. USE OF THE INTERTIE..... IX-9
- F. ALTERNATIVE RESOURCE OPTIONS TO MEET FUTURE CVEA POWER SUPPLY NEEDS..... IX-11
 - 1. New Diesel Generation IX-11
 - 2. New Hydroelectric Facilities IX-13
 - 3. Valdez Coal-Fired Generation Plant IX-16
 - 4. Conservation Potential IX-17
- G. SAFETY AND RELIABILITY ISSUES IX-19

Table IX-1: Solomon Gulch Hydroelectric Project Estimated Available Energy Generation

Table IX-2: CVEA Generating Resources - Valdez Plant

Table IX-3: CVEA Generating Resources - Glennallen Plant

Table IX-4: Generation Reserve Criteria

Section IX

POWER SUPPLY EVALUATION *(continued)*

| | |
|--------------|--|
| Table IX-5: | Project Cost of Power from CEA |
| Table IX-6: | Estimated Costs for New Diesel Generators |
| Table IX-7: | CVEA Conservation Program Assessment - Total Estimated Energy and Demand Savings and Total Estimated Costs |
| Figure IX-1: | Peak Load Requirements and Existing Generation Capacity - Valdez Load Center, Winter Peak |
| Figure IX-2: | Peak Load Requirements and Existing Generation Capacity - Glennallen Load Center, Winter Peak |
| Figure IX-3: | Projected Energy Requirements and Resources - Winter Period |
| Figure IX-4: | Projected Energy Requirements and Resources - Summer Period |

Section X

EVALUATION OF ALTERNATIVE POWER SUPPLY PLANS AND ECONOMIC ANALYSIS

| | | |
|----|---|------|
| A. | OVERVIEW..... | X-1 |
| B. | METHODOLOGY | X-1 |
| 1. | Resource Plans and Energy Generation | X-1 |
| 2. | Economic Analysis | X-2 |
| C. | PRINCIPAL ASSUMPTIONS | X-3 |
| D. | DESCRIPTION OF ALTERNATIVE RESOURCE SCENARIOS | X-6 |
| 1. | All Diesel Case..... | X-7 |
| 2. | Intertie Case | X-8 |
| 3. | Allison Lake Case..... | X-8 |
| 4. | Silver Lake Case | X-9 |
| 5. | Glennallen Coal Project Case..... | X-10 |
| 6. | Conservation Case..... | X-10 |
| E. | COMPARISON OF ECONOMIC ANALYSIS RESULTS | X-12 |
| F. | COST OF POWER AND FINANCE CONSIDERATIONS..... | X-15 |

| | |
|------------|--|
| Table X-1: | Estimated Costs and Operating Characteristics of Resource Options |
| Table X-2: | Year of Generation Additions and Retirements for the Alternative Resource Plans |
| Table X-3: | Summary of Economic Analysis - Cumulative Present Value of Comparable System Costs |
| Table X-4: | Comparison of Benefits and Costs - Benefit/Cost Ratios |
| Table X-5: | Estimated Cost of Power |

| | |
|------------|--|
| Appendix A | - Route Selection Evaluation Documentation |
| Appendix B | - Preliminary Design Documentation |
| Appendix C | - Sample Cost Estimating Sheets |
| Appendix D | - Selected Material Cost Quotes |
| Appendix E | - Technical Review Meeting Summary |
| Appendix F | - Miscellaneous Documents |

- Appendix G - Diesel Generator Emissions Limitations
- Appendix H - Review of Valdez and Glennallen Coal-Fired Generation Plants
- Appendix I - Conservation Analysis
- Appendix J - Resource Model Outputs
- Appendix K - Petro Star Valdez Refinery - Expansion Assessment
- Appendix L - Economic Analysis Methodology Issues

(PROVIDED AS A SEPARATE BOUND DOCUMENT.)

VOLUME 2

- Appendix M - Supplement to Environmental Review
- Appendix N - Environmental Review By Dames & Moore, Inc. and
Initial Public Comment
- Appendix O - Electric System Analysis By Power Technologies, Inc.

(PROVIDED AS A SEPARATE BOUND DOCUMENT.)

VOLUME 3

- Appendix P - Transcripts of Public Testimony
- Appendix Q - Public Comment on Draft Report

Copyright 1994, R. W. Beck
All Rights Reserved.

SUMMARY AND CONCLUSIONS

A. INTRODUCTION

In 1992, the Copper Valley Electric Association (CVEA), a rural electric cooperative that serves the Glennallen and Valdez areas, prepared a screening level cost estimate for a 138-kV transmission line between Sutton and Glennallen (the "Intertie"). Following development of its cost estimate, CVEA prepared an economic analysis showing that the Intertie could provide economic benefits to the electric customers of CVEA. At that time CVEA requested that the Alaska Energy Authority (Authority) conduct a feasibility study of the Intertie that would conform with statutory requirements for proposed Authority projects. R. W. Beck and Associates was retained by the Authority in January 1993 to perform the feasibility study, the results of which are presented in this report. As a result of State legislation that took effect in August 1993, oversight responsibility for this study was transferred from the Authority to the Department of Community and Regional Affairs, Division of Energy (Division).

In May 1993, the State Legislature appropriated \$35 million for payment as a zero-interest, 50-year loan to the participating utilities for design and construction of the Intertie. According to this legislation, the appropriation "is contingent upon the completion of a feasibility study and finance plan satisfactory to the Department of Community and Regional Affairs as set out in former AS 44.83.181." The referenced statute requires that a feasibility study include "a comparative analysis of all reasonable alternatives to construction of the proposed project." The associated regulations further specify that the comparison of alternatives must be conducted with respect to economic, environmental, and technical factors; and that the present value of future costs to meet long-term power requirements in the region must be estimated for each plan and compared. The overall methodology of this feasibility study is dictated by these statutory and regulatory requirements.

CVEA presently sells electric power to approximately 3,000 member-customers in its service territory which includes Valdez, Glennallen and other communities in the Copper River Valley area. CVEA maintains two offices and two power plants, one each in Valdez and Glennallen. The primary source of power supply for CVEA is hydroelectric generation from the 12-megawatt (MW) Solomon Gulch Hydroelectric Project (the "Solomon Gulch Project"), located near Valdez and owned by the State. The full generating capability of the Solomon Gulch Project is sold to CVEA pursuant to a long-term power sales agreement. Since the Solomon Gulch Project does not have the capability to provide all the power needs of CVEA's customers, power generated by diesel generators located in both Valdez and Glennallen is used to supplement the output of the Solomon Gulch Project.

In calendar year 1992, CVEA sold 54,602 megawatt-hours (MWh) of electric energy to its customers. Of this amount 27%, 71%, and 2% was sold to CVEA's residential, commercial and public building customer classes, respectively. CVEA's peak demand in 1992 was 10.9 MW. CVEA's total energy requirements in 1992 were 62,481 MWh, of which 40,880 MWh was supplied by the Solomon Gulch Project and 21,601 MWh was supplied by diesel generators. Beginning in January 1993, CVEA began supplying power to the Petro Star refinery, a new industrial facility in Valdez that produces refined fuels from oil extracted from the Trans-Alaska pipeline. The Petro Star refinery is CVEA's largest customer. During August 1993, Petro Star purchased 1,165 MWh of electric energy from CVEA and had a peak

demand of 1,790 kW. Total energy needs for Petro Star for calendar year 1993 are estimated to be 12,200 MWh.

The Intertie would connect the electric system of CVEA directly to the electric system of the Matanuska Electric Association (MEA) and indirectly, through MEA's transmission system, to the electric systems of Alaska's Railbelt utilities. It is expected that with the Intertie, CVEA would purchase power generated at gas-fired generating plants by either the Chugach Electric Association (CEA) or Anchorage Municipal Light and Power, utilities located in the Anchorage area. Power purchased from the Anchorage area utilities would be used by CVEA to offset diesel generation in Glennallen and Valdez. CVEA is presently an isolated electric system with no interconnections to any other electric utilities.

B. PURPOSE OF STUDY

This feasibility study is intended to define the design and routing criteria and estimated costs related to development of the Intertie, to provide a feasibility level environmental analysis, and to assess the costs of the Intertie as compared to other resource alternatives. The feasibility study includes the following principal tasks:

1. Review the Intertie route options defined in previous studies and identify other possible routing alternatives and define preferred alternatives.
2. Develop a feasibility level design of the Intertie.
3. Develop a construction cost estimate and construction schedule for the Intertie.
4. Develop an estimate of annual operations and maintenance costs for the Intertie.
5. Conduct a review of the environmental factors related to the Intertie. Meet with and solicit input from various governmental and public agencies concerning environmental and other institutional constraints which may affect construction of the Intertie.
6. Conduct public meetings at Sutton, Glennallen and other affected communities to obtain comment concerning the Intertie from the general public.
7. Prepare an environmental report which can serve as the basis for subsequent environmental studies.
8. Compare significant environmental impacts estimated for the most competitive alternatives.
9. Conduct an electric system analysis of the electric systems of CVEA and the Railbelt utilities to determine the effects on system stability and performance resulting from interconnected operation if the Intertie were constructed.
10. Prepare a forecast of CVEA's electric power requirements for the next twenty years.
11. Review and define the costs and operating characteristics of alternative power supply options, including conservation, that may be available to CVEA in the future.

12. Conduct an economic analysis comparing the life-cycle costs and benefits of the Intertie to those of alternative resource scenarios.
13. Prepare a draft report summarizing the findings of the feasibility study.
14. Conduct a final set of public meetings to present the findings of the feasibility study and solicit public comment.
15. Prepare a final report following the receipt of comments on the draft report from the Division and others.

C. STUDY METHODOLOGY

The feasibility study was conducted as an independent study of the Intertie and its identified alternatives and involved the efforts of several engineering, environmental, public policy and economic specialists. R. W. Beck developed the Intertie route alternatives, preliminary design, cost estimate and construction schedule, and also prepared the electric load forecast, the evaluation of alternative power supply options and the economic analysis. Dames & Moore, Inc. of Anchorage conducted an environmental analysis and prepared an environmental report which is included as an appendix to this report. Following review of the draft feasibility study, the environmental analysis was supplemented by R.W. Beck. Power Technologies, Inc. conducted the electric system analysis and provided a report which is also included as an appendix. Both the environmental review and the electric system analysis were used as input to the feasibility level design and cost estimate of the Intertie. In addition, comments received during the public meetings and written comments received from the general public during the course of the feasibility study were reviewed and considered in the development of the analysis. Written comments and transcripts of formal public testimony received during the course of the study are also included as an appendix.

Alternative design and routing criteria for the Intertie were gathered from previous studies and new investigations. These criteria were evaluated based on past experience with similar projects in Alaska and elsewhere. Discussions were held with utility and Authority engineers to solicit input with regard to the basic design and routing criteria. Both the environmental review and the electric system analysis relied upon the routing and design characteristics of the Intertie as part of the basis for their analysis. The electric load forecast that was prepared as part of the feasibility study used a model that was developed to relate energy usage in the CVEA service territory to projected future changes in population, employment, income and other factors.

The review of power supply alternatives available to CVEA was conducted using, for the most part, information developed by others in previous studies. An independent review of a proposed coal-fired generating project was conducted as part of the feasibility study. The economic analysis that was conducted for the feasibility study projected the comparable costs of power supply for CVEA for the various resource alternatives over the expected lifetime of the Intertie and then accumulated the present value of these costs. This method of economic analysis was employed by the Authority for many years in its evaluation of generation and transmission projects throughout the State and is a standard approach for electric utility least cost planning analyses.

Specific descriptions of the methodology incorporated in the various components of the feasibility study are included throughout the sections of the report. Assumptions used throughout the study are also identified in the applicable sections of the report.

Significant effort was extended to gather and incorporate input from local communities, utilities and State and Federal agencies that will be affected by the Intertie. Advertised public meetings were held in Sutton, Glennallen, Chickaloon, the Glacier View area, and Valdez to introduce the general characteristics of the Intertie and obtain comment. A meeting was held with various State and Federal agencies for additional comment and input. Discussions were held with staff members of CVEA and MEA and a design criteria review meeting was conducted with the Authority, CVEA and other local utility and engineering representatives to obtain input. Historical operating and other technical data was received from CVEA and used in the development of the overall analysis.

D. PROJECT DESCRIPTION

1. Route

The Intertie would interconnect the Railbelt electric system at Sutton to the electric system of CVEA at Glennallen and would traverse a distance of approximately 135 miles. Initially, two route alternatives were considered, one relatively close to the Glenn Highway and one farther north. These two routes were both identified in previous studies with the northern route having been proposed by a citizen's group as an alternative to a proposed transmission line near the Glenn Highway. The two initial route alternatives evolved into four route alternatives after several new route segments were identified as part of this feasibility study. The four routes, identified in this study as Route Alternatives A, B, C and D, were compared and an "apparent preferred route" alternative was identified. The route identification and comparison process entailed review of previous studies for transmission lines in the same area, ground and aerial reconnaissance, review of public comment, and the compilation of information on property ownership, wildlife habitat, forest cover and other environmental characteristics affecting route alignments. The apparent preferred route and the other alternative route segments are shown in Figure III-1 and are identified by route segment.

All route alternatives were, to the extent possible, sited to minimize visual impact and to avoid private and, to a lesser extent, native-owned lands. The transmission line was also routed at least 600 feet from known occupied structures in response to public concerns over magnetic fields. At 600 feet from the transmission line, the magnetic field from the line under maximum electrical loading is less than 0.1 milligauss, well below typical ambient field levels within housing units.

A set of evaluation criteria was established and applied with a route evaluation matrix procedure to determine the relative advantages and disadvantages of each route. The evaluation process that was conducted was limited and was not intended to take the place of a formal assessment of the various route options that will be prepared further into the development process. Our limited evaluation procedure considered four categories: environmental, land use, construction and technical issues, and estimated cost. Specific objective criteria in each category were developed and measured. Examples of the criteria are the number of anadromous streams crossed by the transmission line, the distance traversed in wetlands and the unit cost per mile.

An apparent preferred route, Route Alternative D, was identified. This route alternative is shown in bold on the base maps at the end of Section III of this report. It proceeds from Sutton to Simpson Cabin on Boulder Creek, then along the southern flank of Anthracite Ridge to a point west of the Victory Road area. Route Alternative D would pass north of Strelshla Mountain and continue up Hicks Creek, Alfred Creek and Crooked Creek before turning east into the Copper River Basin. The route continues in a general easterly direction from Crooked Creek remaining from two to six miles north of the Glenn Highway until it turns south and crosses the highway approximately five miles west of Glennallen.

The apparent preferred route alternative would not be visible to travelers along the Glenn Highway except possibly for short distances where the transmission line crosses Granite Creek, near Strelshla Mountain and where the transmission line crosses the Glenn Highway approximately five miles west of Glennallen. Brief glimpses of the Intertie may be possible from the Glenn Highway between Chickaloon and Victory Road depending on the perspective of the viewer. The apparent preferred route alternative avoids to a significant extent the Matanuska Valley Moose Range (MVMR), privately-owned land, native lands and unpatented mining claims. The apparent preferred route alternative is only marginally longer than the shortest route alternative and not significantly different in cost.

Route Alternative A differs from the "apparent preferred route" by going up Boulder Creek and across Chitna Pass rather than traversing the southern flank of Anthracite Ridge to Strelshla Mountain and on into the Hicks Creek area. Significant public comment was received from residents in this general area indicating a preference for the Boulder Creek route rather than the Anthracite Ridge route. On the basis of this apparent expression of community preference, it is recommended that additional consideration be given to Route Alternative A as well as Route Alternative D in any future route selection process for the Intertie.

2. Design and Estimated Cost

The Intertie is presently configured as a 138-kilovolt (kV) single circuit transmission line originating at a new substation to be located approximately 0.7 mile west of Sutton and terminating at the Pump Station No. 11 Substation in Glennallen. Improvements and additions will be needed at the Pump Station No. 11 Substation to accommodate the Intertie. No consideration was given in the preliminary design of the Intertie included in this study for future use of the Intertie as a 230-kV link in a second transmission interconnection between Anchorage and Fairbanks. To upgrade the Intertie for this purpose would require essentially dismantling the 138-kV line, constructing a new 230-kV line, and probable acquisition of additional right-of-way.

Seven types of transmission tangent structures (the structures that support the transmission line along straight runs) were investigated for the Intertie. These included self-supporting single steel and wood poles, self-supporting steel and wood H-frame structures, both braced and unbraced, and the guyed steel X-frame structure commonly used in Alaska. Detailed engineering computations were performed for three conductor options and four loading zones which differentiate primarily between the ice and wind conditions which will affect the Intertie along its route. The higher the number of the loading zone, the more significant the ice and wind loading conditions and, consequently, the stronger the structures must be. Based on evaluation of the seven structure types which we reviewed, self-supporting steel H-frames were selected as the lowest cost tangent structure for the Intertie. These structures would be made of self-weathering steel which would appear a dull, reddish-brown in color, similar in appearance to wood H-frame structures. Structure heights would be approximately 60-85 ft above ground and structures would be approximately 1,100 ft apart.

The right-of-way for the Intertie would be typically 100-125 ft wide with a cleared swath of 50-75 ft immediately below the transmission line with the width of the clearcut depending on adjacent forest cover height. A primitive trail would be grubbed along the right-of-way where terrain permits for moving equipment. Although existing access to the right-of-way that may be usable for construction purposes is limited to seven known locations, a more detailed plan for right-of-way access will be prepared during the right-of-way acquisition phase of Intertie development. Potential access points along existing roads, tractor trails, and trails are indicated on the maps at the end of Section III. Construction methods are expected to employ a combination of helicopters and ground equipment.

A detailed cost estimating model was prepared to estimate the cost of construction and materials for the different Intertie route alternatives and design alternatives. Costs for the substation additions and improvements, right-of-way acquisition and clearing, engineering and construction management, permitting, and owner's costs were developed separately. The estimated costs as developed with the cost estimation model for the direct construction cost of the Intertie on a cost per mile basis are shown in Table I-1. The total estimated development cost of the Intertie is shown by major classification in Table I-2. Generally, the lowest unit cost option for each loading zone was applied to the different lengths in each zone to compare the four route alternatives and the costs for the route alternatives varied between \$47,604,000 and \$49,607,000. The total estimated cost for the apparent preferred route alternative is \$47,604,000 in 1993 dollars as shown in detail in Table I-2.

Table I-1
Unit Cost Estimate Comparison
Transmission Line Construction Only
 (Thousands of 1993 Dollars per Mile)⁽¹⁾⁽²⁾⁽³⁾

| Options \ Conductor | LOADING ZONE 1 | | | LOADING ZONE 2 | | | LOADING ZONE 3 | | | LOADING ZONE 4 | |
|------------------------|----------------|------|----------|----------------|------|----------|----------------|------|----------|----------------|--------|
| | Dove | Teal | T2Linnet | Dove | Teal | T2Linnet | Dove | Teal | T2Linnet | Teal | 37#9AW |
| Single Steel Pole | 238 | 239 | 234 | | | | | | | | |
| Single Wood Pole | 294 | 276 | 314 | | | | | | | | |
| Guyed Steel X-Frame | 253 | 247 | 251 | 272 | 270 | 267 | 293 | 292 | 292 | 475 | 430 |
| Steel Unbraced H-Frame | 240 | 227 | 237 | 229 | 223 | 237 | 266 | 245 | 248 | 467 | 391 |
| Steel Braced H-Frame | 259 | 235 | 257 | | | | 283 | 271 | 258 | 468 | 377 |
| Wood Unbraced H-Frame | | | | 230 | 238 | 235 | | | | | |
| Wood Braced H-Frame | 247 | 252 | 245 | | | | 278 | 255 | 267 | | |

- (1) Includes mobilization/demobilization @ 5%, material contingency @ 10%, installation contingency @ 20%.
- (2) Does not include right-of-way clearing costs.
- (3) Unit costs based on Route Alternative D. *Shaded areas were not estimated.

3. Schedule

A preliminary schedule for total project implementation was prepared as part of the feasibility study. This schedule anticipates that environmental studies would be undertaken beginning in September 1994. The schedule further expects completion of the Intertie in late 1998 with environmental work, permitting,

and right-of-way acquisition occurring through spring 1996; engineering from 1995 to 1996; and construction including right-of-way clearing, from mid-1996 to fall 1998. If an Environmental Impact Statement is determined to be required, the schedule may be delayed.

4. Impacts on Railbelt and CVEA Electric Systems

Electric system studies were performed by Power Technologies, Inc. to determine the impacts on operation of the potentially interconnected electric systems of the Railbelt utilities and CVEA. These studies included steady state load flow modeling, switching studies, and transient stability analysis with a maximum electrical load of 10 MW over the Intertie. Supplemental computations were performed to identify the maximum reliable power transfer limit over the Intertie.

The system studies determined that the Intertie is conditionally feasible from the standpoint of its impacts on the Railbelt and CVEA electric systems. A 10 megavolt-ampere reactive (MVAR) unswitched shunt reactor was indicated as necessary for line energization and control of voltage under light load conditions and has been included in the Intertie cost estimate. The supplemental computations showed that power transfers above about 15 MW over the Intertie would exceed transfer limits under single contingency outage conditions on the Railbelt electric system. At this transfer level and above, an outage of certain components in the Railbelt system would cause unacceptable voltage reductions for CVEA and MEA.

If only the CVEA system load grows, the Intertie system intact transfer limit is 27 MW, limited by low voltage conditions on the southern CVEA system that would exist above that transfer amount. If MEA and CVEA loads grow at the same rate, the Intertie system intact transfer limit is 23.7 MW, limited by low voltage conditions on the MEA system. Under single contingency outage conditions on the Railbelt system, the transfer limit drops to 13.7 MW or 14.9 MW depending on the specific outage condition, limited by low voltage or thermal constraints on the MEA system. These limits assume that shunt reactors are disconnected, allowing full reactive voltage support for the MEA system from the Intertie line capacitance. With the reactors connected the transfer limit would be lower.

Assuming that no improvements are made to the existing Railbelt transmission system, transmission of power at the identified 23.7 MW steady state transfer limit would risk voltage collapse in the Railbelt if one of the primary single contingency outage events were to occur on the Railbelt system. The studies indicated that a static VAR compensator (SVC) system would be desirable to dampen possible severe voltage fluctuations due to minor load changes on the CVEA system and to allow reliable transfers of power above the single contingency limit of approximately 15 MW. Alternatively, CVEA could elect to sever the Intertie for the condition of a 15 MW transfer and a single contingency outage on the Railbelt system. CVEA would have to support its load with a mix of internal generation resources and possibly load-shedding. For this reason we have included the costs of CVEA diesel generation to supply the equivalent Intertie import load based on 98% availability of the Intertie. The estimated cost of the Intertie provided herein includes the cost of a shunt reactor but does not include the cost of a SVC system since CVEA can choose to operate the Intertie in such a way that it is disconnected from the Railbelt above a certain transfer limit and a single contingency outage condition on the Railbelt. CVEA has indicated that it is willing to operate the Intertie in this manner.

E. ECONOMIC ANALYSIS

1. Load Forecast

A twenty-year forecast of CVEA's power requirements was included as part of the feasibility analysis to assess the future need for electric power in CVEA's Valdez and Copper River service areas. The

forecasting effort included the development of econometric models to relate electricity requirements to population, employment, income and other factors. The power requirements of CVEA's fifteen largest commercial customers were forecasted separately based on historical trends in power usage and expected economic trends as well as anticipated changes in power requirements provided by the individual customers. Previous studies of the area's economy were reviewed and interviews with area planners, business managers and civic leaders were conducted.

The economy of the Valdez and Copper River Valley areas is predominantly influenced by the petroleum industry, seafood processing, tourism and state and federal spending. Estimated population in Valdez has increased from 3,079 in 1980 to an estimated 4,326 in 1992, a 2.9% average annual rate of growth. Population in the Copper River Valley has increased from 2,721 to an estimated 2,832 over the same period, a 0.3% average annual rate of growth. CVEA's largest commercial customers include the Petro Star refinery in Valdez, the Alyeska Pipeline Service Company and three seafood processors located in Valdez. The Petro Star refinery began commercial operation at the beginning of 1993 and has indicated that it expects to expand its operation and power requirements in the future. CVEA does not sell power to the Alyeska terminal facility in Valdez but does sell power to several remote valve and control locations along the trans-Alaska pipeline and to the pipeline's Pump Station No. 12.

Four load forecast scenarios were defined and alternative assumptions were made for each scenario. The variations among scenarios are mainly due to alternative assumptions in three areas: future operation of the Trans-Alaska oil pipeline and possible construction of a natural gas pipeline, future operation and expansion of the Petro Star Valdez refinery, and underlying population and employment projections for the Valdez and Copper River areas. Two oil price scenarios have been defined as well: a "low" price scenario corresponding to the Alaska Department of Revenue middle case presented in their Fall 1993 forecast, with oil prices reaching approximately \$21 per barrel in 1992 dollars by 2010; and a "high" price scenario based on the idea that oil prices will increase to \$29-30 per barrel in 1992 dollars by 2010. In an effort to define internally consistent scenarios, the "low" oil price is assumed in this study to be associated with the low and medium-low load forecasts, while the "high" oil price is assumed to be associated with the medium-high and high load forecasts.

For the underlying rate of growth in population and employment for the medium growth scenario, the average of two recent projections was used: one developed by the Alaska Department of Labor and the other by the City of Valdez in its 1991 Comprehensive Development Plan. Alternative low and high population and employment projections were derived from review of these reports, review of historical trends and other explicit assumptions on industrial employment.

The high load growth scenario assumes that sufficient additional production is maintained at the North Slope to allow the Trans-Alaska oil pipeline to continue to function throughout the 50-year analysis period, and that the Petro Star Valdez refinery continues to operate throughout the 50-year period as well. Refinery throughput is assumed to increase from the present level of 30,000 barrels per day to 55,000 barrels per day. In addition, it is assumed in the high case that a natural gas pipeline is constructed from the North Slope to a Valdez terminal facility, and that construction of the gas pipeline begins in 2005 with operation beginning in 2009. Average annual population growth in Valdez from 1993 to 2013 is assumed at 2.53% exclusive of growth attributable to the natural gas pipeline, while average annual population growth in the Copper River area is assumed at 1.20%.

The medium-high load growth scenario also assumes that sufficient additional production is maintained at the North Slope to allow the Trans-Alaska oil pipeline to continue to function throughout the

50-year analysis period. Throughput at the Petro Star Valdez refinery is assumed to expand to 50,000 barrels per day, and the refinery is assumed to continue operation throughout the 50-year analysis period as well. No gas pipeline is assumed to be constructed into Valdez in this scenario. Average annual population growth in Valdez from 1993 to 2013 is assumed at 1.47%, while average annual population growth in the Copper River area is assumed at 0.90%.

The medium-low load growth scenario assumes that declining oil production at the North Slope causes the Trans-Alaska oil pipeline to discontinue operation in 2018. This scenario also assumes that other industrial development in Valdez (for example, construction by that time of a natural gas pipeline) will compensate for the loss of the oil terminal in terms of the overall economic impact on the city and the direct impact on electric utility requirements. However, although throughput at the Petro Star refinery is again assumed to increase over the next few years to 50,000 barrels per day in this scenario, loss of oil pipeline operations in 2018 causes the refinery to close in the same year. The net result is that the medium-high and medium-low scenarios are defined to differ in two major ways: the Petro Star Valdez refinery discontinues operation in 2018 in the medium-low case consistent with shut-down of the oil pipeline, and the "Low" oil price is used in the analysis in conjunction with the medium-low load forecast while the "High" oil price is used in conjunction with the medium-high load forecast.

The low load growth scenario assumes that the oil pipeline and terminal shuts down in 2013. Throughput at the Petro Star Valdez refinery expands to 40,000 barrels per day in the near term, but the refinery also shuts down in 2013 consistent with closure of pipeline operations. No natural gas pipeline is built. Average annual population growth in Valdez from 1993 to 2013 is assumed at -0.96%, while average annual population growth in the Copper River area is assumed at 0.54%.

Table I-3 and Figure I-1 show the historical and projected total energy requirements for CVEA for the four alternative load forecast scenarios. Table I-3 also shows the compounded annual growth rates for selected time periods. The significant growth between 1992 and 1997 in all cases is attributed primarily to Petro Star. Figure I-2 shows the historical and projected energy sales by customer class for the medium-high and medium-low load growth scenarios. As can be seen in Figure I-2, energy sales to the Petro Star refinery are projected to be a significant portion of CVEA's total energy sales in the future. In 1994, it is expected that energy sales to Petro Star will represent 20% of CVEA's total energy sales in that year. By 2000, energy sales to Petro Star are projected to be approximately 22,500 MWh for the medium-high and the medium-low scenarios, representing 26% of CVEA's forecasted total energy sales in that year.

For the purposes of the economic analysis, the results of the 20-year load forecast were extended to 2018. Beyond 2018, CVEA loads were assumed to remain constant. Figure I-1 shows the projected total energy requirements for each of the load forecast scenarios through 2025.

**Table I-3
Historical and Projected
CVEA Energy Requirements (MWh)**

| <u>Fiscal Year</u> | <u>High Case</u> | <u>Medium-High Case(1)</u> | <u>Medium-Low Case(1)</u> | <u>Low Case</u> |
|--------------------|------------------|----------------------------|---------------------------|-----------------|
| 1980 | 43,982 | 43,982 | 43,982 | 43,982 |
| 1985 | 50,500 | 50,500 | 50,500 | 50,500 |
| 1992 | 59,227 | 59,227 | 59,227 | 59,227 |
| 1997 | 95,107 | 88,141 | 88,141 | 79,215 |
| 2002 | 104,492 | 92,400 | 92,400 | 77,734 |
| 2013 | 126,369 | 99,453 | 99,453 | 49,360 |

Compounded Annual Growth Rates:

| | | | | |
|-----------|------|------|------|-------|
| 1980-1992 | 2.5% | 2.5% | 2.5% | 2.5% |
| 1988-1992 | 4.7% | 4.7% | 4.7% | 4.7% |
| 1992-1997 | 9.8% | 8.3% | 8.3% | 6.0% |
| 1997-2002 | 1.9% | 1.0% | 1.0% | -0.4% |
| 2002-2013 | 1.7% | 0.7% | 0.7% | -4.0% |
| 1992-2013 | 3.7% | 2.5% | 2.5% | -0.9% |

(1) The medium-high and medium-low case scenarios vary only in the assumed level of power sales to the Petro Star refinery beginning in 2018.




Figure I-1: Historical and Projected Energy Requirements




Figure I-2: Historical and Projected Energy Sales by Customer Class - Medium Load Growth Scenario

The authors of this report have not attempted to attach any probability estimates to factors like the prospects for continued oil pipeline operations after 2018, or to related factors such as the long-term oil price and prospects for major additions to North Slope oil production, or to the long-term likelihood of building a natural gas pipeline into Valdez. These are major uncertainties that continue to be debated by informed observers and participants, and which we cannot begin to resolve within an intertie feasibility study. Consequently, this study does not identify any one of the four scenarios as the "expected case" or "most likely case," but rather presents the analytical results for each case for consideration and judgment by Alaska decision-makers. During the preparation of the load forecast we have focused on identified developments and avoided reliance on general attitudes with regard to unspecified growth in the region, which is consistent with industry practice for feasibility or investment analysis.

2. Comparison of Alternatives -- Present Value of Future Costs

The economic analysis determines the cumulative present value of the costs associated with the various power supply scenarios that have been developed as part of the feasibility study over the expected economic life of the Intertie. Although real escalation in oil prices over time are included, costs included in the analysis have no inflation applied in the future. The cumulative present value is calculated using an inflation free discount rate of 4.5% as presently defined by the Division. Consistent with previous feasibility studies conducted by the State under AS 44.83.181, this analysis compares long-term resource costs that would be borne by Alaskans under each scenario, including any costs that may be paid by State government.

Each power supply scenario defined in the study provides similar levels of electric capacity and identical levels of energy to CVEA over the analysis period; however, the costs for this power supply will vary for each case. The analysis period is the economic lifetime of the Intertie, an assumed 50-year period beginning in 1999, the expected initial year of operation of the Intertie. Costs included in the analysis are capital and operation and maintenance costs of new generation and transmission additions, including the Intertie, and operation, maintenance and fuel costs of new and existing diesel generators. Excluded from the analysis are certain fixed operating and capital costs related to CVEA's existing generation plant and the cost of power purchased by CVEA from the Solomon Gulch Project. These excluded costs do not affect the outcome of the economic analysis because they will be incurred no matter what case is being evaluated.

The economic analysis begins with the definition of the alternative power supply scenarios. Each of the power supply scenarios takes into account the projected energy and capacity needs of CVEA over the analysis period and each scenario provides for necessary backup generation. It is assumed that CVEA will continue to maintain adequate generation capacity in both Glennallen and Valdez to supply local power requirements in the event that either the existing Glennallen to Valdez transmission line or the Intertie are forced out of service. The economic analysis provides a means for determining the least cost long-term resource alternative.

Three of the power supply scenarios specify that a new relatively large single generating plant is to be constructed in or near the CVEA service territory. The All Diesel scenario assumes that diesel generators will be installed by CVEA on an as needed basis and that existing diesel generators will be replaced rather than overhauled during the study period. An evaluation of several energy conservation measures that could be implemented by CVEA to reduce the power needs of its customers was conducted as part of the analysis. For all cases, new diesel generators are specified to be added if installed resources are insufficient

to meet CVEA's power requirements. A detailed evaluation of the need for and timing of new diesel generators was conducted for each of the power supply and load forecast scenarios. The power supply scenarios included in the analysis are described briefly in Table I-4.

Table I-4
Description of Power Supply Scenarios

| Scenario | Description |
|-------------------|---|
| All Diesel Case | 2,150 kW diesel generators are added at times as needed in both Glennallen and Valdez. |
| Intertie Case | The Intertie is constructed and begins operation in 1999. CVEA purchases power generated using natural gas by Anchorage area utilities. |
| Allison Lake Case | The 3,145 kW Allison Lake hydroelectric project (tunnel alternative) is constructed near Valdez and begins operation in 2000. |
| Silver Lake Case | The 15,000 kW Silver Lake hydroelectric project is constructed 15 miles southwest of Valdez and begins operation in 2001. |
| Valdez Coal Case | A 22,000-kW coal fired generation and district heating facility is constructed in Valdez and begins operation in 1998. |
| Conservation Case | Applicable conservation measures are undertaken by CVEA beginning in 1994 to reduce power requirements. To the extent the measures are expected to be insufficient to supply all requirements, diesel generators are added. |

For each power supply scenario, the power supply cost is estimated in each year of the 50-year analysis period, and then discounted to 1993. The sum of these discounted annual costs provides the cumulative present value for each scenario, a value that is suitable for comparing the long-term costs of the alternatives.

The economic analysis has been performed for alternative fuel cost and load growth assumptions to determine the effect of changing these assumptions on the results of the analysis.

Table I-5 provides a comparison of the cumulative present value for various cases and assumptions. As can be seen in this table, the lowest cost alternative for the high load growth scenario is the Intertie Case. For the medium-high and medium-low load growth scenarios, the Allison Lake Case becomes the lowest cost alternative. For the low load growth scenario, the All Diesel Case becomes the lowest cost alternative followed next by Allison Lake and then by the Intertie. Note that Table I-5 also shows benefit-cost ratios for each alternative and each scenario. In each case, the benefit-cost ratio is defined as the present value of future cost for the diesel alternative divided by the present value of future cost for the specified non-diesel alternative. A benefit/cost ratio greater than 1.0 indicates that the benefits exceed the costs for a specific alternative.

Table I-5
Summary of Economic Analysis Results
Cumulative Present Value of Comparable System Costs and
Benefit/Cost Ratios(1)
 (\$000)

| Load Forecast and Fuel Price Escalation Scenario | Power Supply Scenario | | | | | |
|---|-----------------------|----------|--------------|---------------|---------------|--------------|
| | All Diesel | Intertie | Allison Lake | Silver Lake A | Coal Facility | Conservation |
| Medium-High Load Growth (2) | | | | | | |
| High Fuel Price Escalation..... | \$84,771 | \$72,604 | \$71,989 | \$74,929 | \$76,567 | \$84,098 |
| Benefit/Cost Ratio | 1.0 | 1.2 | 1.2 | 1.1 | 1.1 | 1.0 |
| Medium-Low Load Growth(3) | | | | | | |
| Low Fuel Price Escalation | 67,853 | 63,415 | 60,596 | 70,508 | 77,062 | 67,777 |
| Benefit/Cost Ratio | 1.0 | 1.1 | 1.1 | 1.0 | 0.9 | 1.0 |
| High Load Growth(4) | | | | | | |
| High Fuel Price Escalation..... | 121,562 | 91,227 | 108,298 | 108,376 | 98,898 | 120,690 |
| Benefit/Cost Ratio | 1.0 | 1.3 | 1.1 | 1.1 | 1.2 | 1.0 |
| Low Load Growth(5) | | | | | | |
| Low Fuel Price Escalation | 39,565 | 50,042 | 44,808 | 63,462 | 61,432 | 39,775 |
| Benefit/Cost Ratio | 1.0 | 0.8 | 0.9 | 0.6 | 0.6 | 1.0 |

- (1) Benefit/cost ratios are calculated as the cumulative present value of the All Diesel case divided by the cumulative present value of the specific alternative.
- (2) Assumes medium population growth in CVEA's service territory and operation of the Trans-Alaska oil pipeline and Petro Star refinery through the end of the study period.
- (3) Assumes medium population growth in CVEA's service territory, shut down of the Trans-Alaska oil pipeline and Petro Star refinery in 2018. New industrial activity with comparable power requirements on CVEA to the oil pipeline continues through the remainder of the study period.
- (4) Assumes high population growth in CVEA's service territory, operation of the Trans-Alaska oil pipeline and Petro Star refinery through the end of the study period and construction of a North Slope natural gas pipeline.
- (5) Assumes low population growth in the CVEA service territory, limited expansion of Petro Star refinery, and closure of the Trans-Alaska oil pipeline and the Petro Star refinery in 2013.

3. Comparison of Alternatives -- Cost of Power

AS 44.83.181 and associated regulations require not only a comparison of the present value of long-term resource costs but also a comparison of the "cost of power" for each alternative under "hypothetical financing conditions." "Cost of power" is herein assumed to mean the annual nominal wholesale cost per kWh to Copper Valley Electric Association of generating and/or purchasing power delivered to the CVEA distribution system under each power supply scenario under hypothetical financing conditions, excluding costs that are common to all scenarios such as the purchase of Solomon Gulch energy, or depreciation of existing equipment.

The hypothetical financing conditions assumed for this analysis are as follows:

- a. The \$35 million, zero interest, 50-year loan is used to finance the Intertie.
- b. While additional legislative action would be needed to use the \$35 million appropriation for a project other than the Intertie, cases have been developed for illustrative purposes whereby the \$35 million, zero interest loan is used to finance the other capital intensive alternatives as well. The term of the loan is reduced to 30 years for the proposed coal plant to correspond with its estimated economic life. The full 50-year term is assumed to apply to Allison Lake. Diesel generators are not assumed to be financed with State loans in any scenario.

- c. All supplemental financing is assumed to occur at 7.5 percent interest and with repayment terms of 30 years for the Intertie and the hydroelectric projects, 20 years for diesel generators and 25 years for the coal project.
- d. Costs are shown in nominal dollars based on an assumed 3.5 percent annual inflation rate.

A variant of the Allison Lake "cost of power" estimate is also presented based on the possibility that additional energy generated by the existing Solomon Gulch turbines due to the provision of additional water from Allison Lake will be assessed an additional wholesale charge of over 6.4 cents per kWh corresponding to the wholesale power rate for the Four Dam Pool.

Table I-6
Estimated Cost of Power
(nominal cents/kWh)

| Resource Option | Load Forecast/Fuel Forecast Scenario(1) | | | | | | | |
|---|---|------|-------------|------|------------|------|------|------|
| | High | | Medium-High | | Medium-Low | | Low | |
| | 2000 | 2010 | 2000 | 2010 | 2000 | 2010 | 2000 | 2010 |
| ALL DIESEL (2) | 11.7 | 17.1 | 12.6 | 17.7 | 12.0 | 15.5 | 10.6 | 14.6 |
| INTERTIE (3) | 9.5 | 11.1 | 10.7 | 12.2 | 10.3 | 11.0 | 12.0 | 13.6 |
| ALLISON LAKE | | | | | | | | |
| State Loan (4) | | | | | | | | |
| With Payment for Additional Solomon Gulch Energy (5) | 10.1 | 13.6 | 10.1 | 12.5 | 9.9 | 11.6 | 9.2 | 10.4 |
| Without Payment for Solomon Gulch Energy (6) | 8.1 | 12.0 | 7.6 | 10.0 | 7.4 | 9.0 | 6.0 | 6.4 |
| No State Loan (7) | | | | | | | | |
| With Payment for Additional Solomon Gulch Energy (5) | 16.4 | 18.1 | 18.0 | 19.3 | 17.8 | 18.3 | 19.5 | 21.3 |
| Without Payment for Solomon Gulch Energy (6) | 14.4 | 16.4 | 15.5 | 16.7 | 15.3 | 15.8 | 16.3 | 17.3 |
| SILVER LAKE (8) | | | | | | | | |
| State Loan (9) | 10.0 | 11.8 | 11.2 | 10.3 | 11.2 | 10.3 | 13.5 | 14.0 |
| No State Loan (10) | 17.0 | 16.9 | 20.1 | 18.1 | 20.1 | 18.0 | 25.4 | 26.5 |
| VALDEZ COAL PROJECT | | | | | | | | |
| State Loan (11) | 10.3 | 11.3 | 11.3 | 11.8 | 14.1 | 15.2 | 16.9 | 20.3 |
| No State Loan (12) | 15.2 | 14.6 | 17.3 | 16.9 | 17.7 | 18.3 | 21.6 | 25.3 |

- (1) The high and medium load forecast scenarios assume the high fuel price scenario while the low and medium-low load forecast scenarios assume the low fuel price scenario.
- (2) Assumes new diesel generating units are financed with revenue bonds. Includes estimated costs of new fuel storage system and switchyard improvements in 1999.
- (3) Assumes capital cost of Intertie is financed with \$35.0 million zero-interest state loan and \$21.3 million of supplemental debt. Includes cost of power purchased from Anchorage utilities and estimated charges of 0.2 cent per kWh (1993 dollars) for transmission over MEA and CEA transmission lines.
- (4) Assumes \$35.0 million state loan is applied towards construction costs. Remaining capital costs of \$2.5 million assumed to be financed with supplemental debt. It is assumed that the project comes on-line in 2000.

(Footnotes continued on following page.)

- (5) Includes payments of 6.4 cents per kWh (pursuant to Four Dam Pool Power Sales Agreement) for additional energy generated at the Solomon Gulch Project resulting from water released into the Solomon Gulch reservoir from Allison Lake. Debt service component of 4.0 cents per kWh is held constant whereas O&M component is adjusted annually for inflation.
- (6) Assumes additional power generated at the Solomon Gulch Project does not require any additional payment.
- (7) Assumes Allison Lake Project is financed with \$46.6 million of debt financing and no state loan is made available.
- (8) Cost of power shown in the year 2000 column is for 2001, the first year of operation of the Silver Lake Project.
- (9) Assumes \$35.0 million state loan is applied towards construction costs. Remaining capital costs of \$33.1 million assumed to be financed with supplemental debt.
- (10) Assumes project is financed with \$82.5 million of debt financing and that no state loan is made available.
- (11) Assumes Coal Project is financed with \$35.0 million zero-interest state loan and \$6.5 million of supplemental debt.
- (12) Assumes Coal Project is financed with \$47.4 million of debt financing and that no state loan is made available.

F. ENVIRONMENTAL REVIEW

An environmental review of the Intertie was conducted as part of the feasibility study. Appendix K contains the full "Copper Valley Intertie Project Environmental Analysis" report prepared by Dames & Moore. This report presents available environmental information and issues of public concern expressed for the two primary proposed route alternatives - a southern route and a northern route. The northern route is generally located farther away from the Glenn Highway than the southern route. Two sets of five public meetings were held in the development of the draft feasibility study and a meeting with State and federal agencies was held to identify issues to be considered during the feasibility study. A third set of five public meetings was held after issuance of the draft report. Public and agency comments were taken into consideration, where practical, during the route selection process. The findings of the environmental review are summarized in the following paragraphs.

All route alternatives for the Intertie generally parallel the Glenn Highway at some distance and pass through the Matanuska River Valley, tributary river valleys, and the Copper River Basin. The Intertie corridor can be divided into two nearly equal but distinct sections, east and west of Eureka. West of Eureka in the Matanuska River Valley, Intertie route alternatives would encounter or be near comparatively dense forests, extensive trail systems with known historical importance, and higher concentrations of population and variable land ownership. East of Eureka, extensive wetlands and stunted forests of black spruce will be crossed and land is held principally by state and Native interests.

The environmental impacts associated with the two route alternatives are similar. The most significant impacts are likely to be visual impacts and potential impacts on recreation in the immediate area near the Intertie, i.e., backpackers, rafters, skiers and snowmobilers using trails in the back country. The southern route (Route Alternative B) affords visibility from the Glenn Highway more often than does the northern route alternative (Route Alternative A). The northern alternative may reduce the visual and recreation impacts to some degree by decreasing the number of people impacted (fewer people use the back country trails than the Glenn Highway).

Major wildlife within the Intertie corridor include moose, caribou, Dall sheep, black bear, brown bear, trumpeter swans, various waterfowl species, and anadromous fish species. The Intertie route alternatives are all constrained by topography and practical routing considerations to pass through or near wildlife habitat along the corridor.

Impacts to wetlands and other wildlife habitats for either alternative are expected to be minimal. Care taken during construction and operation to use Best Management Practices and minimize clearing of natural vegetation will reduce the likelihood of significant permanent impacts to these habitats.

Project impacts to wildlife will be minimized by employing protective measures such as timing construction activities specifically to avoid disruption to nesting swans, or other species during sensitive time periods. Limiting the number of new access roads to be constructed will minimize increased pressure on wildlife.

Public meetings and written public comment revealed significant concerns regarding effects on quality of life and tourism, and health risks associated with electric and magnetic fields (EMFs) if the Intertie is constructed. Quality of life issues are based on subjective criteria and are hard to quantify. Visual impacts which may negatively affect recreational experiences in the vicinity of the Intertie, may not necessarily reduce the number of tourists who come to the area for the scenic views. Research on the relationship of EMFs to any specific disease has not been conclusive. However, as a precautionary measure, the route alignments were established well away from known occupied structures.

A significant criticism of the draft feasibility study expressed in the public meetings was that no estimate was included for the value of the Intertie's expected environmental impacts, suggesting that these impacts are accorded zero value for purposes of the feasibility assessment. An implication of zero value was not intended, however, and an effort was therefore made prior to issuance of this final report to examine methods that have been used in other studies to place values on environmental impacts and to determine the applicability of these methods to the Intertie case. While potentially useful material was turned up in this effort and is summarized in a new environmental supplement in Appendix M, we were not able to come up with defensible estimates of the value of Intertie environmental impacts within our time and budget constraints.

A limited qualitative comparison of the potential for environmental impact in major impact categories has been conducted, however, for the most competitive resource alternatives considered in the study. This comparison is included in the Supplement to the Environmental Review. In addition, the environmental review from the 1992 Allison Lake Reconnaissance Study, conducted for the Alaska Energy Authority by HDR Engineering, Inc., is also included in Appendix F.

Finally, as evidenced by the public comments included in Appendix Q and the transcripts of public testimony included in Appendix P, it should be acknowledged that there is a considerable level of public resistance to construction of the Intertie on environmental grounds, concentrated among people living west of the Copper Valley Electric Association service territory.

INTRODUCTION

A. BACKGROUND

In 1989, the Alaska Energy Authority (Authority) conducted a reconnaissance study of a 230-kilovolt (kV) transmission interconnection between the electric systems of the Anchorage area and the Fairbanks area that was to have passed through the Matanuska Valley, continue on to Glennallen and then turn north to Delta Junction. This transmission line, referred to as the Northeast Intertie, was to have been used primarily to provide an additional transmission interconnection between Anchorage and Fairbanks. The Northeast Intertie was not judged economically feasible and no further action was taken towards its development by the Authority following completion of the study. In 1992, the Copper Valley Electric Association (CVEA), a rural electric cooperative that serves the Glennallen and Valdez areas, prepared a screening level cost estimate for a 138-kV transmission line between Sutton and Glennallen (the "Intertie"). This transmission line, as anticipated by CVEA, was to have generally followed one of two routes which were originally identified in connection with the study of the Northeast Intertie. Following completion of its cost estimate, CVEA prepared an economic analysis showing that the Intertie could provide economic benefits to the electric customers of CVEA.

After completion of its cost estimate and economic analysis, CVEA requested that the Authority conduct a feasibility study of the Intertie that would conform with statutory requirements for proposed Authority projects. R. W. Beck and Associates was retained by the Authority in January 1993 to perform the feasibility study, the results of which are presented in this report. As a result of State legislation that took effect in August 1993, oversight responsibility for this study was transferred from the Authority to the Department of Community and Regional Affairs, Division of Energy (Division).

CVEA presently sells electric power to approximately 3,000 member-customers in its service territory which includes Valdez, Glennallen and other communities in the Copper River Valley area. CVEA maintains two offices and two power plants, one each in Valdez and Glennallen. The primary source of power supply for CVEA is hydroelectric generation from the 12-megawatt (MW) Solomon Gulch Hydroelectric Project (the "Solomon Gulch Project"), owned by the State. The full generating capability of the Solomon Gulch Project is sold to CVEA pursuant to a long-term power sales agreement. Since the Solomon Gulch Project does not have the capability to provide all the power needs of CVEA's customers, power generated by diesel generators located in both Valdez and Glennallen is used to supplement the output of the Solomon Gulch Project. In calendar year 1992, CVEA sold 54,602 MWh of electric energy to its customers. Of this amount 27%, 71%, and 2% was sold to CVEA's residential, commercial and public building customer classes, respectively. CVEA's peak demand in 1992 was 10.9 MW.

Beginning in January 1993, CVEA began supplying power to the Petro Star refinery, a new industrial facility in Valdez that produces refined fuels from oil extracted from the Trans-Alaska pipeline. The Petro Star refinery is CVEA's largest customer. During August 1993, Petro Star purchased 1,165 MWh of electric energy from CVEA and had a peak demand of 1,790 kW. Total energy needs for Petro Star for calendar year 1993 are estimated to be 12,200 MWh. It is expected that Petro Star's power requirements will increase in the near future as the refinery continues to expand its operating levels.

The Intertie will connect the electric system of CVEA directly to the electric system of the Matanuska Electric Association (MEA) and indirectly, through MEA's transmission system, to the electric systems of Alaska's Railbelt utilities. It is expected that with the Intertie, CVEA will purchase power generated with gas-fired generating plants by either the Chugach Electric Association (CEA) or Anchorage Municipal Light and Power, utilities located in the Anchorage area. CVEA is presently an isolated electric system with no interconnections to any other electric utilities.

B. PURPOSE OF STUDY

This feasibility study is intended to define the design and routing criteria and estimated costs related to development of the Intertie, to provide a feasibility level environmental analysis, and to assess the costs of the Intertie as compared to other resource alternatives. The feasibility study includes the following principal tasks:

1. Review the Intertie route options defined in previous studies and identify other possible routing alternatives and define preferred alternatives.
2. Develop a feasibility level design of the Intertie.
3. Develop a construction cost estimate and construction schedule for the Intertie.
4. Develop an estimate of annual operations and maintenance costs for the Intertie.
5. Conduct a review of the environmental factors related to the Intertie. Meet with and solicit input from various governmental and public agencies concerning environmental and other institutional constraints which may affect construction of the Intertie.
6. Conduct public meetings at Sutton, Glennallen and other affected communities to obtain comment concerning the Intertie from the general public.
7. Prepare an environmental report which can serve as the basis for subsequent environmental studies.
8. Conduct an electric system analysis of the electric systems of CVEA and the Railbelt utilities to determine the effects on system stability and performance resulting from interconnected operation if the Intertie were constructed.
9. Prepare a forecast of CVEA's electric power requirements for the next twenty years.
10. Review and define the costs and operating characteristics of alternative power supply options, including conservation, that may be available to CVEA in the future.
11. Conduct an economic analysis comparing the life-cycle costs and benefits of the Intertie to those of alternative resource scenarios.
12. Prepare a draft report summarizing the findings of the feasibility study.

13. Conduct a final set of public meetings to present the findings of the feasibility study and solicit public comment.
14. Prepare a final report following the receipt of comments on the draft report from the Authority and others.

C. STUDY METHODOLOGY

The feasibility study was conducted as an independent study of the Intertie and its identified alternatives and involved the efforts of several engineering, environmental, public policy and economic specialists. R. W. Beck and Associates developed the Intertie route alternatives, preliminary design, cost estimate and construction schedule. R. W. Beck also prepared the electric load forecast, the evaluation of alternative power supply options and the economic analysis. Dames & Moore, Inc. of Anchorage conducted the environmental analysis and prepared the environmental report which is included as a separately bound appendix to this report. Power Technologies, Inc. conducted the electric system analysis and provided a report which is also included in a separately bound appendix. Both the environmental review and the electric system analysis were used as input to the feasibility level design and cost estimate of the Intertie. In addition, comments received during the public meetings and written comments received from the general public during the course of the feasibility study were reviewed and considered in the development of the analysis. Written comments and transcripts of formal public testimony received during the course of the study are also included as an appendix to this report.

Alternative design and routing criteria for the Intertie were gathered from previous studies and new investigations. These criteria were evaluated based on past experience with similar projects in Alaska and elsewhere. Discussions were held with utility and Authority engineers to solicit input with regard to the basic design and routing criteria. Both the environmental review and the electric system analysis relied upon the initial routing and design characteristics of the Intertie as part of the basis for their analysis. The electric load forecast that was prepared for CVEA as part of the feasibility study used a model that was developed to relate energy usage in the CVEA service territory to projected future changes in population, employment, income and other factors.

The review of power supply alternatives available to CVEA was conducted using, for the most part, information developed by others in previous studies. An independent review of a proposed coal-fired generating project was conducted as part of the feasibility study. The economic analysis that was conducted for the feasibility study projected the comparable costs of power supply for CVEA for the various resource alternatives over the expected lifetime of the Intertie and then accumulated the present value of these costs. This method of economic analysis has been employed by the Authority for many years in its evaluation of generation and transmission projects throughout the State and is a standard approach for electric utility least cost planning analyses.

Specific descriptions of the methodology incorporated in the various components of the feasibility study are included throughout the sections of the report. Assumptions used throughout the study are also identified in the applicable sections of the report.

Significant effort was extended to gather and incorporate input from local communities, utilities and State and Federal agencies that will be affected by the Intertie. Advertised public meetings were held in Sutton, Glennallen, Chickaloon, the Glacier View area, and Valdez to introduce the general characteristics

of the Intertie and obtain comment. A meeting was held with various State and Federal agencies for additional comment and input. Discussions were held with staff members of CVEA and MEA and a design criteria review meeting was conducted with the Authority, CVEA and other local utility and engineering representatives to obtain input. Historical operating and other technical data was received from CVEA and used in the development of the overall analysis.

D. FORMAT OF REPORT

This report includes the description of the work undertaken, discussion of evaluations conducted and a summary of the findings for the various components of the feasibility study. Section III provides an overview of the route alternatives evaluated. The apparent preferred route alternative is identified at the end of Section III. Section IV discusses the conceptual design parameters that determine the basis for the preliminary design of the transmission lines and Section V provides the basis for and preliminary design of the substation components of the Intertie. This section also discusses the design alternatives considered and their evaluation. The cost estimate for the Intertie is presented in Section VI.

The various design and route alternatives considered as part of the feasibility study all have different costs associated with them. In addition to the cost of the apparent preferred alternative, Section VI identifies the estimated cost of several of the alternatives for comparison. A comparison of the costs of similar projects in Alaska is also shown in Section VI. A practical schedule for Intertie development through construction and the basis for this schedule is shown in Section VII.

The electric load forecast for CVEA is provided in Section VIII and the evaluation of alternative power supply options for CVEA is described in Section IX. Alternative power supply plans, their evaluation and the economic analysis are described in Section X. The overall results of the economic analysis are shown at the end of Section X.

Several appendices are provided with this report. Principal among these are Appendix N, the environmental report prepared by Dames & Moore, and Appendix O, the electric system analysis prepared by Power Technologies, Inc. The Dames & Moore report includes the summaries of the initial public meetings conducted as part of the feasibility study and also includes copies of the letters and other comment forms sent in by the general public during the course of the study. A separate appendix is attached to present the written comments received in response to the draft feasibility study. Appendices N and O are bound together in a separate volume but their principal conclusions are summarized in the body of this report, primarily in Sections III and IV as they pertain to routing and design criteria, respectively. A significant amount of written public comment concerning this feasibility study and the Intertie in general was received during the course of the study effort. Comments received prior to the release of the draft feasibility study report are included in Appendix N. Comments received after the release of the draft feasibility study are included as Appendix Q, which is bound in Volume III. Also included in Volume III is Appendix P which provides transcripts of formal public testimony received at the third and final set of public meetings conducted as part of the feasibility study.

ROUTE SELECTION

A. BACKGROUND

The following previous studies [1,2,6] have investigated transmission line routes in the Palmer/Sutton to Glennallen corridor.

1. Cordova Power Supply Study

In 1982-1985 the Cordova Power Supply Project [6] included study of a 230-kV transmission line with a link from Palmer to Glennallen. The route chosen for study basically followed and was adjacent to the Glenn Highway for its entire distance. It passed to the south of Sheep Mountain.

2. Northeast Transmission Intertie Project

In 1989, the Railbelt Intertie Reconnaissance Study, Northeast Transmission Intertie Project [2] looked at several route options for a 230-kV line between Sutton and Glennallen as part of the Railbelt interconnection to Delta Junction.

Two route alternatives, Northwest and Southeast, were identified for evaluation, both following the Glenn Highway corridor from Sutton to Glennallen. The route alternatives were evaluated based on the feasibility of obtaining right-of-way, the absence of environmental obstacles to construction, a reasonable schedule for permitting, and cost of construction. A suggested route for the entire 230-kV Intertie combined elements of the Northwest and Southeast alternatives. The suggested route followed the Northwest alternative from Sutton to Glennallen and was favored over the Southeast alternative because of perceived land acquisition difficulties, permitting, no crossings of the Glenn Highway and lower cost of right-of-way.

The suggested route in [2] would originate at an expanded O'Neill Substation and proceed directly northeast to the bench on the south side of Little Granite Creek, following the Chickaloon Trail. The route passed about 0.5 mile north of Chickaloon and continued parallel to and 0.25 mile to 0.5 mile north of the Glenn Highway to about 1 mile west of Caribou Creek. The route then followed Caribou Creek and Squaw Creek to Tahnetta Lake, whereupon it resumed its course parallel to and about 0.25 mile to 0.5 mile north of the highway, skirting the south flank of Slide Mountain. The route passed north of Snowshoe Lake and proceeded in staircase fashion in a general northeast direction to a crossing of Lake Louise Road about 0.3 mile north of the intersection with the Glenn Highway. The route continued in a northeast direction over Tolsona Mountain and north of Moose Lake before dipping south slightly and resuming a route parallel to and about 1 mile north of the Glenn Highway all the way to Glennallen where it crossed the highway to reach Pump Station 11 Substation.

The Southeast route alternative in this area basically ran parallel to and south of the Northwest alternative from Sutton to about Mile 80, staying within 0.5 mile north of the highway. At Mile 80 the route crossed to the south of the highway. Except for a few route deviations, the Southeast route alternative

remained 0.25 mile to 1.0 mile south of the highway from Mile 80 all the way to Glennallen, passing Sheep Mountain on the south side. This alternative was deemed too visually intrusive and was abandoned.

During the preparation of the study, the Northeast Intertie Concerned Residents (NEICR) group formed to oppose the selection of routes through the Matanuska Valley. They proposed an alternative route which followed Boulder Creek over Chitna Pass to Caribou Creek then via Alfred Creek to Tahmeta Pass where it rejoined the suggested route. This NEICR alternative was not evaluated thoroughly in [2].

The Matanuska-Susitna Borough passed Resolution 89-113 stating among other preferences that no route alternatives on the south side of the Matanuska River or along the Glenn Highway be considered due to the negative impact such routes would have to the high scenic quality of the valley and related tourism.

Significant public comment was offered during [2] and, since it applies to the same proposed corridor, was reviewed in conjunction with the present study.

3. Sutton to Glennallen 138-kV Transmission Intertie Project[1]

In 1992, CVEA commissioned a narrowly-focused screening study to conceptually design and estimate the cost of a 138 kV Intertie. For the purposes of their study, the authors selected a modified version of the suggested route proposed in [2], i.e., the Northwest route alternative.

The study adopted several modifications to the route. A northerly departure from O'Neill Substation for about one mile was selected to avoid passing near the Sutton School and other community use areas. A route passing about one mile farther north of Chickaloon and proceeding north of Bonnie and Rush Lakes to the vicinity of Simpson Cabin was chosen to set the line farther back from the Glenn Highway and high recreation use areas. The former route segment up Caribou Creek was abandoned and a route following Pinochle, Hicks, Caribou and Squaw Creeks was adopted to avoid the rugged terrain of lower Caribou Creek. The route from Tahmeta Pass to where the Glenn Highway turns east was generally moved farther back from the highway to better conceal the line and lessen visual impact. A straight route across the south side of Slide Mountain, more distant from the highway was chosen. The route from Slide Mountain into Glennallen, except for a few minor route shifts, remained unchanged from the suggested route in [2].

The route modifications made in [1] were in partial response to public comment made during the preparation of [2].

The scope of work for this feasibility study directed the initial consideration and comparison of two route alternatives, one close to the Glenn Highway and one distant from the highway. The modified route selected in [1] was chosen as the starting point for the route alternative close to the highway and the NEICR-proposed route in [2] was chosen as the starting point for the route alternative distant from the highway.

B. METHODOLOGY

1. General

The process of route selection requires the input of several sources of information to make reasonable routing decisions. These sources include public comment in written form and at public meetings, local government consultation, agencies charged with stewardship of lands and the protection of the environment, land owners along the corridor, experienced line designers in Alaska, the interconnecting utilities and relevant literature.

The route selection process in [1,2] was reviewed as well as the public comment in [2]. Routing information for the Cordova Intertie, developed in [6], was furnished by CVEA. Matanuska Electric Association (MEA) and CVEA furnished detailed layouts for their respective distribution lines serving the Glenn Highway Corridor.

In April 1993, discussions were held between the Authority and staff of the Matanuska-Susitna Borough Planning Commission during which additional route segment alternatives were defined for the Sutton and Chickaloon areas. Also in April, the Engineering Manager for CVEA, Mr. Mike Easley, conducted a helicopter overflight of the preliminary route alternatives and recorded his observations on a set of maps. On April 20-21, the Authority and CVEA personnel met with R. W. Beck to discuss these possible route modifications.

Several route modifications were adopted as a result of these discussions. These preliminary routes and modifications were then mapped and constituted the initial base maps. Copies of these initial base maps were made available to attendees at a second set of public meetings at the same locations as the first set of meetings during the week of June 21-25, 1993. These initial base maps and the routes shown thereon were modified slightly to (1) delete route Segment 4-5 on Map 2 and move it farther north, (2) delete route Segment 5-6 on Map 3 on the south side of Strelshla Mountain and move it north of the mountain, (3) show minor route enhancements for future consideration, and (4) clearly delineate Route Alternative D, the apparent preferred alternative. The modified maps 1-11 are included at the end of this section. However, it is important to note that further minor route modifications can be expected to fine tune exact line layout in final design if the Intertie is pursued.

To support the process of route selection we obtained complete topographic mapping of the corridor as well as color infrared stereo aerial photography; small scale color aerial photography was also obtained for Sutton. Together with the fixed photography and video documentation obtained in the fixed wing flyovers, these tools provided a detailed picture of the routing options. Overlays showing possible route alternatives were prepared for the aerial photography and used to depict route adjustments on the base maps.

2. Public Meetings

Five public meetings were held in March-April 1993 at Sutton, Chickaloon, Glennallen, Glacier View School and Valdez to inform the public that a feasibility study was starting on the Copper Valley Intertie and to solicit preliminary comments. The initial route alternatives were presented on display boards and reduced copies of the maps were handed out with comment sheets. Full transcripts of each meeting were prepared from recorded proceedings and a summary of the meetings prepared for distribution. A

second set of public meetings was held in late June 1993, at the same locations as the first set of meetings, to discuss recent legislation affecting the Intertie and progress on the feasibility study. See the Environmental Analysis in Volume 2 (Appendix N) and its Appendices A and B for a complete presentation of public meetings and comment. We address major comments on routing issues in this section, Part C.

An agency meeting was held at the offices of Dames & Moore on March 17, 1993. In attendance were representatives of the Matanuska-Susitna Borough, U.S. Fish and Wildlife, the Alaska Department of Environmental Conservation, the Alaska Department of Fish and Game, the US Army Corps of Engineers, the Alaska State Office of History and Archaeology, Dames & Moore and R. W. Beck. Invitees not attending included the U.S. Environmental Protection Agency and the Bureau of Land Management. This was a round table discussion of agency requirements and preferences related to mitigating environmental impacts, construction activities, field surveys and permitting. A consensus opinion emerged that winter construction would minimize damage to wetlands, habitat and cultural resources and would facilitate permitting. The need to design any line for raptor protection in accordance with methods recognized in [12] and to limit bird strikes was reinforced. The extensive network of Chickaloon-Knik-Nelchina (CKN) historic trails will require ground surveys of the cultural resource prior to construction.

Most public written comments were received by late May, reviewed and key points extracted. Volume 2, Appendix B, contains copies of all written comments received by the project team.

3. Route Reconnaissance Flyovers

Four overflights of the route corridor were undertaken. A three-hour, fixed-wing, winter flyover on the various route alternatives was performed on March 16, 1993 with a transmission line design engineer from R. W. Beck, a geotechnical engineer and a visual quality specialist from Dames & Moore, and the Director of Facilities Operations and Engineering from the Authority. Outstanding weather allowed good visual documentation of most of the routes. The flyover was conducted over Matanuska Valley, Boulder Creek, Chitna Pass, Alfred Creek, Squaw Creek, Caribou Creek, Hicks Creek and both north and south of the Glenn Highway east of Tahneta Pass. We investigated the south bank of the Matanuska River as suggested in one of the public meetings. No recent or active avalanches were spotted although the potential for avalanches is known to exist. Particular attention was paid to the ruggedness of terrain on the back country routes. The high level and wide extent of snowmobiling was noted.

In addition to the fixed wing winter flyover, three helicopter flights were taken. The first helicopter flight was undertaken by CVEA on April 13 with only the CVEA engineering manager attending. Several route modifications were identified and conveyed to the project team on April 20-21. Generally this overflight resulted in pushing route alternatives farther north and in crossing the Glenn Highway farther to the west. A second helicopter flyover took place on June 11 with the general manager of CVEA, the manager of engineering for CVEA, an ADNR geologist, an Authority engineer, and a transmission line engineer from Power Engineers attending. This flyover included reconnaissance of Chitna Pass and the Strelshla Mountain rock glacier (Victory Road area). Two route modifications were proposed around the area of Simpson Cabin and Strelshla Mountain. Observations included that Chitna Pass and an alternative route around Strelshla Mountain appeared more constructible and reliable than previously thought. These observations were conveyed to the project team on June 14 in a meeting in Seattle. The final flyover took place on June 25 with the R. W. Beck transmission line engineer, ADNR geologist, Authority engineer, a local experienced transmission line contractor, and the Authority project manager. The objectives of this flyover were to confirm the observations regarding Chitna Pass and Strelshla Mountain, confirm the advantages of

certain route modifications, review terrain and forest cover, and to gain the benefit of a line contractor's perspective on construction methods and costs. Final route modifications were identified following this flyover.

4. Ground Reconnaissance

Limited winter ground reconnaissance was performed on the route corridor separately by the R. W. Beck transmission line engineer and the Dames & Moore visual quality specialist in March 1993. This consisted chiefly of photographing the corridor along the Glenn Highway, Victory Road, Lake Louise Road and Lake Tolsona Road and noting the level of potential visibility of the initial route alternatives from the roadways. It was not possible to schedule any cross-country exploration of the routes at this time. Areas of potential high visibility for the initial route alternatives were noted in the areas of Slide Mountain, Tahnetta Pass, and above Victory Road on the banks of Strelshla Mountain.

Some findings of this ground reconnaissance were that a line along a route north of the Glenn Highway between Sutton and Victory Road would not be visible to travelers along the Glenn Highway, except perhaps from a view of Strelshla Mountain to travelers heading east on the Glenn Highway just before Victory Road and at the crossing with Granite Creek; that a route on the south bank of the Matanuska River would be highly visible and would require long river crossings to exit Sutton and avoid undesirable construction on steep slopes in at least two locations; that a line along the initial routes in the vicinity of the Lake Louise Road scenic overlook would be highly visible and should be rerouted to mitigate this impact; and that a line north of the Glenn Highway and east of Tahnetta Pass would not be visible from the Glenn Highway for the great majority of the initial routes. Areas of potentially high visibility included the south flank of Slide Mountain, Old Man Creek near Eureka and Tahnetta Pass, Lake Louise Road, and possibly a few high vantage points along the Glenn Highway with views of the initial routes in the distance.

In conjunction with the second set of public meetings in June 1993, further ground review was undertaken. Areas reviewed by car included Sutton, Chickaloon, Bonnie Lake, and Lake Louise Road. In addition on June 23, the owner of Eureka Lodge and the R. W. Beck transmission line engineer traveled a 50-mile circuit on all-terrain vehicles (ATVs) in the areas of Old Man Creek, Crooked Creek, Pass Creek, Belanger Pass and Squaw Creek. This ATV tour revealed the wide extent of muskeg in low lying areas around Old Man Creek and Crooked Creek and the availability of elevation contours to either hide the line in the Old Man Creek valley or to site the line in reasonably stable and solid soil conditions above the creek beds. Extensive muskeg situations must still be assumed and winter construction in these areas is prudent from the standpoint of construction ease and minimizing damage to the wetlands. Numerous mining claims, both active and abandoned, were noted in the area. Caribou herds were present.

5. Route Selection Methodology

As a means of preliminary comparison, we first established several objective criteria and weights to apply to the various route segments. The criteria fall into the categories of environmental, land use, construction/technical and financial. These criteria, their weights and units of measure are presented in Appendix A. Each route segment shown on the base maps was measured for its impact in each criterion. Four preliminary route alternatives were developed from among the numerous route segments; they varied in length from 133 miles to 136 miles. A scoring system was used to develop a rating for each route alternative in each of the four categories and this rating served as the first basis of comparison. The sensitivity of the ratings to differences in weights was briefly investigated.

In the remainder of this section we discuss key public comments as they affect route selection, route selection criteria, individual route segments, the route alternatives and route evaluation.

C. PUBLIC COMMENT SUMMARY

The body of public comment that a proposed Intertie in this corridor has engendered is significant and reflects strong feelings about the possible impacts a line might have on the quality of life in the area. The public and their representative organizations have expressed the deepest concerns over the issues of negative visual impact, effects on the tourist industry, recreational experience and quality of life in the area, the perceived risk of health effects from electric and magnetic fields, the effect on property values and the possibility that private land would be taken for right-of-way, and the completeness of the feasibility study in terms of considering all options for increasing local generation on the Copper Valley system. See Appendices N and Q of this report for a detailed presentation of the public comment. We have attempted to address these concerns in the selection and comparison of route alternatives, as discussed below. We also include discussion of the Mental Health Trust lands.

1. Visual Impacts

The issue of visual impact was framed in the dual sense of reducing opportunities for wilderness experiences and reducing the appeal for tourism which forms a major part of the local economy. It is recognized that a line along any of the route alternatives will be visible for some of its length to some people. The objective is to keep the extent of visual intrusion and the number of people exposed to the impact to a minimum.

Depending on the route segment, a line might be visible to travelers on the Glenn Highway or other major roads, by users of the back country trail system, and by aircraft. Efforts were made to route line segments away from known occupied structures, where frequent visual impact is predictable. Within back country valleys it is not possible to hide lines for most of their routes. A line would be visible in these areas to those traveling above the banks of the rivers and creeks, while anyone rafting or kayaking the creeks themselves or using trails following the creek bed may or may not see the line. We made an effort to select route alternatives up and out of the creek beds and to limit creek crossings.

We made the following major adjustments in the conceptual design to lessen visual impact. In Sutton, instead of adopting the course of upgrading the MEA O'Neill Substation, it is proposed to build a new substation on Mat-Su Borough land about 0.7 mile west of O'Neill which will reduce the visual impact of both the substation and the Intertie getaway route. We rejected the siting of a line on the south bank of the Matanuska River due to the high visual impact. Route alternatives were selected to go over and north of Slide Mountain instead of along its exposed southern flank. In the area of Old Man Creek the route alternatives were moved farther away from the Glenn Highway to possibly reduce their visibility; the effectiveness of this change needs to be verified. In the area of Chickaloon the routes were moved north of Boulder Creek and closer to Anthracite Ridge.

A route modification around Knob Hill would lessen or eliminate the visual impact from the mouth of Granite Creek. It would also lessen the potential hazard to hang-gliders taking off from a sharp knob just north of Little Granite Creek.

In the area of Victory Road a route modification was identified to pass north of and around Strelshla Mountain, but at a substantial cost increase.

2. EMF Effects

It has been suggested that design of any Intertie adopt the criterion for siting route alternatives such that field strengths in occupied structures or other public places would be measurably no greater under Intertie maximum loading than they would be without the Intertie. The practical application of this criterion is complicated by the fact that it is not possible to design for a zero field increase at any distance. However, an arbitrary criterion that the field increase be no greater than the smallest reading possible by an EMDEXC meter (i.e., 0.1 milligauss magnetic field) would dictate that the line be situated approximately 600 ft from homes and public places. It would be impractical to acquire a right-of-way of this width, and there is no means for the operating utility to control development around the line. Homes and other public use areas may be developed inside this 1,200 ft band but outside the 100 ft to 125 ft right-of-way and the fields, while still very low, would increase as distance from the line decreases.

Matanuska-Susitna Borough Assembly Resolution 93-035 requests "assessment of EMF hazards at the O'Neill Substation" and relocation of the substation "to mitigate EMF health hazards". We have relocated the Intertie connection in Sutton to a new substation on Borough property about 0.7 mile west of O'Neill Substation. This moves the new substation and getaway line routes away from populated areas of Sutton, but it does not diminish any effects associated with O'Neill Substation which would remain.

To address these concerns we adopted the initial criterion that the line be sited 600 ft from homes and other occupied structures wherever possible. Where this is not possible, alternative line designs can be used in final design to reduce fields. The only area identified where the separation of 600 ft is not attained by the study route alignments is in Sutton near Eska Mine where the shown route passes about 400 ft from a mine complex building. Phone discussions with two Sutton residents indicated that the building is an occupied residence. The route shown on the maps at the end of this section can and would be modified slightly to obtain the stipulated 600 ft separation. The proposed new substation west of the existing O'Neill Substation will distance the line from existing homes in Sutton and result in lower field strengths.

Volume 2, Appendix N, Chapters 2.12 and 3.2 discusses the issue of EMF in more detail, covering the current status and findings of epidemiological research, law and regulations limiting field strengths, expected field strengths of the proposed Intertie and comparison to field strengths generated by typical lines and appliances. We also discuss means which can be taken to reduce the field strengths where necessary. It should be noted that the Intertie initial loading estimated at 15 MVA would generate maximum 60 Hz magnetic fields on the order of 0.03 milligauss at a distance of 600 ft from the line while the ultimate design loading of 40 MVA would yield fields on the order of 0.09 milligauss at 600 ft, well below typical ambient fields.

3. Right-of-Way and Land Ownership

We have researched and mapped land status for the entire corridor and all route segment alternatives (see Volume 2). We selected route alternatives in the Sutton-Chickaloon area to avoid private property and native lands wherever practical. Right-of-way for the route alternatives considered in this study occupies a maximum of 0.25 mile of private land (not counting unpatented mining claims) and 21.25 miles of Native

and Native-selected lands. The new proposed substation in Sutton was located so as to minimize conflicts with private property. The sole crossing of the Glenn Highway was relocated westward to avoid crossing in Glennallen itself. Generally the route alternatives were moved farther from the Glenn Highway which has the dual effect of making the line less visible from the highway and avoiding private properties along the Glenn Highway.

Numerous unpatented mining claims along Boulder Creek, Chitna Pass, Caribou Creek, Alfred Creek, Squaw Creek, Crooked Creek, and other areas in the Talkeetna Mountains are known to exist. Index maps from the Alaska Division of Mines were provided to the study team by MEA with the assistance of Land Field Services. These maps clearly indicate extensive claims but further research at the Division of Mines is required to determine the exact number and extent of claims. The claimants will have to be treated as private landowners for the purposes of obtaining a right-of-way easement.

The potential of increased access to and along the right-of-way, especially by off-road vehicles, was voiced often as a public concern. Anxiety was expressed over a number of adverse impacts due to increased vehicular traffic to the back country, including increased hunting pressure, noise, abandoned campfires and the danger of wildfires, and higher use of and damage to the trail system. Access to the right-of-way is discussed in further detail in Section IV-7 (b).

4. State Mental Health Trust Lands

Approximately 13 miles of the route alternative rights-of-way are located on State Mental Health Trust lands. State Mental Health Trust lands were granted to the state by the federal government prior to statehood to generate revenue to support Alaska's mental health program (Mental Health Enabling Act of 1956). In 1978 the legislature waived the trust status of these lands and some lands were leased for oil and gas development, sold to individuals or transferred to municipalities. In the 1980's mental health advocates sued the state (Weiss vs. State of Alaska, 1982) and the state was ordered to "reconstitute" as nearly as possible the holdings which comprised the trust when the 1978 law became effective.

At this time, no settlement between the State of Alaska and mental health interests has been reached. Pending final settlement, in 1990 an injunction was placed on all activities and conveyances to title to the original Mental Health Trust lands. The 1991 Mental Health Trust Lands Settlement Act is a proposal from the Hickel Administration, which has been signed into law, to settle the issue of mental health trust lands. It would reconstitute the Mental Health Trust with all unencumbered lands from the original trust and provide replacement land in exchange for lands conveyed out of the trust. This law however, will not take effect until the original 1982 case is dismissed and the expiration of time for appeal. In the interim, the 1990 injunction applies.

Mental Health Trust lands depicted on land status maps in Section 2.7 of Appendix N originated from ADNR Division of Lands status plats. Mental Health Trust lands shown on these status plats are part of the original trust and are managed by ADNR in accordance with the original mandate for these lands. Lands which were conveyed out of the trust after the 1978 law would appear as belonging to the third party interests to whom they were conveyed. Mental Health interests, as part of the ongoing litigation, have been asked to select state lands to reconstitute the trust. Based on discussions with ADNR Division of Lands staff, we understand that a confidential priority list of selected lands ("hypothecated lands") has been prepared and is under review by the parties. These same discussions indicated that, based on experience, situating right-of-way on known Mental Health Trust lands would not hinder development of the Intertie, as long as standard right-of-way permitting procedures are followed and a use fee is negotiated that reflects

the fair market value of the lands in question. It is not possible at this time to identify state lands selected to reconstitute the Mental Health lands and, in the course of standard permitting procedures for occupancy of state lands, ADNR would consult with Mental health interests in drawing up right-of-way easement agreement. In legal terms, concurrence of the plaintiff's mental health interests for the right-of-way would be sought and with concurrence the 1990 injunction would be modified to grant the right-of-way easement. This would require court approval.

According to ADNR staff, right-of-way occupancy of mental health lands would not constitute an obstacle to development of the Intertie. Mental Health interests have in the past demonstrated a willingness to negotiate use fees that would return an equitable percentage of fair market value of the land in question. The period for obtaining an easement in Mental Health Trust lands is estimated to be one to two months longer than for other state lands due to the 2-3 week court review and approval cycle and consultation with Mental Health interests. There is a reasonable expectation that the rental fee for the right-of-way on state non-Mental Health Trust lands would be waived since CVEA is a non-profit utility covered under Statute AS 38-05-810-F. However, it is not clear that such a waiver would be granted for right-of-way on Mental Health Trust lands. The governing statute only allows and does not obligate ADNR to grant waivers. Whether to grant a waiver, and, if not, what level of fee is appropriate, are ADNR administrative decisions. Typical use fees can be on the order of \$100/acre-year.

D. INTERTIE CORRIDOR CHARACTERISTICS

1. Soil Conditions

A detailed description of the complex geology and soil conditions expected within the corridor is given in Volume 2, Appendix N, Chapter 2.2. General soil conditions as they might affect routing are summarized below.

West of Syncline Mountain, i.e., between Sutton and Eureka, soils will be predominantly glacial, alluvial and colluvial. Glacial and alluvial soils are expected to dominate in the Matanuska Valley at lower elevations, Boulder Creek Valley, Hicks Creek Valley and the lower reaches of Caribou and Squaw Creeks. Colluvial soils will be found on the broader valley sides of Caribou and Squaw Creeks and along narrow valley walls.

East of Syncline Mountain, i.e., from Eureka to Glennallen, glacial and lacustrine soils will dominate, with occasional colluvial deposits. Along the Tolsona Creek and Tazlina River drainages, alluvial soils will likely be encountered.

No permafrost is expected in Matanuska Valley. Colluvial soils may be frozen at protected higher elevations, discontinuously frozen on lower northern exposures, or sporadically frozen on southern exposures. Soils east of Syncline Mountain will generally be frozen. Typical active layer thickness near Glennallen is reported to be 3 ft to 7 ft. Stunted black spruce forest is an indication of permafrost.

2. Wetlands

A detailed description of wetlands and vegetation is given in Volume 2, Appendix N, Chapter 2.3. A summary of this discussion is given here as it affects routing.

Palustrine, lacustrine and riverine wetlands are common within the corridor. West of Syncline Mountain, riverine wetlands dominate and will affect routing where the line would cross or parallel creeks and streams. Palustrine wetlands, consisting mostly of saturated shrub bogs (muskeg), forested wetlands, and seasonally flooded shrub wetlands, are extensive east of Syncline Mountain in the areas of low relief of the Copper River Basin east of Slide Mountain. These palustrine wetlands are the result of poor drainage caused by the extensive permafrost. Saturated black spruce bog is a common type in the Copper River Basin.

Because of the extensive nature of the wetlands, to avoid construction in them would be impractical. Measures will have to be taken to limit disruption of wetland habitat and to restore damaged wetlands in accordance with guidelines and permit stipulations of the permitting agencies. In the Matanuska Valley Moose Range (MVMR), wetland buffers of 100 ft landward of the wetland are required in general, with a 200 ft buffer along anadromous stream wetland. ADNR prefers that no utility line parallel a wetland, but access to wetlands for utility construction and maintenance is allowable subject to ADNR approval. To minimize wetland damage, winter construction using driven-pile foundations would be used.

3. Forest Cover

The lower elevations of the Matanuska Valley and tributary valleys contain mixed sporadically heavy forests of black cottonwood, white spruce, black spruce, balsam poplar, quaking aspen willow, thinleaf alder, and dwarf birch. Higher elevation route segments in the Talkeetna Mountains (e.g., Chitna Pass, Caribou Creek, Alfred Creek) and the Tahnetna Pass area are essentially barren with only occasional and mostly riparian tree cover.

From Old Man Creek to Glennallen, black spruce forests dominate. Stunted black spruce cover is indicative of permafrost.

No significant forests of commercial value occur along the corridor and removal of merchantable timber is assumed not to be required. However, state regulations (Sec. 41.17.082) do require the removal of commercial timber if it is determined that it is economically feasible to do so. Such a determination would be made by ADNR Division of Forestry during permitting. In its review comments of the Draft Report, ADNR indicated that some commercial stands may be found in the last 10-15 miles of the line route. Special treatment of cleared spruce (other than black spruce) is required by regulation (11 AAC 95.195, Clearing of Spruce trees) to limit spread of the bark beetle infestation. Allowable treatments include controlled burning, chipping and spreading, or repeated passes by a roller crusher. ADNR personnel indicated that special treatment of black spruce was less critical than for white spruce and that it would be reasonable to assume no special treatment of the black spruce. However, to the extent black and white spruce stands cannot be distinguished or treated separately, ADNR would prefer to apply required white spruce treatment to black spruce as well.

4. Wildlife Habitat

A complete discussion of the wildlife habitat along the corridor is contained in Volume 2, Appendix N, Chapter 2.6.5.

With few exceptions, it is not practical to route around the bear, caribou, Dall sheep and moose concentrations in the Talkeetna Mountains and Matanuska Valley. Construction activities will be timed to mitigate impacts. See Section VI, Project Schedule.

Waterfowl and raptor nesting sites can be avoided by detailed route modifications. This especially affects trumpeter swan nesting areas near Mud Lake, Moose Lake, and Lake Louise Road. Raptor nests are possible, but have not been surveyed yet. Again, route modifications can avoid such sites and maintain required buffers (e.g., 330 ft to an eagle or peregrine falcon nest). If they exist along the route, it is probable raptors would nest in the Matanuska Valley. The project could be delayed if maintaining the required buffers forced a realignment and location of the line on another property parcel. To avoid this possibility, it is recommended that a raptor survey be undertaken before right-of-way permitting and acquisition activities.

While nesting sites can be avoided, this is not true of migration patterns. Special designs will have to be implemented to limit trumpeter swan-line strikes. This would include marking the wires with spiral dampers, aerial marker balls, or strobe lights and limiting the height of structures. Because most waterfowl activity occurs in an area east of Eureka where tree height is approximately 40 ft maximum, it will not be possible to keep wires at or below tree height without incurring the exorbitant cost of very short spans.

E. ROUTE SELECTION CRITERIA

Several practical criteria guided the selection of route alternatives as listed below. To the maximum extent possible, without clearly jeopardizing technical or economic feasibility:

1. Avoid siting the line right-of-way on private, native or native-selected lands;
2. Site the line at least 600 ft from known occupied structures (e.g., homes, schools, businesses) to limit magnetic field levels due to the Intertie to below 0.1 milligauss.
3. Avoid creek or river crossings and siting line in flood plain;
4. Avoid slopes between 25-45 percent and obvious signs of avalanche chutes or unstable soil;
5. Site the route so as to mitigate visual impacts from the Glenn Highway and other high-use traveled ways;
6. Conform with constructive recommendations from the public consistent with other selection criteria;
7. Avoid high elevations which are typically associated with severe microclimate loading conditions;
8. Avoid direct conflicts with the CKN Trail system which, in addition to high public use, may be designated a part of the national trail system; and
9. Avoid known wildlife nesting areas, habitat, and migratory paths.

F. DESCRIPTION OF ROUTE SEGMENTS

The feasibility study resulted in the identification of several route segment alternatives throughout the Intertie corridor for comparison. Combinations of these segment alternatives yielded two basic complete route alternatives for comparison: Route Alternative A, the Northern Route, generally the most distant from the Glenn Highway and Route Alternative B, the Southern Route, generally closest to the Glenn Highway. Two other route alternatives were investigated. Route Alternative C, similar to Route Alternative B, except that it follows Hick's Creek to Squaw Creek, and Route Alternative D, which is the same as Route Alternative C from Sutton to the headwaters of Hicks Creek, but then takes Alfred Creek and follows the same segments as Route Alternative A to Glennallen. Route Alternative D emerged from the preliminary route evaluation process as the apparent preferred route alternative as discussed at the end of this section.

Maps 1-11 at the end of this section show the various route segments and Table III-1 gives a tabulation of the segments comprising each route alternative and loading zones for each route segment. Land status maps are found in the Environmental Analysis in Volume 2, Appendix N, Section 2.7. Each route segment is discussed individually below.

**Table III-1
Segment Data Tabulation and Route Alternatives**

| Segment start | end | All Segments | Length (miles) | Minimum Elevation | Maximum Elevation | Loading Zone | Route Alt A | | Route Alt B | | Route Alt C | | Route Alt D | |
|---|-----|-----------------|-------------------|----------------------|----------------------|-----------------|-------------|--------|-------------|--------|-------------|-------|-------------|-------|
| | | | | | | | Segment | miles | Segment | miles | Segment | miles | Segment | miles |
| 1 | 2 | 1-2 | 5.56 | 655 | 1100 | 1 | 1-2 | 5.56 | 1-2 | 5.56 | 1-2 | 5.56 | 1-2 | 5.56 |
| 2 | 3 | 2-3 | 11.36 | 1100 | 1900 | 1 | 2-3 | 11.36 | | 0.00 | | 0.00 | 2-3 | 11.36 |
| 2 | 31 | 2-31 | 6.58 | 800 | 1125 | 1 | | 0.00 | 2-31 | 6.58 | 2-31 | 6.58 | | 0.00 |
| 3 | 4 | 3-4 | 6.68 | 1100 | 2200 | 1 | 3-4 | 6.68 | 3-4 | 6.68 | 3-4 | 6.68 | 3-4 | 6.68 |
| 4 | 4A | 4-4A | 2.92 | 2200 | 2800 | 1 | 4-4A | 2.92 | 4-4A | 2.92 | 4-4A | 2.92 | 4-4A | 2.92 |
| 4A | 5 | 4A-5 | 5.24 | 2200 | 3000 | 1 | | 0.00 | 4A-5 | 5.24 | 4A-5 | 5.24 | 4A-5 | 5.24 |
| 5 | 5A | 5-5A | 2.69 | 2900 | 3100 | 1 | | 0.00 | 5-5A | 2.69 | 5-5A | 2.69 | 5-5A | 2.69 |
| 5A | 5B | 5A-5B | 2.01 | 3100 | 4800 | 4 | | 0.00 | 5A-5B | 2.01 | 5A-5B | 2.01 | 5A-5B | 2.01 |
| 5B | 5C | 5B-5C | 2.28 | 2500 | 4800 | 4 | | 0.00 | 5B-5C | 2.28 | 5B-5C | 2.28 | 5B-5C | 2.28 |
| 4A | 7 | 4A-7 | 10.61 | 2200 | 3400 | 3 | 4A-7 | 10.61 | | 0.00 | | 0.00 | | 0.00 |
| 7 | 7A | 7-7A | 9.27 | 3400 | 4900 | 4 | 7-7A | 9.27 | | 0.00 | | 0.00 | | 0.00 |
| 5C | 6 | 5C-6 | 2.34 | 2900 | 3000 | 1 | | 0.00 | 5C-6 | 2.34 | 5C-6 | 2.34 | 5C-6 | 2.34 |
| 6 | 8 | 6-8 | 8.73 | 2830 | 3500 | 3 | | 0.00 | | 0.00 | 6-8 | 8.73 | 6-8 | 8.73 |
| 6 | 9 | 6-9 | 4.71 | 2200 | 3400 | 1 | | 0.00 | 6-9 | 4.71 | | 0.00 | | 0.00 |
| 7A | 8 | 7A-8 | 3.25 | 3200 | 4900 | 3 | 7A-8 | 3.25 | | 0.00 | | 0.00 | | 0.00 |
| 8 | 10 | 8-10 | 1.44 | 2600 | 2800 | 3 | 8-10 | 1.44 | | 0.00 | 8-10 | 1.44 | 8-10 | 1.44 |
| 9 | 11 | 9-11 | 7.37 | 2200 | 3000 | 3 | | 0.00 | 9-11 | 7.37 | | 0.00 | | 0.00 |
| 10 | 11 | 10-11 | 4.25 | 2500 | 2600 | 3 | | 0.00 | | 0.00 | 10-11 | 4.25 | | 0.00 |
| 10 | 15 | 10-15 | 12.61 | 2600 | 4300 | 3 | 10-15 | 12.61 | | 0.00 | | 0.00 | 10-15 | 12.61 |
| 11 | 12 | 11-12 | 4.74 | 2500 | 2900 | 3 | | 0.00 | 11-12 | 4.74 | 11-12 | 4.74 | | 0.00 |
| 12 | 13 | 12-13 | 3.14 | 2700 | 3000 | 2 | | 0.00 | 12-13 | 3.14 | 12-13 | 3.14 | | 0.00 |
| 13 | 14 | 13-14 | 3.3 | 3200 | 4000 | 3 | | 0.00 | 13-14 | 3.30 | 13-14 | 3.30 | | 0.00 |
| 14 | 15 | 14-15 | 1.91 | 3400 | 3700 | 3 | | 0.00 | | 0.00 | 14-15 | 1.91 | | 0.00 |
| 14 | 16 | 14-16 | 6.2 | 3200 | 3500 | 3 | | 0.00 | 14-16 | 6.20 | | 0.00 | | 0.00 |
| 15 | 16 | 15-16 | 4.57 | 3200 | 4400 | 3 | | 0.00 | | 0.00 | 15-16 | 4.57 | | 0.00 |
| 15 | 17 | 15-17 | 6.26 | 3500 | 3800 | 3 | 15-17 | 6.26 | | 0.00 | | 0.00 | 15-17 | 6.26 |
| 17 | 17A | 17-17A | 3.2 | 3300 | 3900 | 3 | 17-17A | 3.20 | | 0.00 | | 0.00 | 17-17A | 3.20 |
| 16 | 18 | 16-18 | 5.89 | 2950 | 3200 | 2 | | 0.00 | 16-18 | 5.89 | 16-18 | 5.89 | | 0.00 |
| 17A | 19 | 17A-19 | 5.86 | 2600 | 3900 | 2 | 17A-19 | 5.86 | | 0.00 | | 0.00 | 17A-19 | 5.86 |
| 18 | 18A | 18-18A | 3 | 2600 | 3300 | 2 | | 0.00 | 18-18A | 3.00 | 18-18A | 3.00 | | 0.00 |
| 18A | 18B | 18A-18B | 4.45 | 3300 | 3850 | 3 | | 0.00 | 18A-18B | 4.45 | 18A-18B | 4.45 | | 0.00 |
| 18B | 21 | 18B-21 | 6.3 | 2350 | 3800 | 2 | | 0.00 | 18B-21 | 6.30 | 18B-21 | 6.30 | | 0.00 |
| 19 | 20 | 19-20 | 12.13 | 2300 | 3365 | 2 | 19-20 | 12.13 | | 0.00 | | 0.00 | 19-20 | 12.13 |
| 20 | 22 | 20-22 | 4.99 | 2250 | 2725 | 2 | 20-22 | 4.99 | | 0.00 | | 0.00 | 20-22 | 4.99 |
| 21 | 23 | 21-23 | 5.19 | 2200 | 2317 | 2 | | 0.00 | 21-23 | 5.19 | 21-23 | 5.19 | | 0.00 |
| 22 | 26 | 22-26 | 13.56 | 2400 | 3107 | 2 | 22-26 | 13.56 | | 0.00 | | 0.00 | 22-26 | 13.56 |
| 23 | 24 | 23-24 | 6.02 | 2317 | 2660 | 2 | | 0.00 | 23-24 | 6.02 | 23-24 | 6.02 | | 0.00 |
| 24 | 25 | 24-25 | 4.88 | 2660 | 3000 | 2 | | 0.00 | 24-25 | 4.88 | 24-25 | 4.88 | | 0.00 |
| 25 | 26 | 25-26 | 2.27 | 2400 | 2850 | 2 | | 0.00 | 25-26 | 2.27 | 25-26 | 2.27 | | 0.00 |
| 26 | 27 | 26-27 | 7.97 | 2000 | 2200 | 2 | 26-27 | 7.97 | 26-27 | 7.97 | 26-27 | 7.97 | 26-27 | 7.97 |
| 27 | 28 | 27-28 | 6.44 | 1720 | 2100 | 2 | 27-28 | 6.44 | | 0.00 | | 0.00 | 27-28 | 6.44 |
| 27 | 29 | 27-29 | 9.05 | 1682 | 2172 | 2 | | 0.00 | 27-29 | 9.05 | 27-29 | 9.05 | | 0.00 |
| 28 | 29 | 28-29 | 2.6 | 1682 | 1720 | 2 | 28-29 | 2.60 | | 0.00 | | 0.00 | 28-29 | 2.60 |
| 29 | 30 | 29-30 | 7.7 | 1400 | 1682 | 2 | 29-30 | 7.70 | 29-30 | 7.70 | 29-30 | 7.70 | 29-30 | 7.70 |
| 31 | 3 | 31-3 | 5.89 | 1100 | 1900 | 1 | | 0.00 | 31-3 | 5.89 | 31-3 | 5.89 | | 0.00 |
| TOTAL LENGTHS OF ROUTE ALTERNATIVES (miles)>>>> | | | | | | | | 134.41 | 134.37 | 136.99 | 134.57 | | | |

Segment 1-2 (length 5.56 miles)

The segment originates at a new substation on Mat-Su Borough property about 0.7 mile west of the existing MEA O'Neill Substation along the alignment of the existing MEA O'Neill Tap 115 kV transmission line. The route proceeds essentially due north from the substation through rolling, densely-forested hills to a crossing of Jonesville Road at a point just south of the mines and beyond current residential areas of Sutton. About 1.5 miles north of the new substation Segment 1-2 would turn east for a

crossing of Granite Creek at segment mile 4.2 after which the segment occupies high ground on the bench above the Matanuska River bed and the Glenn Highway. This crossing has been moved north to avoid settled areas and private property of Sutton.

The present location on Granite Creek will likely require a long span crossing (estimated at 1,500 ft to 2,000 ft) and may be subject to higher, channeled wind loadings than the former crossing farther downstream. This segment will not be visible from the Glenn Highway due to the hilly terrain, dense forest, and distance from the highway, except from a viewpoint at the Glenn Highway crossing of Granite Creek. The crossing of Jonesville Road will be visible. East of Granite Creek the route segment has been located north of Little Granite Creek to avoid homes and private property in the area.

The line passes within about 400 ft of a building at the Eska mine complex and discussions with Sutton residents indicate it is an occupied residence. A minor route modification would be made to obtain the target 600 ft separation.

Segment 1-2 crosses wetlands about 0.5 mile in extent as it parallels Eska and Little Granite Creeks. It is estimated that wetlands around Granite Creek can be spanned, but the others must be traversed and may require winter construction and pile foundations. Segment 1-2 passes about 0.5 mile south of a Dall sheep mineral lick, an important summer habitat. In winter, Dall sheep congregate on south-facing slopes between Granite Creek and Kings River. This segment crosses one and parallels two anadromous streams and is located in the MVMR which will require special wetland/stream buffer zones. Sections along Eska and Little Granite Creeks may have to be rerouted to address ADNR concerns.

A knob just north of Little Granite Creek is used as a take-off point for hang-gliding and the routing of Segment 1-2 must consider the conflicts a line would create. Curtailment of hang-gliding activities for safety reasons would be considered in land use impacts. Depending on the extent that Granite Creek is used by private aircraft, a long span crossing may be considered an obstruction hazard and will have to appropriately marked and identified for local pilots. A landing strip is shown on Map 1 about 0.5 mile west of the route.

A possible route modification north of Knob Hill would mitigate both visibility of the line from Granite Creek and interference with hang-gliding activities, but with a penalty of adding 1.85 miles to the line at a cost of about \$500,000. This route modification would pass through Dall sheep habitat near node 2.

An alternative substation site about 0.3 mile up a private road at Mile 60 of the Glenn Highway should be investigated since aerial photos indicate more level terrain is possible there. The substation would be fed by a single circuit line from the tap of the O'Neill tap line. Final routing of this segment would have to consider land use impacts to the strip mining operations and impacts of the mines on line design (e.g., blasting operations, excavation and stockpiling).

This segment lies on 1.5 miles Native land (Cook Inlet Regional Incorporated, "CIRI"), 2.8 miles state land, 1.1 miles of Mat-Su Borough land and 0.5 mile of State Mental Health Trust lands.

Segment 2-3 (length 11.36 miles)

The segment travels in a northeast direction up the west side of Young Creek to Chain Lakes at segment mile 7.0 where it heads east, crossing Kings River at segment mile 8.7.

Aerial photos indicate bare rock and or landslide activity at about segment mile 2.35 and mile 5.5 on the slopes of Red Mountain which were investigated closely during the summer flyover and ground review. Alternative paths around these areas are shown on the base maps as dashed lines.

This segment routing was selected to further hide the line from the Glenn Highway travelers and users of the Chickaloon Trail and to avoid impacts to private and native lands. It avoids the Chickaloon Trail, being no closer than about 1.5 miles from the trail. Since the segment is located higher up the mountain sides it is possible that the line would be more visible from a few vantage points along the highway than the Segments 2-31 and 31-3 hidden on the bench above the Glenn Highway or in the Kings River Valley. This should be evaluated in the preliminary design phase with the aid of a visual simulation model.

A long span crossing (estimated at 1,500 ft-1,750 ft) of the Kings River would be required. Depending on the extent that Kings River is used by private aircraft, a long span crossing may be considered an obstruction hazard and will have to be appropriately marked and identified for local pilots.

Segment 2-3 skirts the southeast facing slopes of Red Mountain which are a prime winter habitat for Dall sheep. It also passes about 0.5 mile from a mineral lick. Segment 2-3 traverses wetlands near node 2 and will span wetlands at Kings River. Segment 2-3 essentially lies entirely outside the MVMR.

This segment is located on 3.0 miles Native-selected state lands (CIRI, subsurface, Chickaloon Moose Creek Native Association, "CMCNA", surface claims), 3.3 miles state land, and 4.8 miles of State Mental Health Trust lands.

Segment 2-31-3 (length 12.47 miles)

This segment combination is located directly on the bench above the Glenn Highway heading east to segment mile 2.6 where it turns north across a wide gully at segment mile 2.8, then east again across Kings River and the Chickaloon Trail at segment mile 4.7, with a final northeast run about 0.25 mile east of and parallel to the river and trail to node 31. From here the route heads north across the Chickaloon Trail at segment mile 8.3, then east-northeast above the trail system.

The segment would not be visible to travelers of the Glenn Highway but would be visible in spots to users of Kings River, Chickaloon Trail, Fish Lake and Drill Lake as well as residents in this area. Because of the relative proximity to the trail system and river, there appears to be an increased potential for cultural resource conflicts on this segment compared to Segment 2-3.

Segment 2-31-3 lies almost entirely within the MVMR and passes through three stretches of wetlands. It crosses and parallels Kings River, an anadromous stream.

This segment is located on 0.25 miles of private land, 0.75 mile of Native land (CIRI, subsurface rights, CMCNA, surface rights), 6.5 miles state land, and 4.35 miles of State Mental Health Trust lands.

Segment 3-4 (length 6.68 miles)

This segment heads in an east-northeast direction, crossing California Creek at segment mile 0.4 and the Chickaloon River/Trail at segment mile 3.6. It proceeds on the north side of and parallel to Boulder

Creek where the terrain is relatively flat. The CKN Trail is located on the south side of Boulder Creek and another trail from Simpson Cabin to Chickaloon River parallels this segment on the north side at generally higher elevation.

This segment will not be visible from the Glenn Highway but will be visible to users of the Chickaloon River, Boulder Creek and other trails in the area. The routing of this segment was moved north of Boulder Creek away from the recreational use area around Bonnie and Rush Lakes and the CKN Trail system. Higher, channeled wind loading should be expected out of Chickaloon River transverse to the line.

Segment 3-4 passes through wetlands near node 3, at Chickaloon River and at node 4. Except for about 1 mile at the beginning, this segment lies outside the MVMR. It crosses Chickaloon River, an anadromous stream, and parallels Boulder Creek at a distance of 0.25 mile approximately and high above the creek bed.

This segment is located entirely on State Mental Health Trust lands.

At this point two major alternatives begin: one up Boulder Creek and the other continuing along Anthracite Ridge to Hicks Creek. The latter will be discussed first.

Segment 4-4A (length 2.92 miles)

Node 4A was introduced for convenience after old Segment 4-5 was eliminated from consideration. The combination of Segments 4-4A and 4A-5 replaces Segment 4-5, which crossed the CKN trail twice, had a fairly visible span within the viewshed of Rush Lake, and would disrupt views to the south from the CKN Trail.

Segment 4-4A heads northeast to a point about 0.7 mile north of Simpson Cabin. It crosses a trail at about segment mile 0.8. Elevations range from 2,200 ft at node 4 to 2,500 ft at node 4A. The segment lies north of Boulder Creek and might be visible to CKN Trail users.

This segment lies entirely outside the MVMR and encounters wetland areas in the last 0.7 mile.

This segment lies in 1.8 mile of State Mental Health Trust lands and 1.1 miles of state land. The segment passes to the north of a Native-selected parcel in the vicinity of Simpson Cabin.

Segment 4A-5 (length 5.24 miles)

This segment crosses Boulder Creek above Simpson Cabin and proceeds southeast to Node 5. It is located north of the CKN Trail and does not cross the trail at any point. Although it would be visible at points to users of the CKN Trail, this segment's location on the southern flank of Anthracite Ridge would not disrupt the direct southern viewshed from the trail.

Elevations range from 2,500 ft to over 3,500 ft with most of the segment lying below the 3,000 ft contour. The segment would be on mostly open or sparsely wooded land and might be visible from points along the Glenn Highway.

This segment lies outside the MVMR and entirely on state lands. The segment crosses Boulder Creek, an anadromous stream.

Segment 5-5A-5B-5C-6 (length 9.32 miles)

Segment 5-5A-5B-5C-6, which passes north of Strelshla Mountain, was selected to replace Segment 5-6 which passed south of Strelshla Mountain. Segment 5-6 was abandoned due to its potential for high visibility from the Glenn Highway and to residents of the Victory Road, Index Lake area. The new segment also avoids the two-lobed, active rock glacier which could have exposed about 1 mile of Segment 5-6 to falling or moving rock and debris. An ADNR study of the rock glacier's southwest trending lobe showed it moved 26 ft in the two-year study period.

This new segment might be visible at some points along the Glenn Highway, but not to the same extent as the former route segment.

This new segment is slightly shorter than the old Segment 5-6, but places 4.0 miles of this segment in the severe Loading Zone 4. This would require all-helicopter construction and represents a higher cost for the project.

Segment 5-5A-5B-5C-6 lies outside the MVMR. It is located entirely on 9.32 miles of state land.

Segment 6-9 (length 4.71 miles)

This segment heads in a southeasterly direction crossing from the Hicks Creek to the Pinochle Creek drainage. It crosses the CKN Trail at segment mile 1.2 and then turns east at segment mile 1.8 where it begins to generally parallel Dan Creek on the north side. The terrain is relatively flat for the entire segment length, varying between 3,000 ft and 2,500 ft, except in the vicinity of the trail, where the route drops from elevation 3,000 ft to 2,200 ft in just under one mile.

The portion of the route between Hicks Creek and Pinochle Creek drainages will be visible to users of the Pinochle trail. Travelers along the Glenn Highway may be able to view portions of the route from segment mile 1 to mile 3 depending on forest cover and season.

Segment 6-9 passes to the south of caribou winter/summer habitat in the Fortress Ridge area and to the north of the MVMR. It passes through a 1 mile stretch of wetlands as it parallels Dan Creek.

This segment is located entirely on Native land (CIRI).

Segment 9-11 (length 7.37 miles)

This segment extends from Dan Creek to Squaw Creek heading in a northeasterly direction, parallel to Caribou Creek for its entire length. For the first five miles the segment is routed on the west side of Caribou Creek, along the eastern flank of Fortress Ridge, where the terrain stays relatively flat at about elevation 2,500 ft. At segment mile 5 the route would cross to relatively level and open terrain on the east side of Caribou Creek. Sparse forest cover and open terrain make hiding the line difficult. The route segment would be visible by users of Dan Creek and the Squaw Creek trail. It may also be visible to users

of Caribou Creek downstream of the Glenn Highway crossing. The route segment would not be visible to travelers on the Glenn Highway. See comments regarding unpatented mining claims in Segment S 4-7.

Two long span crossings (estimated at 1,500 ft) of Fortress Creek at mile 3.5 and Caribou Creek at mile 4.8 would be required.

Segment 9-11 lies entirely outside the MVMR and this point represents the easternmost extent of the MVMR. The segment parallels Caribou Creek, an anadromous stream, high above the creek bed. Wetlands along Fortress Creek and Caribou Creek would be spanned or avoided by the recommended route modification shown in dashed lines on Map 3. It is not expected that this segment would affect caribou concentrations on Fortress Ridge or Dall sheep on Sheep Mountain.

This segment passes about 0.5 mile north of the Caribou Creek Recreational Mining Area on the lower stretch of the creek. It is possible that a small section of Segment 9-11 would be visible to users of this area.

This segment is located on 0.7 mile of Native land (CIRI) and 6.7 miles state land.

Segment 4A-7 (length 10.61 miles)

This segment begins one of two major route alternatives, the other being Segment 4A-5, discussed earlier. The segment heads in a northeasterly direction, staying entirely within the Boulder Creek canyon bottom area where it would cross the creek several times to avoid steep slopes or unstable soil conditions. Terrain is extremely flat along the creek bottom. The line may be visible from the CKN Trail up until segment mile 3. The line on this segment would be visible for its entire length to users of the Boulder Creek trail.

Segment 4A-7 will encounter significant stretches of wetlands totaling about 4 miles along Boulder Creek. Final route layout would attempt to avoid wetland and potential landslide areas but it will probably not be possible to avoid traversing some wetlands parallel to Boulder Creek.

Numerous unpatented mining claims appear on Division of Mine records in Fairbanks. These would be treated the same as private land owners. The exact number of claims is not known but it is estimated that a total of 100 to 200 claims along Boulder Creek, Caribou Creek, Squaw Creek, Alfred Creek and in Chitna Pass may exist.

This segment is located entirely on state land (10.61 miles).

Segment 7-7A-8 (length 12.52 miles)

This segment heads northeast, crossing Chitna Pass (elevation 4,800 ft) at segment mile 4 and then heads southeast, paralleling Chitna Creek and Caribou Creek as they descend to elevation 2,900 ft at the end of the segment. This segment will not be visible from Glenn Highway but will be visible to users of the Boulder/Caribou Creek trails in the area. See comments regarding unpatented mining claims in the previous section.

Segment 7-8 lies 75% in Loading Zone 4, the most extreme loading zone. It passes through wetlands near node 7, along Chitna Creek and at the confluence of Caribou and Chitna Creeks. Dall sheep habitat is located in the vicinity of Chitna Creek to the south.

This segment is located entirely on state land (12.5 miles).

Segment 8-10 (length 1.44 miles)

This short segment heads southeast, paralleling Caribou Creek, connecting route segments emerging from Chitna Pass or Hicks Creek valley with the Alfred Creek and Squaw Creek route segments. This segment will not be visible from the Glenn Highway but will be visible to users of the Caribou Creek trail. A suggested route modification would push node 8 southwest approximately 1 mile to remove the line from the Caribou Creek bed as shown and allow it to take a more direct, flatter and less visible route from Hicks Creek to Squaw Creek. See comments regarding unpatented mining claims under Segment S 4A-7.

As shown on Map 5, Segment 8-10 lies in wetland areas along Caribou Creek. The suggested route modification would place the line at higher elevations and probably out of the wetland areas.

This segment is located entirely on state land (1.4 miles).

Segment 6-8 (length 8.73 miles)

This segment heads in a northeasterly direction up the west side of Hicks Creek Valley, passing west of Hicks Lake at segment mile 4.5, paralleling Divide Creek for one mile starting at segment mile 6.3, and ending at Caribou Creek. A suggested route modification would move node 8 southwest approximately 1 mile so as to take a more direct route to Alfred or Squaw Creeks. The terrain is relatively flat, beginning at elevation 3,000 ft, rising to 3,500 ft at Hicks Lake, and falling back to 3,000 ft at segment end. This segment will not be visible from the Glenn Highway but will be visible to users of the Hicks Creek trail, with a short portion visible to Caribou Creek trail users.

Segment 6-8 passes through wetlands near node 6 and adjacent to Divide Creek. The suggested route modification discussed under Segment 8-10 would probably avoid the wetlands on Divide Creek.

This segment is located on 0.7 mile of Native land (CIRI) and 8.0 miles of state land.

Segment 10-11 (length 4.25 miles)

This segment heads southeast, paralleling Caribou Creek either on the west or east side. If a route along the north side of Squaw Creek is selected, parallel to the existing road/trail, the preferred crossing of Caribou Creek would be just south of Alfred Creek and route Segment S10-11 would be on the east side of Caribou Creek. If a route on the south side of Squaw Creek is selected, the preferred crossing of Caribou Creek would be south of the confluence of Squaw and Caribou Creeks and S 10-11 would be located on the west side of Caribou Creek. This segment will not be visible from the Glenn Highway but will be visible to users of the Caribou Creek and Squaw Creek trails. See comments regarding unpatented mining claims under Segment S 4A-7.

Segment 10-11 would not apparently be located in any wetlands if routing follows the suggested route modifications discussed above. All route segment alternatives in this area are located on the lower elevation slopes of Syncline Mountain which is habitat to Dall sheep.

This segment is located entirely on state land (4.25 miles).

Segment 10-15 (length 12.61 miles)

This segment begins in the Caribou Creek Valley (elevation 2,600 ft) and heads northeast up the Alfred Creek valley, which turns due east at segment mile 4, and continues up Alfred Creek to segment mile 8, where the route heads up the Pass Creek valley, also in an easterly direction. The segment follows the Pass Creek valley to the end where it crosses just north of Belanger Pass at elevation 4,300 ft and then begins a one mile descent into the Crooked Creek drainage, elevation 3,700 ft.

This segment will not be visible from the Glenn Highway but will be visible to users of the trail along portions of Caribou Creek and most of Alfred and Pass Creeks, with a short portion visible to Crooked Creek trail users. See comments regarding unpatented mining claims under Segment S 4A-7.

Segment 10-15, as shown, passes through wetlands adjacent to Alfred Creek near Wood and Papoose Creeks. It should be possible to avoid these wetlands by siting the line on the south bank bench of Alfred Creek.

This segment is located on 4.8 miles of state land and 7.8 miles federal land.

Segment 11-12 (length 4.74 miles)

This segment begins at the confluence of the Caribou and Squaw Creeks, heading east along Squaw Creek on either the north or south side. If Segment S 9-11 heading north up Caribou Creek is selected, Segment S 11-12 will be south of Squaw Creek for most of its distance; if S 10-11 coming from the north is selected then S 11-12 may be located north of Squaw Creek. The south side of Squaw Creek is characterized by open terrain but relatively poor access and the possibility of discontinuous permafrost in colluvial soils on the northern exposure, while the north side route is located generally parallel to the existing road but is densely forested. This segment will not be visible from the Glenn Highway but will be visible to users of the Squaw Creek trail. See comments regarding unpatented mining claims under Segment S 4A-7.

Segment 11-12, if located north of Squaw Creek, will pass through about 1 mile of wetlands between Caribou Creek and Inoceramus Creek. The southern alignment would avoid these wetlands.

This segment is located entirely on state land (4.7 miles).

Segment 12-13 (length 3.14 miles)

This segment begins on the south side of Squaw Creek and runs north, crossing the creek and then turning northeast at segment mile 0.4 up the north side of Squaw Creek valley in relatively level and open terrain. Total elevation gain across the segment is only 300 ft. The precise crossing point of Squaw Creek must be selected to take maximum advantage of terrain elevation differences and likely would be shifted

slightly from the location shown on Map 5 in final design. This segment will be visible to users of the Squaw Creek trail and a majority will probably be visible from the Glenn Highway.

Segment 12-13, as shown, crosses wetlands at the crossing of Squaw Creek about 1 mile below Squaw Lake. Lack of elevation contours at this point make spanning the wetlands impractical. A crossing point farther to the west would appear to offer more favorable terrain for avoiding wetlands adjacent to Squaw Creek. However, passing to the north side of Squaw Creek farther west would still require traversing the wetlands near node 12.

This segment is located entirely on state land (3.1 miles).

Segment 13-14 (length 3.3 miles)

This segment loops around a topographic "bowl" at the end of Martin Road and at the point of egress of Belanger Pass in an effort to avoid a number of cabins and private parcels. This segment (beginning elevation 3,200 ft) heads due north reaching elevation 4,000 ft, starts a gradual descent as it turns northeast at segment mile 1.1 reaching elevation 3,800 ft, turns due east at segment mile 2.1, and turns southeast at segment mile 2.7 ending at elevation 3,400 ft. The majority of this segment would be visible to users of the Pass Creek and Crooked Creek trails as they descend into the bowl and would be visible, although at a distance of 2 to 2.5 miles from the Glenn Highway. Based on ground reconnaissance it appears that the line would not be highly visible to occupants of the few cabins off Martin Road since they are located beneath an elevation bench at the lip of the bowl. According to the local lodge owner, there are currently only one or two permanent residents in the group of cabins.

Segment 13-14 passes through about 0.5 mile of unspanable wetlands.

This segment is located on 2.5 miles of state land and 0.8 mile of federal land.

Segment 14-15 (length 1.91 miles)

This segment connects the route alternative emerging from Squaw Creek with that emerging from Alfred Creek. It heads in a northeasterly direction up the Crooked Creek valley, paralleling the trail and creek to the west; ground reconnaissance indicates that a location on the east side is preferable due to favorable, open terrain on high ground. Total elevation gain across the segment is only about 300 ft. The first half-mile of this segment will be visible at a distance of 2 to 2.5 miles from the Glenn Highway, but the entire segment will be visible to users of the Crooked Creek trail.

Segment 14-15 traverses no wetlands.

This segment is located entirely on federal land (1.9 miles).

Segment 14-16 (length 6.2 miles)

This segment follows Old Man Creek beginning north of Startup Lakes. From ground reconnaissance it appears possible to site this line segment on the slopes of the west side of the creek achieving the objectives of mitigating visibility and having relatively dry foundation conditions. This line segment would be potentially highly visible to travelers along the Glenn Highway and visual simulation is recommended to

site the line segment out of view to the maximum extent possible. It would be difficult to hide the line segment as it enters and emerges from the Old Man Creek drainage. Users of the numerous snowmobile and ATV trails in the area would see the line.

Segment 14-16 traverses about 0.5 mile of wetland near node 16. It passes to the south of caribou winter range. It is likely that much of the construction in this segment would take place in winter leading to possible conflicts.

This segment is located entirely on federal land (6.2 miles).

Segment 15-16 (length 4.57 miles)

This segment begins in the Crooked Creek valley and heads northeast to segment mile 0.8, then turns due east to climb over a high, unnamed ridge to segment mile 3.3, then turns northeast to the end of the segment. The segment begins at elevation 3,600 ft and in 2 miles reaches 4400 ft at the top of the ridge, after which it begins a gradual descent to 3,200 ft at the end of the segment. Severe loading conditions can be expected on top of the ridge.

Approximately one mile of the segment, as it descends from the top of the ridge in open terrain, would be visible to travelers along the Glenn Highway, with medium density forest cover and a small knoll between the end of the route and the highway partially hiding the last part from view. The first two miles of this segment which climbs to the top of the ridge will be visible only to users of the Crooked Creek trail.

Segment 15-16 passes through about 0.5 mile of wetlands near node 16. It is about 1 mile closer to the caribou winter range than Segment 14-16.

This segment is located entirely on federal land (4.6 miles).

Segment 15-17 (length 6.26 miles)

This segment heads in a northerly direction up the Crooked Creek valley, paralleling the trail and creek to the east on high ground. The route would cross six small, intermittent streams that feed into Crooked Creek. The creek bed itself is extremely wet terrain, but achieving high ground on eastern slopes will improve construction conditions. The route segment would be located at elevations generally above 3,500 ft reaching 4,000 ft in some locations. This segment will not be visible from Glenn Highway but will be visible to users of the Crooked Creek trail.

Segment 15-17 passes through wetlands near node 15 for less than about 0.5 mile. It appears possible to avoid these wetlands by following Segment 15-16 for about 0.5 mile to its first point of intersection (PI) then heading north on higher ground.

This segment is located on 0.7 mile of state land and 5.6 miles of federal land.

Segment 16-18 (length 5.89 miles)

This segment crosses the Old Man Creek drainage heading in a general northeast direction. Terrain is level with significant muskeg expected. The segment begins at approximate elevation 3,200 ft and drops

steadily to elevation 2,900 ft plus. Depending on perspective the segment would be visible in certain locations to travelers on the Glenn Highway, but at a distance of more than 1.5 miles.

Segment 16-18 passes through wetlands for a stretch of about 1 mile just beyond node 16. It may be possible to avoid these wetlands by moving the line to higher ground, but at the cost of potentially greater visibility from the Glenn Highway. The segment also passes through a 1 mile stretch of wetlands just prior to node 18. Rerouting to avoid these wetlands appears impractical. This segment passes through the southern fringes of caribou winter range.

This segment is located on 5.6 miles of state land and 0.3 mile federal land.

Segment 17-17A-19 (length 9.06 miles)

This segment crosses the Little Nelchina River drainage heading due east from the Crooked Creek valley and crossing Old Man Creek at segment mile 6.0 and the Little Nelchina River at segment mile 8.3. The route would also cross several small, intermittent streams, ponds and lakes. Terrain is flat along the entire segment with significant areas of muskeg anticipated. The segment begins at elevation 3,700 ft, crosses a ridge at elevation 3,900 ft plus before dropping gradually to the river bed at elevation 2,700 ft and starting the climb up Slide Mountain. This segment will not be visible from Glenn Highway but will be partially visible to users of the Crooked Creek trail. A possible route modification would take a more direct route from a point approximately 1.5 miles south on Segment S 15-17 to the PI at segment mile 3.8 on S 17-17A-19. This modification is not shown on the base maps.

Segment 17-17A-19 traverses about 4 miles of wetlands. It does not appear practical to route around these wetlands. Winter construction would be required. This segment passes through caribou winter range which may create construction conflicts.

This segment is located entirely on state land (9.1 miles).

Segment 18-18A-18B-21 (length 13.75 miles)

This segment crosses the Little Nelchina River and Slide Mountain. It heads due east and crosses the Little Nelchina River at segment mile 1.3, turns northeast at segment mile 6.1, crosses Cache Creek several times over 3 miles, turns due east at segment mile 10.8 at a point north of Snowshoe Lake, and turns due north at segment mile 13.2 around Lila Lake. The route would also cross several small, intermittent streams, ponds and lakes. Possible route modifications include (1) removing the 90 degree jog around Lila Lake by taking a direct route from segment mile 10.8 to node 21, (2) locating the final route to the south of Cache Creek on the east side of Slide Mountain, and (3) connecting from segment mile 10.8 to node 20 on the more northerly route. Terrain is flat along the entire segment. The segment starts at elevation 2,900 dropping to elevation 2,700 ft in the Little Nelchina River bed, climbing steadily over the next 3.5 miles to a high point on Slide Mountain at elevation 3,800 ft, then dropping gradually to elevation 2,350 ft near Lila Lake. This segment will probably be visible from some perspectives along the Glenn Highway as it descends the east slope of Slide Mountain, albeit at a distance of some 2 to 3 miles.

Segment 18-18A-18B-21 encounters a solid 4.5-5.0 mile stretch of unavoidable wetlands on the east side of Slide Mountain. It passes through a dispersed waterfowl nesting area above Snowshoe Lake and trumpeter swan nesting areas around Lila Lake. Special mitigation measures will be required to limit

waterfowl-line strikes. These measures may include limiting structure and wire height at a significant cost penalty, or marking wires with marker balls or special damper-like devices. Suggested route modification (1) would eliminate a parallel of Lila Lake and give a greater wetland buffer.

Segment 18-18A-18B-21 passes about 1.5 miles north of the seaplane base at Snowshoe Lake. This should not pose an obstruction to air navigation but still may have to be marked.

This segment is located entirely on state land (13.8 miles).

Segment 19-20 (length 12.13 miles)

This segment crosses Slide Mountain approximately 3 miles farther north than Segment S 18-18A-18B-21. It begins 0.75 mile east of the Little Nelchina River and heads northeast for 3.5 miles at approximately constant elevation 2,950 ft. It then turns due east climbing over the back side of Slide Mountain reaching a high point of elevation 3,400 ft just north of benchmark VABM Ben at segment mile 5.4 and crossing a knoll at elevation 3,200 ft at segment mile 7.1 near VABM Cat. At segment mile 8 approximately the route begins a 4-mile traverse of flat terrain at elevation 2,600 ft-2,400 ft to its end point about 0.5 mile west of Nickoli Lake. The route would cross several small, intermittent streams, ponds and lakes. Possible route modifications include routing around the knoll at segment mile 7.1. This segment will probably not be visible from the Glenn Highway due to the distance from the highway and its location behind Slide Mountain.

Segment 19-20 encounters a solid 3.5 mile stretch of wetlands on the east side of Slide Mountain, again apparently unavoidable. It passes through a dispersed waterfowl nesting area. Both Segments 18-18A-18B-21 and 19-20 pass south of a moose fall rutting area southwest of Old Man Lake and a trumpeter swan nesting area on Old Man Lake.

This segment is located entirely on state land (12.1 miles)

Segment 20-22 (length 4.99 miles)

This segment begins 0.5 mile west of Nickoli Lake and heads northeast, 0.25 mile north of Nickoli Lake, to the end of the segment. The route crosses an unnamed trail at segment mile 0.6, and Mendeltna Creek at mile 1.5. Terrain is flat along the entire segment ranging from elevation 2,400 ft at the beginning of the segment to elevation 2,700 ft at the end. The route segment parallels the Mendeltna Creek road to the east for about 1.5 miles before crossing the road at segment mile 4.5. This route segment is markedly less visible from the scenic overlook on Lake Louise Road and to travelers on Lake Louise Road than route segments farther to the south. This segment will probably not be visible from the Glenn Highway but will be visible to travelers on Mendeltna Creek Road and portions of Lake Louise Road. The segment right-of-way may be oriented along the direct line of view of the valley and mountains to the south for travelers on certain portions of Mendeltna Creek Road.

Segment 20-22 is almost entirely located in wetland areas. It crosses Mendeltna Creek, an anadromous stream, and passes through a waterfowl spring/fall concentration area. Special mitigation measures would be required to limit impacts to waterfowl as mentioned under Segment 18-18A-18B-21. Segment 20-22 also passes through a moose calving area active in spring and summer months. Although

most construction work occurs in winter, stringing operations would take place in summer and could pose a conflict.

This segment is located entirely on state land (5.0 mile).

Segment 21-23 (length 5.19 miles)

This segment begins one-half mile west of Nickoli Lake and heads due east, passing south of the lake, until segment mile 3.4 where it turns northeast to the end of the segment. The route crosses an unnamed trail at segment mile 0.5, 0.7 and 1.3, and Mendeltna Creek at mile 2.3. The route as shown would also cross several small, intermittent lakes and ponds. Terrain is relatively flat along the entire segment with elevations between 2,400 ft and 2,700 ft generally. This segment will probably not be visible from the Glenn Highway but may be visible from some vantage points on Lake Louise Road. Possible route modifications include taking a more direct route from a point south of Nickoli Lake to node 23 and final layout to avoid crossing lakes.

Segment 21-23 passes through extensive, but discontinuous wetlands for an estimated 80% of its length. It passes through a known waterfowl spring/fall concentration area and trumpeter swan nesting area around Lila Lake. It crosses Mendeltna Creek, an anadromous stream. Segment 21-23 also skirts the southern end of Nickoli Lake and may be subject to special buffer requirements. Special mitigation measures will be required to limit impacts to waterfowl as mentioned under Segment 18-18A-18B-21.

This segment is located entirely on state land (5.2 miles).

Segment 23-24 (length 6.02 miles)

This segment generally parallels the Glenn Highway on the north side at a distance of 1-1.5 miles and is located on the lip of an expansive plateau. The segment heads northeast through segment mile 5.8, where it turns almost due north for a short distance to the end of the segment. The route crosses Lake Louise Road at segment mile 4.1, just south of Crater Lake and a scenic overlook with a view shed of the Chugach Mountains to the south and southwest. As shown it would cross an unnamed creek at mile 5.6 and several small, intermittent lakes and ponds. Terrain is undulating but relatively level along the entire segment, ranging in elevation from 2,300 ft to 2,700 ft. This segment will probably be highly visible from the Glenn Highway due to its location on the lip of the plateau to the north of the highway and to travelers on Lake Louise Road. Visual impact to the view shed to the south from points on Lake Louise Road is expected to be high and difficult to mitigate. Possible route modifications include (1) final layout to avoid crossing lakes, (2) shifting the route segment north in an effort to mitigate visual impacts, and (3) eliminating the jog at the end of the segment.

Segment 23-24 passes through extensive but discontinuous wetlands for most of its length. It is located in a dispersed waterfowl nesting area. Route modifications mentioned are not expected to avoid these potential impacts.

This segment is located entirely on state land (6.0 miles).

Segment 24-25 (length 4.88 miles)

This segment heads northeast to the eastern lip of the plateau across flat terrain at elevation 2,700 approximately. Possible route modifications include (1) final layout to avoid crossing lakes, (2) taking a direct route from a point near segment mile 2-3 to segment mile 11 on S 22-26. The route as shown crosses several unnamed creeks and ponds. This segment will probably not be visible from the Glenn Highway, except perhaps the last section near node 25. Visual impact would be mitigated by adopting possible route modification (2).

Segment 24-25 passes through two areas of wetlands each about 0.5 mile long. It does not appear practical to avoid these by any minor reroute. This segment is closer to the Glenn Highway than Segment 22-26 but farther away from caribou winter range.

The combination of wetlands and caribou winter range may create construction conflicts.

This segment is situated entirely on state land (4.88 miles).

Segment 25-26 (length 2.27 miles)

As shown this segment heads due north along the east slope of the plateau at elevation 2700 through segment mile 1.0, where it turns due east through segment mile 2.0, and northeast to the end of the segment at elevation 2400. The route crosses Little Woods Creek at segment mile 1.3. Possible route modifications include (1) moving the first 1.0-mile leg farther to the west to lessen potential visibility, (2) adopt possible route modification (2) for Segment S 24-25 removing the 90 degree turns. As shown, this segment will probably be visible from the Glenn Highway, at least for the first 1.0-mile, and may be visible for parts of its entire length from certain points on the Glenn Highway. This visual impact would be mitigated by adopting possible route modification (1) or (2).

Segment 25-26 is located almost entirely in wetland areas and in the vicinity of caribou winter range, again with the potential of construction conflicts.

This segment is located entirely on state land (2.3 miles).

Segment 26-27 (length 7.97 miles)

This segment generally proceeds eastward, paralleling the Glenn Highway at a distance of 2.5 to 3.0 miles. It passes about 0.3 mile north of Moose Lake before crossing Tolsana Creek, an anadromous stream, at approximately segment mile 3.7. Terrain is very flat along the entire segment starting at elevation 2500 but spending most of its length at elevation 2100-2200. This segment will not be visible from the Glenn Highway, situated as it is for most of its length 3 miles north of the highway in forested lands.

The alignment of this segment passes to the north and east of Mud Lake, a trumpeter swan nesting area, at a distance of about 0.3 mile. Special mitigation measures will be required to limit impacts to the trumpeter swans during nesting and as they fly into and out of the lake area. A possible route modification would extend Segment 26-27 eastward to a point directly north of node 28 to avoid encircling Mud Lake.

Segment 26-27 lies entirely on state lands (7.97 miles). It passes through about 3 miles of wetlands and south of caribou winter range with the potential for construction conflicts.

Segment 22-26 (length 13.56 miles)

This segment climbs, traverses and descends the plateau between the Mendeltna and Tolsona Creeks. It heads due east starting at elevation 2,700 ft, paralleling Mendeltna Creek Road on the north side for 1.3 miles where it passes to the south side of the road before crossing Lake Louise Road at segment mile 2.0 at elevation 3,100. The route segment then traverses the plateau over relatively flat terrain, elevation 2,800-3,100, containing many small lakes and ponds. At approximate segment mile 11.0 the route segment descends to elevation 2,500 ft. Possible route modifications include (1) final layout to avoid crossing lakes, (2) keeping the line segment north of Mendeltna Creek Road for the entire length of parallel to avoid adverse impact to view shed of Chugach Mountains, and (3) routing to further mitigate visual impacts to travelers on Lake Louise Road. This segment will probably not be visible from the Glenn Highway but will be visible to travelers on Mendeltna Creek Road and portions of Lake Louise Road.

Segment 22-26 is located south of caribou summer and winter range, passes through a dispersed waterfowl nesting area, and runs just north of a trumpeter swan nesting area. Segment 22-26 is located in wetlands for about 50% of its length. Special mitigation measures will be required to limit impacts to waterfowl as mentioned under Segment 18-18A-18B-21.

This segment is located entirely on state land (13.6 miles).

Segment 27-28 (length 6.44 miles)

This segment heads due east descending into the Copper River basin, running parallel to and 1.5 miles north of the Glenn Highway, through the end of the segment. Terrain is very flat along the entire segment starting at elevation 2,100 ft and gradually dropping to elevation 1,700 ft approximately. This segment will probably not be visible from the Glenn Highway due to its distance from the highway and relatively heavy, though stunted forest cover.

Segment 27-28 crosses about 5 miles of wetlands and at node 27 lies in a trumpeter swan nesting area. Special mitigation measures will be required to limit impacts to waterfowl as mentioned under Segment 18-18A-18B-21.

This segment is located on 5.0 miles of Native land (Tazlina Village Corporation surface rights, Ahtna Regional Corporation subsurface rights) and 1.4 miles of state land.

Segment 27-29 (length 9.05 miles)

This segment crosses the Glenn Highway and parallels the Tazlina River on the north side. The segment heads due south through segment mile 2.5, where it turns southeast through segment mile 3.2, and east to the end of the segment. The route crosses the Glenn Highway at segment mile 1.5, which is approximately highway mile 174.5. The route also essentially parallels the Tazlina River trail (and crosses it twice) from about segment mile 5.1 to the end of the segment. Terrain is very flat along the entire segment, dropping gradually from elevation 2,100 ft to elevation 1,700 ft. The portion of this segment parallel to the Tazlina River will probably not be visible from the Glenn Highway due to its

distance from the highway and relatively heavy forest cover. The highway crossing, as shown, occurs in open lands and because the line structures will be significantly taller than any surrounding vegetation the right-of-way and line will be highly visible from a section of the Glenn Highway either side of the crossing. It is not expected that the crossing would impair views of the Wrangell Mountains to the east from the Glenn Highway.

This segment passes through about 7.5 miles of wetlands which appear unavoidable. The extent of wetlands crossed by Segment 27-29 is slightly more than that crossed by Segments 27-28, 28-29. The segment parallels the Tazlina River, an anadromous stream, at a distance of 0.3 to 1.5 miles approximately. Some commercial stands of timber may be encountered according to ADNR.

This segment is located on 4.7 miles of Native land (Tazlina Village Corporation surface rights, Ahtna Regional Corporation subsurface rights) and 4.4 miles of state land.

Segment 28-29 (length 2.6 miles)

This segment crosses the Glenn Highway about 6 miles farther east than S 27-29. It heads due south through the end of the segment. The route crosses the Glenn Highway at segment mile 1.5, which is approximately highway mile 181. Terrain is very flat along the entire segment at almost constant elevation 1700. The majority of this segment as shown will probably be visible from the Glenn Highway due to the highway crossing in open terrain and the fact that structures will be much taller than surrounding vegetation. Possible route modifications include (1) shifting this segment west about 0.5 mile to forested lands. This would allow hiding the right-of-way by maintaining a corridor of tree growth adjacent to the highway and it might assist in hiding the line at some distance from the highway. However, this will also increase clearing costs. Some commercial stands of timber may be encountered according to ADNR.

This segment crosses about 2.0 miles of wetlands.

This segment is located entirely on Native land (Tazlina Village Corporation surface rights, Ahtna Regional Corporation subsurface rights) (2.6 miles).

Segment 29-30 (length 7.70 miles)

This segment terminates at the existing Pump Station No. 11 Substation adjacent to the Aleyeska Pipeline in Glennallen and is common to all route alternatives. This segment heads east through segment mile 7.1, where it turns northwest to parallel the existing Glennallen-Valdez 138-kV line and then into the substation. The route as shown crosses the Tazlina River trail four times, an unnamed creek at segment mile 3.5, and Moose Creek just before turning northwest towards the substation. At about segment mile 4.7 it passes about 0.25 miles south of a private parcel but available aerial photography shows no homes exist on the parcel. Terrain is very flat along the entire segment starting at elevation 1700 and dropping gradually to elevation 1400 approximately. Possible route modifications include (1) routing slightly farther north of the Tazlina River bank at the bend in the river at segment mile 1.7 and (2) taking a more direct route into the substation rather than paralleling the existing line. The majority of this segment will not be visible from the Glenn Highway due to fairly heavy forest cover and its distance from the highway. It may be visible at a distance of 1-1.5 miles from high viewpoints north of the Glenn Highway in Glennallen.

It is estimated that this segment crosses 2 miles of wetlands. The segment parallels the Tazlina River, an anadromous stream, at a distance of 0.25 to 1.5 miles and high above the riverbed. Some commercial stands of timber may be encountered according to ADNR.

This segment is located entirely on 7.7 miles of Native land (Tazlina Village Corporation surface rights, Ahtna Regional Corporation subsurface rights).

G. DESCRIPTION OF ROUTE ALTERNATIVES

As discussed earlier, four route alternatives were identified for comparison. They are all combinations of the route segments described above. In Table III-1 (on page III-13 of this Section), elevation, loading zone and length data for these four route alternatives are tabulated.

1. Route Alternative A, The Northern Route

Route Alternative A generally follows route segments located farthest from the Glenn Highway and with a length of 134.4 miles is only slightly longer than Route Alternative B. In common with the other alternatives, Route Alternative A shares Segment 1-2 in the Sutton area before following Segment 2-3 up Young Creek to Chain Lakes and 3-4 to the Chickaloon vicinity. It then takes Segments 4-7, 7-8, 8-10, and 10-15 up Boulder Creek, over Chitna Pass into the Caribou Creek drainage, and then along Alfred Creek, emerging from the divide at Pass Creek on the east side of Syncline Mountain. At this point Route Alternative A follows Segment 15-17 north up Crooked Creek to about Cottonwood Creek before heading east and north of Slide Mountain on Segments 17-19 and 19-20. This alternative then would take Segments 20-22, 22-26 eastward staying a minimum of 2.5 miles north of the Glenn Highway. This alternative crosses Lake Louise Road at approximately mile 6 of the road. Segment 26-27 north of Moose Lake and Mud Lake is common to all route alternatives. The final approach to Glennallen is made along Segments 27-28, 28-29 and 29-30, crossing to the south of the Glenn Highway near mile 181 to follow the north bank of the Tazlina River.

2. Route Alternative B, The Southern Route

Route Alternative B is 134.4 miles long and generally is the closest to the Glenn Highway, although still a considerable distance from the highway. In common with the other alternatives, Route Alternative B shares Segment 1-2 in the Sutton area before following Segments 2-3-1-3 and 3-4 to the Chickaloon vicinity. It then skirts the south slope of Anthracite Ridge following Segment 4-4A-5 and then 5-5A-5B-5C-6 around Strelshla Mountain and up Hicks Creek. At this point Route Alternative B follows Segment 6-9 down Pinochle Creek, around the south side of Fortress Ridge and along Dan Creek before heading up Caribou Creek on Segment 9-11. It passes up Squaw Creek on Segment 11-12 and Old Man Creek on Segments 12-13, 13-14, 14-16 and 16-18. Following Segments 18-21, 21-23, 23-24, 24-25, 25-26 and 26-27 this alternative passes over Slide Mountain and south of Nickoli Lake, crossing Lake Louise Road about 1 mile from the Glenn Highway intersection and passing north of Moose and Mud Lakes. The final approach to Glennallen is made along Segments 27-29 and 29-30, crossing to the south of the Glenn Highway near mile 174 to follow the north bank of the Tazlina River.

3. Route Alternative C

Route Alternative C, 137.0 miles long, follows Route Alternative B (closest to road) from Sutton to the Victory Road area. It differs from other alternatives in taking Segment 6-8 up the west side of Hicks Creek. It then takes Segments 8-10 and 10-11 down Caribou Creek, Segment 11-12 along Squaw Creek, and Segments 12-13 and 13-14 up to Belanger Pass. At this point Route Alternative C takes Segment 14-15 into the Crooked Creek drainage and Segment 15-16 parallel to Old Man Creek. From this point this alternative follows the same Segments as Route Alternative B.

4. Route Alternative D

Route Alternative D, 134.6 miles long, is identical to Route Alternative A except that from node 4 to node 8 it passes south of Anthracite Ridge and up Hicks Creek, where Route Alternative A goes up Boulder Creek and over Chitna Pass.

H. ROUTE ALTERNATIVE COMPARISON

This exercise of route comparison is not intended to take the place of a formal impact assessment as may be required by NEPA regulations for an Environmental Assessment. The evaluation of various route alternatives which follows reflects the sole judgment of the R. W. Beck project engineering staff, based on information compiled during the study. The methodology using measurable objective route evaluation criteria, described below, was adopted to systematically compare route alternatives. The selection of evaluation criteria and their weights was based on the engineers' judgment.

1. Methodology

As a first step in developing a preferred route selection, four route alternatives were compared using a scoring system based on criteria in the categories of environmental concerns, land use impacts, construction and technical concerns, and construction cost. A unit of objective measure (e.g., "each 1000-foot segment in steep terrain counts as one unit of measure" or "each highway crossing counts as one unit of measure") and a subjective weight (0-5) was assigned to each criterion to reflect its perceived importance; public comment was a major factor in selecting weights. For each route segment and for each criterion in the four categories of comparison the product of the measured impact and the criterion weight was determined. The total impact for each criterion over all route segments was summed for each route alternative and normalized to the lowest value sum among the four route alternatives. A summary table of this preliminary comparison is included as Table S-1 in Appendix A.

A description of the four comparison categories and their several criteria and weights is found in Appendix A. Also included is a sample set of the evaluation matrices for all four route alternatives.

Some criteria which were not explicitly addressed include wildlife habitat, environmental concerns expressed by the general public, and unpatented mining claims (land use and financial). Inclusion of these, and perhaps other criteria, might alter findings.

2. A First Comparison

Table III-2 gives one comparison of the route alternatives by uniform weighting of the four categories, i.e., environmental, land use, construction/technical, and financial. Individual criteria weights are as in the attached description; no sensitivity analysis was performed on these weights.

Table III-2 is based on applying equal weighting to each of the four categories.

**Table III-2
Preliminary Comparison of Impacts
Uniform Category Weights**

| Route Alternative | Category | | | | Overall Rank |
|----------------------|---------------|-----------|--------------|------------|-----------------|
| | Environmental | Land Use* | Construction | Financial* | |
| A | Low+ | Medium | High | Medium+ | 3 |
| B | Medium+ | Medium | Low | Medium | 2 |
| C | High | Medium+ | Low+ | Medium+ | 4 |
| D | Low | Medium | Medium | Medium | 1 |

* Weighted indices are essentially equivalent.

3. Sensitivity Analysis

By applying different weights to the four evaluation categories we attempt to predict how the initial ranking of route alternative might change with perspective. Specifically, we assigned a normal weight of 2 to three categories and a high weight of 5 to the other remaining category. The results of this are shown in Table III-3.

**Table III-3
Route Alternative Comparison
Sensitivity Analysis**

| Route Alternative | High Environmental | High Land Use | High Construction | High Financial |
|----------------------|-----------------------|------------------|----------------------|-------------------|
| A | 2 | 3 | 4 | 3 |
| B | 3 | 2 | 1 | 1* |
| C | 4 | 4 | 3 | 4 |
| D | 1 | 1 | 2 | 1* |

* Indicates ranking is essentially the same.

4. Route Alternative Comparison

a. Route Alternative A

(1) Advantages

Route Alternative A is consistently farthest from the Glenn Highway, would have the least visual impact on highway travelers, has relatively low conflict with the MVMR, avoids native lands in Segment 2-31-3, would have the least visual impact to users of the CKN Trail system in

the Matanuska Valley, and has the least length (with Alternatives B and D) in the Chickaloon Special Land Use District ("CSLUD"). Route Alternative A is preferred by Glacier View area residents (Glacier View Community Council, "GVCC," Resolution dated April 7, 1993, Appendix C, Volume 2).

(2) Disadvantages

Route Alternative A would have a high visual impact to users of Boulder Creek, Chitna Pass and Alfred Creek; would be more isolated and expensive to operate and maintain; and would entail dealing with numerous unpatented mining claims.

b. Route Alternative B

(1) Advantages

Route Alternative B avoids the back country areas of Boulder Creek, Chitna Pass, Alfred Creek, etc. and the numerous unpatented mining claims found there.

(2) Disadvantages

Route Alternative B is consistently closest to the Glenn Highway, although at a distance of one to four miles, and will have the highest overall potential for visual impacts to users of the highway. This alternative has the greatest length (with Alternative C) in the MVMR and the CSLUD with the highest potential impacts to these areas. Route Alternative B is opposed by the GVCC. The route has about 4.0 miles in the severe Loading Zone 4, as it passes north of Strelshla Mountain. Route Alternative B is estimated to have the second highest cost.

c. Route Alternative C

(1) Advantages

Route Alternative C shares the advantages of Route Alternative B. It heads up Hicks Creek, rather than following Dan Creek and Caribou Creek as does Alternative B, and therefore would have fewer impacts on the Matanuska Valley.

(2) Disadvantages

Route Alternative C shares the disadvantages of Route Alternative B, except that it would occupy about 6 miles less in the Matanuska Valley. It would use Hicks Creek, a well-used hiking corridor, to the back country. It is the longest route alternative and its estimated construction cost is the highest.

d. Route Alternative D

(1) Advantages

Route Alternative D shares most of the advantages of Route Alternative A except in the area of Anthracite Ridge, where Alternative A passes up Boulder Creek and over Chitna Pass as opposed to Alternative D which passes south of Anthracite Ridge and up Hicks Creek. Route Alternative D was evaluated to have the least estimated development cost.

(2) Disadvantages


Route Alternative D shares the disadvantages of Route Alternative A, except that it is located south of Anthracite Ridge from Boulder Creek to Strelshla Mountain and will have greater impacts to users and resources of the CKN Trail system in the area.

5. Apparent Preferred Route Alternative

This feasibility study stopped short of selecting a preferred route. The foregoing route alternative comparison must be expanded to a full-scale and systematic impact assessment which would consider the magnitude, geographic extent, duration and frequency, and likelihood of impacts. This evaluation would take place during the environmental assessment phase and would follow Council on Environmental Quality guidelines for determining the significance of impacts. However, for the purposes of focusing the feasibility study, we do discuss an apparent preferred route alternative below.


Based on the preliminary comparisons discussed above and Tables III-2 and III-3, Route Alternative D emerges as the apparent preferred route alternative for an Intertie. Although Route Alternative D appears to be preferred, the other route alternatives are competitive. Additional minor route adjustments must be anticipated for any route alternative in response to detailed information on land ownership and input from permitting agencies or other interested parties.

Route Alternative A differs from the "apparent preferred route" by going up Boulder Creek and across Chitna Pass rather than traversing the southern flank of Anthracite Ridge to Strelshla Mountain and on into the Hicks Creek area. Significant public comment was received from residents in this general area indicating a preference for the Boulder Creek route rather than the Anthracite Ridge route. On the basis of this apparent expression of community preference, it is recommended that additional consideration be given to Route Alternative A as well as Route Alternative D in any future route selection process for the Intertie.




NOTE:
UNLESS OTHERWISE NOTED ALL
SEGMENTS THIS MAP IN LOADING
ZONE 1

MAP INDEX



LEGEND

- ROUTE ALTERNATIVE D
- - - ALTERNATIVE ROUTE SEGMENTS
- - - POSSIBLE ROUTE MODIFICATIONS
- EXISTING SUBSTATION
- WITH DOT PROPOSED NEW SUBSTATION
- ① — S 1-2, ② — S 2-31
MILEAGE BETWEEN POINTS IN ()
- KNOWN AVAILABLE ACCESS TO ROW
- SOME POSSIBLE EXISTING ACCESS ROUTES MAY REQUIRE EXTENSION/UPGRADE




**ALASKA ENERGY AUTHORITY
COPPER VALLEY INTERTIE
FEASIBILITY STUDY**

**STUDY ROUTE
ALTERNATIVES
MAP-1 OF 11 MAPS**


APRIL 1994

**R.W. BECK
AND ASSOCIATES**




NOTE:
UNLESS OTHERWISE NOTED ALL
SEGMENTS THIS MAP IN LOADING
ZONE 1

MAP INDEX



LEGEND


- ROUTE ALTERNATIVE D
- ALTERNATIVE ROUTE SEGMENTS
- POSSIBLE ROUTE MODIFICATIONS
- EXISTING SUBSTATION
- PROPOSED NEW SUBSTATION
- SEGMENT DENOMINATION S1-2,
I.e. BETWEEN POINTS 1 AND 2
- MILEAGE BETWEEN POINTS
M ()
- KNOWN AVAILABLE ACCESS TO ROW
- SOME POSSIBLE EXISTING ACCESS ROUTES
MAY REQUIRE EXTENSION/UPGRADE




ALASKA ENERGY AUTHORITY
COPPER VALLEY INTERTIE
FEASIBILITY STUDY

STUDY ROUTE
ALTERNATIVES
MAP-2 OF 11 MAPS
APRIL 1994



R.W. BECK
AND ASSOCIATES



MAP INDEX



LEGEND




**ALASKA ENERGY AUTHORITY
COPPER VALLEY INTERTIE
FEASIBILITY STUDY**


**STUDY ROUTE
ALTERNATIVES
MAP-3 OF 11 MAPS**

APRIL 1994

**R.W. BECK
AND ASSOCIATES**




MAP INDEX



LEGEND


- ROUTE ALTERNATIVE D
- - - ALTERNATIVE ROUTE SEGMENTS
- · - · ROUTE MODIFICATIONS POSSIBLE
- EXISTING SUBSTATION
- PROPOSED NEW SUBSTATION
- ① — S 1-2 (5.56) — ②
- SEGMENT DESIGNATION S1-2, I.e. BETWEEN POINTS 1 AND 2
- MILEAGE BETWEEN POINTS IN ()



ALASKA ENERGY AUTHORITY
 COPPER VALLEY INTERTIE
 FEASIBILITY STUDY


STUDY ROUTE
 ALTERNATIVES
 MAP-4 OF 11 MAPS
 APRIL 1994

R.W. BECK
 AND ASSOCIATES




NOTE:
UNLESS OTHERWISE NOTED ALL
SEGMENTS THIS MAP IN LOADING
ZONE 3

MAP INDEX



- LEGEND**
- ROUTE ALTERNATIVE D
 - ALTERNATIVE ROUTE SEGMENTS
 - POSSIBLE ROUTE MODIFICATIONS
 - EXISTING SUBSTATION
 - PROPOSED NEW SUBSTATION
 - ①-② SEGMENT DESIGNATION S1-2
La. BETWEEN POINTS 1 AND 2
 - MI () MILEAGE BETWEEN POINTS MI ()
 - KNOWN AVAILABLE ACCESS TO ROW
 - SOME POSSIBLE EXISTING ACCESS ROUTES
MAY REQUIRE EXTENSION/UPGRADE




ALASKA ENERGY AUTHORITY
COPPER VALLEY INTERTIE
FEASIBILITY STUDY


STUDY ROUTE
ALTERNATIVES
MAP-5 OF 11 MAPS

APRIL 1994










R.W. BECK
AND ASSOCIATES




MAP INDEX



LEGEND


-  ROUTE ALTERNATIVE D
-  ALTERNATIVE ROUTE SEGMENTS
-  POSSIBLE ROUTE MODIFICATIONS
-  EXISTING SUBSTATION
-  PROPOSED NEW SUBSTATION
-  SEGMENT DENOMINATION S1-2, Ls. BETWEEN POINTS 1 AND 2
-  MILEAGE BETWEEN POINTS IN ()
-  KNOWN AVAILABLE ACCESS TO ROW
-  SOME POSSIBLE EXISTING ACCESS ROUTES MAY REQUIRE EXTENSION/UPGRADE



ALASKA ENERGY AUTHORITY
COPPER VALLEY INTERTIE
FEASIBILITY STUDY

STUDY ROUTE
ALTERNATIVES
MAP-7 OF 11 MAPS
APRIL 1994

R.W. BECK
AND ASSOCIATES




NOTE:
LAKE LOUISE ROAD HAS BEEN REALIGNED
AND IS NOT PRECISELY AS SHOWN
ON THIS MAP

NOTE:
UNLESS OTHERWISE NOTED ALL
SEGMENTS THIS MAP IN LOADING
ZONE 2


**SEGMENT 18A TO 18B
IN LOADING ZONE 3**

MAP INDEX



LEGEND


- ROUTE ALTERNATIVE D
- ALTERNATIVE ROUTE SEGMENTS
- POSSIBLE ROUTE MODIFICATIONS
- EXISTING SUBSTATION
- PROPOSED NEW SUBSTATION
- SEGMENT DESIGNATION 1-2,
i.e. BETWEEN POINTS 1 AND 2
- MILEAGE BETWEEN POINTS
IN ()
- KNOWN AVAILABLE ACCESS TO ROW
- SOME POSSIBLE EXISTING ACCESS ROUTES
MAY REQUIRE EXTENSION/UPGRADE



ALASKA ENERGY AUTHORITY
COPPER VALLEY INTERTIE
FEASIBILITY STUDY

STUDY ROUTE
ALTERNATIVES
MAP-8 OF 11 MAPS
APRIL 1994


R.W. BECK
AND ASSOCIATES



NOTE:
UNLESS OTHERWISE NOTED ALL
SEGMENTS THIS MAP IN LOADING
ZONE 2

NOTE:
LAKE LOUISE ROAD HAS BEEN REALIGNED
AND IS NOT PRECISELY AS SHOWN
ON THIS MAP

MAP INDEX



LEGEND


- ROUTE ALTERNATIVE D
- ALTERNATIVE ROUTE SEGMENTS
- POSSIBLE ROUTE MODIFICATIONS
- EXISTING SUBSTATION
- PROPOSED NEW SUBSTATION
- SEGMENT DENOMINATION S1-2,
Ls. BETWEEN POINTS 1 AND 2
- MILEAGE BETWEEN POINTS
ON ()
- KNOWN AVAILABLE ACCESS TO ROW
- SOME POSSIBLE EXISTING ACCESS ROUTES
MAY REQUIRE EXTENSION/UPGRADE


ALASKA ENERGY AUTHORITY
COPPER VALLEY INTERTIE
FEASIBILITY STUDY

STUDY ROUTE
ALTERNATIVES
MAP-9 OF 11 MAPS


APRIL 1994

R.W. BECK
AND ASSOCIATES






MAP INDEX



LEGEND


- ROUTE ALTERNATIVE D
- ALTERNATIVE ROUTE SEGMENTS
- - - POSSIBLE ROUTE MODIFICATIONS
- EXISTING SUBSTATION
- PROPOSED NEW SUBSTATION
- ① — S 1-2 (5.56) ②
- MILEAGE BETWEEN POINTS IN ()
- KNOWN AVAILABLE ACCESS TO ROAD
- SOME POSSIBLE EXISTING ACCESS ROUTES MAY REQUIRE EXTENSION/UPGRADE




**ALASKA ENERGY AUTHORITY
COPPER VALLEY INTERTIE
FEASIBILITY STUDY**

**STUDY ROUTE
ALTERNATIVES
MAP-10 OF 11 MAPS
APRIL 1994**

**R.W. BECK
AND ASSOCIATES**




MAP INDEX



LEGEND

- ROUTE ALTERNATIVE D
- ALTERNATIVE ROUTE SEGMENTS
- POSSIBLE ROUTE MODIFICATIONS
- EXISTING SUBSTATION
- PROPOSED NEW SUBSTATION
- SEGMENT DESIGNATION S1-2, I.e. BETWEEN PORTS 1 AND 2
- MILEAGE BETWEEN PORTS M ()
- KNOWN AVAILABLE ACCESS TO ROW
- SOME POSSIBLE EXISTING ACCESS ROUTES MAY REQUIRE EXTENSION/UPGRADE



**ALASKA ENERGY AUTHORITY
COPPER VALLEY INTERTIE
FEASIBILITY STUDY**

**STUDY ROUTE
ALTERNATIVES
MAP-11 OF 11 MAPS**

APRIL 1994

**R.W. BECK
AND ASSOCIATES**

FEASIBILITY DESIGN - TRANSMISSION LINE

A. SYSTEM CONFIGURATION OPTIONS

There are several basic options for constructing an Intertie from an interconnection with MEA to CVEA. These options are discussed below.

1. Voltage Selection for the Intertie

The legislative authorization for a CVEA Intertie specified a line rating of 'at least 138 kV.' The project studied in this feasibility study is for a 138-kV line to serve only CVEA's long-term power needs. Future upgrading of the line to 230 kV was not considered. To upgrade the line to 230 kV (or higher) for use as a second Anchorage-Fairbanks intertie in an expanded Railbelt system would require (1) essentially completely dismantling the 138 kV line and constructing a new 230-kV line, and (2) reevaluating ROW width and probably acquiring additional ROW and renegotiating easement agreements.

The MEA 115-kV and CVEA 138-kV systems are voltage incompatible and an autotransformer is required to mate the systems. The auto could be located at either end of the Intertie, but higher losses and maybe overall higher life cycle costs for a 115 kV line make it preferable to locate the auto on the MEA system and operate an Intertie at 138 kV. This voltage level is adequate to serve the assumed long term power needs of the CVEA system, but it is not adequate to serve as a link to other systems beyond CVEA as might be desirable in the context of regional network planning. Power Technologies, Inc. (PTI) has expressed the preliminary opinion that a 138-kV Intertie rated at 80-100 MW for future use as a link in a second Anchorage-Fairbanks Intertie is feasible. However, the use of 556 Dove or 605 Teal would lead to unacceptable voltage drop, on the order of 18% just to Glennallen of which about 5%-6% is pure resistive drop. This would require substantial reactive compensation probably in the form of a static VAR compensator. No detailed study of this scenario was undertaken for the Intertie.

2. Location of the Autotransformer on MEA System

The 115/138 kV autotransformer could be located logically in any one of three places: at the existing MEA O'Neill Substation in Sutton, at a new substation fed from the 115 kV O'Neill Tap Line, or at the O'Neill Tap point.

Location of the autotransformer in the existing O'Neill Substation has few advantages other than existing right-of-way (ROW) and easement. Considerable expansion of the substation would be required while maintaining service to Sutton. To avoid working the substation hot a mobile substation could be used to maintain service. However, since the existing substation is located in a residential zone between two existing homes off Jonesville Road, selecting a getaway route for an Intertie is very restricted and could engender increased public opposition. This option was selected for study in [1].

The Mat-Su Borough Planning Commission proposed, and we support, use of a new substation located on a borough parcel about 0.7 mile west of O'Neill adjacent to the O'Neill 115 kV Tap Line.

The autotransformer could also be placed at the O'Neill Tap point. This would require the uprating of the tap line to 138 kV operation and replacement of certain equipment at the O'Neill Substation. Increasing voltage level could also require modification of easement agreements and lead to further public opposition. MEA has considered conversion to 138 kV.

3. Substation Switching Arrangements

The existing MEA O'Neill Substation in Sutton is fed radially via a 16-mile, 115-kV transmission line from an unbreakered, three-way tap of the Teeland-Eklutna 115-kV line. The O'Neill Tap line and the lines adjacent to the O'Neill Tap are protected by a circuit switcher at MEA's Shaw Substation, about 8 miles toward Teeland from the tap, and a circuit breaker at Eklutna, about 18 miles from the tap. Currently a fault on any of the three lines emanating from the tap will outage the O'Neill Tap line and an Intertie.

Although the lines in question have been highly reliable, a ring-bus switching station at the O'Neill Tap would enhance reliability and continuity of service to the O'Neill Tap Line and an Intertie, and it would provide MEA with increased operational flexibility. This is discussed further in Volume 2, PTI Reports. However, no switching station at the O'Neill Tap has been included in this study due to the marginal near-term benefit to CVEA.

At the Sutton interconnection with MEA, a direct, radial tap of the O'Neill Tap Line is proposed. This is the simplest and least costly practical alternative for the new substation at Sutton. This configuration would require one interrupting device, either a circuit switcher or breaker, on each side of the autotransformer. CVEA requested, and we have included, isolation and bypass switching of the interrupting devices. In view of the fact that bypassing an interrupting device compromises autotransformer protection, we would not recommend extended bypass operation. Special measures should be studied and implemented in final design to isolate the autotransformer from all sources in the event of an internal transformer fault.

In the event of a fault on any line adjacent to the O'Neill Tap, the O'Neill Tap Line will be lost. If CVEA sources are paralleled at the Pump Station No. 11 Substation bus, this would directly connect the MEA Sutton load to the CVEA system, creating up to a 1.5 MW backfeed situation. Not only would the CVEA connected sources have to pick up the CVEA load served by the Intertie prior to the loss of Railbelt power, but also this 1.5 MW load. CVEA would likely experience underfrequency problems under this scenario. Generally, the higher the proportion of CVEA load served by the Intertie the more severe will be the frequency changes due to an outage of the O'Neill Tap Line. To mitigate the severity of this interruption, reverse power and underfrequency relays would be used to sever the Intertie at Sutton or Pump Station No. 11.

Sutton load could be served by CVEA in the event the Railbelt interconnection is lost, but this would require shunt reactor compensation to limit voltage rise under the light load (1.5 MW) condition in Sutton. We have not determined the required size of reactor nor taken into account any specific provisions for serving the load in Sutton from the CVEA grid. The presence of a shunt reactor in Sutton will not correct the adverse underfrequency effects caused by islanding the CVEA system for conditions when a significant portion of CVEA load is being served over the Intertie. Before Sutton load could be served, adequate CVEA local generation resources would have to be brought on line and Sutton load picked up together with CVEA load.

At Pump Station No. 11 Substation in Glennallen, a single bus arrangement is proposed with the existing power distribution transformer connected to the bus through a circuit switcher and the two lines

(i.e., from Valdez and the Intertie) connected via breakers. CVEA has expressed the opinion that it does not need the additional operational flexibility of a ring-bus or main-transfer bus arrangement.

4. Future Regional Grid Concerns

The link from MEA to CVEA has been considered as part of an eventual second Intertie with GVEA through Delta Junction. These regional plans would logically include consideration of an upgrade of the MEA 115-kV system and extension of the existing 230-kV system to at least O'Neill Tap. We have not given any consideration in the feasibility study to the sizing or rating of Intertie equipment for the eventual purpose of relocating to other parts of the grid. For a discussion of possible region-wide ramifications see Volume 2, PTI Reports and the following section.

In summary then, we selected a system based on a direct tap of the O'Neill tap line, a new substation in Sutton with a single bus and a 138 kV Intertie voltage, and a single bus configuration at Pump Station No. 11 Substation.

B. SUMMARY OF PTI SYSTEM STUDIES

PTI was retained as a subconsultant by R. W. Beck to perform electrical system studies for proposed project. These studies included steady-state power flow, fundamental voltage switching response, and transient stability simulations. The system as modeled for each study included the proposed Intertie, the multi-utility Alaska Railbelt system (which includes MEA) and the CVEA system. A maximum Intertie transfer capability of 10 MW into the CVEA system was assumed in the original study analysis. A supplementary study was performed to identify the maximum transfer limits for the Intertie under steady state conditions. PTI's full report is found in Volume 2, Appendix O.

1. Original Study Conclusions

The steady-state power flow analysis showed that the interconnection of the CVEA and Railbelt systems by the proposed Intertie is technically feasible and provides acceptable steady state performance under the various load level, power transfer and generation dispatches analyzed. However, a 10 MVAR line-connected shunt reactor will be required at the Glennallen end to obtain acceptable line energizations and steady-state voltage performance. The power flow analysis also confirmed that the Intertie will only marginally affect potential MEA 115-kV system line overloading situations but will not degrade the voltage performance of that system.

Switching performance is better when the Intertie is energized from the MEA side although switching simulations concluded that the Intertie can be energized from either end provided that the reactive compensation as discussed above is in place. The reactive compensation is required to control the voltage rise due to the large amount of capacitance developed in the long transmission Intertie.

Transient stability studies confirmed that the interconnected CVEA and Railbelt system exhibits stable dynamic response for non-islanding disturbances in either system. Disturbances in the CVEA system do not significantly affect the MEA system. The Railbelt system is subject to instability across the Northern Intertie for loss of the Pt. Mackenzie-Teeland 230-kV line when transferring about 40 MW to the north. The proposed Intertie does not significantly affect the Northern Intertie transfer stability limit. However,

for loss of the CVEA 138-kV lines, the Valdez area of the system responds no better than without the Intertie. The remainder of the system which remains interconnected responds significantly better. Loss of the Intertie with no power transfer creates no problems for either system.

Although connection to the comparatively robust Railbelt grid via the Intertie will make the CVEA system more immune to loss of load due to loss of internal generating units and other internal disturbances, the loss of the Intertie itself under moderate to heavy import conditions would result in a blackout or significant loss of load in the CVEA system. Moreover, interconnection to the Railbelt grid via the Intertie will expose the CVEA system to Railbelt system disturbances, specifically underfrequency situations which would follow the loss of large generating units. The magnitude of such an impact will depend on the amount and nature of spinning reserve in the CVEA system, implementation of CVEA's load shedding program, and the percentage of CVEA load provided over the Intertie prior to the disturbance.

2. Supplemental Study

PTI produced a supplemental study which analyzed the proposed Intertie and interconnected systems under future load conditions where power transfers into CVEA were maximized. This study consisted of steady-state power flow analysis only. The results of this supplemental study indicate that the Intertie can provide a power transfer capability of about 24 MW into the CVEA system under system intact conditions. Under single contingency outage conditions, power transfer capability is reduced to approximately 15 MW. These transfer limits assume that both CVEA and MEA systems loads are increased by the same percentage above present winter peak levels. The limiting factor in all cases is the steady-state voltage limit being reached on the MEA system, and to a lesser extent on the CVEA system. For the single contingency condition of an outage of the Pt. Mackenzie-Teeland 230-kV line, Intertie transfer capability is reduced to about 14 MW, based on line loading limitations in the MEA system.

In all cases, the above transfer limits are achievable only by switching off most all of the shunt reactors, including the recommended 10 MVAR unit at Glennallen, in the CVEA system. Based on the large difference between the system intact and single contingency transfer levels, operation at the system intact level would not be possible without the risk of voltage collapse following a single contingency. Operation at or above the single contingency transfer limits noted would require facilities to provide dynamic voltage control (static VAR compensators - SVC) since small load changes would result in large voltage changes under the conditions simulated. However, use of an appropriately sized SVC at the Glennallen end of the Intertie would replace the need for the 10 MVAR reactor recommended in the main study and also limit or eliminate the need to provide switching facilities for the existing 138-kV line reactor at Pump Station No. 11.

3. Discussion of Intertie Operation and SVC

It has been demonstrated in the PTI supplemental study, Volume 2, Appendix O, that maximum transfers of about 24 MW are possible for an intact system based on low voltage limits on the MEA system and assuming equal load growth on MEA and CVEA systems. If only CVEA system load growth is assumed, i.e. MEA load growth is zero, the maximum intact transfer climbs to 27 MW based on low voltage limits on the CVEA system. These limits correspond roughly with the High Case Scenario peak demand of 22 MW in year 2013. Under two scenarios of a single contingency (N-1) outage, the maximum transfer is reduced to about 13-15 MW based on line loading or low voltage limits on the MEA system.

PTI states that "depending on the transfer level to which the Intertie would be operated, the pattern of future load growth, and minimum generation configurations to be used, one or more SVC (static VAR controller) would be required. ... switched, shunt capacitor additions would also be required on the MEA system in conjunction with the SVCs." PTI goes on to note that the MEA line loading limit of 13.7 MW for a Pt. MacKenzie - Teeland 230 kV line outage would not be corrected by the addition of capacitors or SVCs. The only corrections for this limit would be to reconductor the overloaded line or build a 230-kV line from Teeland to Anchorage.

It is clear from the PTI study that improvements to the MEA system would be required to fully use the 40 MW design transfer capacity of the Intertie. The need for certain improvements will depend on load growth on both MEA and CVEA systems. In the absence of a CVEA intertie, MEA may still have to make improvements. Given a certain level of load at which the MEA improvements are necessary and assuming MEA load grows at the same rate with or without the Intertie, the addition of Intertie load will cause MEA to make those improvements sooner than without the Intertie. Stated another way, without the Intertie MEA could defer capital expenditure for the improvements.

Standard industry planning practice would dictate that the Intertie power flow not reduce the reliability of service or quality of power on the wheeling Railbelt Utilities under N-1 outage conditions, at a minimum. This standard of practice is well-established by the North American Electric Reliability Council (NERC) and is employed by the Railbelt Utilities. For planning purposes a N-1 outage is assumed to happen at any time, usually under the most likely or restrictive conditions. If reliability and power quality are to be maintained over the largest service area possible or, conversely, if adverse impacts are to be limited, the interconnected utilities must take some appropriate action to accommodate the Intertie.

There are four basic ways in which the impacts of a N-1 outage on the MEA system could be limited and contained: (1) sever the Intertie and island the CVEA system for a given Intertie power flow and a N-1 condition, (2) implement a load shedding program on the CVEA system, (3) make improvements to certain MEA system facilities, or (4) implement dynamic voltage control via a SVC on the CVEA system. We understand that the Anchorage-Fairbanks Intertie is operated based on response (1) for a 40-MW northern transfer to GVEA.

Both responses (1) and (2) raise issues of lower reliability and power quality for CVEA customers. CVEA could limit or eliminate these effects by maintaining a substantial amount of spinning reserve capacity. However, this would be contrary to the guiding reasoning for the Intertie, namely retiring CVEA diesel generation. CVEA has advanced the position that the N-1 contingencies studied by PTI are infrequent and of short duration, thereby making a SVC unnecessary. Based on this reasoning, CVEA confirmed it is amenable to implementing responses (1) and (2) for those short periods, perhaps in conjunction with maintaining hydro spinning reserve. No costs have been assigned to maintaining CVEA hydro spinning reserve capacity or implementing a load shedding program. However, the cost of diesel generation to replace Intertie power imports is included based on an Intertie unavailability of 2% (availability of 98%).

The line loading limit of 13.7 MW in the PTI study cannot be improved without upgrading MEA facilities (Response (3)). MEA may need to consider upgrading irrespective of the Intertie, based on its own load projections. No costs have been included for upgrading MEA facilities because they would not necessarily be attributable to the Intertie.

Response (4), one or more SVCs on CVEA system, would provide the dynamic voltage control required for reliable operation of the Intertie at power flows in excess of the N-1 limits identified by PTI.

They would not remedy the overloaded line on the MEA system. Although the SVCs would improve power quality and reliability for the interconnected utilities, they are not absolutely necessary since CVEA is willing to suffer loss of the Intertie under the N-1 contingencies, taking remedial action within its own system.

C. DESIGN CRITERIA

1. Background

A Sutton to Glennallen transmission line has been studied previously on its own to serve the Copper Valley system [1], as part of the Railbelt Intertie [2], or as a link from the Railbelt to Cordova [6]. For the latter two studies the proposed line was rated at 230 kV and was intended to interconnect the Golden Valley Electric Association system or the City of Cordova to the Railbelt. The most recent study [1], prepared for CVEA by Power Engineers (PEI) covers the Sutton to Glennallen 138-kV Intertie along the same basic route as the present feasibility study. It also represents the most thorough discussion to date of design criteria in concert with the current operating and maintenance desires of CVEA.

In [2] the capital cost of the complete second Railbelt Intertie at 230-kV from Palmer through Glennallen to Delta Junction was estimated at \$156 million in 1989 dollars and was subsequently judged to be too expensive to pursue at the time of the study. The scope of the present feasibility study requires only consideration of a 138 kV transmission line to serve the needs of CVEA without regard for possible future use as a link in a regional network despite demonstrations that a second Railbelt Intertie would have definite regional electrical system performance advantages [2]. A line designed for 138 kV operation and with a conductor sized only to serve a 40 MW projected CVEA load (i.e., 556 ACSR Dove or similar) would rule out effective upgrading to serve as a link in a wider network without essentially completely reconstructing the line. Further studies would be required to verify that 138 kV is or is not suitable for a second Intertie to GVEA. No computations were made to predict the impact a 90 MW flow would have on operating temperature.

We were initially directed by the Authority to develop a basis of feasibility design which would provide a level of reliability for the Intertie comparable to other lines in Alaska. In agreement with the Authority, we took [1] as a reasonable starting point for the basis of design.

A thorough review of [1] was conducted. To supplement our firm's experience, the Intertie was discussed with the engineering and operations staff of CVEA, MEA, GVEA and AEA as well as other transmission design engineers familiar with Alaskan conditions. Meteorological data was assembled from [6] and national or state organizations. Computations were performed as necessary to confirm or modify design assumptions in [1].

The culmination of this effort was a draft basis of feasibility design which was circulated to members of the Technical Review Committee, comprised of representatives from Railbelt Utilities, the Authority, and CVEA, prior to a technical review meeting (TRM) held in Anchorage on July 6, 1993. The meeting proceedings were recorded, transcribed, summarized and distributed to participants for comment. The meeting summary is included in Appendix E.

Based on results of the TRM, we revised some basic design criteria and assumptions. In the remainder of this section we present the basis of feasibility design.

2. Project Location

The Sutton to Glennallen 138-kV Intertie will originate in Sutton at a new substation located approximately 0.7 mile west of the O'Neill Substation on a parcel owned by the Matanuska-Susitna Borough. The line will terminate and interconnect with the CVEA system at the Pump Station No. 11 Substation, currently owned by AEA but operated and maintained by CVEA, located adjacent to the Alyeska Pipeline in Glennallen about one mile south of Glenn Highway.

The Intertie alternative routes will principally follow combinations of the Matanuska River Valley, Boulder Creek, Caribou Creek, Hicks Creek, Squaw Creek, and Alfred Creek before crossing into the Copper River Basin where the line will run generally parallel to the Glenn Highway. Refer to base maps 1 through 11 at the end of Section III for the routes.

For most of the routes study segments, elevations are 500 to 2,500 ft. In the mountain passes, elevations will increase to nearly 5,000 ft and will require consideration of more severe loading criteria. The Intertie would be approximately 135 miles in length and would be approximately located at latitude 62 degrees north and longitude 145.5 to 148.5 degrees east.

3. Electric Loading

The Intertie will be designed for the ultimate transfer of 40 MW at 0.90 lagging power factor (receiving) at 138 kV. As mentioned earlier, no consideration was given to providing for higher transfer levels as part of a second Railbelt Intertie.

The basic conductor for the Intertie was initially designated by others [1] as 556 kcmil 26/7 ACSR (code name "Dove"). The selection of 556 Dove was based largely on CVEA stocking considerations. However, based on design loading conditions and preliminary computations, alternative conductors with strength and sag advantages should be considered for the potential of significant project cost benefits. Alternative conductors include 556 Dove with an extra-high strength steel core, standard 605 and 636 kcmil sizes of ACSR with 30/19 stranding (i.e., higher steel content stranding), 605 kcmil size of steel-supported aluminum conductor (SSACTTM), ACSR/T2Linnet, and Dove ACSR/SD self-damping conductor.

We performed detailed computations and compared the effects of using 556 Dove ACSR, 605 Teal ACSR, 605 Teal ACSR/EHSS, 556 Dove ACSR/SD, 2 x 336 T2Linnet ACSR/T2, 605 Teal SSAC, and 37 No. 9 Alumoweld. The results of this comparison are given later in this Section. In summary, we recommend, as the most appropriate conductors, 605 Teal ACSR in Loading Zones 1, 2, and 3 and 37 No. 9 Alumoweld in Loading Zone 4. However, the range of line unit cost variations among Dove, Teal and T2Linnet was not significant for most cases, and a full optimization study in final design should determine the optimal conductor selection.

Computations for 556 Dove, based on a pure radial transfer of 40 MW, 0.90 power factor lagging (receiving end conditions), indicate about 3.8% power losses and a voltage drop of about 5.8%, which are acceptable for the feasibility study. For the same loading conditions, losses for 605 Teal are 3.6%. System studies were based on 556 Dove and will provide more definitive values for losses and system performance

under steady state heavy and light loading plus transient behavior. See Volume 2, Appendix O, PTI Report.

4. Ampacity

Reference [1] proposed developing ampacity ratings and maximum operating temperature based on (1) maximum MVA transfer rather than arbitrary standard values such as 75°C or 100°C; (2) maximum ambient temperatures 90°F (32°C) summer full sun and 50°F (10°C) winter with no solar input, i.e., cloudy; and (3) windspeed at 2 feet per second (fps), coefficient of absorptivity of 0.55 and coefficient of emissivity of 0.5. Maximum operating temperatures of about 110°F in summer and less than 60°F in winter for 40 MVA loading were predicted. Recognizing that CVEA is currently a winter-peaking utility, [1] states that future consideration could be given to reducing the MVA basis for the summer ampacity rating, but that the recommendation is to use 110°F as the maximum design conductor operating temperature for clearance determination. CVEA later indicated that fish processing load may eventually create a summer-peaking scenario.

Actual maximum MVA loading should be the basis for determining maximum operating temperature in accordance with the NESC. We verified that the ambient temperature assumptions in [1] are reasonable. The value of windspeed of 2 fps (2.9 mph) is a commonly-used and accepted number in the industry and we have no reason to question its use in [1]. However, it is now generally thought that the 2 fps value is on the conservative side (i.e., lower than typically occurs) and a meteorological study could be requested to recommend an average value of windspeed which might be different and serve to reduce operating temperatures, especially in the Copper River Basin area.

The use of 110°F as a maximum operating temperature, however, would not be in compliance with NESC Rule 232 which requires a minimum of 120°F for the application of Rule 232.

For some of their length, most line route segments follow valleys which may tend to channel wind parallel to the line with reduced cooling effect[3]. The assumptions of 0.55 for solar absorptivity and emissivity are typical of new, unoxidized aluminum conductors. The line will be in service many years and values for a typical blackened conductor, 0.95 for solar absorptivity and 0.91 for infrared emissivity, would appear appropriate for a check.

We computed maximum operating temperatures for three conductors and four scenarios as shown in Table IV-1.

Table IV-1
Conductor Operating Temperatures (1)(2)

| | WINTER 10°C <i>Wind E-W</i> | SUMMER 32°C <i>Wind E-W</i> | SUMMER 32°C <i>Wind N-S</i> | SUMMER 32°C <i>Wind E-W / Aged Conductor</i> |
|------------------------------|--------------------------------|--------------------------------|--------------------------------|---|
| Teal 605 ACSR ⁽³⁾ | 24.5°C (76°F) | 55.8°C (132°F) | 45.5°C (114°F) | 61.0°C (142°F) |
| Dove 556 ACSR ⁽³⁾ | 24.9°C (77°F) | 56.1°C (133°F) | 45.5°C (114°F) | 61.1°C (142°F) |
| 37 No. 9 AW ⁽⁴⁾ | 35.3°C (96°F) | 67.0°C (153°F) | 48.9°C (120°F) | 69.6°C (157°F) |

- (1) Line current is 170 amps, latitude 62 N, longitude 147 E, summer date July 4, time 15:00 PST, winter date January 1, time 13:00 PST.
- (2) Coefficient of solar absorptivity is 0.55 and coefficient of infrared emissivity is 0.50, except for aged conductor which uses 0.95 and 0.91, respectively.
- (3) Elevation is 2,500 ft above sea level, windspeed 2 ft per second.
- (4) Elevation is 4,500 ft above sea level, windspeed 3 ft per second.

Based on the results in Table IV-1, we will assume for the feasibility study a maximum operating temperature of 150°F (66°C) for 556 Dove ACSR, 605 Teal ACSR and other ACSR-variant conductor types. For reference we also include temperatures for a 37 No. 9 Alumoweld conductor which might be used in the Chitna Pass area. The maximum operating temperature for this conductor will be chosen as 160°F (71°C). We note that a maximum temperature of 120°F where prevailing winds are north-south and 135°F where they are east-west could be considered for some reduced sag benefits in final design.

The TRM did not address operating temperature.

5. Weather Data

Weather data is critical for formulating reasonable physical loading criteria. Most critical is information on ambient temperatures, windspeed and direction, ice, snow and frost accumulation and densities, snow pack, and isokeraunic level (i.e., thunderstorm activity) for lightning protection design. Weather data for the Intertie corridor is very limited. This situation is complicated by micro-climates which can create very severe and special loading conditions.

Major sources of basic weather data measurements are the Alaska Climate Summary (ACS), the Western Regional Climate Center (WRCC, Reno, Nevada), and the National Climate Data Center (Asheville, North Carolina). In addition, reference [3] provides meteorological analysis of limited weather data for the Palmer-Glennallen corridor in the Matanuska River Valley and parallel to the Glenn Highway and develops detailed recommendations for extreme loading conditions [see Part e. below]. Firsthand observations by local utility workers and line designers are also invaluable for selecting extreme loading conditions. The TRM addressed, in-depth, the issue of extreme ice/snow and wind loading.

Minimum and maximum ambient temperature data were obtained for weather stations at Palmer, Sutton, Gunsight Mountain, Snowshoe Lake, Eureka, Little Nelchina Road Camp, Tahnetta Pass, Glenn-

allen, and Gulkana from the WRCC. This basic information was used to evaluate the appropriateness of conductor operating temperatures and ambient conditions under different loadings.

a. Extreme Windspeed

Recorded values of 70-75 mph at Glennallen in 1992 and 115 mph in Palmer in 1979 were cited in [1]. The consensus opinion of people familiar with the area, including the Anchorage National Weather Service, was that the line route can be a "very windy place." The ACS provides no wind data of significance. One fastest mile sample reading was obtained for Gulkana and converted to 50-year and 100-year recurrent interval wind speeds of 91 mph and 100 mph respectively. Reference [1] concludes that an extreme 100 mph windspeed is reasonable and should be used. PEI further suggest that reductions in the design wind speed for the shielding effects of trees and terrain can be considered in final design.

An extreme windspeed of 100 mph is generally in agreement with meteorological analysis of the corridor [3], which estimated a maximum one-minute 75-year windspeed of 89 mph and maximum 5-second 75-year gust windspeed of 121 mph. These maxima were predicted for a portion of the corridor near Sheep Mountain and Lions Head. The wind channeling in this area is high and similar loads could be expected in back country valley routes. Weighted averages of the 75-year windspeeds for the entire length of the corridor were calculated to be 75 mph for the one-minute windspeed and 103 mph for the 5-second gust windspeed.

We will use an extreme windspeed of 100 mph applied to horizontal spans and a gust windspeed of 120 mph applied to the structure only for most of the Intertie, Loading Zones 1, 2 and 3. Shielding effects of trees and terrain may be possible for transverse winds in certain locations and this is considered in detail in [3]; in the absence of a detailed meteorological analysis for the present routes, however, shielding effects will not be considered in this study. Higher, channeled winds may be experienced when crossing major streams and creeks. Longitudinal winds would be largely unshielded but their loading effect on wires is also reduced by the shallow impact angle.

We will use an extreme windspeed of 125 mph applied to horizontal spans and a gust windspeed of 150 mph applied to the structure only for the Chitna Pass route (Loading Zone 4). Extreme winds of 100-175 mph have been used for design of several high, exposed line segments in Alaska, e.g., 175 mph for Glennallen-Valdez line in Thompson Pass and 200 mph at Snettisham.

Since extreme wind loading typically controls the design and sizing of tangent structures, final design should explore the opportunities to rationally reduce extreme wind loads. Such opportunities include the shielding effect of trees, the direction of prevailing winds and perhaps the dependence of the wind pressure coefficient on elevation and temperature [5, Table 2.1-1]. A meteorological study is also recommended.

b. Ambient Temperature

Temperature records for Gulkana, Snowshoe Lake, Tahnetta Pass, and Sutton, are listed [1]. The Gulkana station recording period is the longest (1942-1987) and shows the most extreme ambient temperature values (-65°F record low and 91°F record high).

Several ambient temperatures are of interest: maximum summer temperature for determining maximum operating temperature, extreme minimum temperature for studying uplift situations, ambient

temperatures during extreme loading conditions, and the annual average minimum temperature (AAMT) used with tension limits to control aeolian vibration for certain conductor types.

The selection in [1] of maximum ambient temperature of 90°F in summer for computation of maximum conductor temperature is appropriate. Since CVEA is currently a winter-peaking utility it appears unlikely that the maximum operating temperature will be reached thus giving the Intertie substantial thermal margin.

A single cold temperature of -60°F for the entire project is recommended in [1]. This recommendation is based on the fact that the cold temperature tension limits will not control sag-tension behavior in view of the extreme ice loadings, except in very short spans where tensions at -60°F should be checked against limits. The selection of -60°F as the extreme minimum cold condition is appropriate for the line and will affect only structure locations and types in uplift situations, e.g., in the bottom of valleys and toes of slopes.

An AAMT is used essentially for aeolian vibration tension limits and [1] selects -25°C (-1°F), based on a 10% coldest temperature criterion. This value appears appropriate for the western portion of the line but not for the back country routes and eastern portion based on estimated minimum temperatures in Table IV-2. For this feasibility study we will use an AAMT of -32°C (-25°F) for the ACSR conductors. Note that SSAC, ACSR/SD, and ACSR/T2 conductor types have inherent self-damping characteristics which do not require application of the AAMT limits.

Table IV-2
Average of Annual Minimum of Monthly Average
of Daily Minimum Temperatures
(degrees Fahrenheit)

| Station | Years | Highest/Lowest Annual Minimum | Mean | Std Dev | Mean-2SD |
|------------|-----------|----------------------------------|-------|---------|----------|
| Sutton | 1978-1992 | 16.4/-11.3 | 2.8 | 7.8 | -12.8 |
| Palmer | 1961-1992 | 12.5/-11.4 | -0.6 | 6.3 | -13.2 |
| Gunsight | 1966-1974 | -20.9/-40.4 | -29.7 | 5.7 | -41.1 |
| Eureka | 1957-1968 | 10.5/-2.1 | 4.3 | 4.1 | -3.9 |
| Snowshoe | 1963-1992 | -9.7/-35.8 | -23.1 | 6.2 | -35.5 |
| Glennallen | 1965-1992 | -1.68/-37.7 | -23.2 | 9.1 | -41.4 |
| Gulkana | 1961-1992 | -0.3/-36.5 | -19.7 | 8.4 | -36.5 |

c. Snow Ground Cover

Reference [1] cites maximum snow accumulation data from the ACS for Gulkana (48"), Snowshoe Lake (36"), Tahnetta Pass (48"), and Sutton (36"). A design value of 48 inches of snow ground cover was chosen for the determination of NESC clearances to grade. The need to consider greater snow cover or clearances in areas of high snow machine usage is prudently mentioned in [1].

We will use 48 inches of snow cover as the basis for the feasibility study for non-back country areas (i.e., Loading Zones 1 and 2). We will assume a snow cover of 60 inches in back country areas (i.e., Loading Zones 3 and 4).

d. Ice and Snow Accumulation

The TRM addressed extreme combined ice/snow and wind loading at length. The selection of ice and snow loading criteria for transmission line design in Alaska has been the subject of much discussion and study over the past few years. Engaging meteorological consultants to develop recommended extreme loadings has been common in recent transmission line design and failure analysis work in Alaska. We recommend that a meteorological consultant be hired to develop such recommended loadings prior to final design.

Very large build-ups of snow and underlying ice have been observed on several lines including the Healy-Willow 345-kV Transmission Line, the Glennallen-Valdez 138-kV Transmission Line, and the Tyee Lake 138-kV Transmission Line in Southeast Alaska. Each of these lines has experienced excessive sags due to accumulated ice and snow, but no outright cascading failures due to ice build-up.

On the Tyee Lake Transmission Line 556 Dove section across Vank and Woronkofski Islands, excessive sags have led to conductor-snow/ground contact and low-level ground faults [4]. On the Healy-Willow line with 2-954 ACSR conductors, contact with 15' tall trees and severely reduced highway clearances have been experienced [8]; ice has also been observed to bridge the subconductors at spacer locations. CVEA personnel reported that 5"-6" diameter snow at unknown density over 1" radial ice were observed on the CVEA Glennallen-Valdez line just north of Thompson Pass with no failures. Extreme diameters of heavy ice and snow accumulation of up to 18 inches and typically 4-12 inches have commonly been observed on Alaskan lines but efforts to measure accumulation have been only partially successful.

MEA designs its distribution and transmission lines to NESC Heavy and reportedly has encountered no failures[1]. CVEA also designs its distribution lines for NESC Heavy and has also experienced no failures to date.

In [1] a value of 1" of radial ice was selected for design extreme ice loading, reasoning that it is better to accept the risk of greater ice loading and consequent failures than the certainty of increased capital costs for improved reliability. This is a trade-off made for virtually all lines designed for areas where extreme loading is unknown or where the cost to withstand infrequent but severe loading (e.g., hurricanes, tornadoes) would be exorbitant.

A 1" radial ice extreme loading is consistent with criteria selected for several lines in Alaska, including loading zone II for the Glennallen-Valdez line extending from Pump Station No. 11 south to mile 70. The reliability of this line segment has been excellent in its 8-9 year service life. We note that this section is parallel to prevailing winds in the Copper River basin, whereas an Intertie would be perpendicular to the prevailing winds.

Reference [5] cites recommended procedures for assuming ice loadings based on maximum measurement or observations in the absence of statistical data. Specifically one suggested procedure would assume a mean ice radial thickness of 0.60 times the maximum observed thickness with a standard deviation of 0.40 times the mean [5]. Table IV-3a below gives several examples of how this methodology would apply to observations. The two-standard deviation assumption is only slightly greater than the

maximum observation. Assuming a Gaussian distribution the one-standard deviation radius would have an annual probability of occurrence of 15.9%, corresponding to approximately a 6-year mean recurrence interval, while a two-standard deviation radius would have a 2.2% annual probability, corresponding to a 50-year recurrence interval. A probability of occurrence for a given project lifetime can be computed and is shown in Table IV-3b.

Table IV 3a
Extreme Ice Assumptions in the Absence of Statistical Data
 (All values of radial ice in inches)

| Maximum Observed Ice Radius (inches) | Estimated Mean (inches) | Calculated Std. Dev. (inches) | One Std. Radius (inches) | Two-Std. Radius (inches) |
|---|--|--|---|---|
| 0.50 | 0.30 | 0.12 | 0.42 | 0.54 |
| 1.00 | 0.60 | 0.24 | 0.84 | 1.08 |
| 1.50 | 0.90 | 0.36 | 1.26 | 1.62 |
| 2.00 | 1.20 | 0.48 | 1.68 | 2.16 |
| 2.50 | 1.50 | 0.60 | 2.10 | 2.70 |
| 3.00 | 1.80 | 0.72 | 2.52 | 3.24 |

Table IV-3b
Probability of Occurrence of 1-SD and 2-SD Ice Loadings

| Project Lifetime (years) | Probability of 1 SD Ice | Probability of 2 SD Ice |
|---|------------------------------------|------------------------------------|
| 5 | 0.5785 | 0.1084 |
| 10 | 0.8223 | 0.2051 |
| 15 | 0.9251 | 0.2913 |
| 20 | 0.9684 | 0.3682 |
| 25 | 0.9867 | 0.4367 |
| 30 | 0.9943 | 0.4978 |
| 35 | 0.9976 | 0.5523 |
| 40 | 0.9990 | 0.6008 |
| 45 | 0.9995 | 0.6441 |
| 50 | 0.9998 | 0.6827 |

For this feasibility study we will assume ice and snow loadings as given in Table IV-5.

e. Meteorological Research, Inc. Technical Report

Reference [3] contains a detailed analysis of limited available weather information and develops specific extreme loading criteria for the Palmer-Glennallen corridor, basically following the Glenn Highway. One of the principal authors of [3] was contacted during the present study to discuss the appropriateness of the findings in [3] to the route alternatives under consideration in this study. He advised that the findings in [3] are not valid for the route alternatives under study but that they are still probably valid for the routes studied in 1982. Despite its limitation to the 1982 routes, the findings and recommendations of this report are discussed in this section.

Two climatic zones are identified. The western portion lies in a transition zone through the Matanuska River Valley, characterized by a mixture of cool, moist weather and cold, dry weather. The eastern portion lies in the continental zone through the Copper River Valley, characterized by cold, dry weather.

A tabulation for twelve weather stations indicates maximum ambient temperatures of 90°F for Palmer and Glennallen, 91°F for Gulkana, and 85°F for Eureka and Snowshoe Lake. This corroborates the selection of 90°F for maximum ambient temperature.

A tabulation for the same twelve weather stations indicates minimum ambient temperatures of -60° to -65°F in the Copper River Valley and -35° to -44°F from Palmer to Eureka. This corroborates the selection of -60°F for extreme cold temperature.

A tabulation for the same twelve weather stations indicates a mean annual snowfall of 65 to 68 inches on the western end of the Matanuska Valley, 41 to 53 inches between Snowshoe Lake and Gulkana in the Copper River Valley, and 117 inches in Eureka. This would seem to corroborate the selection of 48 inches of ground snow cover for clearance checks. However, the value of nearly 10 ft of total annual snowfall in Eureka indicates a higher value of snow cover would be appropriate for the areas of Eureka and back country routes. We will use a snow cover of 60 inches for clearance checks in these areas.

Analysis of maximum one-minute hourly winds (e.g., extreme wind values) at 30 ft above ground showed 50-year return period windspeeds for Gulkana of 59 mph, Sheep Mountain 69 mph and Palmer 74 mph. The direction of extreme winds was generally NNE or SSE for Gulkana, S and SSE for Snowshoe Lake, and NE or ENE for Sheep Mountain and Palmer respectively. Extreme wind occurrences are distributed evenly from fall to spring for Gulkana but are somewhat concentrated in the winter months November to March for Sheep Mountain, Palmer and Snowshoe Lake. This data indicates that extreme winds will generally be transverse to the Intertie route east of Eureka and longitudinal to the route in the valleys west of Eureka, and that extreme winds are very likely to occur in winter. MRI suggests that a reduction of windspeed up to 20% in the "lee of stands (of spruce)" is possible and that larger reductions of 20-50% are possible in denser, taller forest stands. The value of 20% should be used, according to MRI, where the transmission line cleared ROW is parallel to the prevailing winds.

The MRI report discusses span factors which reflect the span coverage of winds of different durations. For instance, gusts will not typically affect more than 100 ft of span while steady one-minute winds will affect up to 1,000 ft. Mountainous terrain is recognized as creating special wind turbulence.

The report culminates with tables giving 25-, 50- and 75-year return period values for one-minute wind speeds, 5-second gust speeds, mixed icing loads, glaze icing loads and rime icing loads by proposed line segment. The windspeed values are adjusted for exposure, elevation and for a common height above

ground of 30 ft. Total transverse wind load on iced conductors is included. Wet snow occurrences were cited as being too infrequent and short to result in any significant accumulation. We reverse-computed assumptions for coincident wind loading embedded in the 50-year table and derived Table IV-4 which summarizes the maximum MRI-recommended 50-year loadings for the 1982 route.

**Table IV-4
Reduction of MRI 50-Year Data for Intertie Study**

| <u>Loading Condition</u> | <u>West</u> | <u>East</u> | <u>Maximum</u> | <u>Glaze Ice Equivalent</u> |
|---------------------------------------|-------------|-------------|----------------|-----------------------------|
| <i>EXTREME WIND</i> One-minute mph | 74 | 71 | 85 | NA |
| <i>GUST</i> 5-sec mph | 101 | 98 | 115 | NA |
| <i>MIXED ICE</i> (1)(2)(3) | | | | |
| Radial inches | 0.75 | 1.00 | 1.00 | 0.573 |
| Weight lb/ft | 0.68 | 1.05 | 1.05 | |
| Wind mph | 5 | 10 | 10 | 12 |
| <i>RIME ICE</i> (1)(2)(3) | | | | |
| Radial inches | NA | NA | 1.50 | 0.893 |
| Weight lb/ft | NA | NA | 1.98 | |
| Wind mph | NA | NA | 40 | 48 |
| <i>GLAZE ICE</i> (1)(2)(3) | | | | |
| Radial inches | 0.25 | 0.25 | 0.25 | 0.25 |
| Weight lb/ft | 0.36 | | 0.36 | |
| Wind mph | 15 | | 18 | |

(1) Weight of ice loading is weight of ice only over Dove 556 ACSR conductor.

(2) All ice loadings considered at 0°F.

(3) Rime and mixed ice at 0.4 g/cc or 25 pcf and glaze ice at 0.9 g/cc or 56 pcf.

MRI comments that mixed icing events (i.e., rime and hoarfrost) are the result of light winds and dense fog conditions and that significant accumulations can be expected at elevations below 2,000 ft in the Matanuska River Valley. In the Copper River Valley significant rime ice accumulations are expected at elevations above 3,300 ft, which would also apply to back country areas in our opinion, and that significant mixed icing events will occur in the basin from Tolsona to Glennallen, at elevations below 2,500 ft.

No recommendations are given for assumed ambient temperatures during ice and wind loading.

MRI recommended low windspeeds for icing events based on the line being generally parallel to prevailing winds in the Matanuska River Valley and based on weather records in the Copper River Valley. We note that observed extreme loadings in the region have apparently exceeded MRI findings.

6. Design Loadings and Loading Zones

The Intertie corridor spans at least two distinct climatic zones, the Matanuska River Valley and the Copper River Basin. Moreover, several route segments are located in more remote high elevation back country valleys which must be expected to present more extreme loading conditions than either distinct climatic zone. Pursuant to the TRM, four loading zones were selected. These are depicted in the base maps at the end of Section III and listed along with associated route segments in Table III-1. Table IV-5 summarizes the design loading conditions for all loading zones which will be used in the feasibility study.

Table IV-5
Assumed Study Design Criteria

| <i>LOADING CONDITION</i> | Parameter | Units | Loading Zone 1 | Loading Zone 2 | Loading Zone 3 | Loading Zone 4 |
|---|------------------|--------------|---------------------------|---------------------------|---------------------------|---------------------------|
| NESC Heavy | Radial Ice | in | 0.5 | 0.5 | 0.5 | 0.5 |
| | Wind speed | mph | 40 | 40 | 40 | 40 |
| | Wind PSF | lb/sf | 4 | 4 | 4 | 4 |
| | Temperature | deg F | | | | |
| Extreme Ice | Radial Ice | in | 1 | 1.5 | 1.5 | 2 |
| | Temperature | deg F | | | | |
| Extreme Wind | Wind speed | mph | 100 | 100 | 100 | 125 |
| | Wind PSF | lb/sf | 26 | 26 | 26 | 40 |
| | Gust | mph | 120 | 120 | 120 | 150 |
| | Gust | lb/sf | 37 | 37 | 37 | 58 |
| | Temperature | deg F | 20 | 10 | 10 | 10 |
| Extreme Combined Ice/Snow and Wind | Radial Ice | in | 0 | 1 | 1.5 | 2 |
| | Radial Snow | in | 2.5 | 0 | 0 | 0 |
| | Snow Density | pcf | 30 | NA | NA | NA |
| | Ice Equiv | in | 1.704 | 1 | 1.5 | 2 |
| | Wind speed | mph | 20 | 40 | 40 | 75 |
| | Wind PSF | lb/sf | 1 | 4 | 4 | 14 |
| | Wind Equiv | lb/sf | 1.362 | 4 | 4 | 14 |
| Temperature | deg F | 30 | 20 | 20 | 20 | |
| Ambient Temperatures | AAMT | deg F | -25 | -25 | -25 | -25 |
| | Maximum | deg F | 90 | 90 | 90 | 90 |
| | Mimumum | deg F | -60 | -60 | -60 | -60 |
| Elevation | Maximum | ft | 2500 | 3300 | 4400 | 4900 |
| Air Gap Structure Dims | No Wind | in | 54 | 54 | 60 | 60 |
| | Mod Wind | in | 36 | 36 | 40 | 40 |
| | High Wind | in | 20 | 20 | 24 | 24 |

Loading Zone 1 extends east from Sutton to approximately Caribou Creek in the Matanuska River Valley and is generally located at elevations less than 2,500 ft above sea level (ASL). Loading Zone 2 extends east from Tahnetta Pass to Glennallen in the Copper River Basin and is generally located at elevations less than 3,000 ft ASL. Loading Zone 3 includes all route segments above 3,300 ft ASL, or in remote back country valleys. The cutoff of 3,300 ft was suggested at the TRM as that maximum elevation at which CVEA has line operating experience, e.g., near Eureka. Loading Zone 4 is a 9-mile segment over Chitna Pass, reaching elevations up to 4,900 ft ASL.

7. Overload Capacity Factors and Safety Factors

The overload capacity factors in Table IV-6 will be used to size transmission line structures, guys, and anchors:

Table IV-6
Overload Capacity Factors

| <i>STEEL STRUCTURES</i> | | | |
|-------------------------|--------------------------|---------------|--------------------|
| Loading Condition | Overload Capacity Factor | | |
| | Transverse Wind | Vertical Load | Transverse Tension |
| NESC Heavy, Grade B | 2.50 | 1.50 | 1.65 |
| Extreme Loadings | 1.10 | 1.10 | 1.10 |

| <i>WOOD STRUCTURES</i> | | | |
|------------------------|--------------------------|---------------|--------------------|
| Loading Condition | Overload Capacity Factor | | |
| | Transverse Wind | Vertical Load | Transverse Tension |
| NESC Heavy, Grade B | 4.00 | 2.20 | 2.00 |
| Extreme Loadings | 1.30 | 1.30 | 1.30 |

| <i>GUYS, ANCHORS AND FOUNDATIONS</i> | | | |
|--------------------------------------|--------------------------|---------------|--------------------|
| Loading Condition | Overload Capacity Factor | | |
| | Transverse Wind | Vertical Load | Transverse Tension |
| NESC Heavy, Grade B | 2.50 | 1.50 | 1.65 |

Anchors will be designed for an additional safety factor of 1.3 based on calculated maximum loads. Guy strand will be selected based on not exceeding 90% of its ultimate rated strength (URS) under the above loading conditions and overload capacity factors applied.

8. Conductor Sag-Tension Limits

Conductor tension limiting conditions and limits are summarized in Table IV-7.

**Table IV-7
Conductor Tension Limits**

| <u>Loading Condition</u> | <u>Self-Damping Types</u> | <u>Loading Zone 1 Non-Self Damping Conductors</u> | <u>Loading Zones 2, 3 and 4 Non-Self Damping Conductors</u> |
|--------------------------|---------------------------|---|---|
| NESC Heavy | 60%(1) | 60% | 60% |
| Extreme Wind, No Ice | 70% | 70% | 70% |
| Extreme Ice, No Wind | 70% | 70% | 70% |
| Combined Extreme Loading | 80% | 80% | 80% |
| Initial Unloaded Tension | 35% (60°F)(1) | 35% (-25°F) | 25% (-25°F) |
| Final Unloaded Tension | 25% (60°F)(1) | 25% (-25°F) | 20% (-25°F) |

(1) NESC Rule 261 required maximum limits.

The selection of unloaded tension limits depends on the type of conductor and the estimated risk of aeolian vibration damage. For standard ACSR conductors our practice is to use reduced initial unloaded tension limits of about 20% URS at the AAMT without dampers. This is in line with REA recommendations [9]. However, this will lead to increased sags and shorter spans with an attendant cost penalty. The NESC stipulates that the unloaded tension must not exceed 35% URS under initial conditions or 25% URS under final conditions at 60°F. REA and Alcoa recommend about the same limits, 33% initial and 25% final, but at 0°F for the NESC Heavy Zone. Manufacturers have indicated that self-damping type conductors (ACSR/SD, SSAC, ACSR/T2) can use the NESC limits.

The corridor can be divided into two parts where prevailing winds are generally parallel (west of Eureka) or perpendicular (east of Eureka) to the alignment. For this study we will apply the higher NESC unloaded tension limits to all self-damping type conductors in all loading zones. For ACSR and Alumo-weld conductors we will apply limits of 35% initial and 25% final at the AAMT (-25°F) in Loading Zone 1 since the prevailing wind is parallel to the alignment. In Loading Zones 2, 3 and 4, we will apply lower limits of 25% initial and 20% final at the AAMT since the prevailing wind is perpendicular to the alignment in the case of Loading Zone 2 or as a somewhat conservative assumption in the less well-known severe Loading Zones 3 and 4.

Vibration dampers would be used as needed depending on the final conductor chosen and a vibration analysis in final design.

Sag tension runs are not included due to the volume of material. A summary of sags for the various conductors is discussed under heading D - Feasibility Design Alternatives, later in this section.

9. Failure Containment and Sequence

A decision to implement a failure containment design is based on the premise that it is too costly and perhaps unreliable to design the line against any failures for any extreme loading conditions. Recognizing the possibility of severe extreme loading conditions in Alaska, failure containment is a primary concern of all experienced line designers in Alaska. Several different approaches have been taken ranging from guyed X structures designed to have their guy yokes yield under high unbalanced longitudinal load (e.g., Tyee-Wrangell) to the frequent application of longitudinally strong structures (e.g., Swan Lake).

Reference [1] discusses at length a design philosophy to contain failures and achieve a specified failure sequence based on a CVEA-stated preference that "loadings that develop high conductor tensions should result in conductor failure before structure failure." The basis for this preference is the widespread failure that occurred due to an avalanche in Thompson Ridge Pass in 1991 it is reported that the high strength 19 No. 5 Alumoweld conductor (URS 73350 lbs) used in the pass did not break during the avalanche and tore down several structures which otherwise might not have failed.

Coordinating conductor and structure failure is difficult to implement with confidence. We further agree with the rephrasing of the design requirements in [1]: "... *the failure of an element on the line should not be allowed to propagate into the failure of other elements such that the cost of the failure is disproportionate to the probability of its occurring.*" Implementing this philosophy is made difficult by a lack of knowledge of the probability of extreme loading conditions. The failure containment philosophy in [1], i.e., based on the premise of accepting limited failure and containing failures by providing periodic longitudinally and transversely strong structures, is commonly used and comparatively easily implemented.

Relying on the conductor as the weak link in the system is not reliable due to the nature of ACSR stress-strain at high tensions and that other elements of the system would have to be substantially over designed to accommodate this weak link. We agree with the conclusion that depending on the conductor to fail before structures is not a practical or desirable solution, except perhaps in known, well-defined avalanche chutes.

Avalanches are a concern, especially in some back country routes. Where practical unavoidable avalanche chutes should be spanned and where not practical structures should be made "sacrificial." Strong containment structures would be used either side of known or suspected chutes or with deadend fuse links. A weak conductor could be used for passing through avalanche areas as well. Where spanning avalanche chutes with the expectation of avoiding the forces of moving rock or snow, high frontal avalanche winds should nevertheless be considered for the span.

The use of fuse links, propagation damping and containment are discussed in [1] to limit failures due to unbalanced longitudinal loads. Using fuse links will require structures with high longitudinal strength to withstand the dynamic release of conductor tension from one side of the structure and the residual longitudinal unbalance due to the remaining conductor which may or may not drop. This method should be used to prevent the conductor from exceeding its serviceable, working limit. However, if the fuse link is designed to act at or before the working limit and if the working limit is applied to reasonably probable loading conditions, nuisance failures can be expected.

Propagation damping relies basically on insulator swing and structure deflection to relieve longitudinal unbalance loads. This feature is inherent in a line with suspension strings and unguyed H-frame or guyed X-frame construction. The level of damping may be fairly well predicted for given loading cases and struc-

ture load-deflection data; typically, longitudinal unbalance due to the extreme case of a broken conductor will die out after 5-10 spans in a tangent run.

Containment relies on strong deadend structures to withstand longitudinal loads. This is the most reliable method of limiting failures due to unbalanced longitudinal loads.

The proposed failure sequence in [1], while reasonable in general, has the following shortcoming. The failure sequence specifies that conductor attachments and insulator string assemblies will be designed to withstand all load cases combined V, T and L loads with NESC load factor 2.00 (actually a strength factor of 50%, Rule 277). This factored load is then used as the basis for calculating loads on all other structure components. Application of NESC load factors to extreme loads will distort the strength requirements for the insulator string and structure components. While this imparts strength to the line it can also be costly in materials. It can also be unreliable in predicting a failure sequence.

Rather than relate all loads to NESC values, we recommend for final design a load factor reliability design approach in which ultimate loads are used in conjunction with component or line importance factors and the ultimate strengths of system components [5] to establish line performance. Design loads would be compared to NESC Rule 252 loads to verify compliance.

For the feasibility study we will not apply a detailed failure sequence or compute design loads for achieving an order of strength. Deadend structures will be applied in heavy angle situations at about one every 3.5 miles. In addition, longitudinal guying at selected tangent structures would provide intermediate strength.

10. Electrical Clearances

Electrical clearances to grade are stipulated in the NESC Rule 232. The basic clearances required by the NESC have been adjusted for voltage, elevation and design margins as given in Table IV-8 below and discussed later.

Table IV-8
Electrical Clearances (ft)

| Nature of Crossing | Clearance ⁽²⁾ | | |
|-------------------------------|--------------------------|-------------------------------------|--|
| | NESC Table 232-1(1) | Net Winter Loading Zones 1, 2 | Net Winter Loading Zones 3, 4 ⁽³⁾ |
| Railway | 26.5 | 30.6 | NA |
| Major Road | 18.5 | 22.6 | NA |
| Minor Road Driveway | 18.5 | 26.6(4) | 32.8(5) |
| Land Accessible to Vehicles | 18.5 | 26.6(4) | 32.8(5) |
| Land Inaccessible to Vehicles | 14.5 | 22.6 | 28.8(5) |
| Water Bodies - No Boating | 17.0 | 21.1 | 27.2(5) |

- (1) Includes NESC reference, electrical and mechanical components of clearance.
- (2) Includes voltage adder of 2.1 ft and 2.0 ft for survey and construction variances.
- (3) Includes adder for elevation at 3% times the voltage adder per 1,000 ft in excess of 3,300 ft, assuming 5,300 ft maximum elevation.
- (4) Includes 4.0 ft snow cover.
- (5) Includes 5.0 ft snow cover and 5.0 ft margin to account for structure deflection.

We will determine the above-clearances under maximum sag conditions either at NESC Heavy ice loading, i.e., 0.5 radial inches of ice at 32°F, or maximum operating temperature, e.g., 150°F for ACSR variant conductors

On studies for the Bradley Lake transmission line maximum vehicle height on snow-covered terrain was determined to be about 12 ft (Sno-Cat with antenna). Added to the 5 ft snow cover this results in a reference height of 17 ft, compared to the standard NESC reference height of 14 ft derived from state regulations limiting vehicle heights. In the clearances in Table IV-8 we have applied the NESC reference height on top of the snow cover, giving an extra margin of 2 ft clearance. This extra margin is desirable in part to account for increased sag due to structure and insulator deflection.

The substantial amount of snowmobiling in back country areas in Loading Zones 3 and 4 makes it very important to consider clearances under extreme loading conditions. The situation of very high sags in remote areas of the Tye Lake 138-kV line (i.e., on Vank and Woronkofski Islands) cannot be tolerated on the Intertie because of the snowmobile activity. Means to provide extra clearance include shortening spans, reducing the longitudinal flexibility of structures, raising structure height, using inverted V insulator strings, and perhaps other methods. In the case of actual contact with the snow, ground fault current may be severely limited by high resistivity snow and too low to trip the line on the CVEA end. Methods to deliberately short the line to ground with interset structures or underbuilt ground wires could be used but are considered much less desirable than providing extra clearance margins. Where practical, the line should be routed away from established snowmobile routes, recognizing though that the ROW itself will be an attractive new route for some snowmobilers.

To account for the increase in sag under extreme ice loading unbalance consider the case of Teal ACSR, Loading Zone 3, and a 1,100 ft span. The sag under 1.5 inches radial ice at 0°F (43.6 ft) is 8.8 ft greater than the sag at 0.5 inches radial ice at 32°F (34.8 ft) under which Table IV-8 clearances are applied. The basic clearance to grade for Loading Zone 3 was 27.8 ft in Table IV-8 before considering structure deflection. The clearance to 5 ft snow cover would be 14.0 ft (27.8 ft-8.8 ft-5 ft) without

structure deflection. A very small total deflection will yield a much larger increase in sag. For example, an increase in slack due to structure or insulator deflection of about 1 ft will lead to an increase of about 5 ft in sag. A 1 ft limit on deflection is stringent. To account for deflection, we would not recommend less than 9 ft clearance to the 5 ft snow cover under extreme unbalanced ice and therefore have added 5 ft to the basic clearance margin in Table IV-8 for Loading Zones 3 and 4.

11. Foundations, Guys and Anchors

Reference [1] proposed direct embedment of structures in granular soils and erection on driven pipe piles for structures in permafrost and muskeg locations. Pipe piles were selected in [1] due to their omnidirectional strength properties, required to match the strength of H-frame poles. H-piles were eliminated because of their typical application with the weak axis resisting longitudinal loads. PEI recommends study of other pile options with the promise of large cost savings. Rock may be encountered in Loading Zone 1 and we will assume rock-anchored foundation types for the feasibility study. A typical pile length of 20 is assumed in [1]. For the feasibility study, we will assume that X-frame structures and 3-pole structures in muskeg are supported on H-pile foundations. An active layer of 3-5 ft in permafrost areas will be assumed and pile lengths computed accordingly.

We will assume that guy anchors are driven H-piles in muskeg, driven H-piles or log anchors in granular soils or rock anchors. H-pile is assumed as 10x57, although smaller piles may suffice for tangent X-frame structures.

12. Insulator Assemblies

Polymer insulators will be assumed for the feasibility study. H-frame and X-frame structures will use outboard I-strings and a center V-string. We would recommend consideration of inverted V assemblies to limit conductor slack increase. For the feasibility study, insulator maximum working load (i.e., equal to the routine test load "RTL" of polymeric insulators) will not be exceeded under NESC Heavy loading conditions without overload factors. Because of concern over long term extreme loading effects on the strength rating of polymer insulators and the underlying assumption that the importance of this line increases with time, we will assume that under any extreme loading condition the insulators will not be loaded to more than 125% of the RTL.

13. ROW Width

There is no industry-wide standard for prescribing ROW width. The actual ROW width requirements are computed based on several criteria for a given line. Reference [9] cites a typical ROW width range of 100-150 ft for 138 kV lines.

ROW width provides for clear construction of a line, containment of energized conductors under wind conditions (e.g., blowout) and containment of structure failure, access for maintenance, removal of encroaching vegetation and danger trees, and some control over unsafe development occurring in the ROW. Conductors must not extend beyond ROW limits under wind conditions for safety reasons. This requires that wider ROW be acquired for longer spans. Recently electric and magnetic field limits have played a role in determining ROW widths and public concern over possible health effects has made magnetic fields an issue in the design and siting of an Intertie. However, no field limits are used to determine ROW width for an Intertie and no State regulations limit fields at this time. We have accepted the line routing criterion

that magnetic fields in occupied structures should not be measurably greater than they would be without an Intertie, i.e., practically meaning the increase should be calculated at less than 0.1 milligauss. Because this limit is not attainable at the edge of typical rights-of-way, we sited the line at least 600 ft from known occupied buildings.

ROW width is determined by the need to contain the line and its conductors within the ROW under moderate and extreme wind conditions and the extent to which danger trees must be removed. Some utilities select width such that if structures fail they would fall inside the ROW. For this study we will determine ROW width based on conductor blowout at 60 mph wind (6 psf) maintaining NESC Rule 234 clearances -- in this case 10 ft -- to the edge of ROW or under extreme wind conditions with a margin of 0-2 ft. Because development immediately adjacent to the ROW is unlikely, we adopted a 0-ft margin under extreme wind. It should be noted that where prevailing winds are parallel to the line, the ROW width determination in final design should consider a smaller blowout wind force.

D. FEASIBILITY DESIGN ALTERNATIVES

1. Background

The feasibility study was initially directed to base its cost estimate for an Intertie on a line design of comparable reliability to existing lines in Alaska. Efforts were focused on an X-frame steel tangent structure design, commonly used on Alaskan lines, especially in permafrost zones (e.g., Tyee Lake, Glennallen to Valdez, Anchorage-Fairbanks Intertie, and other lines). Pursuant to the TRM held on July 6, 1993 the study team was directed to expand the study to seek a least cost alternative for construction of the Intertie, considering alternative conductor types, wood construction, reduced ROW clearing, and other line design aspects.

The following section presents our methodology, findings and recommendations on a least cost alternative for estimating the Intertie. All exhibit references in this section are found in Appendix B, Preliminary Design Documentation.

2. Methodology

We first ran sag tension computations for candidate conductors and tabulated maximum sags versus ruling span. We also ran power loss computations for Dove, Teal and T2Linnet. We selected seven tangent structure types for evaluation: single wood pole, single steel pole, wood unbraced H-frame, wood braced H-frame, steel unbraced H-frame, steel braced H-frame, and X-frame structures. We used appropriate software to size the different structure types and selected as a starting point the best match of maximum span allowed by sag/clearance requirements and that allowed by structure strength; in doing this we attempted to minimize under- or oversizing basic structures.

A simple structure family was established for all construction options to include tangent, light angle (up to 15 degrees line angle), medium angle (up to 30 degrees line angle), and a deadend/heavy angle structure designed for full-deadend capacity. Except for the single pole options which were assumed to have guyed single pole angles and deadends, all non-tangent structures were assumed to be three-pole structures. We expect that a different and expanded family of structures will be developed in final design to best fit the line angle distribution of the final route alignment. All angle structures were assumed to be guyed and

were evaluated based on axial loading limits and REA criteria of maintaining a safety factor of 2.00 for light and medium angle structures and 3.00 for heavy angles and deadends [9].

We sized all non X-frame structures with software available in-house. We prepared a detailed package of concept and design loadings for X-frame structures and sent it to Meyer Industries for estimating; however, they were overburdened and unable to lend engineering assistance for sizing the structures in the short time available. We resorted to sizing the X-frames using an approximate method wherein we tabulated weights and maximum resultant loadings (and then ground line moments) from the Tye Lake and Bradley Lake projects, and estimated the weights of the Intertie structures based on interpolating with Intertie ground line moments. While approximate, this does lead to Intertie structure weights lying between the more lightly designed Tye Lake structures and the more heavily designed Bradley Lake structures. A spot computation of structure weight, based on axial loading of upper and lower legs and bending loads on the crossarm, for Teal in Loading Zone 1, came within 1% of our estimated weight by the approximate method.

Non direct-embedment foundations were sized only for Teal conductor loads in Loading Zones 1-3 and 37 No. 9 Alumoweld in Loading Zone 4. We developed designs for H-pile foundations for use with X-frame structures, pipe pile (or driven caisson) foundations for use with H-frame structures, and concrete cap/rock anchor bolt foundations for special deadend A-frame structures.

After all material sizing was complete we solicited material quotes from various vendors and developed the unit cost estimating database suite. This is discussed in further detail in Section VI, Project Cost Estimates.

3. Conductor Selection

a. Introduction

We investigated the use of several conductors including 556 kcmil 26/7 ACSR Dove, 556 kcmil 26/7 ACSR/EHS Dove (with an extra high strength steel core), 556 kcmil 26/7 ACSR/SD Dove (self-damping ACSR), 605 kcmil 30/19 ACSR Teal, 605 kcmil 30/19 Teal SSAC, 2x336 kcmil 26/7 ACSR/T2Linnet, and 37 No. 9 Alumoweld. Other conductor types are worthy of consideration in final design. Such types might include using 6201 aluminum alloy strands in place of standard 1350-H19 alloy, conductors using trapezoidal strands (i.e., TW and TWD designations), and non-standard constructions. Descriptions of the main conductors investigated follow.

(1) Dove ACSR with an Extra High Strength (EHS) Steel Core

Standard ACSR conductor is typically fabricated using high strength steel core. It is possible to fabricate Dove ACSR with an extra-high strength steel core. Special compression fittings would probably be required to be compatible with the increased strength of the core. Because the Dove/EHS would be identical in appearance to the standard Dove used elsewhere on the system, there is a risk that the standard Dove conductor or fittings could be inadvertently installed in lieu of the Dove/EHS conductor or fittings for repairs; this could be prevented with stamping and color coding. Vibration dampers and galloping considerations for phase spacing apply.

(2) 605 kcmil ACSR 30/19 stranding, Code Name "Teal"

Teal ACSR has a nominally larger overall diameter of 0.994 inches compared to Dove ACSR at 0.927 inches. The higher content of steel in Teal ACSR gives it markedly improved sag characteristics over Dove ACSR for the same loading conditions. In Loading Zone 1, the sag of Teal is 7 ft less than standard Dove for a 1000 ft ruling span. The disadvantages to using Teal are (1) new requirements for spare materials and (2) higher tensions and marginally higher design wind and ice loads. Additional sag benefits would be obtained with an EHS core. Vibration dampers and galloping considerations for phase spacing apply.

(3) SSAC, Teal Stranding 605 kcmil

SSAC uses a standard steel core (high strength or extra high strength) with soft temper (alloy 1350-O temper) aluminum outer strands, forcing the steel core to take up most or all of the conductor mechanical load throughout the loading regime. It appears essentially the same as its standard ACSR counterpart. The disadvantages of Teal SSAC are (1) new requirements for spare materials, (2) higher cost for conductor and (3) a higher cost to install if prestretching is specified. Because of its marginal sag advantages, though, this conductor was not considered in the search for a least cost option. SSAC conductor exhibits a high degree of self-damping which could eliminate the need for dampers. Galloping must still be considered for phase spacing with this conductor.

(4) Alumoweld Conductor

Alumoweld strand has been frequently used in Alaska where severe loadings are expected (e.g., Glennallen-Valdez 138-kV line in Thompson Pass uses 19 No. 5 AW and Tye Lake - Petersburg 138-kV line at high elevations uses 37 No. 8 AW). CVEA has experienced a major avalanche failure in Thompson Pass when the Alumoweld conductor did not break and took out several structures which were outside the avalanche zone. The recurrence of this type of incident can be countered by carefully routing around possible landslide chutes, placing sacrificial structures and low strength conductors/assemblies in the chute where unavoidable, and installing strong structures either side of the chutes with comparatively weak deadend strings which would fail before cascading could occur.

Alumoweld conductor shows much less sag than ACSR or SSAC conductors for the same loading conditions. The disadvantages of Alumoweld include (1) much higher tensions and (2) much greater power losses. Alumoweld conductor would only be considered for use in Loading Zone 4. Vibration dampers and galloping considerations for phase spacing apply.

(5) T2Linnet, 2x336 kcmil 26/7 ACSR Conductor

T2Linnet conductor consists of two standard Linnet (336 kcmil 26/7 ACSR) subconductors helically wound around each other. The principal application of T2 conductor is to prevent galloping. It has a high degree of self-damping and needs no vibration dampers. It was suggested to the study team for its possible savings in ROW costs due to higher allowable design tensions and no need to consider galloping in the determination of phase spacing. Special hardware is required for T2 conductor, but is now widely available. We confined our comparison to T2Linnet because it offered the closest match to the 556-605 kcmil size of conductor required for adequate electrical performance. Other special strandings could be considered. We found that

T2 conductor was not appropriate for the severe loadings in Loading Zone 4. (As a note "T2" is the designation used by the original developer of the conductor, Kaiser Aluminum. Currently, though, Southwire is the only manufacturer of this conductor which it designates as Type VR.)

b. Sag Tension Characteristics

Sag tension computations were made using ALCOA SAG10[™] and the SAGT task module of EPRI TL Workstation[™] for most conductor types. For the extra-high strength core types sag tension computations were performed by ALCAN at our request. CABLEC also supplied SSAC conductor sag tension computations which would differ slightly from the EPRI program results due to the use of a higher order polynomial for approximating stress-strain curves. Sag tension conditions and tension limits were as cited in the previous Part C, Design Criteria. Table IV-9 gives a summary of maximum sags for a 1000 ft ruling span, allowing quick inspection of the height advantages of different conductor types. Exhibit B-1 gives a summary of key design data (e.g., ruling span, tensions and sags) for each of the major conductors in each appropriate loading zone. No sag tension program output is included because of the volume of material generated.

Table IV-9
Maximum Sag Comparison⁽¹⁾

| Conductor | Ruling Span = 1,000 ft (sags in feet) | | | |
|--------------------|--|-------|-------|-------|
| | Loading Zone | | | |
| | 1 | 2 | 3 | 4 |
| Dove 556 ACSR | 33.92 | 35.08 | 35.04 | 61.18 |
| Dove 556 ACSR/SD | 33.76 | 34.94 | 34.89 | NA |
| Dove 556 ACSR/EHS | 25.83 | 34.52 | NA | NA |
| Teal 605 ACSR | 26.93 | 29.82 | 29.73 | 42.19 |
| Teal 605 ACSR/EHS | NA | NA | NA | NA |
| Teal 605 SSAC | 28.11 | 27.47 | 27.52 | 46.76 |
| T2Linnet 2X336 | 28.59 | 29.45 | 29.36 | NA |
| 37 No. 9 Alumoweld | NA | NA | 18.68 | 18.18 |

(1) Sags at NESC heavy 0.5 inch radial ice, 32°F, no wind final condition or maximum operating temperature sag final condition.

c. Power Loss Comparison

Power loss computations were made using a long-line, radial model for Dove 556 ACSR, Teal 605 ACSR, and T2Linnet 2x336 ACSR. To evaluate this effect we assumed an Intertie load factor at 0.60, cost of energy at \$0.08/kWh, 15 MVA loading and a 135-mile length of line. The resultant total line losses under these conditions were estimated to be 525 kW for Dove, 508 kW for Teal and 482 kW for T2Linnet. The annual cost of losses was estimated at \$220,725 for Dove, \$213,570 for Teal, and \$206,650 for T2Linnet. These differences are considered practically insignificant.

d. Phase Spacing

Phase spacing was computed in two ways: (1) by performing galloping analysis for the various conductors and loading zones (see Exhibit B-2 for a sample computation and plot), and (2) using recom-

mended REA methods [9] for computing spacing based principally on conductor sags. Table IV-10 gives a comparison of the methods and resulting phase spacings, demonstrating that phase spacings do not vary greatly among conductors, except 37 No. 9 Alumoweld in Loading Zone 4, where clearing is not an issue. The range of spacings for Teal over all loading zones is 15 to 17 ft, for T2Linnet the range is 14 to 16 ft and for Dove the range is 17 to 19+ ft. It is worth noting that a minimum spacing will be determined by electrical clearances at the structure and will be on the order of 13 ft for a typical flat configuration structure and would require restrained insulator assemblies to limit conductor swing.

**Table IV-10
Horizontal Phase Spacing Comparison**

| | | | | | |
|---------------------|-------|-------|-------|-------|-------|
| Line voltage (kV) | 138 | | PSF | 6 | |
| Line Voltage *1.05 | 144.9 | kV | | | |
| Unit Weight (lb/ft) | 0.766 | 0.939 | 0.939 | 1.108 | 0.926 |
| Bare Diameter (in) | 0.927 | 0.994 | 0.994 | 0.801 | 1.180 |
| Phi/Swing Angle | 31.2 | 27.9 | 27.9 | 19.9 | 32.5 |

| | CONDUCTOR | | | | | |
|-----------------------|------------------|-------|-----------|--------|----------|-----------|
| | Dove | Teal | Teal SSAC | 37#9AW | T2Linnet | |
| LOADING ZONE 1 | | | | | | |
| Ruling Span | 1000 | 1000 | 1000 | NA | 1000 | |
| Ruling Span Sag | 28.61 | 21.75 | 21.96 | NA | 23.94 | |
| Length of Insulator | 5 | 5 | 5 | 5 | 5 | |
| Experience Factor | 1.25 | 1.25 | 1.25 | 1.25 | 1.25 | |
| Input Spacing >>> | 15 | 14 | 14 | 16 | 14 | |
| Maximum Span | 1315 | 1336 | 1330 | NA | 1274 | Seek 1300 |
| Spacing/Gallop | 17 | 15 | 16 | NA | NA | |
| LOADING ZONE 2 | | | | | | |
| Ruling Span | 1200 | 1200 | 1200 | NA | 1200 | |
| Ruling Span Sag | 49.97 | 34.76 | 36.1 | | 41.56 | |
| Length of Insulator | 5 | 5 | 5 | 5 | 5 | |
| Experience Factor | 1.25 | 1.25 | 1.25 | 1.25 | 1.25 | |
| Input Spacing >>> | 16 | 14.5 | 14.5 | 16 | 15 | |
| Maximum Span | 1329 | 1350 | 1324 | NA | 1309 | Seek 1300 |
| Spacing/Gallop | 18+ | 16 | 16 | NA | NA | |
| LOADING ZONE 3 | | | | | | |
| Ruling Span | 1100 | 1100 | 1100 | NA | 1100 | |
| Ruling Span Sag | 40.31 | 30.01 | 27.65 | NA | 33.2 | |
| Length of Insulator | 6 | 6 | 6 | 6 | 6 | |
| Experience Factor | 1.3 | 1.3 | 1.3 | 1.3 | 1.3 | |
| Input Spacing >>> | 16.5 | 15.5 | 15 | 16 | 16 | |
| Maximum Span | 1302 | 1355 | 1331 | NA | 1362 | Seek 1300 |
| Spacing/Gallop | 18 | 16 | 15 | NA | NA | |
| LOADING ZONE 4 | | | | | | |
| Ruling Span | 900 | 1000 | 1000 | 1000 | NA | |
| Ruling Span Sag | 45.16 | 38.91 | 44.2 | 13.84 | NA | |
| Length of Insulator | 5 | 5 | 5 | 5 | 5 | |
| Experience Factor | 1.4 | 1.4 | 1.4 | 1.4 | 1.4 | |
| Input Spacing >>> | 18 | 16 | 17 | 12 | 16 | |
| Maximum Span | 1128 | 1121 | 1159 | 1111 | NA | Seek 1100 |
| Spacing/Gallop | 19+ | 17 | 17 | NA | NA | |

e. ROW Width Effects

Using phase spacing as determined in the previous section we investigated ROW width in several ways.

First we computed the required ROW width to accommodate the same maximum span length - based on the selected ruling span - for each conductor and loading zone. See Exhibit B-3 for a sample computation. This resulted in ROW widths as given in Table IV-11, which shows that of the three ACSR-variant conductors Teal has the narrowest ROW requirements for the given assumptions and that both Teal and T2Linnet are narrower than Dove. Since the use of the same maximum span for the different conductors and types of construction may not be a valid assumption, we investigated ROW width in another fashion.

Table IV-11
ROW Width for Same Given Maximum Span⁽¹⁾
(in feet)

| Maximum Span>> | Loading Zone 1 | Loading Zone 2 | Loading Zone 3 | Loading Zone 4 |
|-----------------------------|---------------------------|---------------------------|---------------------------|---------------------------|
| | 1,100' | 1,400' | 1,300' | 1,200' |
| Teal | 121.3 | 151.4 | 139.8 | 170.4 |
| Dove | 145.1 | 191.1 | 169.1 | 195.5 |
| T2Linnet | 127.8 | 168.2 | 152.6 | NA |
| 37 No. 9 Alumoweld | NA | NA | NA | 92.2 |

(1) All ROW widths controlled by extreme wind blowout.

Second we computed the maximum allowable span for the same 125-ft ROW width. See Exhibit B-4 for a sample computation. This resulted in maximum spans as given in Table IV-12, which shows that Teal will allow a longer maximum span in a 125-ft ROW than Dove or T2Linnet. Inspection of Exhibit B-4 indicates that a 125-ft ROW width is well-matched to the maximum allowable span for all conductor and loading zone combinations except Dove and T2Linnet in Loading Zone 2, which require greater widths than 125 ft.

Table IV-12
Maximum Spans for 125-ft Right-of-Way⁽¹⁾
(in feet)

| | Loading Zone 1 | Loading Zone 2 | Loading Zone 3 | Loading Zone 4 |
|--------------------|---------------------------|---------------------------|---------------------------|---------------------------|
| Teal | 1,230 | 1,205 | 1,190 | 950 |
| Dove | 1,060 | 1,010 | 1,025 | 775 |
| T2Linnet | 1,180 | 1,122 | 1,125 | NA |
| 37 No. 9 Alumoweld | NA | NA | NA | 1,450 |

(1) All maximum spans controlled by extreme wind blowout.

Third we computed ROW widths based on danger tree removal. In practice, ROW widths need to be sufficient to allow felling of danger trees at the typical height of the prevailing forest cover. Sometimes it is possible to obtain permission to clear danger trees outside the ROW, but we do not consider this a practical assumption for this project. The computation accounts for danger tree height as well as terrain slope. See Exhibit B-5 for the computation for flat configuration/multi-pole structures and Exhibit B-6 for single pole construction. This computation indicates that a 125-ft ROW is appropriate for slopes up to 30% and tree height less than 60 ft roughly in the case of a flat configuration structure. In the case of single pole construction, a 125-ft ROW would be appropriate up to a 70-ft tree height and 30% slope. These are typical tree heights in Loading Zone 1.

As a final check on ROW width effects, we computed the required ROW width based solely on conductor blowout for flat configuration structures (X-frames) and single pole structures in Loading Zones 1 and 2 for Dove, Teal and T2Linnet. The computations (see Exhibit B-7 for sample computation) used the maximum span based on clearances for the base structure heights. Required ROW widths are given in Table IV-13 below.

Table IV-13
ROW Width Requirements Based on Conductor Blowout
and Maximum Spans - Loading Zones 1 and 2

| | Required ROW Width (ft) | | |
|----------|-------------------------|-----|-------------|
| | Type of Structure | | |
| | Flat Configuration | | Single-Pole |
| | LZ1 | LZ2 | LZ1 |
| Dove | 111 | 152 | 93 |
| Teal | 98 | 119 | 83 |
| T2Linnet | 100 | 136 | 89 |

The bottom line is that ROW width is not much affected by conductor selection and a 125-ft ROW is sufficient and basically well-matched to design maximum spans. Single pole construction would not appear to reduce the ROW requirements significantly in heavily forested areas (i.e., Loading Zone 1) due to danger tree removal requirements. Typical ROW cross sections are shown in Figures IV-7 (heavy forest) and IV-8 (low growth forest). REA [9] cites the typical range for ROW width at 100-150 ft for 138 kV lines.

f. Summary of Conductor Selection

Conductor selection for the feasibility study was based principally on sag tension behavior and the attendant effects on structure size and quantity. Other factors considered included effects on ROW width, clearing, power losses, and phase spacing.

Sag tension runs showed Teal ACSR and T2Linnet ACSR to have 5-7 ft less sag than Dove ACSR in Loading Zones 1-3. EHS core variants of Teal ACSR and T2Linnet ACSR would produce additional sag benefits. There was no significant difference in maximum sag between Teal ACSR and T2Linnet ACSR (1.7 ft-0.7 ft), based on assumed sag tension limits; this indicates the offsetting effects of the greater steel

content of Teal ACSR and higher allowable unloaded tension limits for T2Linnet ACSR. T2Linnet was found not capable of handling the loading conditions of Loading Zone 4. Type 37 No. 9 Alumoweld conductor was considered only for Loading Zone 4 and had 28 ft and 43 ft less sag than Teal ACSR and Dove ACSR, respectively. Based on clearances alone, Teal ACSR and T2Linnet were considered equivalent choices for Loading Zones 1-3 and both T2Linnet ACSR and Dove ACSR were eliminated as practical choices for Loading Zone 4. Advantage: Teal and T2Linnet for Loading Zones 1-3 and 37 No. 9 Alumoweld in Loading Zone 4; this impact is reflected to a greater extent in the computation of number of structures per 10-mile segment discussed below.

Power loss computations for Teal ACSR, Dove ACSR and T2Linnet ACSR showed an estimated total annual benefit of \$7,000 for T2Linnet compared to Teal ACSR and \$14,000 for T2Linnet compared to Dove ACSR. This difference is insignificant given the feasibility nature of this study. Over a 40-year project life and assuming a 5% discount rate, the stream of annual \$7,000 benefits would only amount to a net present value of about \$120,000. Advantage: T2Linnet, slight impact.

Phase spacing varied from 14 ft to over 19 ft for the various conductors and loading zone combinations. Dove ACSR had required spacings of 16-19+ ft typically more than 2 ft greater than Teal ACSR. T2Linnet showed a 1 ft advantage over Teal ACSR, a figure which could conceivably be improved to 2-3 ft if additional money is spent to fix all insulator assemblies at each structure, maintaining bare clearances to structure of about 6 ft. This advantage would lead to overall structure widths of 28 ft for T2Linnet ACSR and 32 ft for Teal ACSR. Advantage: T2Linnet, moderate impact.

ROW widths were investigated in several ways. Teal ACSR consistently showed narrower ROW requirements based on maximum assumed spans or longer allowable spans for given ROW width than T2Linnet and, to a greater extent, Dove ACSR. Advantage: Teal, moderate impact.

The quantity and size of structures was also considered. We made these comparisons for all seven structure types and four loading zones. In Tables IV-14 through IV-17 comparisons are shown which demonstrate that Teal ACSR fairly consistently requires the fewest number of similar-sized structures or roughly the same number of smaller-sized structures per 10-mile segment based on the best match of structure size and maximum clearance span. Advantage: Teal.

The conductors selected for this feasibility study based on the above technical considerations are Teal ACSR in Loading Zones 1-3 and 37 No. 9 Alumoweld in Loading Zone 4. Unit cost model results also indicate an advantage for these conductors. It should be emphasized that an optimal conductor selection must be part of final project design. The differences among the conductor types chosen for comparison in this study are in many respects slight and small changes to study assumptions could affect the outcome of this study's findings.

4. Structure Selection

We selected seven tangent structure types for evaluation: single wood pole, single steel pole, wood unbraced H-frame, wood braced H-frame, steel unbraced H-frame, steel braced H-frame, and X-frame structures. Typical structure outlines are shown in Figure IV-1 (X-frame), Figure IV-2 (wood H-frame), Figure IV-3 (single wood pole), Figure IV-4 (single steel pole), and Figure IV-5 (3-pole angle structure). In addition, a self-supporting A-frame structure was assumed for failure containment in Loading Zone 4 (see Figure IV-6).

a. Wood H-Frame Structures

The selection of wood H-frame structures began with running H-frame sizing software for the various Loading Zone and conductor data (see Exhibit B-8). This led to maximum spans for Type 1 (i.e., REA TH-10 unbraced) and Type 4 (i.e., REA TH-10V4X braced structures) based on wood pole strength. We assumed western red cedar poles for this computation to facilitate the supply of poles in a tight market, for its natural resistance to decay, and its comparative lightness. A mix of Douglas fir and western red cedar may be desirable to expedite supply for the project.

We then combined tables of spans limited by sag and these maximum horizontal spans limited by pole strength to match appropriate pole size with ruling span. Exhibit B-9 is a sample of this combined spreadsheet for Type 4 H-frames for Loading Zone 1 and ruling spans 800-1,200 ft. This table also computes the number of tangent structures in a level 10-mile segment to evaluate the effect of different sags. In the table you will note, for instance, that a theoretical horizontal span limit for 75/1 poles is 973 ft for Teal and that this corresponds well with the 962 ft span limited by sag, which corresponds to an assumed ruling span of 1,000 ft. The number of structures per 10-mile segment for this case is 55, shown in the outlined box in the table. Several tables were developed for all loading zones and for both braced and unbraced H-frames, both direct embedded and pile-supported.

Table IV-14 summarizes the selection of pole sizes and span lengths for wood H-frame structures for Loading Zones 1,2 and 3 and conductor types Dove, Teal and T2Linnet. Wood H-frame structures were not considered for the severe Loading Zone 4. Also, consultation with McFarland-Cascade Pole Company indicated that, although pole supply is still relatively stable, length/class combinations greater than H2/85 would be more difficult to furnish and that it would be prudent to design with smaller poles. As can be inferred from Exhibit B-9, class H1 or H2 poles would be generally oversized for the allowable span lengths due to sag for poles less than 85 ft long, except for the use of T2Linnet.

Wood was not a practical selection for angle and deadend structures, which were taken as guyed, 3-pole, tubular steel structures, direct embedded in Loading Zones 1,3 and 4 but supported on pile foundations in Loading Zone 2.

Wood H-frames Type 1, unbraced, were considered only for Loading Zone 2, since they would respond better to uneven foundation jacking than Type 4 braced H-frames. Type 4 braced H-frames were considered for Loading Zone 3, although geotechnical investigations may indicate Type 1 is more suitable in Loading Zone 3 if permafrost is encountered.

b. Steel H-frame Structures

H-frame structures are also used frequently in Alaska (GVEA, HEA, CEA, and other utilities). They can be direct-embedded in rock and good, native soil where either there is no permafrost or the active layer is shallow. In poor soil they can be direct embedded with gravel or rock backfill, inserted in a caisson driven into good soil layers and backfilled with select material, or supported on piles (e.g. Swan Lake). H-frames are simple, standard REA structures and can make good use of pole sizes less than H2/85 (wood). There would be no limit on steel H-frames.

Table IV-14
Comparison of Wood H-Frame Spans

| LOADING ZONE | ITEM | CONDUCTOR | | | | | |
|-----------------|-------------------|-------------|-------|-------------|-------|-----------------|-------|
| | | <i>Dove</i> | | <i>Teal</i> | | <i>T2Linnet</i> | |
| | | HF4 | HF1 | HF4 | HF1 | HF4 | HF1 |
| 1 | Max HS (ft) | 1025 | 1025 | 972 | 1175 | 1013 | 1007 |
| | Max Clr Span (ft) | 1000 | 970 | 962 | 1101 | 1014 | 979 |
| | Average Span (ft) | 900 | 873 | 866 | 991 | 912 | 881 |
| | Ruling Span (ft) | 1000 | 1000 | 950 | 1100 | 1000 | 1000 |
| | L/Class-Match | 85/1 | 75/H1 | 75/1 | 75/H2 | 80/H1 | 70/H2 |
| | Qty/10-mi | 59 | 60 | 61 | 53 | 58 | 60 |
| 2 | Max HS (ft) | 1045 | 1076 | 1205 | 1039 | 1027 | 1042 |
| | Max Clr Span (ft) | 1033 | 1060 | 1139 | 993 | 965 | 999 |
| | Average Span (ft) | 930 | 954 | 1025 | 894 | 869 | 899 |
| | Ruling Span (ft) | 1000 | 1000 | 1100 | 1000 | 1000 | 1000 |
| | L/Class-Match | 75/1 | 70/H1 | 75/H1 | 60/H1 | 65/H1 | 60/H2 |
| | Qty/10-mi | 57 | 55 | 52 | 59 | 61 | 59 |
| 3 | Max HS (ft) | 1039 | 1025 | 1207 | 1175 | 1018 | 1015 |
| | Max Clr Span (ft) | 991 | 1026 | 1157 | 1132 | 1009 | 975 |
| | Average Span (ft) | 892 | 923 | 1041 | 1019 | 908 | 878 |
| | Ruling Span (ft) | 1000 | 1000 | 1200 | 1100 | 1000 | 1000 |
| | L/Class-Match | 80/1 | 75/H1 | 75/H1 | 75/H2 | 75/H1 | 65/H2 |
| | Qty/10-mi | 59 | 57 | 51 | 52 | 58 | 60 |

General Notes

1. Average spans calculated at 90% * minimum of Max HS or Max Clr Span.
2. Not used.
3. Max HS is the maximum horizontal span based on pole strength for given length/class.
4. Max Clr Span is the maximum span for the given structure type, pole length and class based on providing code clearances under maximum sag for the given ruling span.
5. L/Class-Match is the selection of pole length and class at which Max HS and Max Clr Span are most equal. This results in the optimum preliminary match of strength and clearance requirements.
6. Qty/10-mi is number of structures in 10-mile segment based on Average Span.

H-frames do not typically respond well to permafrost and frost jack situations. GVEA has experienced several H-frame failures due to frost-heave. This is especially true of the braced H-frame, whose stiffness is a distinct disadvantage in permafrost soils. Even the unbraced H-frame has reportedly not performed well on the GVEA system. A serious disadvantage to the H-frame in Loading Zone 2 is that repair of jacked foundations would require removal of the structure and maybe the pile cap to lengthen and redrive the foundation piles. This would take significantly longer than for an X-frame. It might be possible to design a fix using outboard driven piles that would not require removal of the structure, but in any case repair of H-frame jacking will be more expensive than for the X-frame alternative.

The selection of steel H-frame structures began with running wood H-frame sizing software with steel overload capacity factors for the various loading zone and conductor data (see Exhibit B-10). This led to maximum spans for Type 1 (i.e., REA TH-10 unbraced) and Type 4 (i.e., REA TH-10V4X braced structures) based on wood pole strength. We then substituted wood-pole equivalent steel poles, in this case Meyer LD Series poles.

We then combined tables of spans limited by sag and these maximum horizontal spans limited by pole strength to match appropriate pole size with ruling span. Exhibit B-11 is a sample of this combined spreadsheet for Type 4 H-frames for Loading Zone 1 and ruling spans 800-1200 ft. This table also computes the number of tangent structures in a level 10-mile segment to evaluate the effect of different sags. Several tables were developed for all loading zones and for both braced and unbraced H-frames, both direct embedded and pile-supported.

In Exhibit B-11, it can be seen for instance that 85/1 poles (or LD-1 in the Meyer series) would be a good match for Teal conductor with a 10-mile count of 47, that 75/1 poles are a good match for T2Linnet conductor with a 10-mile count of 57, and that steel poles generally are oversized for Dove conductor.

Table IV-15 summarizes the selection of pole sizes and span lengths for steel H-frame structures for Loading Zones 1,2 and 3 and conductor types Dove, Teal and T2Linnet.

Angle and deadend structures were assumed to be guyed, 3-pole tubular steel structures, direct embedded in Loading Zones 1, 3 and 4 but supported on pile foundations in Loading Zone 2. They were sized using point load information (see Exhibit B-12) and axial loading analysis (see Exhibit B-13).

Steel H-frames, both Types 1 and 4, were considered for all loading zones.

**Table IV-15
Comparison of Steel H-Frame Spans**

| LOADING ZONE | Conductor>>> ITEM | Dove | | | | Teal | | | | T2Linnet | | | | 37#9AW | | | |
|-----------------|----------------------|-------------------|------|-------------------|------|-------------------|-------|-------------------|------|-------------------|-------|-------------------|-------|-------------------|-------|-------------------|-------|
| | | Type 1 HF Pile | DE | Type 4 HF Pile | DE | Type 1 HF Pile | DE | Type 4 HF Pile | DE | Type 1 HF Pile | DE | Type 4 HF Pile | DE | Type 1 HF Pile | DE | Type 4 HF Pile | DE |
| 1 | Max Clr Span (ft) | na | 970 | na | 938 | na | 1101 | na | 1134 | na | 979 | na | 933 | na | na | na | na |
| | Max HS (ft) | na | 1030 | na | 1236 | na | 1178 | na | 1140 | na | 1016 | na | 975 | na | na | na | na |
| | Average Span (ft) | na | 873 | na | 844 | na | 991 | na | 1021 | na | 881 | na | 840 | na | na | na | na |
| | Ruling Span (ft) | na | 1000 | na | 900 | na | 1100 | na | 1100 | na | 1000 | na | 1000 | na | na | na | na |
| | L/Class- Match | na | 75/1 | na | 80/1 | na | 75/H1 | na | 85/1 | na | 70/H1 | na | 75/1 | na | na | na | na |
| | Qty/10-mi | na | 60 | na | 63 | na | 53 | na | 52 | na | 60 | na | 63 | na | na | na | na |
| 2 | Max Clr Span (ft) | 1150 | na | 1080 | na | 1187 | na | 1139 | na | 999 | na | 1152 | na | na | na | na | |
| | Max HS (ft) | 1273 | na | 1236 | na | 1235 | na | 1156 | na | 1068 | na | 1204 | na | na | na | na | |
| | Average Span (ft) | 1035 | na | 972 | na | 1068 | na | 1025 | na | 899 | na | 1037 | na | na | na | na | |
| | Ruling Span (ft) | 1200 | na | 1100 | na | 1200 | na | 1100 | na | 1000 | na | 1200 | na | na | na | na | |
| | L/Class- Match | 80/H1 | na | 80/1 | na | 70/H1 | na | 75/1 | na | 60/H1 | na | 80/H1 | na | na | na | na | |
| | Qty/10-mi | 51 | na | 54 | na | 49 | na | 52 | na | 59 | na | 51 | na | na | na | na | |
| 3 | Max Clr Span (ft) | na | 1026 | na | 991 | na | 1187 | na | 1093 | na | 1178 | na | 1151 | na | na | na | |
| | Max HS (ft) | na | 1030 | na | 1236 | na | 1206 | na | 1153 | na | 1217 | na | 1204 | na | na | na | |
| | Average Span (ft) | na | 923 | na | 892 | na | 1068 | na | 984 | na | 1060 | na | 1036 | na | na | na | |
| | Ruling Span (ft) | na | 1000 | na | 1000 | na | 1200 | na | 1100 | na | 1200 | na | 1200 | na | na | na | |
| | L/Class- Match | na | 75/1 | na | 80/1 | na | 70/H1 | na | 80/1 | na | 75/H2 | na | 80/H1 | na | na | na | |
| | Qty/10-mi | na | 57 | na | 59 | na | 49 | na | 54 | na | 50 | na | 51 | na | na | na | |
| 4 | Max Clr Span (ft) | na | na | na | na | na | 675 | na | 706 | na | na | na | na | na | 1065 | na | 1139 |
| | Max HS (ft) | na | na | na | na | na | 725 | na | 737 | na | na | na | na | na | 1064 | na | 1132 |
| | Average Span (ft) | na | na | na | na | na | 608 | na | 635 | na | na | na | na | na | 958 | na | 1019 |
| | L/Class- Match | na | na | na | na | na | 750 | na | 700 | na | na | na | na | na | 1000 | na | 1100 |
| | Basic Height (ft) | na | na | na | na | na | 75/H1 | na | 75/1 | na | na | na | na | na | 70/H2 | na | 80/H1 |
| | Qty/10-mi | na | na | na | na | na | 87 | na | 83 | na | na | na | na | na | 55 | na | 52 |

Notes:

1. Average spans calculated at 90%*minimum of Max HS or Max Clr Span.
2. Not used.
3. Max Clr Span is the maximum span for the given structure height based on providing code clearances under maximum sag for the given ruling span.
4. L/Class-Match is best match of pole strength and clearance span.
5. Qty/10-mi is number of structures in 10-mile segment based on Average Span.
6. Type 1 HF is unbraced, Type 4 HF is fully braced.
7. Pile refers to pile supported structures with assumed 2' stickup, assuming moment at 6' from base (butt).
8. DE refers to direct embedment structures at 10% + 3 ft.
9. Wood pole equivalents computed for extreme wind, using steel OCFs 1.10.

c. Steel X-frame Structures

The X-frame tangent structure is used extensively in Alaska (e.g., Anchorage-Fairbanks Intertie, Lake Tyee, Bradley Lake, and the Glennallen-Valdez lines) due to its inherent longitudinal capacity, ease of maintenance and installation, and response to frost-jacking situations, likely to be extensively encountered in Loading Zone 2.

A study of alternatives for the Anchorage-Fairbanks Intertie [13] evaluated ten different structure types including single steel pole, steel and wood H-frames, steel X-frame, both aluminum and steel guyed lattice, and self-supporting steel lattice structures and concluded that the X-frame structure promised to be the most long-term, cost-effective tangent structure selection.

Advantages of the X-frame are numerous. With its fore and aft longitudinal guys and guy yokes, designed to yield but not fail under excessive longitudinal unbalanced loading, the X-frame provides a significant degree of longitudinal strength to the line. Design of pile foundations and field guidelines are made simpler by the fact that, due to its geometry, foundation base reactions are relatively independent of structure height. The X-frame is a lighter structure than a comparably loaded, self-supporting H-frame, especially if sizable longitudinal capacity is required. The installation of X-frames by helicopter is less cumbersome than for direct-embedded H-frame structures. While X-frame structures require pile foundations, this also has the advantages of (1) standardizing foundation types and materials, and (2) allowing relatively easy correction of jacked footings and other out of plumb situations. The X-frame structure does not absolutely need to be removed from the foundations to lengthen and redrive the piles to achieve greater penetration, although this operation may be facilitated by temporary removal.

The X-frame is a more complicated structure to design, fabricate and assemble. Its unit cost in dollars per pound, therefore, is slightly higher than tubular steel pole structures. Each structure has two driven pile foundations and two guys, which might require more maintenance than self-supporting, direct-embedded structures to retighten guys and redrive piles. It is expected, though, that jacking situations would appear most frequently in the early stages of project life and would diminish as the project ages. This also depends on the extent of geotechnical investigation done for foundation design.

Steel X-frame structures are custom designed, meaning that, based on selected design spans and loading criteria, point loads are developed and specified for detailed sizing of the structures. It is not possible to accurately design these structures without utilizing complex structural analysis software, something we had neither time nor budget to do. To size the X-frames we first determined basic heights according to sag tension data for Dove, Teal, T2Linnet, and 37 No. 9 Alumoweld for the four loading zones as appropriate. Basic heights were limited to less than 85 ft above ground generally to be consistent with other structure choices. Maximum spans and corresponding heights are given in Exhibit B-14. Based on these spans we developed point loads for all X-frame structure/conductor/loading zone combination using load computation software (see Exhibit B-12). We then developed a complete set of loading tables and concept drawings to submit to Meyer Industries with a request for estimated weights and costs. Our load tables included unbalanced longitudinal loading but not a loading case for nominal differential foundation jacking in permafrost areas, which could control. Unfortunately, Meyer engineering staff was unable to lend any modeling assistance because of other obligations and it appeared that all tubular steel fabricators were in the same bind.

We then resorted to an approximate method whereby we tabulated X-frame weights and maximum loadings for the Tyee Lake and Bradley Lake lines and basically used interpolation of resultant overturning moment to estimate Intertie weights. While not highly accurate, this method did result in weights for Inter-

tie structures between the more lightly loaded Tyee structures and the more heavily loaded Bradley Lake structures and was considered sufficiently accurate for evaluating a least cost construction type.

Table IV-16 summarizes the selection of structure heights and span lengths for steel X-frame structures. Because the use of H-pile foundations is feasible for all expected geotechnical conditions, the X-frame structure was considered for all loading zones.

Table IV-16
Comparison of X-Frame Spans

| LOADING ZONE | ITEM | CONDUCTOR | | | |
|--------------|-------------------|-----------|------|----------|--------|
| | | Dove | Teal | T2Linnet | 37#9AW |
| 1 | Max Clr Span (ft) | 1007 | 1045 | 1014 | na |
| | Average Span (ft) | 906 | 941 | 913 | na |
| | Ruling Span (ft) | 1000 | 1000 | 1000 | na |
| | Basic Height (ft) | 65 | 60 | 60 | na |
| | Qty/10-mi | 58 | 56 | 58 | na |
| 2 | Max Clr Span (ft) | 1206 | 1187 | 1228 | na |
| | Average Span (ft) | 1085 | 1068 | 1105 | na |
| | Ruling Span (ft) | 1200 | 1200 | 1200 | na |
| | Basic Height (ft) | 85 | 75 | 80 | na |
| | Qty/10-mi | 49 | 49 | 48 | na |
| 3 | Max Clr Span (ft) | 1090 | 1074 | 1085 | na |
| | Average Span (ft) | 981 | 967 | 977 | na |
| | Ruling Span (ft) | 1100 | 1100 | 1100 | na |
| | Basic Height (ft) | 80 | 70 | 75 | na |
| | Qty/10-mi | 54 | 55 | 54 | na |
| 4 | Max Clr Span (ft) | 906 | 1012 | na | 987 |
| | Average Span (ft) | 815 | 911 | na | 888 |
| | Ruling Span (ft) | 900 | 1000 | na | 1000 |
| | Basic Height (ft) | 85 | 80 | na | 55 |
| | Qty/10-mi | 65 | 58 | na | 59 |

General Notes

1. Average spans calculated as 90%* Max Clr Span.
2. Not used.
3. Max Clr Span is the maximum span for the given structure height based on providing code clearances under maximum sag for the given ruling span.
4. Basic Height is the structure height corresponding to the Max Clr Span.
5. Qty/10-mi is number of structures in 10-mile segment based on Average Span.

Angle and deadend structures were assumed to be guyed, 3-pole tubular steel structures, direct embedded in Loading Zones 1,3 and 4 but supported on pile foundations in Loading Zone 2. They were sized using point load information (see Exhibit B-12) and axial loading analysis (see Exhibit B-13).

d. Single Wood and Steel Poles

Single wood pole construction is common on the MEA system and is used on the O'Neill Tap Line. Spans of 300-400 ft are typical, largely because the line is designed to carry distribution circuit underbuild. Although the Intertie would not have to carry underbuild, design loadings and conductor sag tension characteristics limit effective spans to 300-450 ft. This is familiar construction which facilitates maintenance. The south central region of Alaska is not harsh on wood poles and a relatively long wood pole life can be expected. Single pole construction would take less space at line angle points than the flat configuration options which have been assumed as three-pole structures. In Loading Zone 1 many line angle points would be necessary at property corners and self-supporting single pole construction would make it easier to turn those angles without guys reaching into adjoining properties; flat configuration construction options are assumed to be three-pole structures and would take more room at such corners.

Wood pole supply may be questionable at project time and wood is penalized for its variable physical characteristics with higher overload capacity factors than steel. A major wood pole supplier has indicated that supply of wood poles up to class and length H2/85 ft is not a foreseeable problem although it would be prudent to consider a mix of Douglas fir and western red cedar. A promising alternative to wood poles is the laminated pole which can be custom fabricated to fit the length, dimension, camber, and strength requirements of the project without apparent supply problems.

Single steel poles offer the same basic advantages of wood except that they can handle spans about twice as long as for single wood poles. Although wood poles are reportedly long-lasting in south central Alaska, the steel pole must be considered to have a somewhat longer lifetime. Self-supporting steel poles with pier foundations may be required where absolute minimum ROW is required at property corner heavy line angles.

Single poles, whether wood or steel, were considered not appropriate in Loading Zone 2 because of their relatively poor response to frost-heave in the extensive permafrost and the vertical phase configuration which presents a greater risk for line-trumpeter swan collisions. They were not considered appropriate in Loading Zones 3 and 4 because of the advantages of spanning out with flat configuration structures.

Tangent single wood poles were evaluated based on ground line moment capacity for both Douglas fir and western red cedar. Computations were made to compare maximum span length based on ground line moment capacity to maximum spans based on sags and clearance with a check of maximum span based on REA ice jump criteria (see Exhibit B-15). The most appropriate match of class/height for each conductor type is given in Table IV-17. Angle and deadend structures were assumed to be single guyed wood or steel pole structures. Computations based on axial loading indicate that H2 wood poles may be appropriate for light angle structures but that higher class poles would be required for medium angle and deadend structures. Based on conversations with a major wood pole supplier, who advised that it would not be prudent to design with poles greater than class H2 at this stage given the wood pole market, we assumed guyed tubular steel structures for medium angle and deadend structures. These structures were sized based on axial loading criteria (see Exhibit B-13). It is noted that, to prevent conductor slapping incidents due to ice unloading, local utilities have expressed a preference for using vertical post insulators to offset conductors. The use of vertical posts is practical with wood structures although double post assemblies may be needed to provide adequate cantilever strength. We have assumed a structure with horizontal-vee pivoting type insulator assemblies with increased vertical phase spacing to achieve similar reliability.

Tangent steel poles were evaluated using VALMONT tubular steel pole sizing software which basically selected poles from their wood-pole equivalent SWP series. Tangent steel pole span lengths were

on the order of twice the wood pole span lengths. We evaluated all conductors for a 950 ft maximum span. Structures would utilize davit arm construction and V-string insulator assemblies. Table IV-17 also gives a summary of tangent steel structure sizing. All angle and deadend structures were assumed to guyed, single steel pole structures whose sizing is based on axial loading (see Exhibit B-13).

Table IV-17
Single Pole Comparison

| LOADING ZONE | ITEM | CONDUCTOR | | |
|-----------------|-------------------|-----------|--------|----------|
| | | Dove | Teal | T2Linnet |
| 1 | WOOD | | | |
| | Max HS (ft) | 458 | 522 | 459 |
| | Max Clr Span (ft) | 468 | 518 | 423 |
| | Average Span (ft) | 412 | 466 | 381 |
| | Ruling Span (ft) | 425 | 475 | 375 |
| | Basic L/Class | 65/1 | 65/H1 | 60/H1 |
| | Qty/10-mi | 128 | 113 | 139 |
| 1 | STEEL | | | |
| | Max HS (ft) | 950 | 950 | 950 |
| | Max Clr Span (ft) | 800 | 800 | 800 |
| | Average Span (ft) | 720 | 720 | 720 |
| | Ruling Span (ft) | 800 | 800 | 800 |
| | Basic Length (ft) | 80 | 75 | 75 |
| | Steel Pole Size | 80.063 | 75.063 | 75.07 |
| | Qty/10-mi | 73 | 73 | 73 |

General Notes

1. Average spans calculated at 90% minimum of Max HS or Max Clr Span.
2. Not used.
3. Max Clr Span is the maximum span for the given structure height based on providing code clearances under maximum sag for the given ruling span.
4. Basic Height is the structure height corresponding to the Max Clr Span.
5. Qty/10-mi is number of structures in 10-mile segment based on Average Span.
6. Steel Pole Size is Valmont catalog number for their SW series.

5. Foundation and Anchor Selection

a. Introduction

Several different soil and rock conditions will be present along the transmission line corridor. Dames & Moore provided a preliminary overview of geotechnical conditions along the proposed Intertie alignments (see Exhibit B-F-1). A family of foundations with application guidelines for on-the-spot-field decisions will be necessary to provide schedule and for cost efficiencies. Wetland and poor soil conditions will have to be delineated in Loading Zones 1, 3 and 4. In Loading Zone 2, wetlands are so extensive that it is prudent to assume pile foundations everywhere. Depending on the extent of geotechnical surveys and if piles are selected throughout, the H-pile driving crew can act as a discovery crew; if refusal due to bedrock is premature, the H-pile crew can move on, leaving that site for a rock crew. Generally, only three types of foundations will be considered appropriate for the Intertie: direct embedment, pile foundations, and rock anchor/concrete cap foundations.

Granular alluvial and colluvial soils with varying frequency and size of cobbles and boulders are typical of Matanuska Valley and back country valleys. Soils overlays bedrock at estimated 10'-20' usually at lower elevations, closer to creek beds, with exposed or shallow bedrock in some locations. The presence of rock and boulders is expected to increase with slope. It is expected that we can adjust structure spotting during construction to limit rock foundations and to avoid large boulders, although a price will be paid in terms of delay and remobilization.

East of Tahnetta Pass, in the Copper River Basin, the soil structure is dominated by glacial till or muskeg overlaying permafrost. Muskeg areas also exist in pockets along route segments west of Tahnetta Pass, but without permafrost. The active layer in the vicinity of Pump Stations 11 and 12 on the Aleyeska Pipeline is 3-5 ft and the permafrost is estimated at about 2,000 ft thick. CVEA has successfully and routinely driven H-pile to 15 ft penetration to support jacked single distribution poles. This is consistent with the cited active layer.

In remote areas of expected severe loading strategically placed, self-supporting structures with increased longitudinal capability are planned. These structures would be mounted to rock anchor/anchor bolt concrete foundations. These areas are in Loading Zone 4 and include sections of the line above 3,500 ft in Chitna Pass and the route alternative around Strelshla Mountain.

b. Direct Embedment Foundations

Direct embedment is appropriate for glacial till, rock and permafrost areas with shallow active layers. Direct embedment is practical for glacial till soils but presents problems for rock encounters and keeping excavated holes open if poles are to be set at a later date. Excavation also represents a greater impact on the environment in terms of soil disturbance and spoils. This could require more lengthy permitting scrutiny in the case of a Corps 404 permit in wetland areas.

Direct embedment would apply to single pole or H-frame structures, guyed and unguyed. However, direct embedment foundations for unguyed structures may be limited by the deformation properties of the annular backfill material. Direct embedment requires augering to sufficient embedment depth, typically 9 ft to 15 ft, setting the poles or structures, backfilling and tamping. The hole must be maintained, i.e., must be prevented from collapsing, until the poles are set. Direct embedment in rock requires drilling for and blasting, excavating, then backfilling holes with imported material and tamping.

Direct embedment is not desirable in permafrost areas with thick active layers or in areas of thick muskeg because of excessive embedment depth. Gravel and rock backfill have been used with mixed results in muskeg situations, but we do not recommend this for the Intertie. Correcting a jacked situation is expensive requiring removal of the structure, temporary support of wires, re-augering the hole, and resetting the pole(s). It would not be practical to set the same structure deeper, and the jacking problem would likely persist intermittently throughout the project life.

Three operation sequences can be envisioned for different geotechnical conditions. First, for glacial till of adequate resisting capacity and depth after the site is laid out, holes can be augered and the pole immediately set or, if the poles aren't going to be set until later, casing can be installed for shoring, and the casing backfilled, tamped and capped. The poles could then be installed at anytime, similar to the X-frame.

Second, for sites with poor or unstable upper soil layers, after the site is laid out, a pipe pile can be driven, the poor or unstable soil within the pile removed, and the pipe pile capped for later pole installation.

This procedure would require a pile driving device and an auger. Driving the pipe pile could also serve as discovery for rock. This is a good/tried method in poor muskeg soils. The pipe pile is driven to required penetration of good soil or permafrost, a hole is augered inside the pipe pile and backfilled with suitable material to desired depth, the pole set to standard embedment depth in the augered hole inside the pipe pile, then backfilled and tamped. The pipe pile serves to transfer lateral loads from the pole to good soil.

Third, if rock is discovered, the augering crew would be demobilized, and a blasting/rock crew mobilized. No shoring is required but import of suitable backfill material may be necessary. If rock is known and planned, no demobilization is necessary. If large boulders are encountered either by the auger or pipe pile, structure relocation would be the preferred solution if it could be assured this would solve the problem. This would involve extra survey time to restake the structure and engineering time to evaluate the move from a spotting standpoint. A new site could also require review for the presence of important cultural resources.

In creek beds and occasional swampy/bog areas, direct embed holes will have to be shored and dewatered. Final design would attempt to limit the number of these sites. Winter construction would allow augering or pile driving without dewatering.

Direct embedment equal to 10% pole length plus 3 ft was assumed for Loading Zones 1, 3 and 4.

c. Pile Foundations

Pile foundations are appropriate for almost all soil and rock conditions. Since concrete foundations are not considered a feasible option, pile foundations would be used with X-frame structures; this is the common practice in Alaska. Pile foundations could also be used with guyed and unguyed single pole and H-frame structures. Pile types that could reasonably be considered include H-piles, pipe piles, and perhaps screw-tripod footings, a hybrid. Pile foundations are desirable for glacial till /muskeg/permafrost situations. This is due to (a) the relatively minor soil and wetland disturbance, especially during winter, and hence permitting advantages, (b) the ability to penetrate deep into the soil in order to obtain sufficient holding capacity, and (c) the flexibility to easily adjust to variable depth requirements. Pile foundations would apply best to structures with light lateral loads such as guyed single pole and X-frame structures.

Piles are usually used at sites where the soil layers, in which direct embedment foundations would normally be established, consist of poor or unstable soils. Piles provide good vertical load capacity as governed by their penetration into the good soil or permafrost. A single pile supporting a pole or structure must be sized to resist the design lateral loads. Therefore, in order to minimize the cost of a pile foundation the structures are often designed as a truss and/or guyed to reduce the lateral loading on the pile. Thus the popularity of the X-frame structure, an inherent braced design, in areas of poor or unstable soils.

Pile foundations, loaded to more than a single pile's capacity consist of multiple piles often installed at an incline (or batter) and tied together with pile caps that also connect the pole or structure. The batter provides some stability for eccentrically applied axial loads, should the pole ever go out-of-plumb.

H-piles have a strong and weak axis, making them optimal choices for applications where the design lateral loading on one axis is light relative to the other axis. H-piles with special, proven pin-connecting brackets are the usual choice for X-frame structures in Alaska.

Round (pipe) piles have the advantage of having equal strength in all lateral directions. They also can provide an adequate socket for direct embedding pole structures inside the pipe. A pinned connection to the top of the pipe pile would require a more elaborate attachment bracket than those commonly used for H-piles.

For guyed single pole structures a system of two, battered piles would be used as is common in Alaska. Alternatively three screw anchors in tripod formation could be, and have been, used.

Pile foundations require driving two H-piles, one for each X-frame structure leg, and an assumed two H-piles for each guyed single pole structure (six piles per 3-pole structure). There is no need to shore and protect a hole or backfill and tamp after setting a structure, as is the case with direct embedment. Welding is required for splicing pile sections (can be performed in marshall yards) and perhaps installation of pile caps for mounting single poles. Bolted connections for splices and pile caps may be a practical alternative.

To support self-supporting, unguyed structures the piles would have to have sufficient section modulus to resist the moment reaction from the mating structure leg. Special moment connection fittings would be required to attach self-supporting structures to the foundation pile(s). Such connection alternatives include (a) a can or baseplate mounted via a bolted connection to multiple H-piles with the pole fitted and grouted inside the can or bolted to the baseplate, (b) a driven pipe pile with an anchor bolt cap/mating plate with anchor bolt connection to baseplate of poles, (c) a special pole-slip-over-pile fitting as yet undesignated, and (d) a driven pipe pile with internal support ring at grade with pole set in the pipe pile stick-up and backfilled with select material or grout.

Practical pile-driving equipment alternatives include vibratory hammer with separate power pack or hydraulic hammer. In cold permafrost areas, piles may be installed with the aid of a preheated pilot hole.

Three operation sequences can be envisioned for different geotechnical conditions. First, after the site is laid out, piles are driven the full required length. Poles or structures could then be installed at anytime. For the X-frame structure it might be advisable to drive H-piles for the fore and aft guy anchors. Pile stick-up would be 4-6 ft.

Second, if bedrock is encountered, i.e., refusal occurs prematurely, the pile-driving crew would (a) attempt to drive at other foundation/anchors to verify extent and depth of rock then demobilize/mobilize to next site, or (b) directly demobilize/mobilize to next site. A rock foundation crew would then mobilize to install rock-anchored and grouted H-pile, excavating and backfilling as necessary. An alternative construction method, which may not work well in the bedrock of the Matanuska Valley, would entail pre-drilling the foundation rock, driving the pile in to refusal (estimated 2-3 ft), then installing rock anchors from the surface. This latter method, if practical, would probably result in less disturbance to the surface and soils.

If large boulders are encountered which lead to premature refusal structure relocation would be the preferred solution if it could be assured this would solve the problem. Driven H-piles generally penetrate boulder-laden soils fairly well, and it is expected that the number of structure relocations will be fewer than for the direct embedment alternative. If relocation is deemed desirable, it would involve extra survey time to restake the structure and engineering time to evaluate the move from a spotting standpoint. A new site could also require review for the presence of important cultural resources.

Pile foundations were sized for extreme wind conditions and Teal conductor. H-pile foundations were sized for X-frame structures assuming 10X57 piles, 3H/8V batter on legs, 21-ft crossarm to waist dimension, medium soil compaction, a 7-ft active layer, a 3-ft reveal, compressive skin friction 2,000 lb/sf, and uplift skin friction of 1,000 lb/sf. Pipe pile foundations for H-frames in Loading Zone 2 were sized based on shear and overturning moment at 30-inches diameter and 0.25 inch thick.

d. Anchors

Discussions with an Alaskan line contractor indicate a strong preference for log anchors where excavation is practical, due to their reliable development of adequate holding capacity under test. H-pile anchors would be practical for X-frame structures since a pile driver would already be mobilized. Rock anchors, either grouted or expandable type, would be used in rock situations.

6. Anchorage-Fairbanks Intertie Structure Study

Prior to design of the Anchorage-Fairbanks 345-kV Intertie, Commonwealth Associates, Inc. prepared a comparative study of structure types [13]. This study evaluated eight different structure types including self-supporting steel poles, self-supporting steel and wood H-frames, guyed steel X-frames, self-supporting steel lattice towers, guyed steel or aluminum lattice X-frame, guyed steel or aluminum lattice delta, and guyed aluminum lattice wye configurations. The observations and conclusions of [13] are applicable to the present feasibility study as well. Major findings are summarized below.

The self-supporting steel pole was judged to be the most aesthetically pleasing type due to its simplicity, narrow silhouette, self-weathering steel color (light to dark brown), and potential for screening. The self-supporting steel H-frame, guyed steel X-frame, and self-supporting wood H-frame were considered acceptable in this regard.

The guyed X-frame and self-supporting steel pole structures were evaluated to be the most reliable and easiest to maintain, except that the self-supporting steel pole was a much taller and heavier structure which would make replacement difficult. This latter concern does not apply to the same extent on the Sutton-Glennallen Intertie because the design loads are much smaller. The X-frame structure was overall judged the best in terms of reliability and maintenance because of simple, reliable foundations, flexibility in frost-heave situations, and ease of replacement. Steel H-frames (braced) were penalized for poor performance in frost-heave situations and difficult replacement due to their weight. Wood H-frames were critiqued for their susceptibility to fire damage, low resistance to avalanche forces, and poor performance in frost-heave or differential settlement situations. The authors mention that in remote locations, where helicopter access may be severely limited at certain times of the year, it may be prudent to station replacement structures or components along the line.

The guyed X-frame was judged to be the most constructible type considering foundations and anchor requirements, terrain and ease of setting in uneven terrain, number of components, and weight of components. The advantages of the X-frame were cited as its comparatively light structure component weights, the less critical tolerance on foundations, and simplicity of foundations. The required fore and aft anchors were listed as disadvantages although their possible use as a field erection aid was mentioned.

The guyed X-frame was evaluated to have the least total 100-year life-cycle cost per mile including both capital and maintenance costs. The self-supporting steel H-frame was evaluated to be not significantly more costly (only 1.02 times the X-frame cost/mile) than the X-frame structure option.

Overall [13] recommended the guyed steel X-frame structure as the most desirable structure type for the project considering its high rating in all the evaluation categories above.

7. Construction Plan

a. Background

The Intertie corridor can be logically divided into three or four construction zones roughly parallel to the loading zones selected for the feasibility study. For the purposes of this study the construction zones will be taken as equivalent to the four loading zones, although differences in terrain, permitting restrictions, access, and other factors would be expected to create some overlaps.

Characteristics of the four zones can be described as follows:

Loading Zone 1 stretches from Sutton to Caribou Creek in the Matanuska River Valley. It is generally heavily to moderately heavily forested with alder, cottonwood, white spruce, and birch on the western end of the zone. It is estimated that the forest resources have no commercial value and would not have to be removed, but a formal determination of this rests with ADNR. Special treatment of cleared white spruce (e.g., chipping, crushing, or controlled burning) will be required to control the bark beetle infestation. The zone lies in parts of the Matanuska Valley Moose Range (MVMR) and has the most potential conflict with private, native and native-selected lands. Elevations are 500-2,500 ft ASL. Glacial till is the dominant soil type with pockets of muskeg and rock expected. No permafrost is expected and direct embedment foundations are practical. There are four major creek and river crossings (Granite, Kings, Chickaloon, Boulder) and limited access to the ROW from the Glenn Highway unless the few existing trails can be upgraded for use. Access overland along ROW is possible. Year round construction is possible.

Loading Zone 2 lies in the Copper River Basin and east of Syncline Mountain. The terrain is barren at higher elevations and moderately heavily forested with predominantly black spruce from Slide Mountain eastward. There may be some forest stands of commercial value mostly in Ahtna lands in the easternmost 10-15 miles of line corridor. Winter roller crusher clearing is appropriate for this zone. The zone lies mostly in state and Ahtna lands. The soils are characterized by extensive permafrost and wetlands. There is high potential for impacts and construction restrictions due to wildlife and waterfowl habitat. No new access roads are assumed but there will be good access in winter. Foundation construction will take place in winter only and will use driven piles to minimize damage to wetland areas. Special construction methods would be required for stringing in non-frozen conditions. Elevations are 1,700-3,300 ft ASL.

Loading Zone 3 is located at elevations generally greater than 3,300 and not in Zone 4. This includes back country valleys in the Talkeetna Mountains. Soils will be mostly glacial till and colluvial with pockets of muskeg and wetlands. No permafrost is anticipated except perhaps on north-facing slopes. Direct embedment foundations are estimated to be practical. Route alternatives in Loading Zone 3 follow creeks and streams with only a few crossings. Construction would require a combination of helicopter and limited overland access to the ROW. Access along ROW is assumed practical between major streams. Except for the

north bank of Squaw Creek with relatively heavy forest cover, open land is the rule with little or no clearing required. Loading Zone 3 would be non-winter construction mostly with some fringe winter construction possible such as in the higher elevation muskeg areas near Pass Creek and Crooked Creek. Routes in Loading Zone 3 lie mostly on state and federal lands with numerous unpatented mining claims. Moderate construction restrictions may apply to limit impacts to wildlife habitat.

Loading Zone 4 includes all route segments above elevation 3,300 ft and occurs in only two locations, north of Strelshla Mountain and over Chitna Pass. The dominant soil types are expected to be glacial till, colluvial soils with increased presence of rock compared to Loading Zone 3. Loading Zone 4 would require all-helicopter construction with no overland access assumed. Construction would be restricted to non-winter periods only. The terrain is characterized by open land with no clearing required. All route segments in Loading Zone 4 are on state land, with some unpatented mining claims expected. The only wildlife habitat construction restrictions would appear to be with regard to Dall sheep.

b. Feasibility Study Construction Plan

Several factors determine how the Intertie would be constructed. A project schedule is presented in Section VII and is based largely on the assumptions below.

(1) Road and Trail Access

The line route alternatives do not parallel at close distance any existing road. The Glenn Highway would be used to move material, equipment and labor along the length of the corridor to several marshall yards. Access to the ROW along adequate existing roads is only known to be possible from seven locations: Jonesville Road, Martin Road, Tractor Trail at Eureka, Lake Louise Road, Tolsona Lake/Moose Lake Road, the Glenn Highway crossing and the Alyeska Pipeline access road. An estimated 50 miles of ROW could be accessed without crossing major streams using these access points.

From aerial photography and topographic maps, supplemented by helicopter reconnaissance, we note that several major and many minor trails lead from the Glenn Highway to the various route segments. It does not appear desirable, however, to upgrade or use most of the public trails in the Matanuska Valley for construction access due to the historic and recreational importance of many trails. However, based on review of aerial photos there do appear to be some trails which might be usable for a single entry point to the ROW on otherwise isolated line sections (e.g. Segment 2-3). It is assumed that trails in state land in the Copper River Basin (e.g. Nickoli Lake, Atlasta Creek) could be upgraded and used, although this would be subject to ADNR approval. Trails also extend the length of Boulder, Caribou, Alfred, Squaw and Crooked Creeks. The Squaw Creek trail is apparently heavily used and would be suitable for construction access, although if the final line route is on the south bank of Squaw Creek the road would be of limited use unless Squaw Creek can be crossed. Portions of Squaw Creek and Crooked Creek trails were explored on ATVs during the study. The Crooked Creek trail and most trails in the area passed through pockets of muskeg which would not support heavy equipment except in winter or perhaps using special vehicles. Several active mining claims, and a few abandoned ones, were noted and it is clear that this part of the corridor is no stranger to moderately heavy mining equipment.

Crossing anadromous streams is of particular concern, as evidenced by construction delays on the Anchorage-Fairbanks Intertie project. To construct a route segment between two streams a contractor would have to (a) gain direct access to the ROW, (b) cross the streams either by fording or temporary bridge, or (c) transport equipment by helicopter.

Option (a) has been ruled out for some segments such as Segments 4-7 and 7-8 by not assuming any new access points to the ROW or use of popular public trails for access.

Option (b) would be the most cost effective if it could be assured that the crossings would be possible and allowed in a timely way. Granite Creek, Kings River, and Chickaloon River are apparently too steep at the ROW juncture to allow crossing within the ROW. The open-water timing windows for fording or construction in anadromous streams is tied to the absence of salmon eggs or frye in the stream (May 15 to July 15 approximately in Matanuska Valley, June 1 to August 1 in the Copper River Basin) and, generally, eggs are fairly resistant to cold and other disturbance about two months after spawning in mid-July to early-August. Crossing the streams or construction in them is also permissible under frozen conditions, say late November to late February. ADF&G personnel indicate that damage to stream banks and restoration of same would be highly important permitting criteria.

Several types of temporary bridges could be considered such as culvert beds, flat railcar deck or extendible Bailey truss bridges. The use of temporary bridges would facilitate the movement of different equipment along the ROW for the duration of the project but would allow increased off-road vehicle access to corridor lands during the project.

Option (c), the transportation of equipment by helicopter is practical in most circumstances but requires equipment that weighs less than the practical lift capacity of heavy helicopters (25,000 lb approximately) or which can be broken down and assembled at the project site. Pile-drivers, diggers, rock drills, and most stringing equipment will meet this criterion. This is a costly solution to ROW access unless it could be dovetailed with other tasks to give a high utilization of the helicopter and avoid high mobilization/demobilization costs.

Of special concern are the significant wetlands in the Copper River Basin. Most construction through structure erection will occur in winter. However, conductor installation will occur anywhere from late spring to early fall during which time the ground may not be frozen enough to allow tensioners, pullers and sagging equipment to move along the ROW without causing some damage to the wetlands. The damage may be viewed as temporary by ADF&G and ADNR and allowable. Wetlands may be avoidable by leaving the ROW. Permits with the ADNR, ADF&G and BLM should strive to include a provision of this nature. Site improvement or mats may be necessary to support certain equipment at stringing set-up locations. Construction activities may be restricted in the vicinity of trumpeter swan habitat in the May 1 to August 31 period.

For the purposes of the feasibility study and based on public concern over the issue of increased access to corridor lands, we assume that no new access roads would be built to the ROW, although access would be initiated at the road crossings cited above. It is assumed that some trails could be upgraded to allow access to a few segments, e.g., Segment 2-3. East of Syncline Mountain, where most construction will be during the winter, access is assumed very good using tracked, snow vehicles. We also assume, based on discussions with ADF&G, that equipment can be moved along the ROW over most of the Intertie route, subject to timing

windows cited above. A grubbed, 12 ft primitive path along the ROW would be available for equipment travel on good soil.

(2) Helicopter Use

Helicopters may be used throughout the project for appropriate tasks. Only in a few situations will a contractor be required by the construction specifications to use helicopters. Such helicopter-requirement instances will be identified during the permitting process and might include stringing a pilot line in the wetland areas of Zone 2. Otherwise, use of helicopters would largely be up to the line contractor(s). Generally, helicopters are viewed as cost efficient for tasks like structure installation, pilot line stringing, material delivery, crew transport, etc., and are often a contractor's method of choice.

For the feasibility study it is assumed that all structure material will be delivered to the site by helicopter, including foundation and anchor material, fully-framed structures and conductor reels. Helicopters would be used selectively to move construction equipment and personnel to the ROW and from site to site, and exclusively for both materials and construction in Zone 4.

A wide range of helicopter capacity is appropriate for different tasks, as demonstrated on the Anchorage-Fairbanks 345 kV Intertie and other Alaskan transmission line projects. Light helicopters, such as the Bell 205-206 variety, would be used for personnel transport, light material transport, and pilot line stringing. Typical costs for this class of helicopters would be \$550-\$700/flight-hour plus fuel.

Medium lift helicopters such as a Boeing VERTOL 107 (10,500 lb sea-level lift capacity), operated by Columbia Helicopters out of Oregon, or, to a much smaller extent, an Aerospatiale Super Puma (6,000 lb sea-level lift capacity), operated by ERA Helicopter in Anchorage, are capable of hauling typical fully-framed X-frame, H-frames and single pole structures. Weights for these structures are generally expected to be 3,000-9,000 lb. Our rough engineering computations show some structure weights above that amount but we expect that special care during engineering design to limit structure weights or break them down into lighter components would be successful in meeting the 10,500 lb limit, but it would be more difficult to meet the 6,000 lb limit. The 10,500 lb limit capacity is sufficient for the maximum reel weight for 10,490 ft of Teal ACSR at 9,860 lb, while the 6,000 lb limit would be restricted to half-size reels. Typical costs for this class of helicopter would be \$2500-\$3000/flight-hour plus fuel. The Columbia VERTOL 107 is commonly used for logging in Southeast Alaska and returned to Oregon in the winter. If high utilization rate is probable, the VERTOL can be made available for line construction in Alaska, with a lower mobilization cost than a helicopter coming directly from Oregon.

Heavy lift helicopters, such as the Boeing CHINOOK 234 (26,000 lb sea level lift capacity), operated by Columbia Helicopters or the Sikorski SKYCRANE (20,000 or 24,000 lb sea level lift capacity) operated by Erickson Skycrane, both based in Oregon, could easily lift any structure or standard reel size contemplated for the project as well as most equipment. Erickson has developed and implemented an anti-rotation lift device that allows precise and rapid placement of structures. The SKYCRANE also features a rear-facing pilot position that facilitates lifting and placement of loads. Both firms principally use these helicopters for logging due to the high utilization rate. Neither is based in Alaska and would require a mobilization and demobilization cost

estimated at \$150,000. If any portion of the work absolutely requires this lift capacity it would seem prudent to maximize its use. For the purpose of this feasibility study, we have assumed no usage of this helicopter since it is not certain if this capacity would be required. Typical costs for this class of helicopter would be \$6500-\$7500/flight-hour.

The efficiency in structure erection gained by use of helicopters is impressive. On a recent storm rebuild project (345-kV, wood H-frame, 65-miles long), 149 structures were set by helicopter in one 9-hour day and all 400 structures were set in four days. In this case marshall yards were located on the ROW. On a section of a New Jersey project which traversed inaccessible wetlands, helicopters were used to fly in vibratory hammers/power packs for driving 9-10 steel caissons and then to fly in and set framed single steel pole structures, all in one day. There have been similar experiences on Alaskan projects such as Swan Lake, Tyee Lake, Anchorage-Fairbanks Intertie, and Bradley Lake.

We have assumed for the feasibility study that such efficiencies would also be beneficial and that all structure erection takes place over a two-month period by flying in fully-framed structures. There may be sections of the line which would benefit from land-based installation, such as in Sutton and other areas where access to the ROW with construction equipment is easy. We have not precisely accounted for these sections in the study.

(3) Foundations

Foundations for transmission structures can be of several basic types with the most commonly used being direct embedment, driven pile, drilled concrete-pier, concrete pad with rock anchoring, and concrete or steel spread footings in excavated holes. The high cost of transporting concrete to distant line locations makes drilled concrete piers, concrete spread footings and concrete pad footings undesirable except where special self-supporting structures are required.

Direct embedment and driven piles are the most commonly used support systems for transmission structures in Alaska and the most cost-effective. Concrete foundations will be considered only for self-supporting deadend or angle structures.

Direct embedment is only practical where granular soils or rock allow sufficient development of soil overturning resistance for a stable footing. This method would appear to be most appropriate for Loading Zones 1, 3 and 4. A modified construction technique has been used where a caisson is driven through poor soil like muskeg and into underlying good soil strata, then overaugering and backfilling with select backfill to standard embedment depth, setting the pole and backfilling the hole; the caisson is relied on to transfer base reactions to good soil strata and must be properly sized. This technique might be used in Loading Zones 2 and 3 where wetlands are encountered, except that it would require significant excavation and spoils which might complicate permitting.

If helicopter-erection of structures is assumed, the direct embedment of structures on the Intertie would require a caisson or some other means of shoring to maintain the holes ahead of structure erection. In areas where boulders and cobbles dominate, wide holes would be excavated and suitable backfill material would have to be imported at significant cost. In rock areas holes would have to be blasted and excavated. In all direct embedment cases the embedment hole will have to be backfilled in a separate operation. Direct embedment is suitable for both self-support-

ing and guyed structures. Equipment required would depend on the type of soil but would typically be a pile-driver for the caisson, an auger for excavating holes and equipment for handling the caisson.

Efficient and productive pile-driving will depend largely on the type and size of equipment selected for the task. We discussed pile-driving options with a line contractor with experience on the Swan Lake Project and familiarity with the Anchorage-Fairbanks Intertie.

On the Swan Lake Project versatile, relatively lightweight pile-driving equipment was developed for rough terrain operation and where no roads were allowed. A modified hydraulic demolition hammer was mounted on a Menzi-Muck all-terrain backhoe (*Transmission & Distribution*, September 1987 issue, page 50). The Menzi-Muck was also modified and special construction equipment developed to carry rock drills and to perform foundation uplift tests. It was highly mobile at the structure sites, with the ability to swivel 360 degrees, an articulated arm and self-propulsion. On the Swan Lake Project, a 20,000-lb lift helicopter was used to move the Menzi-Muck with pile-driver (total weight 17,000 lb) along the ROW in conjunction with logging operations. However, it is feasible to assume a Menzi-Muck would be able to move along the ROW without helicopter assistance, albeit at a rate of about 500 ft/hr. It can be outfitted with oversized tires to traverse swampy areas with minimal disruption. It can operate on slopes up to 45 degrees without the need for anchors and as outfitted for the Swan lake Project could manipulate and handle up to 30-ft piles.

A mix of Menzi-Muck mounted pile drivers for rough or unfrozen wetland terrain and more common tracked crawler-backhoes outfitted for pile drivers on firm ground where a grubbed primitive road is available for movement along the ROW would be most desirable coupled with an appropriate selection of pile-driver equipment.

Pile-supported foundations would be suitable for the pin connection of the guyed X-frame structure and poles of the three-pole structure family. In rocky areas, drilling a pilot hole prior to pile driving has proven effective in achieving required driven lengths. Another method used on Swan Lake involved driving piles to resistance, and depending on embedment at that point, installation of anchor rock bolts to provide the balance of strength required; prefabricated cans were mounted on the H-piles for receiving the (wood) poles. Driven piles offer distinct advantages in terms of construction plan scheduling since the foundation may be left in place until structure erection can be scheduled and will be ready to immediately accept the structure. Driven piles would be used for all structures in permafrost and wetlands areas, i.e., mostly in Loading Zones 2 and 3. Equipment would include a rock drill rig where rock is known to exist, an hydraulic ram pile driver and equipment to handle the piles.

Piles would be used for X-frame structures in all loading zones, all structure types in Loading Zone 2, and for 3-pole structures in mostly Loading Zones 2 and 3 where wetlands are encountered. Direct embedment could be used for 3-pole structures in Loading Zones 1, 3 and 4.

(4) Structure Erection

Two basic methods could be considered for the Intertie. First, structures could be delivered to the structure sites ahead of foundations and in a disassembled state. The structure field assembly, framing and erection would then take place immediately after foundations are

completed. Second, the structures could be assembled in marshall yards, flown to the structure site fully framed with travellers and installed well after foundations are in place.

The first method would likely suffer some inefficiencies because of the poorer field conditions and lack of some equipment to aid structure assembly. Because this method would allow immediate erection and backfilling, it would not be necessary to shore or case augered holes in good soil. Structures could be delivered to the site any time prior to foundations. However, the project schedule in Section VII assumes a furnish and install contract in which the line contractor(s) purchase structures from August 1996 to January 1997, while foundations are being installed. To use the first method and keep the same schedule, structures would have to be purchased (and later stored) by CVEA under separate procurement contract earlier in the project. While this would save contractor mark-up costs, the additional owner costs for storage, an extra contract process and the risks associated with possible realignments and relocations after structure purchase are compelling reasons to use the furnish and install contract. Major equipment would typically include a tracked auger and rough terrain crane.

The second method entails the assembly and full framing of structures in one of 7-8 marshall yards located along the Glenn Highway. Assembly would include insulator strings and stringing travellers and fixed climbing devices for steel structures. Folding ladders could also be attached and flown in with the structure for rapid ascent by field crews. In this method the structure site would be inspected and prepared for arrival of the structure. For direct embedded structures this might entail removing any cover on augered holes, verifying the condition of the hole bottom, and perhaps verifying the hole depth. On pile-supported structures, the same level of preparation would not be necessary. This method allows for a concentrated helicopter lift period and excellent helicopter utilization, on the order of 8 hours per day, well above the usual minimum-use stipulation in helicopter contracts. Although we have allotted two months in the schedule for structure erection by this method, it is not unreasonable to expect that helicopter delivery of about 700 structures to their sites, assuming a well-organized operation on the ground, would take no more than one month or less, based on recent experience. No major equipment would be required for this operation, only small tools and, for direct embed operations, tampers for backfilling.

We assumed the second method for all structure erection. It may be desirable to use the first method in Loading Zone 1. There is a definite possibility that, especially for direct embed structures, helicopter delivery could outrun ground crew productivity. Some means to rapidly transport ground crews from site to site will be required to keep up with the helicopter.


(5) Conductor Stringing

Conductor stringing involves installation of the travellers on the insulator strings, establishing conductor reel and pulling sites, pulling in the pilot line usually with a small helicopter, then pulling in and sagging the conductor. Later operations include clipping in the conductor, installation of vibration dampers, and making up deadend assemblies.

Typical reel sizes on the project contain about 5,000 ft of conductor; larger reels are possible but would require larger stringing equipment. It would appear practical to double-sock and even triple-sock using stringing equipment with 5,000 lb tension rating, to limit the number of set-up sites. This would be especially important in Loading Zone 2 wetlands.

Conductor stringing would take place from late spring to early fall, beyond the possibility of ice-up or other significant loads which could render the critical stringing sag specifications useless.

Stringing would take place immediately following structure erection as shown in the project schedule in Section VII.




NOTE:
PHASE SPACING VARIES WITH CONDUCTOR
AND LOADING ZONE.

FIGURE IV-1
ALASKA ENERGY AUTHORITY
COPPER VALLEY INERTIE
FEASIBILITY STUDY

TANGENT
X- FRAME STRUCTURE

R.W. BECK
AND ASSOCIATES



DIRECT-EMBEDDED OPTION SHOWN
ALTERNATIVE PILE-MOUNTING

FIGURE IV-2
ALASKA ENERGY AUTHORITY
COPPER VALLEY INERTIE
FEASIBILITY STUDY
TANGENT
WOOD H-FRAME STRUCTURE

R.W. BECK
AND ASSOCIATES




FIGURE IV-3
ALASKA ENERGY AUTHORITY
COPPER VALLEY INTERTIE
FEASIBILITY STUDY
TANGENT
SINGLE WOOD POLE
R.W. BECK
AND ASSOCIATES




FIGURE IV-4
ALASKA ENERGY AUTHORITY
COPPER VALLEY INERTIE
FEASIBILITY STUDY
TANGENT
SINGLE STEEL POLE
R.W. BECK
AND ASSOCIATES





FIGURE IV-5
ALASKA ENERGY AUTHORITY
COPPER VALLEY INTERTIE
FEASIBILITY STUDY
RUNNING ANGLE
THREE POLE STRUCTURE

R.W. BECK
AND ASSOCIATES



NOTE:
ONE STRUCTURE PER PHASE.

FIGURE IV-6
ALASKA ENERGY AUTHORITY
COPPER VALLEY INERTIE
FEASIBILITY STUDY
TYPICAL STEEL
A-FRAME STRUCTURE
LONG SPAN CROSSINGS

R.W. BECK
AND ASSOCIATES




FIGURE IV-7
ALASKA ENERGY AUTHORITY
COPPER VALLEY INTERTIE
FEASIBILITY STUDY
RIGHT-OF-WAY CROSS SECTION
HEAVY FOREST

R.W. BECK
AND ASSOCIATES




FIGURE IV-8
ALASKA ENERGY AUTHORITY
COPPER VALLEY INTERTIE
FEASIBILITY STUDY
RIGHT-OF-WAY CROSS SECTION
SPARSE / LOW FOREST

R.W. BECK
AND ASSOCIATES

FEASIBILITY DESIGN - SUBSTATIONS

A. BACKGROUND

Reference [1] assumed that the Intertie would originate at MEA's O'Neill Substation in Sutton and terminate at Authority Pump Station No. 11 Substation in Glennallen. The switching configuration and cost estimates were developed based on expansion of the two substations.

The difficulty of routing a new transmission line out of O'Neill Substation, located in a residential zone of Sutton, and expanding the substation while maintaining load, have made it preferable in our opinion, to situate the starting point of the Intertie at a new substation located about 0.7 mile west of the O'Neill Substation on Mat-Su Borough land, along the 115-kV transmission line feeding O'Neill Substation.

Figure V-1 shows a one-line system configuration of the proposed Intertie.

B. NEW SUBSTATION NEAR O'NEILL SUBSTATION

Figure V-2 shows an equipment layout of the new substation. The new substation will tap into the existing 115-kV line feeding O'Neill Substation at about 0.7 mile west of O'Neill Substation. Two disconnect switches will be provided at the tap point for line maintenance purposes as discussed with MEA staff. We have proposed a simple, radial transformer tap switching configuration with a circuit switcher on the 115-kV side and a circuit breaker on the 138-kV side. Omission of the 138-kV side circuit breaker and replacement of the 115-kV side circuit switcher with a circuit breaker should be considered during final detail design. No integral disconnect switch is provided with the circuit switcher, but separate disconnects are provided on each side of the circuit switcher as well as for the circuit breaker. Both the circuit switcher and the circuit breaker are provided with a bypass disconnect switch as requested by CVEA.

During circuit breaker or circuit switcher bypass operation, a line-side, spring-loaded short-circuit ground switch could provide transformer protection by creating a ground fault that would be sensed and cleared by remote end overcurrent protection. It should also be considered during detail engineering whether the 138-kV side circuit breaker could be omitted, and only rely on the short-circuiting ground switch and the remote end circuit breaker (at Pump Station No. 11 Substation) to clear transformer faults from the 138-kV side.

A 12/16/20 MVA auto-transformer steps the voltage up from 115 kV to 138 kV. The transformer rating is adequate for the 20-year load projection of about 20 MW and greater than the single contingency transfer limit identified by PTI (Volume 2, Appendix O). The foundations and oil containment will be sized for the ultimate station capacity.

CVEA requested that no PLC communication system be included for transfer tripping on the Intertie based on perceived marginal benefit and poor experience with existing PLC systems. We did not investigate alternative means of providing a communications link (e.g., microwave, leased telephone line, fiber optic). Omitting a communications link requires that stepped distance relaying at each end operate

independently to isolate faults. If Intertie interruption devices are bypassed, the far end distance relays may not reliably recognize and clear internal transformer faults. Special attention to protection schemes under bypass operation will be required in final design.

The Intertie will be provided with stepped distance relays with built in directional ground overcurrent relays. Distance and directional ground overcurrent relaying on the 115-kV side has also been included in the cost estimate, but the 115-kV side protection philosophy and relay coordination need to be studied further during detail design. Disconnection of the Intertie from the MEA system would transfer the O'Neill load (up to 1.5 MW maximum) to the CVEA system which could result in underfrequency condition on the CVEA system. Underfrequency relaying or underfrequency in conjunction with directional power relays may therefore be necessary at the new substation near O'Neill or at O'Neill substation to drop O'Neill during underfrequency conditions.

Station service power will be sourced from two power voltage transformers, located on the 115-kV and 138-kV line sides. Alternatively, MEA could feed the station service system with a distribution line. A small prefabricated building will house control, protective relay and auxiliary equipment. Tubular steel type, combined dead-end and circuit breaker disconnect and bypass switch supports are proposed on both the 115-kV and 138-kV sides. The station will occupy an area of approximately 100 ft x 70 ft.

C. PUMP STATION NO. 11 SUBSTATION EXPANSION

The existing Pump Station No. 11 Substation consists of a 12/16/20 MVA 138-14.4 kV transformer, a single 138-kV oil circuit breaker with bypass switch and a 5 MVAR reactor connected permanently to the 138-kV incoming transmission line from Valdez. The existing substation layout makes it difficult to connect the Intertie in a radial bus configuration without first modifying the equipment arrangement.

We propose to relocate the existing line-connected 5-MVAR shunt reactor, voltage transformers, and line traps to make room for a 138-kV bus to which the Intertie can be connected. We also propose to relocate the existing 138-kV circuit breaker on the line to Pump Station No. 12 Substation, and to provide a circuit switcher without built-on disconnect switch in place of the relocated circuit breaker for the existing power transformer. Figure V-3 shows the proposed equipment layout. The existing reactor will be provided with a disconnect switch to facilitate disconnecting it from the line and space will be provided for future addition of a circuit breaker to facilitate reactor switching under load.


A new 10-MVAR shunt reactor will be connected to the 138-kV Intertie for voltage control. In the absence of an Intertie communication channel, reactor faults cannot be reliably cleared from the new substation near O'Neill substation. The reactor will therefore be provided with fuses for short-circuit protection and to facilitate disconnecting it from the line for maintenance purposes. Space will be provided for future addition of a reactor circuit breaker or circuit switcher. Intertie protection will be provided by stepped distance relays with built-in directional ground fault relays.

Oil containment will be provided for the reactors as well as for the relocated circuit breaker.

The new configuration will not fit within the existing substation fence (about 150 ft x 150 ft), but will be contained within the substation property lines as furnished by CVEA/Authority. It is estimated that the fence line will have to be moved about 55 ft to the west and about 15-20 ft on the north and south sides. The rebuilt substation will thus occupy an area of about 205 ft x 185 ft.

Outages required to rebuild the substation will have to be coordinated with diesel generator maintenance and periods of low hydropower generation. Due to these constraints, construction of the substation modifications should be scheduled for the fall.

No SVC is included in the design of Pump Station No. 11 modifications. See Section IV.B.1.c. for a discussion.



NOTES:


1. CIRCUIT SWITCHES SHOWN ARE INTERRUPT UNITS ONLY, WITH SEPARATE ISOLATION DISCONNECT SWITCHES.

LEGEND:

- CB CIRCUIT BREAKER
- CCVT COUPLING CAPACITOR VOLTAGE TRANSFORMER
- CS CIRCUIT SWITCHER
- LA LIGHTNING ARRESTER
- LT LINE TRAP
- PVT POWER VOLTAGE TRANSFORMER

FIGURE V-1
ALASKA ENERGY AUTHORITY
COPPER VALLEY INTERTIE
FEASIBILITY STUDY
SYSTEM ONE-LINE DIAGRAM


R.W. BECK
 AND ASSOCIATES



CCVT - CAPACITOR VOLTAGE TRANSFORMER
 PVT - POWER VOLTAGE TRANSFORMER
 LA - LIGHTNING ARRESTER

FIGURE V-2
ALASKA ENERGY AUTHORITY
COPPER VALLEY INTERTIE
FEASIBILITY STUDY
LAYOUT
NEW SUTTON SUBSTATION

R.W. BECK
 AND ASSOCIATES



PROJECT COST ESTIMATES

A. INTRODUCTION AND BACKGROUND**1. Introduction**

Pursuant to the Technical Review Meeting (TRM) of July 6, 1993, we were essentially directed to seek a least cost construction option for the Intertie, based on design criteria established at the meeting. Section IV presented these design criteria and discussed the various construction alternatives.

This section presents the assumptions, methodology, and results of the feasibility-level cost estimates for the various Intertie project alternatives. Project costs include all costs required to plan, develop, engineer, build, operate, and maintain the Intertie. Project costs are broken down into construction costs, engineering costs, owner costs, and operation/maintenance costs for discussion.

Three other studies have included a capital cost estimate for an Intertie between the Railbelt and CVEA in some form [1, 2, 6]. In two studies, the Intertie was a 230-kV link in a longer interconnection [2, 6]. Total capital cost estimates for the 230-kV Intertie links ranged from approximately \$48 million [2, Vol. 8A, p. XII-92, 1989] to \$61.6 million [6, for 155-mile line, 1982].

In the most recent study [1] a similar 138-kV configuration was estimated to have a total project development cost of slightly over \$40 million. The latter estimate was termed a "screening study" for the purposes of determining initial feasibility. Although we reviewed [1] in the course of this study, our scope required us to develop our estimate independently of any previous work. As discussed in this section we developed an estimating model using a different and independent approach from [1]. Furthermore, our cost estimates were prepared by transmission line engineers who did not participate in the economic analysis or cost estimates of alternative power sources.

Two very recent transmission line projects in South Central Alaska provide some basis for comparison with our cost estimates. These are the Bradley Lake Transmission Line (1992, X-frame design, 34 line-miles) and the Soldotna-Fritz Creek Project (1988-1991, wood H-frame, 65 line-miles). In addition, several transmission lines built in Alaska in the 1980's also provide a basis for comparison although the difference between them and the present Intertie are significant. These lines include the Tyee Lake 138-kV Transmission Line (82 miles total, steel X-frame construction, 1984), the Swan Lake 115-kV Transmission Line (30 miles total, wood H-frame on pile construction, 1983), the Terror Lake 138-kV Transmission Line (13 miles total, single steel pole construction with concrete pier foundations, 1985), and the Anchorage-Fairbanks 345-kV Intertie (170 miles, combination steel X-frame/single steel pole, 1985). The actual costs of these projects are compared to the cost estimate for this project later in this section.

2. Final Report Cost Estimate Adjustments - A Discussion

During the Draft Report review several comments were made on the report and its cost estimates. Design and cost assumptions were critiqued and possible cost item omissions were brought to the study team's attention. We did not modify any design or cost assumptions because we stand behind the

assumptions and the methods used to obtain them. Below we discuss ramifications to the cost estimate based on the possible omissions.

MEA commented that no land acquisition costs were included for State Mental Health, Native-Selected or Mat-Su Borough lands, nor is the cost of a right-of-way agent's services included. At \$1000/ac for land acquisition the total impact of these costs with 10% contingency would be approximately plus \$372,000 to the estimate. These costs have been added in the Final Report cost estimates.

No costs were included in the Draft Report for preparation of a full Environmental Impact Statement (EIS), under the assumption that an Environmental Assessment (EA) would result in a finding-of-no-significant-impact (FONSI). Review of the probable federal permits required for the Intertie and the level of public opposition to the Intertie has made it clear that an EIS will likely be required in fulfillment of the NEPA regulations, adding both time and money to the project. An EIS has been incorporated in the cost estimate at \$1.3 million (estimated range is \$775,000 to \$1,840,000) and in the project schedule. The effect of the \$1.3 million EIS with 10% contingency is to add \$1.43 million to the project development cost.

No explicit costs for litigation or condemnation proceedings have been included, although this is a real possibility if the project moves forward. We cannot estimate this cost with any confidence.

No cost for an SVC system is included based on CVEA operating the Intertie in such a way that it is severed from the Railbelt under Intertie power flow near the N-1 transfer limit during a N-1 event. Costs have been included for the CVEA diesel generation required to replace Intertie imports based on Intertie availability of 98%. No cost for a communication system end-to-end is included because of very marginal benefits.

There are many elements which could also push the cost estimate down by using less expensive equipment in the substations or fine-tuning transmission line design assumptions for instance. However, no adjustments to the transmission line or substation construction costs were implemented in the Final Report.

B. TRANSMISSION LINE CONSTRUCTION COST ESTIMATES

Construction costs cover all the material, labor, and equipment required to build the Intertie transmission line facilities. Engineering, construction management, and owner costs are treated separately. Overhead and profit are included.

1. Methodology

The following steps were taken to develop reliable feasibility level cost estimates:

a. Select Design Criteria

Design criteria were selected after review of assumptions in [1, 2, 6] and discussion with other line designers with experience in Alaska. After the TRM on July 6, 1993, final design criteria assumptions were adopted for guiding engineering analysis (see Section IV).

b. Preliminary Engineering

Using these design criteria, we performed preliminary engineering calculations in sufficient detail on seven construction options, three conductor options, and four loading zones to select preliminary material requirements such as structure dimensions and size, insulator strength and dimensions, and conductor size. Manufacturer engineering assistance was requested for wood H-frame structure alternatives, sag tension data for SSAC and EHS-core conductors, and steel X-frame structures.

c. Line Layout, Quantity Tabulations and Assumptions

Key line layout information was tabulated or estimated for each loading zone and each route alternative. Tabulated information included total line lengths, length of each loading zone, and distribution of line angles. For each combination of construction option, loading zone and conductor type, we determined a base height or length and size of structure, average span length and height distribution of structures. All this information was tabulated on spreadsheet UNITCOST.XLS and the various database files, e.g., DBSHF1.XLS. Height distribution on a preliminary optimization run in [1] was reviewed for a comparison and slight adjustments in the assumed height distributions were made. Preliminary quantities were developed from the foregoing and used to request budgetary quotes for material from suppliers.

d. Right-of-Way Costs

Right-of-way costs include the costs to clear and prepare the right-of-way, permit and acquire right-of-way easements, and rental of land.

(1) Right-of-Way Clearing Costs

Right-of-way clearing costs include the cost to fell and buck trees, treat slash, and grub a primitive road where allowable. Burning or chipping white spruce trees may be required west of Sheep Mountain if roller crushers are not feasible.

From large scale, color infrared aerial photography and photos taken during the aerial and ground reconnaissance, we estimated the percentage of each route segment which could be characterized by dense, medium, sparse or open forest cover. We assumed an average tree height and an average right-of-way width for each segment based on computations and observations. We computed the total right-of-way acres for each segment and, based on an assumption for clear-cut width (50 ft or 75 ft), we then computed the subtotal of acres to be cleared.

One of four types of clearing methods was assigned to each route segment and an estimated clearcut cost computed. Assumed costs and descriptions of those clearing methods are given in Table VI-1. We estimated a number of danger trees per each uncleared acre in the right-of-way and added in a cost to remove the danger trees. Finally, a cost to clear each route segment was computed and a total for each route alternative determined. A cost of \$1,500 per mile of open terrain was included to cover the costs of moving operations down the right-of-way.

ADNR commented, in its review of the Draft Report, that some commercial grade timber resources may exist in the easternmost 10-15 miles of the line route. Final determination of the extent and value of these resources would depend on a pre-clearing timber cruise. No cost for harvesting commercial grade timber or benefit from the sale of such timber is included in the cost estimate under the assumption that the timber would not be harvested if it were found financially unfeasible to do so.

We solicited comments from Red Carlos Contracting and met with Mr. Carlos in Seattle to discuss our methodology. Mr. Carlos assisted us with proposed clearing methods, timing and production rates.

Table VI-1
Right-of-Way Clearing Cost Assumptions

| <u>Clearing Method</u> | <u>Description</u> | <u>Unit Cost</u> |
|------------------------|--|------------------|
| 1 | Combination manual/machine clearing, high cost of slash treatment, with grubbed road, some burning | \$6,000/acre |
| 2 | Combination manual/machine clearing, minimal cost of slash treatment with grubbed road, no burning | \$5,000/acre |
| 3 | Not used | -- |
| 4 | Roller crusher, timber crushed and left | \$3,500/acre |
| 5 | Manual clearing for remote, spot situations by T-line contractor | \$4,000/acre |
| | Danger trees | \$75/each |

(2) Right-of-Way Permits

Dames & Moore provided a preliminary list of probable permitting requirements, permit application fees, and land rental fees. Costs to support and file permit applications were developed jointly with Dames & Moore. Costs to perform studies and conduct a full NEPA process to prepare an EIS were included. (See part A.2. earlier in this Section.)

(3) Right-of-Way Acquisition and Rental Fees

We discussed right-of-way easement acquisition costs with MEA right-of-way personnel and Land Field Services. An acquisition cost of \$1,000/acre was assumed for private parcels and native lands although the final acquisition cost will be based on fair market value appraisal. For our estimates we did not explicitly account for any condemnation proceedings, which would be a last resort. We assumed \$1,000/claim for unpatented mining claims in state and federal lands. MEA, with the assistance of Land Field Services, furnished a large scale map obtained from the Division of Mines in Fairbanks, showing large, 640-acre sections of mining claim set asides. Typical state and federal individual claims vary between 20 and 40 acres. No precise data on the number of individual claims was available and we estimated claims as 125, 20, 50, and 125 for route alternatives A, B, C, and D, respectively. The actual number of claims, if all tracts shown were fully allocated could be several hundred.

In addition to these costs we estimated that the services of a right-of-way agent for one year would cost about \$100,000. (See part A.2. earlier in this Section.) The right-of-way agent would be indispensable to the smooth prosecution of the project. The agent would prepare initial ownership lists, make initial contacts with landowners, coordinate permitting, obtain temporary agreements for survey, geotechnical and other field crews, perform appraisals and negotiate final easement agreements.

e. Request Material and Other Cost Quotes

Based on preliminary quantities we solicited cost quotes for major material delivered to Anchorage for wood structures and framing, conductors, steel structures, and miscellaneous items. Selected major material quotes are included in Appendix D for reference.

f. Develop Spreadsheets for Estimates

Exhibit references in this section are found in Appendix C.

To evaluate least-cost construction alternative estimates and our final least cost project development cost we prepared a custom, linked set of spreadsheets. Four unit cost estimate spreadsheets, e.g., COSTMOD1.XLS (see Exhibit C-1), were developed, one for each loading zone, to keep the size of files manageable and to allow links from all four to a summary sheet. Each COSTMODX.XLS spreadsheet has five construction item groups: structures, foundations, guys and anchors, framing, and conductor. The activities performed and included under each of these construction item groups is discussed briefly below.

(1) Structures

Structures are off-loaded in Anchorage (or Valdez) and moved to a central storage yard for control and packaging. Structures are packaged and delivered by truck to marshall yards located along the Glenn Highway. At the marshall yards the structures are assembled and framed by yard crews for transportation by helicopter to specific structure locations on the right-of-way. Alternatively, structure components could be flown in with assembly and framing in the field. This activity includes the actual ground crews employed to guide structure installation at each site and construction surveying to reestablish stakes.

(2) Foundations

Foundation material is purchased and received in the central storage yard. Foundation material is then bulk-packaged for truck delivery to marshall yards where foundation piles and other materials would be prepared for delivery to specific structure sites. Preparation in the marshall yards would include installation of pile tips and splices to obtain longer piles where known to be necessary, thus avoiding field splices. This task includes augering for direct embedment structures, installation of shoring material, driving piles, and construction surveying for the foundations.

(3) Guys and Anchors

Anchor and guy material are purchased and delivered to marshall yards. The material is delivered to structure sites. This item includes excavation for anchors, placement of anchors, and installation of structure guys. It also includes surveyor time for staking guys.

(4) Framing

This includes furnishing and installation of crossarm, crossbrace, insulators, grounding, and other miscellaneous assemblies. Only minimal labor is included for arms and braces because this logically would be done under structure assembly.

(5) Conductor

Under this item conductor is furnished and installed. This includes all stringing, sagging and clipping operations. Marker balls, vibration dampers and miscellaneous units associated with conductor installation are included.

The unit cost spreadsheets derive structure data (Group A) from one of seven database files, e.g., DBSHF1.XLS for type 1 steel, unbraced H-frame structures (see Exhibit C-2). A criteria range and extract range are set on COSTMODX.XLS and the database range is set externally to the database in one of the seven structure database files. Depending on conductor type and construction option input in the criteria range, the external database is searched for the appropriate structure type, height, quantity, size, and cost.

Material costs in COSTMODX.XLS are linked to UNITCOST.XLS (see Exhibit C-3) which, in turn, is linked to material take-off sheets, e.g., MATTEAL.XLS (see Exhibit C-4).

Installation costs were estimated based on a computation of crew sizes, crew hourly rates and crew productivity for each task. Crews were developed in spreadsheet CREWS.XLS (see Exhibit C-5) whose rates are fed to the COSTMODX.XLS unit cost estimate sheets. We estimated a normal number of crew hours for the installation of each material item and adjusted them for impacts due to height, winter or summer construction, etc. The assumptions, in the form of adjustment factors, are located above the crew designations in COSTMODX.XLS.

A summary cost sheet, SUMMARY.XLS (see Exhibit C-6) totals all construction costs by group over all four unit cost estimate sheets, one per loading zone, and pulls in costs for substations (Exhibit C-8), right-of-way clearing (Exhibit C-9), engineering design (Exhibit C-10), right-of-way land ownership (Exhibit C-11), and other costs via links to various other spreadsheets as indicated. SUMMARY.XLS computes a total project development cost for specific construction options in each loading zone and for a specific route alternative (A, B, C, or D). A tabulation of loading zone lengths is found in Exhibit C-12.

Exhibit C-7 gives a diagram showing the links between spreadsheets.

Table VI-2 shows a comparison of unit costs per mile for all construction options, loading zone and conductor combinations considered. The least cost alternative was estimated to be the steel H-frame, Type 1, unbraced structure (designation "ShF1") using Teal conductor in Loading Zones 1-3, and the braced steel structure (designation "ShF4") using 37#9AW in Loading Zone 4. This is similar to the construction assumed for most of the line in [1]. Table VI-2 indicates that several options are competitive for each loading zone within the accuracy limits of the estimates.

Table VI-2
Unit Cost Estimate Comparison
Transmission Line Construction Only
(\$1,000/mile units)⁽¹⁾⁽²⁾⁽³⁾

| <i>Options</i> \ <i>Conductor</i> | LOADING ZONE 1 | | | LOADING ZONE 2 | | | LOADING ZONE 3 | | | LOADING ZONE 4 | |
|-----------------------------------|----------------|-------------|-----------------|----------------|-------------|-----------------|----------------|-------------|-----------------|----------------|---------------|
| | <i>Dove</i> | <i>Teal</i> | <i>T2Linnet</i> | <i>Dove</i> | <i>Teal</i> | <i>T2Linnet</i> | <i>Dove</i> | <i>Teal</i> | <i>T2Linnet</i> | <i>Teal</i> | <i>37#9AW</i> |
| SSP-Single Steel Pole | 238K | 239K | 234K | | | | | | | | |
| SWP-Single Wood Pole | 294K | 276K | 314K | | | | | | | | |
| X-FrameGuyed Steel X-Frame | 253K | 247K | 251K | 272K | 270K | 267K | 293K | 292K | 292K | 475K | 430K |
| Shf1-Steel Unbraced H-Frame | 240K | 227K | 237K | 229K | 223K | 237K | 266K | 245K | 248K | 467K | 391K |
| Shf4-Steel Braced H-Frame | 259K | 235K | 257K | | | | 283K | 271K | 258K | 468K | 377K |
| Whf1-Wood Unbraced H-Frame | | | | 230K | 238K | 235K | | | | | |
| Whf4-Wood Braced H-Frame | 247K | 252K | 245K | | | | 278K | 255K | 267K | | |

(1) Includes mobilization/demobilization @ 5%, material contingency @ 10%, installation contingency @ 20%.

(2) Does not include right-of-way clearing costs.

(3) Unit costs based on Route Alternative D. *Shaded areas were not estimated.

g. Develop Labor Rates and Productivity

We obtained current NECA/IBEW total burdened labor rates from an Alaskan line contractor. We were informed that new contracts are being negotiated and that it would be prudent to assume some nominal increase in base wages. We discussed overhead, overtime, work week, and other cost assumptions with the line contractor in a meeting held October 1, 1993. They critiqued our crew sizes and manhour allocations per task. The cost estimating model was too detailed to discuss all assumptions, but per mile costs for major tasks on recent lines in Alaska were discussed. In conjunction with the meeting, CVEA suggested that it would help other parties review our work if per mile costs were computed in the SUMMARY.XLS file. We implemented this suggestion as well as a computation of manhours per task and loaded labor rate per task on the unit cost spreadsheets, COSTMODX.XLS.

h. Feasibility Cost Estimates

For each Intertie route alternative we prepared a detailed transmission line construction cost estimate. These are summarized in Table VI-4.

2. Cost Assumptions

Numerous assumptions form the basis for these feasibility-level estimates. Typical assumptions are contained in sample spreadsheets included in Appendix C, Exhibits 1-6. Key assumptions are discussed below for the major line components.

a. Structure Size and Type/Height Distribution

The distribution of structure types was selected based on measurement of major line angles for Route Alternatives A, B, C and D. Five structure types were selected for estimating with the approximate percentages shown as follows for Route Alternative A, steel H-frame, Teal conductor option:

| | | |
|--|------|-----------------------|
| Tangent Structure..... | 90% | |
| Light Angle 3-Pole Structure | 1.3% | |
| Medium Angle 3-Pole Structure..... | 2.6% | |
| Heavy Angle/Deadend 3-Pole Structure | 5.5% | |
| Long-Span, Deadend A-Frame Structure | 0.6% | (Loading Zone 4 only) |

Deviations from this percentage distribution will depend largely on the number of minor route changes late in the design phase. The dimensions and size of structures were determined in preliminary engineering (see Section IV for design criteria). Structure base heights were 50 ft to 85 ft typically.

Based on preliminary engineering computations an appropriate match of structure height/length and allowable span was determined for each construction/conductor/loading zone combination. This base height of structures was taken as a median value and two heights above (+10 ft and +20 ft) and below (-10 ft and -15 ft) the base were computed. In some cases where a very short base structure occurred, the shortest structure computed this way would violate code clearances at the structure itself. A minimum structure height test was applied to the computation of heights and the heights adjusted upward slightly.

The distribution of heights for Loading Zones 1, 3 and 4 was taken as 10%, 20%, 40%, 15% and 15% from shortest to tallest. For Loading Zone 2, where terrain is very level and predictable, the distribution was 5%, 15%, 60%, 15% and 5%, again shortest to tallest.

Costs for coastal Douglas Fir and Western Red Cedar wood poles and structure framing materials were obtained from manufacturers. Steel costs were discussed with a major supplier and were estimated between \$1.05 and \$1.20 per pound delivered to Anchorage depending on complexity of structure and size.

b. Foundations

For structures in muskeg and permafrost areas and for all X-frame structures, we assumed either 30-inch pipe pile at \$110/ft or 10 X 57 H-pile at \$80/ft. All other construction options were direct embedded either in soil or rock. Shoring at \$300 each in soil and at \$200 each in rock were included to maintain holes for structure installation at a later date.

c. Conductor

Conductor costs were obtained from two manufacturers. The basis for these budgetary quotes was slightly different, leading to greater costs from one manufacturer. We used the lower of the two costs. The estimating costs used were for regular, specular conductor. A price escalation factor of 10% was applied to aluminum costs on the aluminum content of one manufacturer's costs in accordance with its recommendations. We note, however, that there is current downward pressure on aluminum prices due to the recent high level of imports from the Commonwealth of Independent States (e.g., ex-Soviet Union). The costs used in the study estimates are: Dove ACSR @ \$0.92/lb., Teal ACSR @ \$0.97/lb., T2 Linnet ACSR @ \$1.03/lb., and 37#9 Alumoweld @ \$1.47/lb. Conductor length includes a 5% margin for sag, jumpers, and wastage.

d. Burdened Labor Rates

We obtained current union labor rates from an experienced Alaskan line contractor which applied to a recent Alaskan project including all fund contributions, payroll taxes and insurance. Rates for straight time, time and a half, and double time were obtained, as were average rates based on a work week of six 9-hour days and six 10-hour days. Using the six days, 9 hours per day work week, typical leveled current

hourly rates are: Journeyman Lineman @ \$49.38, Lineman Foreman @ \$52.71, and Groundman @ \$41.05 (equivalent to an Apprentice @ 80%).

Selling prices for labor were obtained by applying a 40% overhead, 15% profit, and a \$75/day per person subsistence allowance. Typical equipment was selected and assigned to each crew. Equipment rates were taken from Data Quest or helicopter operators. A total crew hourly cost was determined.

Overhead rates merit some discussion. Overhead covers bonding, insurance, field office operations including maintenance and surveillance, home office operations dedicated to the project, small tools and equipment, mark-up on subcontractors, and other miscellaneous operating expenses. Overhead rates vary typically from 30% to 50% depending on the nature of the project. High overhead rates would apply to projects with high material procurement components, a joint venture or many subcontractors, remote construction, or burdensome submittal and reporting requirements. The overhead rate on the Bradley Lake Transmission Line was reported close to 50% while other projects on the Kenai Peninsula were closer to 30%. We selected a median 40% overhead largely based on discussions with the prospective owner, CVEA, that streamlined contracting would be the rule but tempered by the fact that the rate would be pushed up if schedule and bonding requirements dictated a joint venture or multiple subcontracts.

e. Crews

Exhibit C-5 gives the make-up of crews, their rates, and short descriptions. This information was reviewed with an experienced line contractor in Alaska, and adjusted based on the line contractor's comments.

f. Miscellaneous Materials

Aerial marker balls (36" EHV type) were assumed at eight per span for ten spans in each loading zone, for the purpose of marking potential obstructions to air navigation across major streams and rivers. In addition, 24" EHV marker balls were assumed every 200' for 15% of the length of Loading Zone 2 for the purpose of mitigating the risk of trumpeter swan and other waterfowl collisions. It should be noted that we did not take into account any effect these marker balls would have on conductor sags or tensions. It is also noted here that CVEA has found aerial marker balls susceptible to breakage under suspected eccentric snow load and bum down. Alternative marking devices should be explored in final design.

g. Mobilization/Demobilization

A mobilization/demobilization rate of 5% was applied to the construction cost of the transmission line. For comparison, we show figures for the Bradley Lake, Tyee Lake, Swan Lake, and Intertie numbers:

**Table VI-3
Mobilization Costs**

| <u>Project</u> | <u>Total Cost of Construction⁽¹⁾</u> | <u>Cost of Mobilization/ Demobilization</u> | <u>Base of Operation</u> |
|----------------|---|---|---------------------------------|
| Bradley Lake | \$16,066,495 ⁽²⁾ | \$1,099,798 (6.9%) | Remote/Homer |
| Tyee Lake | \$20,111,889 ⁽³⁾ | \$1,100,000 (5.5%) | Wrangell, Bradfield, Petersburg |
| Swan Lake | \$15,576,367 ⁽⁴⁾ | \$1,190,108 (7.6%) | Ketchikan |
| Intertie | \$26,972,496 ⁽⁵⁾ | \$1,284,405 (5%) | Palmer/Glennallen |

(1) Excludes ROW clearing.

(2) Initial bid tabulation March 14, 1989.

(3) Based on final BID/Change Item Status March 15, 1984.

(4) Based on Change Order No. 15, October 5, 1983.

(5) Route Alternative D feasibility level cost estimate, December 1993, no contingency.

A figure of 5% was selected due to the relatively good access to the Intertie corridor via the Glenn Highway.

h. Contingency

Based on discussions and general consensus at the TRM, a contingency of 10% was placed on material costs and 20% on installation costs. There are many compelling reasons not to reduce these contingencies based on a feasibility-level design. First, a final route has not been selected and while we could fairly confidently predict the final length would fall in the range of 133 to 138 miles, it is probable that minor route or design adjustments will have to be implemented during the right-of-way acquisition and permitting phase. Second, final geotechnical survey data could end up increasing foundation costs. If soils turn out to be highly variable, many small structure relocations can be expected unless a very adaptable foundation plan is implemented. Third, competing Alaskan or Pacific Northwest line projects could create tight labor and/or material markets and drive up bids. Fourth, unforeseen weather conditions could lead to costly construction delays and missed timing construction windows for stream crossings. Fifth, it is not clear at this stage that removal of some commercial timber would not be required. If determined to be required by ADNR, it would add to costs although these costs would be offset by the commercial value of the timber sales. These and other reasons are ample justification for the contingency values used.

i. Spares and Structure Testing

No allowances for spare materials or structure tests are explicitly included in the cost estimate.

3. Feasibility Cost Estimates - Transmission Line Construction

Transmission line construction cost estimates only are presented in Table VI-4. These costs would be the combined sum of contractor bids for line construction and right-of-way clearing.

Table VI-4
Transmission Line Feasibility Level Construction Cost Estimates⁽¹⁾
Least Cost Option - All Route Alternatives⁽²⁾
(\$1993)⁽³⁾

| <u>Route Alternative</u> | <u>Transmission Line Estimated Construction Cost</u> |
|--------------------------|--|
| A | \$34,742,576 |
| B | \$35,575,209 |
| C | \$36,012,373 |
| D | \$34,112,928 |

- (1) Does not include engineering, construction management, permitting, right-of-way acquisition, owner's cost, or any costs related to substations.
(2) Based on least cost options identified for each Route Alternative.
(3) Includes 20% contingency on installation, 10% contingency on materials, and right-of-way clearing costs.

4. Transmission Line Cost Estimate Reasonableness

In addition to detailed checking of input assumptions and computations, the transmission line cost estimate should also be subjected to reasonableness tests (e.g. total manhours vs. schedule, final loaded labor rates, material/labor ratio, and construction cost breakdown) and comparison with historical line construction costs in Alaska.

a. Reasonableness Checks

(1) Total Labor Effort

We modified the cost estimate sheets to compute total estimated manhours to complete the Intertie. For Route Alternative D, using the unbraced steel H-frame design for most of the line, the total estimated labor effort is 136,000 person-hours. We consulted two line contractors for an estimate of effort to complete the Intertie, without divulging our estimate. These estimates varied widely from a high of 250,000 person-hours to 110,000-140,000 person-hours, the latter closely corroborating our estimate. The 110,000 ph effort represents about 815 ph/mile for a 135-mile line; this is considered efficient construction in the US outside of Alaska. For example a recent 30-mile wood pole 115-kV line along a railroad with significant guying requirements in Pennsylvania required about 50,000 ph over an 18-month period, or about 1,668 ph/mile.

Over a 20-month construction period, a 136,000 ph effort would require on average 6,800 ph/month. Based on six 9-hour days per workweek or about 238 ph/month-person, this effort would equate to about a 29-person full time construction team. This could represent a project management and support team of 10 (PM, time keeper, office assistant, resident construction engineer, equipment maintenance crews, material handling crews) and 3-4 construction crews ranging in size from 4-7 persons.

(2) Material/Labor Ratio

Given the high cost of labor and challenging construction environment in Alaska, material costs range from 33% to 50% and labor costs from 67% to 50% of total construction costs for typical Alaskan projects. For Route Alternative D, the total estimated material and labor costs, excluding right-of-way clearing, are \$11,517,296 and \$19,802,672 respectively for an M/L breakdown of 37%M/63%L which is in line with other Alaskan work.

(3) Loaded Labor Rates

The loaded labor rate includes all project construction cost elements such as direct and indirect salary, overhead, equipment rental and profit, and is computed by dividing total cost to complete a task by the number of hours devoted to the task. Loaded rates are computed in Exhibit C-1 and for Route Alternative D typically fall in the range \$105/hr-\$125/hr. The average loaded labor rate, calculated without contingency, is \$121/hr., which compares closely with a commonly used loaded labor rate of \$125/hr [1].

(4) Cost Breakdown and Comparison to Recent Alaskan Projects

It is useful to determine the percentage contribution of major cost components (i.e., structures and framing, foundations and anchors, and conductor) and compare them with other completed projects. For the purpose of comparison clearing costs have been excluded since they vary significantly. Table VI-5 below shows a comparison of the breakdowns for Swan Lake, Tyee Lake, Bradley Lake, and the Intertie estimate.

**Table VI-5
Construction Cost Comparison
Swan Lake, Tyee Lake and Intertie
% of Total (\$ million)**

| COST COMPONENT | SWAN LAKE LINE(1) (Entire Line) | TYEE LAKE LINE(2) (Overhead Portion) | BRADLEY LAKE LINE(3) | INTERTIE ROUTE(4) ALTERNATIVE D |
|----------------------------------|--|---|---|-------------------------------------|
| Mobilization/ Demobilization | 6% (0.8) | 4% (0.8) | 7% (1.1) | 5% (1.5) |
| Conductor | 20% (2.9) | 22% (4.4) | 22% (3.7) | 24% (7.6) |
| Structures & Framing | 33% (4.7) | 37% (7.3) | 37% (6.2) | 42% (13.5) |
| Foundation & Anchors | 41% (5.9) | 37% (7.3) | 34% (5.6) | 29% (9.5) |
| <i>Differing Characteristics</i> | Wood Pole H-Frame 336 Oriole/AW Significant Underbuild CFC Lands, Urban Portion | Tubular Steel X-Frame 556 Dove/AW, 37 No. AW | Tubular Steel X-Frame 556 AACSR Conductor No Clearing | Steel Pole H-Frame 605 Teal ACSR |

- (1) Based on Change Order No. 15, October 5, 1983, excluding clearing costs.
- (2) Based on Bid/Change Item Status, March 15, 1984, excluding clearing costs.
- (3) Based on initial construction bids, March 1989, excluding clearing costs.
- (4) Feasibility-level estimate October 1993, excluding contingencies.

b. Comparison of Historical Line Costs in Alaska

Reference [15] tabulated line costs on a per mile basis for some eighteen projects completed throughout Alaska starting in 1974. In their tabulation, the authors attempted to point out the very differ-

ent construction circumstances which affected the ultimate construction cost. We reformatted the table in [15], added the Bradley Lake and Soldotna-Fritz Creek projects, and applied two different escalation factors to adjust costs to 1993.

One escalation factor is derived from a weighted average of the cost indices for line-related categories (75% Towers & Fixtures and 25% Overhead Conductors & Devices) from the Handy-Whitman Index[16] for the Pacific Region of the US. This weighted index is applied directly to the actual historical construction cost to obtain an adjusted 1993 cost. Any special escalation factor for Alaskan work is assumed to be accounted for in the original historical cost. Costs were also escalated at a fixed annual rate of 5%.

Table VI-6 gives the results of this exercise and shows a wide range of costs for 115-kV and 138-kV construction, from \$93k/mile to \$983k/mile. The considerable variation in costs is due to the equally considerable variation in design, construction circumstances, level of right-of-way clearing and logging, use of helicopters for construction in remote or sensitive areas, and other factors. The total per mile estimated cost of the Intertie for Route Alternative D is about \$254k/mile including clearing and contingencies. The cost per mile varies according to loading zone between approximately \$240k/mile and \$400k/mile. The line mileage-weighted average of all 115-kV and 138-kV transmission lines in Table VI-6 is \$352k/mile based on escalation of costs at 5% and \$288k/mile based on escalation of costs using Handy-Whitman indices.

Based on Table VI-6 and considering the significant differences among the projects, the unit cost per mile for Route Alternative D is in line with historical costs and recent project costs for similar construction circumstances. Bradley Lake has been cited as representative of typical line costs in Alaska. It is not appropriate to compare Bradley Lake to the Intertie directly because of more extreme loading conditions, the type of structure (steel X-frame), expensive foundations, remote site requiring essentially all-helicopter construction, burdensome state reporting requirements, and other differences. There are several examples of lines built by utilities at 115-kV and 138-kV for far less, on the order of \$100k/mile to \$300k/mile, than Bradley Lake at \$530k/mile.

C. SUBSTATION CONSTRUCTION COST ESTIMATES

Construction costs cover all the material, labor and equipment required to build the substation facilities. Engineering, construction management and owner costs are treated separately. Overhead and profit are included.

1. Methodology

The following steps were taken to develop feasibility-level cost estimates.

a. Select Design Criteria

Design criteria in terms of switching arrangements were selected based on existing switching configurations, on reliability considerations, and CVEA preferences. Equipment ratings were selected based on system characteristics such as load levels and fault current levels.

b. Preliminary Engineering

Based on the selected switching configurations and other design criteria we performed basic engineering to determine equipment ratings, civil works estimates, substation size requirements and materials quantities.

c. Request Material Cost Quotes

For the estimated material quantities we solicited cost quotes from suppliers for major equipment such as the autotransformer, circuit breakers, disconnect switches, etc. The quotes included transport to Anchorage.

d. Develop Other Cost Components

Construction costs, local transport and storage costs, mobilization/demobilization costs, as well as overhead and profits were lumped together and added to the material costs.

The main basis for estimating these costs was the Means Electrical Cost Data 1993 and R.W. Beck and Associates' recent bidding experience. Civil works and major equipment costs were estimated separately.

e. Develop Spreadsheets for Estimates

The various cost components were entered into spreadsheets showing estimated material quantities, unit prices, and total costs. Total costs were computed for each substation alternative.

2. Cost Assumptions

Key assumptions affecting the cost estimates for the substations are discussed below.

a. Power Transformer and Shunt Reactor

We have assumed that an autotransformer rated 12/16/20 MVA OA/FA/FA will be used to interconnect the 115-kV and 138-kV systems. The transformer would be equipped with only no-load taps. The shunt reactor proposed for the Intertie is an oil-filled unit, rated 10 MVAR at 138 kV. No power transformer tertiary winding is available at Pump Station No. 11 Substation for connecting the reactor at medium voltage. No shunt reactor was included in Sutton, but may be necessary to allow CVEA to serve Sutton load.

b. Communication System

No communication link has been included between the new O'Neill Substation and Pump Station No. 11 Substation. This decision is based on CVEA's poor experience with existing power line carrier systems and on CVEA's desire to lower the overall initial cost of the Intertie. Although the lack of a communication link puts some limitation on the Intertie protective relay systems and may also complicate future operational issues, it is not absolutely necessary for the reliable operation of the Intertie.

c. Static VAR Compensator (SVC)

The PTI report, Volume 2, Appendix O, indicates that a SVC system would be a preferred system improvement to permit reliable Intertie power transfers in excess of 15 MW, the transfer limit for single

contingency (N-1) outage events in the Railbelt system. The -10 to +25 MVAR SVC at Dave's Creek on the Kenai Peninsula on the CEA system cost about \$5.6 million in 1992-93. This is approximately the size of SVC that would be required on the CVEA system.

Certain improvements to the Railbelt system, such as MEA upgrades to a 230-kV trunk system or reconductoring certain 115-kV lines, would appear necessary at some future point to correct low voltage and thermal limit problems on the MEA grid based on assumed study load growth and irrespective of the Intertie. These improvements could delay the need for a SVC. However, Intertie loading would also accelerate the need for the improvements to maintain reliability on the MEA system. It is also possible for CVEA and the Railbelt Utilities to operate the Intertie such that it is disconnected from the Railbelt during critical N-1 outage conditions on the Railbelt system during Intertie transfers in excess of the N-1 limit.

We have not included the cost of a SVC system in the project cost estimate because CVEA has expressed willingness to sever the Intertie for critical N-1 outage conditions in the Railbelt. If included, the cost of the SVC would appear as an O&M cost expenditure in roughly the year when 15 MW load transfer is forecast.

3. Feasibility Cost Estimates - Substation Construction

Total feasibility construction cost estimates for the new substation in Sutton and Pump Station No. 11 Substation are \$1,824,000 and \$1,794,000, respectively.

**Table VI-6
Tabulation of Historical Transmission Line Construction Costs**

| Project | Year | Voltage kV | Approx Length (mi) | Basic Structure Type | Project Description | | | | | | | Approximate Construction Cost/Mile (\$1000/ml) | Escalation Factor (Notes 1,2) | 1993 Adjusted Construction Cost/Mile (\$1000/ml) |
|---------|------|---------------|-----------------------|--|---|------------|-----------|------------|----------|--------------|------------|---|-------------------------------------|--|
| | | | | | Area | Terrain | Access | Helicopter | Clearing | Distribution | Hot Line | | | |
| 1 | 1976 | 115 | 17.7 | HPT-1 | MEA - Four Corners to Hering to Teeland | | | | | | | \$54 | 1.95 | \$105 |
| | | | | Wood Single Poles | Palmer | Roll/Flat | Excellent | No | No | Majority | yes | | | |
| 2 | 1979 | 115 | 3.9 | HPT-1 | MEA- LaZelle 115 IV Tap | | | | | | | \$57 | 1.62 | \$93 |
| | | | | Wood Single Pole | Wasilla | Roll/Flat | Excellent | No | Owner | Some | yes | | | |
| 3 | 1980 | 115 | 6.5 | STX-10 | MEA- Eagle River | | | | | | | \$95 | 1.44 | \$137 |
| | | | | Tubular Steel X-frame | Eagle Riv | Rolling | Very Good | Yes | Owner | No | No | | | |
| 4 | 1974 | 115 | 4.2 | TH-1A | MEA - Palmer to Four Corners | | | | | | | \$56 | 2.50 | \$141 |
| | | | | Wood H-frame | Palmer | Roll/Steep | Good | No | Owner | No | No | | | |
| 5 | 1977 | 115 | 20.5 | STX-10 | MEA - Teeland to Willow | | | | | | | \$71 | 1.86 | \$132 |
| | | | | Tubular Steel X-frame | Willow | Flat | Good | No | Owner | No | No | | | |
| 6 | 1982 | 115 | 30.5 | Wood | APA - Swan Lake Hydro Project | | | | | | | \$390 | 1.30 | \$505 |
| | | | | H-frame (25.5 mi) Single Steel Pole (5 mi) | Ketchikan | Rolling | poor (HF) | Yes | Yes/Log | Yes(5mi) | Yes (5 mi) | | | |
| 7 | 1976 | 138 | 12.5 | TH-10S | GVEA - T Line North to Fairbanks | | | | | | | \$81 | 1.95 | \$159 |
| | | | | Wood H-frame | Fairbanks | Flat | Excellent | No | Owner | No | No | | | |
| 8 | 1977 | 138 | 7.4 | TH-10S | GVEA - Johnson Road to Delta - Part 1 | | | | | | | \$68 | 1.86 | \$126 |
| | | | | Wood H-frame &Single Pole | Fairbanks | Roll/Steep | Excellent | No | Some | No | No | | | |
| 9 | 1977 | 138 | 24 | TH-10S | GVEA - Johnson Road to Delta - Part 2 | | | | | | | \$66 | 1.86 | \$123 |
| | | | | Wood H-frame | Fairbanks | Roll/Steep | Excellent | No | Some | No | No | | | |

Table VI-6 (continued)

| Project | Year | Voltage kV | Approx Length (mi) | Basic Structure Type | Project Description | | | | | | | | Approximate Construction Cost/Mile (\$1000/mi) | Escalation Factor (Notes 1,2) | 1993 Adjusted Construction Cost/Mile (\$1000/mi) |
|---------|-----------------|---------------|-----------------------|--|---|------------|-----------|------------|----------|--------------|----------|------------|---|-------------------------------------|--|
| | | | | | Area | Terrain | Access | Helicopter | Clearing | Distribution | Hot Line | Equipment | | | |
| 10 | 1974 | 138 | 26.2 | TX-10 AL X-Tower | CEA - Point McKenzie to Teeland | | | | | | | | \$65 | 2.50 2.53 | \$162 \$163 |
| | | | | | GooseBay | Flat | poor | yes | Yes | No | No | Heli/track | | | |
| 11 | 1979 | 138 | 55.8 | STX-138 Tubular Steel X-Tower | CVEA - Solomon Gulch to Glenallen Phase 1 | | | | | | | | \$112 | 1.62 1.98 | \$182 \$222 |
| | | | | | Glennallen | Fla/Hilly | TAP road | Yes | NA | No | No | Helicopter | | | |
| 12 | 1979 | 138 | 50.1 | STX-138 TH-10 | CVEA - Solomon Gulch to Glenallen Phase 2 | | | | | | | | \$229 | 1.62 1.98 | \$370 \$453 |
| | | | | | Valdez | Mountain | poor/TAP | Yes | NA | No | No | Helicopter | | | |
| 13 | 1982 | 138 | 68.2 | STX-E Tubular Steel | APA - Tyee Lake Hydro Project | | | | | | | | \$256 | 1.30 1.71 | \$332 \$438 |
| | | | | | Wrangell | Mountain | poor | Yes | Yes | No | No | Helicopter | | | |
| 14 | 1983 | 138 | 17.4 | Tubular Self-Supp Steel Poles | APA - Terror Lake Hydro Project | | | | | | | | \$603 | 1.25 1.63 | \$752 \$983 |
| | | | | | Kodiak | Mountain | poor | Yes | Minimal | No | No | Helicopter | | | |
| 15 | 1981 | 230 | 11 | Single SP 2-ckt | CEA - Fritz Creek to University Substation | | | | | | | | \$318 | 1.32 1.80 | \$421 \$571 |
| | | | | | Anchorage | Flat | Excellent | No | Some | No | No | Highway | | | |
| 16 | 1982 | 230 | 20.1 | STX-10 Aluminum X-Tower | CEA - Six Mile Line | | | | | | | | \$147 | 1.30 1.71 | \$190 \$251 |
| | | | | | Pt Mc-Sus | Flat | Good | No | Yes | No | No | NA | | | |
| 17 | 1983 | 345 | 97 | Tubular Steel X-Tower | APA - Anchorage to Fairbanks Intertie (South End) | | | | | | | | \$349 | 1.25 1.63 | \$434 \$568 |
| | | | | | Willow -Hur | Flat/Roll | Poor | NA | Yes | No | No | NA | | | |
| 18 | 1983 | 345 | 72 | Tubular Steel X-Tower | APA - Anchorage to Fairbanks Intertie (NorthEnd) | | | | | | | | \$346 | 1.25 1.63 | \$431 \$563 |
| | | | | | Hur-Healy | Flat/Mount | Poor | Some | Yes | No | No | Heli/Mix | | | |
| 19 | 1992 Assumed | 115 | 34 | Tubular Steel X-Tower | AEA - Bradley Lake Project | | | | | | | | \$505 | 1.05 1.05 | \$529 \$530 |
| | | | | | Kenai | Mountain | Poor | Yes | Not Incl | No | No | Heli/Mix | | | |
| 20 | 1991 Assumed | 115 | 60 Estimated | Wood H-frame | HEA - Soldotna - Fritz Creek Line | | | | | | | | 233 | 1.01 1.10 | \$236 \$257 |
| | | | | | Kenai | Roll/Flat | Fair | No | Not Incl | No | No | Mix | | | |

Notes

1. Based on an average of the Handy-Whitman Indices for categories Towers&Fixtures and Overhead Conductors&Devices for the Pacific Region and assuming 1993 = 1.00, times Alaska factor = 1.00
2. Factor on top is derived per Note 1, Factor on bottom is based on straight escalation at 5%

D. ENGINEERING COSTS

Engineering costs cover preliminary design and route selection, permitting support, surveying, geotechnical investigations, meteorological investigations, final engineering design, contract document preparation, bidding assistance, and construction phase technical assistance.

Geotechnical investigation costs were obtained from Dames & Moore (Exhibit F-1) and cover review of aerial photographs and alignment, helicopter and ground reconnaissance, a 50-bore hole drilling program (assuming boring frequency of one/two miles Sutton-Syncline Mountain and one/five miles Copper River Basin), a limited 25-line seismic survey, laboratory testing program, and final geotechnical report with foundation recommendations. It should be noted that no account was taken of potential seismic loads on structures as these loads typically do not control design.

Survey costs were estimated at \$10,000 per mile. This cost is based on discussions with two survey firms experienced in transmission line surveying. A detailed plan for surveying was furnished by G. E. Raleigh and Associates (Exhibit F-5). Survey tasks would include setting vertical and horizontal control, aerial photogrammetry, preparation of plan and profile drawings, centerline ground survey, property corner and monument ties, right-of-way clearing demarcation, and structure staking.

A meteorological survey is included at \$35,000 based on extensive discussions with Richmond Meteorological Consulting. We highly recommend such a study to assist value engineering efforts.

Substation engineering costs are estimated at \$350,500 total for both substations. This is approximately 10% of the total estimated construction cost of the substations. It includes preparation of a major equipment procurement contract, a construction contract for the substations, and special construction plan for the cutover at Pump Station 11 Substation.

Transmission line engineering costs are estimated at \$912,500 and include permitting support, subcontracts for survey, geotechnical and meteorological services, preparation of REA documents, final system studies, final design, and contracts for right-of-way clearing and construction. This cost represents about 2% of the total transmission line and clearing estimated costs of approximately \$40 million. This is a minimum level of engineering effort which basically reflects the economies of scale for a long line.

E. CONSTRUCTION MANAGEMENT COSTS

Construction management costs cover contract execution and administration, inspection services, change order control, testing and start-up, and construction records. Construction management costs are estimated at 5% of total construction costs.

For comparison, on the Tye Lake Project final engineering and construction management costs were 8% of total construction costs for a more complex project than the Intertie. On the Swan Lake Project, they represented about 14% of total construction costs, again for a more complex project. We estimate on the Swan Lake Project that construction management itself amounted to about 5% to 6% of total project costs. We were not able to obtain similar data for other projects.

F. PERMITTING COSTS

Permitting costs cover all scientific studies and engineering support, the actual costs of filing and obtaining all required permits. The permits which may be required for the Intertie are discussed briefly in Volume 2, Appendix N. Filing fees for each permit are nominal as reported by Dames & Moore, but costs for permit preparation, including attachments, will be substantially greater.

Permitting costs include an EIS and associated field studies, limited visual simulation studies, and preparation/support of required permits. The major permits likely to be required for an Intertie are a Mat-Su Conditional Use Permit for the Chickaloon Special Land Use District, a Title 16 Fish Habitat permit from ADF&G for crossing anadromous streams, a right-of-way permit from ADNR, possibly a Section 404 permit from COE for construction in wetlands, and an ASDOT-PF permit for state road crossings. It should be noted that construction of transmission lines in wetland areas may be covered by COE Nationwide Permit No. 12, requiring only that excavated materials be deposited in upland areas and that disturbed areas be revegetated. Winter construction and driven piles will minimize such disturbance. The total cost of permitting is estimated at \$340,000. It does not include any reimbursement of costs to permitting agencies for work done by their own staffs either for processing the permits or conducting field investigations. See part A.2. earlier in this section regarding an EIS.

G. OWNER COSTS

Owner costs include all costs incurred by CVEA for its own project staff and supporting independent services required to plan and manage the project. We estimated this cost at 3% of total project costs, including construction costs, engineering and construction management, and permitting. For comparison, on the more complex Tye Lake Project, owner costs were about 5.4% of total project costs. Our selection of 3% is based on CVEA's stated willingness to streamline its management of the project, by relinquishing a substantial portion of the burdensome requirements on similar state projects.

H. TOTAL PROJECT DEVELOPMENT COST ESTIMATES

Total feasibility-level project development cost estimates, including all costs to plan, permit, design and construct the Intertie, are summarized in Table VI-7 below.

Table VI-7
Total Intertie Development Cost Estimates
All Alternatives

| <u>Route Alternative</u> | <u>Total Development Cost Estimate⁽¹⁾</u> |
|------------------------------|--|
| A | \$48,342,000 |
| B | \$49,147,000 |
| C | \$49,607,000 |
| D | \$47,604,000 |

(1) Based on the least cost option identified at the feasibility-design level.

A breakdown of project development cost estimates for each alternative shown in Table VI-7 is given in Exhibit C-6.

I. OPERATION AND MAINTENANCE COSTS

1. Basic O&M Cost Estimate

Operation and maintenance (O&M) costs cover periodic inspection of the Intertie facilities, repair, replacement and maintenance activities, right-of-way vegetation management, dispatch operations for power transfer over the Intertie, any FERC, REA, APUC or other reporting requirements attributable to the Intertie, insurance on major equipment, and right-of-way rental fees. Contributions to an O&M contingency fund may also be included.

The O&M costs of the Tye Lake line from 1988 to 1991 averaged about \$330,000 or 1.1% per year [11]. For the Swan Lake line, O&M costs have fluctuated from about \$2,000 to \$48,000 per year, representing less than 0.3% maximum of construction costs for the line. Discussions with Homer Electric Association indicate O&M budgets between 0.5% and 1.0% of construction costs are appropriate for lines in its area. The expenditure level for O&M will increase when substation equipment is included and as the system ages. O&M expenditures also are a function of the responsible party's estimate of the inspection and maintenance frequency, and level of effort required.

For the purpose of this feasibility study a stream of annual O&M expenditures was estimated in current (1993) dollars over the 30-year assumed project life span, as shown in Table VI-8 for steel H-frame, Table VI-9 for wood construction, and Table VI-10 for steel X-frame construction.

State land rental fees could be on the order of \$100/acre-year, although according to ADNR this figure is negotiable. The various route alternatives will occupy approximately 1,400 to 1,660 acres, which could require an annual rental payment of \$140,000 to \$166,000 based on \$100/acre. This level of rental fee is not explicitly included in the O&M cost stream projected in Tables VI-8 to VI-10 although the \$75,000 miscellaneous expenses fund was meant to cover rental fees. Alaska statutes allow, but do not require, ADNR to waive rental fees for qualifying utilities, such as CVEA. CVEA has represented that they do not currently pay such fees.

2. Impact of Using Steel X-Frames on O&M Costs

X-frame structures are particularly forgiving in permafrost situations where frost action in active layers can differentially heave the foundations. The X-frame footing piles can probably be readily redriven and even lengthened without need to completely remove the structure. The problem of underestimated active layers can be comparatively inexpensively addressed. With effective remediation it is reasonable to expect that frost heaving problems would be largely eliminated over time or stabilize at a low level of occurrence.

Typical H-frame construction in permafrost areas would require expensive removal and temporary support of the H-frame structure to redrive pile footings. The H-frame would be typically attached to a welded pile cap or pole shoe which would have to be removed to add and drive more pile length, then reinstalled. We have given no thought to conceptualizing a detachable footing connection for the H-frame to facilitate correction of a frost heave situation. H-frame structures themselves do not handle differential jacking well and would be expected to suffer more damage than the X-frame.

To account for this difference we have assumed that three frost jack situations occur in each of the first twenty years and that the H-frames require two replacements through year 20 and one replacement per year thereafter while no replacements are required for the X-frame through year 20 and one every five years thereafter. Also we assume different costs for repair or replacement of the structures as given in Tables VI-8 and VI-10.

The X-frame further affords significant longitudinal strength to the line with longitudinal guying and inherent flexibility due to the use of guy-yoke designed to yield at a predetermined load. If properly designed, the X-frame construction will contain failures due to longitudinal unbalanced loads by yielding and relieving stress without failing. H-frame structures will depend on pole strength and bending moment resistance in the longitudinal direction or longitudinal guying to prevent cascading failures. There is no confident way to estimate the different impacts on O&M costs of these two construction methods and their response to longitudinal unbalanced loads of unpredictable severity.

Table VI-8
Annual Operation and Maintenance Costs
Steel H-Frame Construction Alternative
(1993 dollars)

| Years | Scheduled Full Line Inspections(1) | Unscheduled Line Inspections(2) | Climbing Inspections(3) | Wood Pole Test Program(4) | Repair Cost(5) | Replacement Cost(6) | Testing/Inspection(7) | Substation Repair(8) | Substation Equipment Replacement(9) | Right-of-Way Trimming(10) | Other Costs(11) | Total Annual O&M Cost |
|-------|------------------------------------|---------------------------------|-------------------------|---------------------------|----------------|---------------------|-----------------------|----------------------|-------------------------------------|---------------------------|-----------------|-----------------------|
| 1-4 | \$18,160 | \$3,950 | \$6,160 | n/a | \$17,880 | \$50,000 | \$24,000 | \$1,500 | -0- | \$10,000 | \$75,000 | \$206,650 |
| 5 | \$18,160 | \$3,950 | \$6,160 | n/a | \$17,880 | \$50,000 | \$99,000 | \$1,500 | -0- | \$10,000 | \$75,000 | \$281,650 |
| 6-9 | \$18,160 | \$3,950 | \$6,160 | n/a | \$17,880 | \$50,000 | \$24,000 | \$1,500 | -0- | \$10,000 | \$75,000 | \$206,650 |
| 10 | \$18,160 | \$3,950 | \$6,160 | n/a | \$17,880 | \$50,000 | \$99,000 | \$1,500 | -0- | \$10,000 | \$75,000 | \$281,650 |
| 11-14 | \$18,160 | \$3,950 | \$6,160 | n/a | \$29,800 | \$50,000 | \$24,000 | \$4,000 | -0- | \$10,000 | \$75,000 | \$221,070 |
| 15 | \$18,160 | \$3,950 | \$6,160 | n/a | \$29,800 | \$50,000 | \$99,000 | \$4,000 | \$50,000 | \$10,000 | \$75,000 | \$346,070 |
| 16-19 | \$27,240 | \$7,900 | \$12,320 | n/a | \$29,800 | \$50,000 | \$24,000 | \$4,000 | -0- | \$10,000 | \$75,000 | \$240,260 |
| 20 | \$27,240 | \$7,900 | \$12,320 | n/a | \$29,800 | \$50,000 | \$99,000 | \$4,000 | \$50,000 | \$10,000 | \$75,000 | \$365,260 |
| 21-24 | \$27,240 | \$7,900 | \$12,320 | n/a | \$47,680 | \$20,000 | \$24,000 | \$10,000 | -0- | \$10,000 | \$75,000 | \$234,140 |
| 25 | \$27,240 | \$7,900 | \$12,320 | n/a | \$47,680 | \$20,000 | \$99,000 | \$10,000 | \$300,000 | \$10,000 | \$75,000 | \$609,140 |
| 26-29 | \$27,240 | \$7,900 | \$12,320 | n/a | \$47,680 | \$20,000 | \$24,000 | \$10,000 | -0- | \$10,000 | \$75,000 | \$234,140 |
| 30 | \$27,240 | \$7,900 | \$12,320 | n/a | \$47,680 | \$20,000 | \$99,000 | \$10,000 | \$500,000 | \$10,000 | \$75,000 | \$809,140 |

- (1) Full line inspection costs two person days (8 hrs/day, \$70/hr), helicopter at \$650/hr for 8 hours, for \$9,080/inspection; two inspections/yr for years 1-15, three inspections/yr for years 16-30.
- (2) Unscheduled (outage) inspection costs 10 person-hours at \$70/hr, helicopter at \$650/hr for 5 hours, for \$3,950/inspection; one inspection/yr for years 1-15, two inspections/yr for years 16-30.
- (3) Climbing inspections at 1 person-hour/structure, including transportation time, 8 structures per day per lineman, 2 linemen per trip at \$60/hr, helicopter at \$650/hr and 8 hrs/16 structures; 16 structure inspections/yr for years 1-15 at an annual cost of \$6,160 and 32 inspections/yr for years 16-30 at an annual cost of \$12,320.
- (4) Based on discussions with utilities in South Central Alaska wood pole decay is rare and wood pole inspection and testing programs are not required as a rule.
- (5) Includes all costs allocated to actual repair of existing facilities, such as broken insulators, downed conductors, damaged marker balls, jacked foundations, loose guys, etc. O&M costs assumed at \$1,000 material/structure, 16 person-hours/structure at \$60/hr, helicopter and other equipment at \$1,000/hr, 4 hrs per structure, three structures/yr for years 1-10 for an annual cost of \$17,880, five structures/yr for years 11-20 (\$29,800), eight structures/yr for years 21-30 (\$47,680).
- (6) Replacement cost is for replacing a structure and framing. Cost to replace a steel structure and transfer wires is assumed to be \$25,000. Two replacements per year are assumed for years 1-20 and one per year thereafter.
- (7) Monthly testing/inspection of new Sulton Substation and expansion of Pump Station No. 11 Substation equipment at \$750/mo or \$9,000/yr. Annual inspection/testing at \$15,000/yr. Major testing by outside firm assumed every five years at \$75,000/yr for both substations.
- (8) Repair of substation equipment assumed at \$1,500/yr for years 1-10, \$4,000/yr for years 11-20, \$10,000/yr for years 21-30.
- (9) Replacement assumed at \$50,000 in years 15 and 20, at \$300,000 in year 25, and \$500,000 in year 30.
- (10) Right-of-way trimming and vegetation management costs assumed at two person-weeks for 80 person-hours @ \$60/hr plus equipment and subsistence for total estimate of \$10,000/yr.
- (11) Other costs include contributions to an O&M contingency fund, equipment insurance, reporting requirements linked to operation of the Intertie, and miscellaneous costs (level cost assumed at \$75,000/yr).

Table VI-9
Annual Operation and Maintenance Costs
Wood Construction Alternative
(1993 dollars)

| Years | Scheduled Full Line Inspections(1) | Unscheduled Line Inspections(2) | Climbing Inspections(3) | Wood Pole Test Program(4) | Repair Cost(5) | Replacement Cost(6) | Testing/Inspection(7) | Substation Repair(8) | Substation Equipment Replacement(9) | Right-of-Way Trimming(10) | Other Costs(11) | Total Annual O&M Cost |
|-------|------------------------------------|---------------------------------|-------------------------|---------------------------|----------------|---------------------|-----------------------|----------------------|-------------------------------------|---------------------------|-----------------|-----------------------|
| 1-4 | \$18,160 | \$3,950 | \$6,160 | -0- | \$22,840 | \$30,000 | \$24,000 | \$1,500 | -0- | \$10,000 | \$75,000 | \$191,610 |
| 5 | \$18,160 | \$3,950 | \$6,160 | -0- | \$22,840 | \$30,000 | \$99,000 | \$1,500 | -0- | \$10,000 | \$75,000 | \$266,610 |
| 6-9 | \$18,160 | \$3,950 | \$6,160 | -0- | \$22,840 | \$30,000 | \$24,000 | \$1,500 | -0- | \$10,000 | \$75,000 | \$191,610 |
| 10 | \$18,160 | \$3,950 | \$6,160 | -0- | \$22,840 | \$30,000 | \$99,000 | \$1,500 | -0- | \$10,000 | \$75,000 | \$266,600 |
| 11-14 | \$18,160 | \$3,950 | \$6,160 | -0- | \$34,260 | \$30,000 | \$24,000 | \$4,000 | -0- | \$10,000 | \$75,000 | \$205,530 |
| 15 | \$18,160 | \$3,950 | \$6,160 | -0- | \$34,260 | \$30,000 | \$99,000 | \$4,000 | \$50,000 | \$10,000 | \$75,000 | \$330,530 |
| 16-19 | \$27,240 | \$7,900 | \$12,320 | -0- | \$34,260 | \$30,000 | \$24,000 | \$4,000 | -0- | \$10,000 | \$75,000 | \$224,720 |
| 20 | \$27,240 | \$7,900 | \$12,320 | -0- | \$34,260 | \$30,000 | \$99,000 | \$4,000 | \$50,000 | \$10,000 | \$75,000 | \$349,720 |
| 21-24 | \$27,240 | \$7,900 | \$12,320 | -0- | \$45,680 | \$15,000 | \$24,000 | \$10,000 | -0- | \$10,000 | \$75,000 | \$277,140 |
| 25 | \$27,240 | \$7,900 | \$12,320 | -0- | \$45,680 | \$15,000 | \$99,000 | \$10,000 | \$300,000 | \$10,000 | \$75,000 | \$652,140 |
| 26-29 | \$27,240 | \$7,900 | \$12,320 | -0- | \$45,680 | \$15,000 | \$24,000 | \$10,000 | -0- | \$10,000 | \$75,000 | \$277,140 |
| 30 | \$27,240 | \$7,900 | \$12,320 | -0- | \$45,680 | \$15,000 | \$99,000 | \$10,000 | \$500,000 | \$10,000 | \$75,000 | \$852,140 |

- (1) Full line inspection costs two person days (8 hrs/day, \$70/hr), helicopter at \$650/hr for 8 hours, for \$9,080/inspection; two inspections/yr for years 1-15, three inspections/yr for years 16-30.
- (2) Unscheduled (outage) inspection costs 10 person-hours at \$70/hr, helicopter at \$650/hr for 5 hours, for \$3,950/inspection; one inspection/yr for years 1-15, two inspections/yr for years 16-30.
- (3) Climbing inspections at 1 person-hour/structure, including transportation time, 8 structures per day per lineman, 2 linemen per trip at \$60/hr, helicopter at \$650/hr and 8 hrs/16 structures; 16 structure inspections/yr for years 1-15 at an annual cost of \$6,160 and 32 inspections/yr for years 16-30 at an annual cost of \$12,320.
- (4) A wood pole test program would cover the cost of a specialized firm to test wood poles for residual strength and signs of decay and prescribe remedial action. Based on discussions with utility personnel, South Central Alaska is a favorable climate for wood poles and pole inspection programs are not required.
- (5) Includes all costs allocated to actual repair of existing facilities, such as broken insulators, downed conductors, damaged marker balls, jacked foundations loose guys, etc. O&M costs assumed at \$750 material/structure, 16 person-hours/structure at \$60/hr, helicopter and other equipment at \$1,000/hr, 4 hrs per structure, four structures/yr for years 1-10 for an annual cost of \$22,840, six structures/yr for years 11-20 (\$34,260), eight structures/yr for years 21-30 (\$45,680).
- (6) Replacement cost is for replacing a structure and framing. Cost to replace a wood structure and transfer wires is assumed to be \$15,000. Two replacements/yr for years 1-20 for a total of \$30,000/yr is assumed; for years 21-30, one replacement/yr for a total of \$15,000/yr is assumed.
- (7) Monthly testing/inspection of new Sutton Substation and expansion of Pump Station No. 11 Substation equipment at \$750/mo or \$9,000/yr. Annual inspection/testing at \$15,000/yr. Major testing by outside firm assumed every five years at \$75,000 /yr for both substations.
- (8) Repair of switchyard equipment assumed at \$1,500/yr for years 1-10, \$4,000/yr for years 11-20, \$10,000/yr for years 21-30.
- (9) Replacement assumed at \$50,000 in years 15 and 20, at \$300,000 in year 25, and \$500,000 in year 30.
- (10) Right-of-way trimming and vegetation management costs assumed at two person-weeks for 80 person-hours @ \$60/hr plus equipment and subsistence for total estimate of \$10,000/yr.
- (11) Other costs include contributions to an O&M contingency fund, equipment insurance, reporting requirements linked to operation of the Intertie, and miscellaneous costs (level cost assumed at \$75,000/yr).

Table VI-10
Annual Operation and Maintenance Costs
Steel X-Frame Construction Alternative
(1993 dollars)

| Years | Scheduled Full Line Inspections ⁽¹⁾ | Unscheduled Line Inspections ⁽²⁾ | Climbing Inspections ⁽³⁾ | Wood Pole Test Program ⁽⁴⁾ | Repair Cost ⁽⁵⁾ | Replacement Cost ⁽⁶⁾ | Testing/Inspection ⁽⁷⁾ | Substation Repair ⁽⁸⁾ | Substation Equipment Replacement ⁽⁹⁾ | Right-of-Way Trimming ⁽¹⁰⁾ | Other Costs ⁽¹¹⁾ | Total Annual O&M Cost |
|-------|--|---|-------------------------------------|---------------------------------------|----------------------------|---------------------------------|-----------------------------------|----------------------------------|---|---------------------------------------|-----------------------------|-----------------------|
| 1-4 | \$18,160 | \$3,950 | \$6,160 | n/a | \$15,690 | -0- | \$24,000 | \$1,500 | -0- | \$10,000 | \$75,000 | \$154,460 |
| 5 | \$18,160 | \$3,950 | \$6,160 | n/a | \$15,690 | -0- | \$99,000 | \$1,500 | -0- | \$10,000 | \$75,000 | \$229,460 |
| 6-9 | \$18,160 | \$3,950 | \$6,160 | n/a | \$15,690 | -0- | \$24,000 | \$1,500 | -0- | \$10,000 | \$75,000 | \$154,460 |
| 10 | \$18,160 | \$3,950 | \$6,160 | n/a | \$15,690 | -0- | \$99,000 | \$1,500 | -0- | \$10,000 | \$75,000 | \$229,460 |
| 11-14 | \$18,160 | \$3,950 | \$6,160 | n/a | \$26,150 | -0- | \$24,000 | \$4,000 | -0- | \$10,000 | \$75,000 | \$167,420 |
| 15 | \$18,160 | \$3,950 | \$6,160 | n/a | \$26,150 | -0- | \$99,000 | \$4,000 | \$50,000 | \$10,000 | \$75,000 | \$292,420 |
| 16-19 | \$27,240 | \$7,900 | \$12,320 | n/a | \$26,150 | -0- | \$24,000 | \$4,000 | -0- | \$10,000 | \$75,000 | \$186,610 |
| 20 | \$27,240 | \$7,900 | \$12,320 | n/a | \$26,150 | -0- | \$99,000 | \$4,000 | \$50,000 | \$10,000 | \$75,000 | \$311,610 |
| 21-24 | \$27,240 | \$7,900 | \$12,320 | n/a | \$41,840 | \$20,000 | \$24,000 | \$10,000 | -0- | \$10,000 | \$75,000 | \$208,300 |
| 25 | \$27,240 | \$7,900 | \$12,320 | n/a | \$41,840 | \$20,000 | \$99,000 | \$10,000 | \$300,000 | \$10,000 | \$75,000 | \$603,300 |
| 26-29 | \$27,240 | \$7,900 | \$12,320 | n/a | \$41,840 | \$20,000 | \$24,000 | \$10,000 | -0- | \$10,000 | \$75,000 | \$208,300 |
| 30 | \$27,240 | \$7,900 | \$12,320 | n/a | \$41,840 | \$20,000 | \$99,000 | \$10,000 | \$500,000 | \$10,000 | \$75,000 | \$803,300 |

- (1) Full line inspection costs two person days (8 hrs/day, \$70/hr), helicopter at \$650/hr for 8 hours, for \$9,080/inspection; two inspections/yr for years 1-15, three inspections/yr for years 16-30.
- (2) Unscheduled (outage) inspection costs 10 person-hours at \$70/hr, helicopter at \$650/hr for 5 hours, for \$3,950/inspection; one inspection/yr for years 1-15, two inspections/yr for years 16-30.
- (3) Climbing inspections at 1 person-hour/structure, including transportation time, 8 structures per day per lineman, 2 linemen per trip at \$60/hr, helicopter at \$650/hr and 8 hrs/16 structures; 16 structure inspections/yr for years 1-15 at an annual cost of \$6,160 and 32 inspections/yr for years 16-30 at an annual cost of \$12,320.
- (4) Based on discussions with utilities in South Central Alaska wood pole decay is rare and wood pole inspection and testing programs are not required as a rule.
- (5) Includes all costs allocated to actual repair of existing facilities, such as broken insulators, downed conductors, damaged marker balls, jacked foundations, loose guys, etc. O&M costs assumed at \$750 material/structure, 8 person-hours/structure at \$60/hr, helicopter and other equipment at \$1,000/hr, 4 hrs per structure, three structures/yr for years 1-10 for an annual cost of \$15,690, five structures/yr for years 11-20 (\$26,150), eight structures/yr for years 21-30 (\$41,840).
- (6) Replacement cost is for replacing a structure and framing. Cost to replace a steel structure and transfer wires is assumed to be \$20,000. No replacements are assumed for years 1-10. Steel X-frame structure replacements will be at a rate of one every five years starting in year 21.
- (7) Monthly testing/inspection of new Sutton Substation and expansion of Pump Station No. 11 Substation equipment at \$750/mo or \$9,000/yr. Annual inspection/testing at \$15,000/yr. Major testing by outside firm assumed every five years at \$75,000 /yr for both substations.
- (8) Repair of substation equipment assumed at \$1,500/yr for years 1-10, \$4,000/yr for years 11-20, \$10,000/yr for years 21-30.
- (9) Replacement assumed at \$50,000 in years 15 and 20, at \$300,000 in year 25, and \$500,000 in year 30.
- (10) Right-of-way trimming and vegetation management costs assumed at two person-weeks for 80 person-hours @ \$60/hr plus equipment and subsistence for total estimate of \$10,000/yr.
- (11) Other costs include contributions to an O&M contingency fund, equipment insurance, reporting requirements linked to operation of the Intertie, and miscellaneous costs (level cost assumed at \$75,000/yr).

PROJECT SCHEDULE

The following section on project schedule was prepared for the Draft Feasibility Report and was based on completion of the NEPA process through an Environmental Assessment. Completion of a full Environmental Impact Statement (EIS) and other schedule factors could delay this schedule by approximately one to two years. Some schedule could be regained by committing sufficient resources and performing certain tasks in parallel. A project schedule assuming the full EIS was briefly investigated and its estimated completion date was in late 1999.

A preliminary schedule for total project implementation is shown in Figure VII-1. This schedule was developed based on other project experience in Alaska and the project organization described below. We believe the schedule is practical, though it depends on many assumptions and, above all, careful planning for an accelerated schedule.

If funding to pursue a project EIS and other permitting is authorized in July 1994, we estimate completion of the Intertie in the fall of 1998.

Each major project phase, its duration, and relationship to other phases are shown in Figure VII-1. Further elaboration of project schedule phases and assumptions follows.

A. PROJECT DEVELOPMENT ORGANIZATION

The project can be organized and managed in four basic ways, namely (1) CVEA acts as the project manager, (2) CVEA contracts externally for project manager, (3) a turnkey design and construct project, or (4) a combination of the above depending on project phase.

The project schedule is based on (2) above where CVEA contracts for a project manager but retains some oversight control over the project. The four alternative project organization methods are discussed below.

1. CVEA Acts as Project Manager

Under this option CVEA would maintain management of the project and would contract with several entities for the permitting, design and construction of the project. As project manager CVEA would then retain control and the entities selected would have the best qualifications for the different stages of project work. These entities would each be accountable to CVEA.

This approach provides the greatest degree of input and control for CVEA and would tend to have more distinct decision points for the project. However, CVEA would have greater administrative and project management responsibilities that would require staff additions and more staff time. Since several contracts would be involved for outside services, the project schedule would be longer for this option.

2. CVEA Contracts Externally for Project Manager

Under this option CVEA would contract with a single entity for the management, permitting, design and construction of the project. This project manager (PM) would then be responsible for progress on the project and would maintain project records and books for allocation of costs. The PM would perform some project duties directly and in turn would likely utilize subcontracts for services which may be outside of PM area of expertise, such as environmental, right-of-way acquisition, and possibly design.

Advantages of this option are several. Utilizing PM would relieve CVEA staff of majority of time commitment to the project. Use of single contract for PM may slightly shorten the project development schedule since many services will be obtained/negotiated by PM which may streamline the formal RFP-Proposal-Selection process and time associated with this for each subcontract.

This option may also allow some concurrent prosecution of project tasks such as environmental, permitting and conceptual design provided PM has all of these capabilities in-house or under contract.

Disadvantages are also manifold. CVEA's direct involvement is limited and this insulation may decrease input or control of decisions. CVEA has expressed a preference for controlling independent inspection during construction. Typically, the multiple stages of the RFP-Proposal-Selection process provides more flexibility and some additional cost control. If schedule acceleration is warranted it may not be identified as soon as if CVEA acts as PM. In the event that the individual acting as PM is changed and a new PM is acquired the project could suffer since the new PM would be lacking much knowledge about the early stages of the project and CVEA staff would have also been isolated from the project. If an external entity were to serve as PM, this may add another layer of costs to the project.

3. Turnkey (Design/Build)

Under this option CVEA would contract with a single entity for the design, construction, and energization of the project. The prime would likely be the construction contractor. The contractor would perform the material procurement and construction and in turn would likely utilize subcontracts for services which may be outside of the contractor's area of expertise, such as surveying, geotechnical investigations, and design.

The primary advantage of this type of contract is ability to compress/accelerate schedule. If a detailed bid document can be developed, this approach may provide the best estimate of the total development cost for the project at the earliest point in the project. It is expected that a turnkey contract would be issued after environmental and permitting work is complete.

In the way of disadvantages, this type of contract is typically more difficult or costly to suspend if CVEA chooses to change approach. Importantly, CVEA would have limited input to decisions.

4. Hybrid - CVEA as Project Manager & Turnkey (Design/Build)

Under this option CVEA would manage the project through the permitting and conceptual design stage to fully define the project requirements and would then contract with a single entity for the design, construction, and energization of the project.

This approach provides the best opportunity for schedule acceleration at some mid-point of the project. This approach provides for a relatively firm cost for the project at about a third of the way through the project effort.

The disadvantages of this approach are basically the same as described for the turnkey contract in 3. above.

B. SCHEDULE ASSUMPTIONS

Many assumptions underlie the project development schedule in Figure VII-1. These are discussed below.

1. Project Financing

The feasibility study in final form is assumed to be issued March 31, 1994. Assuming feasibility is demonstrated, a plan of finance would have to be prepared. It is not clear at this stage how the balance of financing would be obtained nor how long that would take. It is assumed though that the state would release funds set aside for the Intertie by July 15, 1994 and that this would not depend on securing the balance of financing.

2. Environmental Assessment

In our schedule, it is assumed that if feasibility is shown, CVEA will undertake on its own to complete an EA. It is recommended that the draft feasibility study with environmental report be distributed to key permitting agencies for their detailed review. It is estimated that completion and processing of the EA would take five to six months. It has also been suggested that the EA work should be timed so that permitting agencies can schedule any required field work for summer 1995. The REA Borrower's Environmental Report would be prepared after the EA and is assumed to take one month.

Based on discussions at the agency meeting on March 17, 1993, it appears that an EIS will not be required although this cannot be guaranteed until the EA is actually ruled on. See Section VI, part A.2., regarding an EIS. If an EIS is required, the schedule may be delayed.

3. Permitting

At a minimum, permits from the Alaska Department of Natural Resources, Alaska Department of Fish and Game, Alaska Department of Transportation and Public Facilities, U.S. Army Corps of Engineers, Bureau of Land Management, and the Matanuska-Susitna Borough will be required.

Careful preparation of construction plans using best management practices and mitigation measures should facilitate permitting. It is assumed that this process would begin in late spring 1995 and take nine months, with completion in December 1995.

The most difficult permit to obtain would appear to be the Conditional Use Permit for the Chickaloon Special Land Use District (CSLUD) within the jurisdiction of the Matanuska-Susitna Borough. The

Chickaloon Community Plan, which sets out the prohibited and conditional land uses for the CSLUD, specifically lists power lines in the latter category. There appears no way to route the Intertie so as to completely avoid the CSLUD and a CUP will have to be submitted to the Matanuska-Susitna Planning Commission which would approve or disapprove the CUP. There is no indication that a CUP would be disapproved if all reasonable efforts are taken to reduce adverse impacts.

4. Right-of-Way Easement Acquisition

We assume right-of-way easement acquisition would be handled by a right-of-way agent. It would begin during the late stages of the EA work, in winter 1995, with compiling land owner lists for a selected route corridor. Initial owner contacts would be made and temporary access agreements obtained to allow entry of survey and geotechnical crews. Detailed review of unpatented mining claims would be made. It is assumed that right-of-way acquisition would be completed within sixteen months, by May 1996. This should occur before clearing contracts could be issued although limited clearing contracts could be considered for significant, contiguous lengths of right-of-way. No condemnation proceedings have been accounted for, although they may be required.

5. Preliminary Design

The preliminary design phase includes aerial surveys, geotechnical investigations, final route selection, support of permitting, value engineering, final system and switching studies, meteorological study, and plan/profile preparation.

The final route alignment is assumed to be selected prior to the EA work, by September 1994.

Aerial surveys are assumed to take place July-October 1995 after selection of the final route. Late spring has been suggested as the best time for an aerial survey but this cannot be accommodated, in our view, before the assumed time. Geotechnical studies and a foundation report are shown taking place in winter/spring 1996. It is possible that some borings could take place in summer/fall 1995 to accelerate schedule but this would depend highly on the status of right-of-way acquisition. Preparation of plan and profile drawings and strip drawings for right-of-way clearing contracts would be prepared over seven months with completion by May 1996. System studies and meteorological studies would be completed in winter/spring 1995, and do not control the schedule.

6. Final Design

This includes final line and substation design, drawing and plan preparation, procurement and construction contracts, and centerline surveys. This phase can begin during preparation of the plan and profile drawings but cannot end until after the geotechnical report is issued. It is assumed that final design will take about 13 months and be completed by the end of December 1996. If survey and geotechnical work can be accelerated, there may be room for accelerating final design.

7. Contracts

Five contracts have been assumed for this project, although more may be necessary to attract competitive bids. A three-month bid period, i.e., between advertisement and notice of award, is assumed for each contract.

A substation major equipment procurement contract would be awarded in December 1996 with completion of delivery by September 1997.

The material supply contracting and actual supply are assumed to extend about 13 months total. Included in a separate contract would be substation equipment, including the power transformer, circuit breakers, circuit switchers, disconnect switches, line traps and instrument transformers, and pre-wired control building. Estimated lead times for major items are as follows:

| Item | Lead Time (ARO) |
|--|-----------------|
| Power Transformer..... | 44 weeks |
| Switchgear | 34 weeks |
| Conductor | 24 weeks |
| Wood Poles | 24 weeks |
| Steel Structures (including Shop Drawing Review)..... | 24-30 weeks |

The substation construction contract would be awarded in spring 1997 allowing for completion of civil works at the substations by fall when CVEA has indicated it would be preferable to take an outage for equipment installation at Pump Station 11 Substation. The substation work as shown could be completed under the above scenario about one year ahead of the Intertie; it is not on the critical path. Completion of work on the substations could also be delayed until fall 1998.

One clearing contract with three schedules or multiple clearing contracts would be required to make schedule. This would be awarded in September 1996 and take an assumed seven months to complete. Discussions with Red Carlos Contracting indicated that use of roller crushers east of Little Nelchina River during the winter would be the most efficient and least costly clearing method if allowed by ADNR and BLM. The Ahtna Native Corporation has indicated that it wants to perform the clearing work for right-of-way on its lands, about 13 miles. In the Matanuska River Valley, a combination of manual and machine clearing would be used and would also be completed by May 1997.

Two transmission line construction contracts or a single contract with multiple schedules are planned. It does not appear that local Alaskan contractors alone could support the bonding requirements of the full project. The contract(s) would be awarded in spring 1997.

It is suggested that the line contract(s) be of the furnish-and-install variety. The contractor(s) would furnish structures and conductor by December 1997. Driving the schedule are the requirements to set foundations in Loading Zone 2 in the winter and to string conductor from late spring to early fall. To achieve energization by fall 1998, two sets of foundation crews are assumed to complete Zones 1, 3 and 4 by November 1997 when they can be merged to complete Zone 2 by April 1998. Structure installation by

helicopter is scheduled for a two-month period ending in late May 1998. Conductor stringing would be accomplished by two separate sets of crews in a period of five months ending by October 1998.

8. Energization Date

We estimate an energization date of December 31, 1998 for a total project development time of about five years.

C. PROJECT SCHEDULE COMPARISONS

It has been assumed that CVEA would contract an engineering firm to (1) support the EA and permitting processes, (2) execute final design and, later, construction management, (3) coordinate all specialized services such as surveying and geotechnical investigations, and (4) prepare material and construction contracts. Under this scenario, it is assumed that a period of 30 months would be required for engineering up to a notice-to-proceed (NTP) for construction. By comparison, and recognizing that major hydroelectric facilities were involved, similar phases for the shorter Tyee Lake and Swan Lake projects took 27 and 23 months, respectively.

The construction phase is assumed to last 19 months, commencing with mobilization in March 1997. Foundation and anchor construction is assumed to take place mostly from spring 1997 to winter 1998 over a 12-month construction season, with structure framing and staging over the 1997-1998 winter, and structure erection and stringing in the spring/summer/fall of 1998.

For comparison, on the Swan Lake line a construction contract NTP was issued in April 1982, and construction was completed by June 1983, almost five months ahead of schedule, for a total construction period of 14 months. The Tyee Lake line was completed over a 15-month period, from a NTP in July 1982 to October 1983. Construction contracts on both lines took advantage of two construction seasons, beginning in spring/summer and ending in fall/winter of the following year, similar to the schedule for the Intertie.

ELECTRIC LOAD FORECAST

A. INTRODUCTION

This section of the report describes the methodology, assumptions, and results of the load forecast prepared as part of the process to assess the future need for electric power in the Valdez and Copper River service areas and serves as the basis for an economic evaluation of the Intertie. The actual load projections for Copper Valley Electric Association's (CVEA) service area are provided in detail in the attached appendices, along with comparable historical data.

CVEA provides electric service to its customers in two distinct load centers, Valdez and the Copper Basin, which is primarily the Glennallen area. These load centers, although served by CVEA as a single utility service area, are considered sufficiently diverse in economic activity, climate and location to warrant separate load forecasts for each area. In addition, the two areas are interconnected by a 106-mile transmission line that has experienced outages in the past, electrically isolating the two load centers from each other. CVEA maintains generation capacity in both Glennallen and Valdez and it is important to consider each area separately when estimating which generating plants are to be used by CVEA in the future. The load forecast presented in this report was prepared separately for both Valdez and Glennallen and then totaled for the entire CVEA system.

B. METHODOLOGY

The preparation of the electric system load forecast for the Valdez and Copper River areas involved a combination of several efforts. The general economic growth of the area and its influence on energy usage was modeled based on historical relationships between energy usage and changes in population, employment, income, and other factors. Because of the relative importance of several large commercial loads, the loads of the fifteen largest commercial class customers were examined separately. Previous studies of the area's economy were also reviewed and adjusted based on interviews with area planners, business managers, and civic leaders. The methodology used in developing this load forecast is consistent with current techniques used to project loads for smaller utility systems, including the methodological requirements and standards described in the Rural Electrification Administration Revised REA Bulletin 120-1, Development, Approval, and Use of Power Requirements Studies.

Historical CVEA data for disaggregated customer classes were analyzed in conjunction with available economic and demographic data for the Valdez and Copper River areas. Based on these analyses, an econometric load forecasting model was developed for the CVEA service area. Briefly, the load forecast model includes the effects of changing population, employment, per capita income, and inflation levels (among other factors) in the Valdez and Copper River areas to produce various projections of future energy and demand requirements for CVEA. Among other features, the model is able to account for the impact of changes in the price of electricity on the future demand for electricity. There are specific price elasticity estimates included in the model for both the residential and commercial customer classes that were developed using CVEA historical operating data.

The following specific steps were taken in developing the econometric system load forecast for the CVEA service area in Valdez and the Copper River Valley:

- Review CVEA annual billing records and energy requirement statistics for the period of 1980 through 1992.
- Collect historical population, employment, per capita income, inflation, and other non-utility data for the same time period, as available.
- Review monthly billing records for CVEA's fifteen largest customers and analyze historical energy and demand levels for these customers.
- Conduct interviews with several of CVEA's largest customers concerning historical, current, and future energy characteristics and requirements.
- Conduct a statistical analysis of historical energy and demand levels for each CVEA customer class.
- Collect economic and demographic data and develop input projections for the alternative load forecast scenarios.
- Develop an econometric system load forecasting model and develop CVEA load forecast projections under medium, high, and low growth case scenarios.

The number of CVEA residential class customer accounts was modeled using an equation based on past statistical relationships between residential customers and population. The equation for Valdez explains 86% of the historical growth of the number of residential class customers from 1980 to 1992 in Valdez. The equation indicates that a 1% increase in Valdez population would result in a 0.72% increase in CVEA's Valdez residential customer accounts. Glennallen residential customers were modeled using a simple statistical relationship between the number of customers and Copper River Valley population. Valdez residential average electricity usage per customer was modeled using a distributed lag equation using prior year's average usage per customer, average real (inflation adjusted) residential rates and heating degree days. A short-term price elasticity factor of -0.23 and a long-term price elasticity estimate of -0.45 were used based on an equation explaining 81% of the historical residential average usage pattern from 1981 to 1992. Glennallen residential electricity usage per customer was also modeled using an equation based on average real residential rates for the prior year. A price elasticity factor of -0.30 was used based on the historical Glennallen residential average usage pattern from 1980 to 1992.

Commercial class energy usage was modeled using a combination of econometric equations and projected discrete additions derived from interviews with large commercial class customers. For Valdez small commercial energy sales, a statistical equation was developed based on estimates of Valdez employment levels and real commercial electric rates (lagged one year) and was based on small commercial energy usage data from 1980 through 1992. The statistical equation explains 71% of the historical pattern and has a price elasticity factor of -0.16. Glennallen small commercial energy usage per customer is modeled using an average 1992 level which is slightly higher than the historical pattern of 1980 to 1992.

Data from the fifteen large CVEA commercial customers (constituting about 95% of total CVEA large commercial class energy sales in 1992) collected through interviews and from CVEA were used in the

development of the discrete power requirement projections for the large commercial class with the remainder of the large commercial class being projected using historical ratios.

Energy sales to public class accounts were also projected using a combination of an econometric approach as well as other statistical relationships. A statistical review of the public class data indicated no significant price elasticity component. The Valdez public building class energy sales was modeled based on an equation estimated using statistical relationships experienced over the 1984 to 1992 time horizon that explains 90% of the historical growth for that class. This equation is based on Valdez employment and real per capita income. Glennallen public building energy sales is a product of public building customers and public building usage per customer. Both the Valdez and Glennallen number of public building customers are assumed to grow at half of the rate of population growth for the respective areas. Valdez public building energy usage per customer is calculated, and Glennallen public building usage per customer is assumed to remain constant. Public streetlighting customers in both Valdez and Glennallen are estimated to increase at the rate of population growth in the respective areas, while usage per customer, in both locations, is assumed to remain constant.

Projected CVEA energy sales for each year of the forecast period were derived by adding the energy sales projections for the residential, commercial, and public classes in both Valdez and Glennallen. Estimates of future energy requirements were derived by adding estimated energy losses to CVEA's projected annual system energy sales. CVEA's system losses were projected at 8.0% of total energy requirements in all three cases, based on average losses experienced in the past.

The peak demand for the CVEA system in the Valdez and Copper River Valley areas was projected separately for each area based on an average relationship between total annual energy requirements and peak demand experienced in the past. An explicit adjustment to the peak demand for Valdez has been made to account for the addition of the Petro Star refinery load, which has a higher load factor than that for the rest of the community. This adjustment results in a higher load factor for the system than has been exhibited in the past. The projected peak demand, which is based solely on projected annual energy requirements, does not include the effects on CVEA's peak demand that can be caused by possible extreme weather conditions.

Alternative load forecast cases have been developed to accommodate a range of possible future growth scenarios for the CVEA service area. These cases use alternative low, medium and high population growth projections, among other alternative assumptions, as the basis for the number of customers served and total energy sales in the future. Alternative growth scenarios for the fifteen largest commercial customers have also been developed. The Petro Star refinery located in Valdez began full operation in early 1993 and Petro Star is CVEA's largest customer. Petro Star has indicated that it expects to expand its production facility over the next few years. An independent assessment conducted in early 1994 by Petroleum Marketing Solutions at the request of the Division, indicated that it is very likely that the Petro Star refinery will substantially increase its production capability in the next two to three years but that further expansion beyond the capability achieved at that time would be unlikely. The report on the assessment of the Petro Star refinery expansion is included as Appendix N of this report. Three separate forecasts of the power requirements of the Petro Star refinery have been developed, one each for the low, medium and high forecast scenarios. The basis for these scenarios are described in more detail throughout this section of the report.

C. ASSUMPTIONS OF THE LOAD FORECAST

The economy of the Valdez and Copper River Valley areas is predominantly influenced by the petroleum industry, seafood processing, tourism, and state and federal spending.

Estimated population in Valdez has increased from 3,079 in 1980 to an estimated 4,279 in 1991, a 3.0% average annual rate of growth. Population in the Copper River Valley has increased from 2,721 in 1980 to an estimated 2,801 in 1991, a 0.3% annual rate of growth (see Figure VIII-1). Total employment in Valdez increased from 1,746 in 1980 to 2,146 in 1991, a 1.9% average annual rate of growth. Total Copper River Valley employment has decreased from 935 in 1980 to an estimated 728 in 1991, a -2.2% annual rate of growth. Total population in both areas increased 2.2% per year from 1985 to 1991. Per capita income data are available for the Valdez/Cordova area and has increased significantly during this time period from \$12,675 in 1980 to \$24,523 in 1990. Real (inflation adjusted) per capita income increased from \$21,663 in 1980 to \$25,312 in 1990. (See Appendix A, page 6, for historical economic and demographic data for the Valdez and Copper River Valley.)




Figure VIII-1: Copper Valley Electric Association - Population

Given the limited size and remote location of the Valdez and Copper River Valley areas and dependence of the areas on a few key industries, projecting future economic and demographic growth is difficult. A review of recent studies of the areas indicates that:

- The State Department of Revenue (DOR) is projecting diminishing oil flows from the Alaska North Slope (ANS) over the next twenty years. These projections include anticipated production from the new fields at Point McIntyre and Niakuk. Some fields, such as

Kuparuk, have produced far more than was predicted in past projections. The current DOR projections do not include ARCO's Kuvlum field. According to ARCO, this field will only be developed if it can be confirmed that the field can produce at least 1 billion barrels, although some estimates indicate it could produce as much as 6 billion barrels. As of October 1993, ARCO had failed to confirm at least 1 billion barrels at the Kuvlum field. ARCO has also recently announced that the Wild Weasel prospect near Kuvlum has no commercial quantities of oil and there are no further plans for further drilling in the area. If Kuvlum is eventually developed, it could spur other remote smaller fields to connect to the pipeline, and other exploration projects in the Beaufort Sea. Any or all of these projects could extend the oil flow to Valdez beyond the horizon of Prudhoe Bay production, as presently projected.




Figure VIII-2: DOR-Alaska North Slope Production

- In April 1993, the United States General Accounting Office (GAO) issued a report entitled "Trans-Alaska Pipeline - Projections of Long-Term Viability Are Uncertain". In its report, the GAO focused much of its effort on the review of projections made in 1991 in a report prepared by the United States Department of Energy (DOE), of the year in which the Trans-Alaska pipeline would be shut down. DOE concluded that the pipeline will shut down between 2006 and 2011, with 2009 identified as the "most likely" year considering projected oil availability on the North Slope, the pipeline's minimum operating levels, and other factors. GAO indicated that although the shut down could actually be predicted to occur anytime between 2001 and 2021 by varying the basic assumptions, it could not estimate a more reliable termination date than DOE. It is important to note that both DOE and GAO

assume some new oil field development in making their projections, but neither has assumed development of oil fields in the Arctic National Wildlife Refuge (ANWR). DOE and GAO estimate that development of oil fields in the ANWR would require 10 to 12 years following congressional approval of a lease sale.

- According to the City of Valdez Comprehensive Development Plan dated Spring 1991, the fishery resource in the Prince William Sound area is able to support further development of fish processing activity in Valdez. In its "most likely" scenario, the Comprehensive Development Plan projects that there will be a 3.4% annual growth in the demand for Prince William Sound fish that results in an annual Prince William Sound salmon catch of 40.2 million fish units by the year 2000.. The Comprehensive Development Plan also states that there is no reason to expect any future changes in the Valdez share of the total Prince William Sound commercial fishing activity. The Comprehensive Development Plan further acknowledges that there could be fluctuations in the year-to-year catch volumes. This is evidenced by a record harvest in 1992 and a moderately low catch in 1993. The establishment and contribution of the salmon hatcheries in the Prince William Sound area is considered to be the likely explanation of the continued increases in the pink salmon harvests since 1979.
- The Division of Tourism reports that Alaska is very competitive as a tourist destination, and predicts that the growth in tourism will continue. Growth of tourism in Valdez in the long-term should continue in parallel with the growth throughout Alaska. The anticipated National Park Service Visitor Information Center in the Copper River Valley will create more tourism and "ecotourism" opportunities in that area. The Valdez Comprehensive Development Plan estimates that tourism activity in Valdez will increase at a rate between 2.2% and 4.3% per year.

Although few specific population and employment projections for the Valdez and Copper River areas have been made, projections by the Alaska Department of Labor (DOL) and local agencies, along with those of other studies, have ranged between a low of -2.5% to a high of 3.5% annually over the next ten to 20 years. Given the outlook of slowly diminishing oil flow and moderate development of the fish processing and tourism industries, we have estimated that total long-term population and employment for the CVEA service territory will increase at 1.3% and 1.1% annually. These growth rates are higher than projections used by the City of Valdez in its Comprehensive Development Plan and historical patterns for Glennallen, but lower than projections made by the DOL. DOL projections use a census area migration estimate reflecting the pattern observed in the 1988 and 1989 period. This may cause over-estimation in Valdez. For this and other reasons, a long-term population growth rate between the DOL series and the Comprehensive Development Plan long-term projections was used. It should be noted that the Institute of Social and Economic Research (ISER) of the University of Alaska regularly prepares population projections for the Railbelt region of Alaska. ISER has not developed population projections for Valdez or the Copper River Valley.

The Valdez Comprehensive Development Plan prepared for the Valdez Community Development Department contains an economic base study that includes a demand analysis as well as a forecast of future trends. It includes analysis regarding various sectors of the Valdez economy, namely; the petroleum industry, fisheries, tourism, federal and state government spending, other external markets and potential local investment projects. The net effect of these individual demand projections were analyzed in the Comprehensive Development Plan and presented in a forecast for the Valdez economy and ultimately, in a

projection of population growth in the Valdez area of 1.1% per year for its most likely scenario. The medium case population growth projection used in the development of the electric load forecast of 1.3% per year was derived as an average of the population growth rate provided in the Comprehensive Development Plan and DOL's population projection. Since the resulting medium case population growth is higher than the Comprehensive Development Plan projection, it can be implied that the underlying assumed economic growth factors for the Valdez economy would be higher than those defined in the Comprehensive Development Plan.

Alternative high and low population and employment annual growth projections of 2.0% and 2.5% for high case population and employment and -0.3% and -1.8% for low case population and employment have also been assumed in the development of this load forecast. The low case population estimates for Valdez are not as low as the estimates contained in the Valdez Comprehensive Development Plan (pessimistic case) where there is a growth rate of -2.4% per year, but are lower than the Alaska Department of Labor's projections (low case) of +0.57%. The low case developed for this load forecast assumes that the Trans-Alaska pipeline ceases operation prior to the end of the projection period. Consequently, 400 Alyeska jobs at the Valdez terminal facility are projected to be lost in the last four years of the projection period for the low case.

Estimates of the key input variables used in the load forecast are provided on Page 5 of the attached load forecast projections for each scenario, medium, high and low, in Appendix B. Table VIII-1 provides a summary of the major assumptions used in the load forecast with compounded annual growth rates for population, employment, and other assumptions summarized for the medium, high, and low case scenarios.

Table VIII-1
Load Forecast Assumptions for
High, Medium, and Low Case Scenarios⁽¹⁾

| Input Assumption | Compound Annual Growth Rates (%) | | | | | | | | |
|---------------------------------|----------------------------------|--------|-------|-----------|--------|-------|-----------|--------|-------|
| | 1992-1997 | | | 1997-2002 | | | 1992-2013 | | |
| | High | Medium | Low | High | Medium | Low | High | Medium | Low |
| Valdez Population | 2.55 | 1.87 | -0.19 | 2.20 | 1.35 | -1.20 | 2.53 | 1.47 | -0.96 |
| Copper River Population | 1.96 | 1.62 | 1.32 | 1.10 | 0.67 | 0.30 | 1.20 | 0.90 | 0.54 |
| Valdez Employment | 2.10 | 1.38 | -0.14 | 2.10 | 1.00 | -0.89 | 2.86 | 1.09 | -1.78 |
| Copper River Employment | 2.39 | 2.05 | -1.70 | 1.10 | 0.67 | -1.70 | 1.36 | 1.00 | -1.70 |
| Real Per Capita Income | 2.00 | 0.00 | -1.00 | 2.00 | 0.00 | -1.00 | 2.00 | 0.00 | -1.00 |
| Inflation | 4.50 | 3.50 | 2.50 | 4.50 | 3.50 | 2.50 | 4.50 | 3.50 | 2.50 |
| Average Electric Rate Increases | -1.02 | -1.02 | -1.02 | 0.88 | 0.69 | 0.50 | 2.30 | 1.74 | 1.17 |

(1) See Appendix B for specific data.

Following is a summary of major assumptions that underlie the medium, high, and low growth load forecast scenarios in this load forecast:

- For the medium case, it is assumed that oil flows in the Alaska pipeline will continue at declining levels corresponding to recent DOR projections throughout the study period. The

assumed continued flow of ANS oil is assumed to provide for continued operation and employment, although at slowly decreasing levels, at Alyeska's tanker loading facility in Valdez through the forecast period. The medium case is further differentiated into medium-low and medium-high cases beginning in the year 2018. At that time it is assumed for the medium-low case that the Alaska pipeline and the Petro Star refinery are both shut down but that the economic impact in Valdez of the pipeline shut down itself will be compensated by other industrial growth (e.g., a natural gas pipeline). There is no compensation assumed, however, for loss of the refinery load. The medium-high case assumes continued operation of both the pipeline and the Petro Star refinery beyond 2018. The differentiation between the medium-low and medium-high cases is not shown in the results of the load forecast because the load forecast period is only through 2013, and the only difference between the two cases is the refinery load beyond 2018. The affects of the two medium growth cases on the results of the economic analysis, which evaluates costs and benefits over a much longer period of time, is shown in Section 10 of this report.

- For the low case, oil flows in the pipeline are assumed to decrease over time in accordance with low projections as developed by the Alaska DOR and that it is assumed the pipeline is shut down by 2013. In the high case, oil flows are assumed to decline, but at a slower rate as projected in the DOR high case, and the Trans-Alaska Gas System (TAGS) is assumed to become operational in 2009. Construction of TAGS is assumed to begin in 2005.
- Continued development of fish processing activity in Valdez will result in moderate energy increases for commercial processors in all three scenarios, with growth ranging between 0.0% annually in the low case and 5.2% annually in the high case. These estimates are based on interviews with the various seafood processors.
- At the present time, it has been indicated by various entities that a prototype facility for the High Altitude Auroral Research Project (HAARP) will be constructed by the federal government at a proposed site approximately 30 miles northeast of Glennallen. It is not known, however, if the federal government will continue to fully develop the HAARP facility in the future and whether or not any of the facility's electrical requirements would be supplied by CVEA. Presently, CVEA does not have adequate distribution facilities in place to serve electric power to HAARP. No potential power requirements of HAARP are included in any of the load forecast scenarios because of the speculative nature of additional federal funding, estimated in excess of \$70 million, needed to build the proposed facility.
- Heating degree days in the Valdez and Copper River area are assumed to be at 30-year normal levels in each year of the forecast. No attempt has been made to analyze the impact of extreme weather conditions on CVEA's electric load, however, because there is very little, if any, electric space heat used by CVEA customers, it is not expected that extreme weather conditions would significantly impact electricity requirements.
- The cost of electricity to consumers is assumed to decrease by 5% in 1994 and remain constant thereafter until 2002, at which time it is assumed to increase at the assumed rate of general inflation over the remainder of the forecast period. CVEA has indicated that it expects to lower electric rates to its consumers in the near future and does not foresee any need to increase rates for many years to come. The cost of electricity is an input variable for the equations for forecasted electricity usage per customer and energy sales.

- A general inflation rate of 3.5% annually has been assumed in the medium case, bracketed by 4.5% in the high case and 2.5% in the low case scenarios, respectively. Inflation is used in the forecast to adjust per capita income and electric rate increases.
- For the medium case scenario, real per capita income has been assumed to remain constant. Real per capita income growth of 2% and -1.0% annually has been assumed for the high and low case scenarios, respectively. Per capita income is used in the forecast for public class energy sales.

These economic and demographic assumptions were used in the econometric model to project future energy and demand levels for CVEA. The econometric equations used to update the load forecasting model are provided in Appendix C.

D. LARGE COMMERCIAL CUSTOMERS

In order to acknowledge discrete changes in the energy requirements of CVEA's fifteen largest commercial customers, the energy requirements of these customers have been forecasted for each customer separately. The energy requirements of these customers represented over 50% of CVEA's total energy sales in 1992, excluding most of the impacts of energy sales to the Petro Star refinery which became fully operational in early 1993. For the most part, the energy requirements of these customers have been forecasted using growth patterns experienced by each customer in recent years. The actual rate of increase in energy use for each customer has been adjusted to account for assumed and projected changes in a customer's related industry. Much of the variation in projected industrial activity is acknowledged in the differences indicated between the low, medium and high growth scenarios for each customer.

The following descriptions provide an overview of the size of the electric load, the type of business and the assumed changes in electricity requirements for several of the large customers. Many of CVEA's large customers in both Valdez and Glennallen were visited personally to discuss expected electricity needs. Except for a few specific changes, however, most of the large customers visited were unable to indicate precisely when and in what amount electricity requirements might change in the near future.

1. Petro Star Refinery

Petro Star operates an oil refinery that primarily produces aviation and marine fuels and is located on the south shore of Port Valdez not far from the Alyeska Marine Terminal. Regular operation began in January 1993. By mid-1993, the average electric load of the Petro Star refinery was approximately 1.6 MW. As indicated in the Petro Star Valdez Refinery Expansion Assessment prepared by Petroleum Marketing Solutions, dated February 28, 1994 (See Appendix M), the Petro Star refinery presently operates at a level of approximately 30,000 barrels per day. The Expansion Assessment further indicates that it is very likely that Petro Star will expand its operation to 50,000 barrels per day in the next two to three years but that expansion beyond 50,000 barrels per day is unlikely because of the necessary capital and permitting requirements and the fact that at that level of operation the refinery would need to cross the threshold from in-state markets to export markets. It is estimated that at 50,000 barrels per day, the refinery power requirements would be in the range of 2.85 MW.

As an industrial facility, Petro Star could possibly produce electricity with waste heat or other waste products (cogeneration) that would reduce its need to purchase power from CVEA. Although some mention of cogeneration opportunities have been made, Petro Star presently has no plans to install cogeneration facilities, nor have any studies been conducted to evaluate the feasibility of cogeneration at the Petro Star Refinery. At the present time, the Tesoro refinery in Soldotna has cogeneration facilities whereas the two refineries in the Fairbanks area do not. With the installation of cogeneration facilities in recent years, the Tesoro refinery has greatly reduced its power purchases from the Homer Electric Association. The decision to cogenerate at some time in the future may be made by Petro Star based on, among other factors, economic and power delivery reliability issues. As Petro Star continues to establish its operation in Valdez, it should be expected that the option of cogeneration will be evaluated more thoroughly. We have not conducted a review of Petro Star's cogeneration options as part of this study and it is not known whether Petro Star will determine at some time that cogeneration is economically and operationally beneficial. Given the importance of the Petro Star load, a long-term power sales agreement between Petro Star and CVEA would be an important means to reduce the uncertainty of CVEA's future power requirements with regards to Petro Star.

For purposes of the medium scenario of the load forecast, it has been estimated that Petro Star's electric energy requirements will be 14,600 MWh in 1994 and that peak demand will be approximately 1.9 MW. Peak demand is projected to increase each year to approximately 2.4 MW in 1995 and to 2.85 MW by 1997 and energy requirements are projected to increase accordingly at an assumed 90% annual load factor. Energy requirements thereafter are not projected to increase through the remainder of the forecast period. The total annual energy requirements of Petro Star are estimated to be 22,500 MWh once the maximum load is achieved.

In the low case, it is assumed that Petro Star energy requirements will increase to 2.4 MW by 1995 but that they will remain constant at projected 1995 levels of 18,900 MWh with a peak demand of 2.4 MW until the year 2012. The Petro Star load is removed from the forecast in 2013 consistent with the assumed shutdown of the Trans-Alaska pipeline for the low load forecast scenario. Although Petro Star could conceivably install cogeneration equipment at sometime in the future, it is expected that if oil flows in the pipeline continue to decline to the point where the pipeline will no longer operate, as projected in the low case, Petro Star will not invest in cogeneration improvements. The high case assumes that Petro Star's electricity requirements will increase at the same rate as defined previously for the medium load forecast scenario but that the peak load expands to 3.1 MW by 1997. This level of power requirement is assumed to be consistent with operation of the refinery at 55,000 barrels per day.

2. Seafood Processors

CVEA sells power to three seafood processors in Valdez; Seahawk Seafoods, Peter Pan Seafoods and Nautilus Marine. At the present time, most of the processing activity at these facilities is in the summer and fall months, although some indication was made that operations could be extended through the winter months in the future with bottom-fish processing. Seahawk Seafoods is presently in the process of adding additional cold storage capacity at its facility.

It has been assumed that the energy requirements of the seafood processors will increase annually by between 1% and 2.6% (different rates of growth are assumed for each processor) for the medium case forecast. The assumed growth rates are reflective of increases experienced by the seafood processors in recent years with acknowledgment of projected increases in general activity. For the low case energy

requirements are assumed to essentially remain constant and for the high case, energy requirements are projected to increase between 1.5% and 5.2% annually.

3. Alyeska Pipeline Service Company

Alyeska purchases power from CVEA to operate certain facilities located along the Trans-Alaska Pipeline such as Pump Station 12 and various communication facilities. Much of this power is purchased under a long-term contract that terminates in 2004 and guarantees minimum purchase amounts. The amount of energy purchased by Alyeska has increased steadily over the past few years, despite decreases in the amount of oil flowing through the pipeline. The medium case assumes that the amount of energy purchased by Alyeska will remain constant at 1990 levels through the end of the forecast period. Energy sales to Alyeska are projected to increase at 3.0% per year in the high case, which is approximately the rate of growth in sales to Alyeska between 1985 and 1992. For the low case, energy sales to Alyeska are projected to decrease by 2.8% per year through 2010, which still considers the contract minimum purchase amounts in effect through 2004. After 2010, energy sales are projected to decrease by 50% per year, resulting in no energy sales beginning in 2013. The decrease in energy requirements forecasted in the low case are based on the assumed reduction and eventual termination of oil flows in the pipeline as described earlier in the overall assumptions for the low case.

CVEA does not sell power to the terminal facility in Valdez. Recently, however, Alyeska has discussed the possibility of purchasing power from CVEA for use at the terminal facility, indicating that the price of power is critical to its decision. At the present time, Alyeska generates its power requirements at the terminal facility, estimated to be approximately 7-9 MW, using its own combustion turbines fueled with diesel fuel and hydrocarbon laden waste gases extracted from storage tanks as the tanks are filled. With the addition of Alyeska's proposed tanker vapor recovery system sometime in the next few years, Alyeska has indicated that it may have additional waste gases to use for combustion turbine fuel. If Alyeska were to purchase power in the future, CVEA would need to sell power at a rate comparable to Alyeska's cost of generation. Although the possibility does exist that CVEA could sell power to the terminal facility in the future, there is a significant degree of uncertainty as to how much and at what price power could be sold. Power sales to the terminal facility are not included in any of the load forecast scenarios.

Alyeska has also recently indicated that its installed power generation facilities at the terminal facility are aging and that it will be evaluating its power supply options over the next few months. Issues of concern to Alyeska will include the cost of replacing the existing facilities, the need to use or dispose of an increasing amount of recovered waste gases and vapors, and the need to produce certain quantities of non-combustible gases (typically exhaust gases) for filling empty storage tanks.

4. State of Alaska Department of Mental Health

The State operates the Harborview Developmental Center in Valdez adjacent to and in the same complex with the City of Valdez Community Hospital. In recent years, the number of residents at Harborview has declined primarily due to more patient out-placement. The State has discussed the possibility of closing Harborview and it is not certain what the future of the facility will be. For the purposes of the forecast, it has been assumed that Harborview or some other operation will continue to utilize the existing facility in the medium and high cases. For the medium case, energy use is assumed to

remain constant at the 1992 level. The high case uses a slow growth rate of 1.0% per year, while the low case assumes the facility is closed in 1998.

5. City of Valdez

CVEA sells power to the City of Valdez for various public buildings and other municipal facilities. Since 1985, the amount of energy purchased by the City has increased steadily at 2.6% per year, while population growth in Valdez has grown at an estimated 4.1% per year during that same time period. For the medium case, sales to the City are estimated to grow at a rate of 1.2% per year. A continuation of the recent trend of 2.6% growth per year is estimated for the high case, and energy sales are held constant at 1992 levels in the low case.

6. Other Large Commercial Customers

The energy requirements of the following large commercial customers were also discretely forecasted:

- Alascom
- Alaska Department of Transportation
- City (of Valdez) Schools
- Copper River School District
- Miro Eagle QVC
- Sheffield Hotel
- United States Coast Guard
- Valdez (Convention) Center

7. Potential New Large Loads

a. *Ship Escort Response Vessel System (SERVS)*

SERVS was established in 1989 to assist oil tankers in safe navigation through Prince William Sound and to provide the first level of response in the event of a tanker problem or oil spill. SERVS presently operates out of a facility leased from Tesoro and is planning to construct a new facility elsewhere in Valdez. The new facility is expected to begin operation in December 1994 and is estimated to require power mainly for lighting and boiler feed pumps. Presently, it is estimated that the net increase in SERVS annual energy requirements caused by the new SERVS facility will be approximately 1,000 MWh.

b. *Trans-Alaska Gas System (TAGS)*

The feasibility of TAGS is presently under investigation by the Yukon Pacific Corporation. TAGS would conceivably involve a pipeline system presumably adjacent to the existing Trans-Alaska pipeline to deliver natural gas from the North Slope to Anderson Bay near Valdez. At Anderson Bay the gas would be liquefied and loaded on ocean tankers for shipment to Pacific Rim Asian nations. It is expected that TAGS would self-generate most if not all of the power it requires at its liquefaction and shipping facility and that the direct demand on CVEA would be minimal. The impact of construction and operation of TAGS on the Valdez community, from an employment and demographic perspective, would be extensive, however. It is not known if or when construction of TAGS would begin, although Yukon Pacific currently projects that construction and operation could begin sometime after the year 2000.

For the purposes of the high case of the load forecast, it has been assumed that TAGS would be constructed between 2005 and 2009. TAGS is not assumed to be constructed for either the low or medium scenarios. It is further assumed that the impact of construction and operation of TAGS on the Valdez economy would be similar to that experienced during the construction and subsequent operation of the Trans-Alaska pipeline and its Valdez terminal facility.

c. High Altitude Auroral Research Project (HAARP)

HAARP is presently being considered by the U.S. government for development northeast of Glennallen, near Gulkana. The HAARP facility if developed as a full-scale facility is estimated to require a significant amount of power, possibly in the range of 12 to 13 MW, much of it to supply a radically fluctuating radar pulse load during research campaigns. A constant load in the range of 1 to 2 MW is expected to be in place for heat, air circulation and lighting. HAARP officials have discussed the possibility of purchasing power from CVEA to supply HAARP's power needs. CVEA would need to construct additional distribution facilities to supply HAARP. Although federal officials associated with HAARP have recently indicated that some limited development has been approved, significant questions exist with regard to long-term HAARP development plans, what the power requirements would be and how the HAARP load would be integrated into CVEA's system if it can be integrated at all. No portion of the potential HAARP load has been included in any of the load forecast scenarios.

E. LOAD FORECAST PROJECTIONS

The load forecast results for CVEA under medium-high, medium-low, high, and low case scenarios for the period 1993 through 2013 are presented in detail in a series of tables in Appendix B and are summarized in Tables VIII-2 and VIII-3 below. For comparison purposes, comparable historical data for the CVEA service area in Valdez and Copper River are provided in Appendix A.

1. Medium Case Scenarios

The medium-high case scenario provides load projections for CVEA under moderate growth conditions given current expectations and also assumes expansion of the Petro Star refinery. The economic scenario that underlies this forecast is one of moderate economic and demographic growth during the forecasted period based on a slowly declining oil industry, increasing seafood processing activity and continued development of tourism in the area. The medium-low scenario is identical to the medium-high, except that the Petro Star refinery load is dropped from the forecast in the years beyond 2018.




Figure VIII-3: Energy Sales by Class - MEDIUM CASES

a. CVEA Retail Sales

Under the medium case scenario, the CVEA retail sales are projected to increase moderately for the 20-year forecast period (see Table VIII-2 and Figure VIII-3). The number of CVEA residential, commercial, and public customer accounts are projected to increase at nearly the rate of population growth. Overall, customer growth is projected to be 1.1% annually compared to the projected total population growth of 1.3% annually. The overall projected customer growth rate of 1.1% is the same rate experienced historically between 1980 and 1988. The projected total population growth of 1.3% annually is higher than the 0.0% experienced between 1980 and 1988 but lower than the 1.8% experienced between 1980 and 1992. The forecast projects total employment to increase 1.1% annually, which is similar to the 1.0% annual rate experienced historically between 1980 and 1992 but higher than the -1.4% annual average rate between 1980 and 1988. Average electricity usage per customer for the residential and commercial classes is projected to increase significantly between 1992 and 1995 as a result of the expected decrease in CVEA rates in 1994. Thereafter, usage per customer is projected to increase moderately, but remain mostly unchanged in the public classes.

(1) Residential Class

In Valdez, residential sales are forecasted to increase at an average annual rate of 2.0% over the entire forecast period compared to a 2.3% rate experienced from 1980 to 1988. In the short term, sales are forecasted to increase at an annual rate of 3.6% from 1992 to 1997. This is higher than the 2.6% annual average rate experienced between 1989 and 1992. Residential sales in Glennallen are forecasted to increase at an average annual rate of 2.0% from 1992 to 2013. Glennallen's residential sales grew at 3.1% annually from 1980 to 1988 and 3.4% annually from

1980 to 1992. In the short term, sales are forecasted to increase at 5.3% annually between 1992 and 1997 compared to the historical 4.1% annual increase experienced between 1988 and 1992.

In Valdez, the number of residential customers is forecasted to increase at an average annual rate of 0.9% over the entire 20-year forecast period. This is higher than the 0.6% historical rate experienced in Valdez from 1980 to 1988 but lower than the 2.1% from 1980 to 1992. The number of Glennallen residential customers is projected to grow at 1.4% annually over the entire forecast period compared to the 2.5% and 2.6% annual growth rates experienced between 1980 and 1988, and 1980 and 1992, respectively. The short-term results of the forecast of residential customers in the Glennallen area show an average annual increase of 3.7% between 1992 and 1997, compared to 3.0% annually between 1989 and 1992 and 2.7% annually between 1988 and 1992. A portion of this projected increase is due to allowances made for CVEA's expectation that it may interconnect to additional areas such as Lake Louise, Summit, Chitina, and Paxson. (Similar allowances are made in the high and low cases.)

Energy usage per residential customer in Valdez is projected to increase at 1.0% annually over the entire forecast period. This is higher than the average growth rate experienced from 1988 to 1992, although lower than the 1.3% annual growth rate experienced from 1980 to 1992. In the short term, the forecast indicates an average annual growth rate of 2.7% between 1992 and 1997. This is higher than the historical rate of growth of 1.8% experienced between 1980 and 1988. (See Figure VIII-4.) Glennallen residential energy usage per customer is projected to increase at an annual average rate of 0.6% over the 20-year forecast period. This is compared to the 0.6% rate between 1980 and 1992. In the short term, the forecast shows a 1.6% annual growth rate between 1992 and 1997, higher than the 1.3% experienced between 1988 and 1992 and the 0.9% experienced between 1989 and 1992. As previously mentioned, much of the projected increase in electricity usage per customer is attributed to the assumed decrease in CVEA electricity rates. (See Figure VIII-4.)




Figure VIII-4: Residential Usage per Customer

(2) Small Commercial Class

Energy sales to the small commercial class in Valdez are forecasted to increase 1.1% annually over the entire forecast period. This rate of growth is higher than the -0.4% annual rate experienced between 1980 and 1988 but lower than the 2.0% annual rate experienced between 1980 and 1992. The forecast shows a 2.2% average annual growth rate between 1992 and 1997, which is similar to the historical 2.0% annual rate between 1980 and 1992. Energy sales in Glennallen are forecasted to grow at a 0.8% annual rate over the entire 1993 through 2013 time horizon. The growth rate projected between 1992 and 1997 is 2.0% per year, which is twice as much as the short-term historical rate of 1.0% per year between 1988 and 1992.

The number of small commercial customers in Valdez is projected to increase 0.7% per year over the entire forecast. This growth rate is almost midway between the growth rates experienced from 1980 to 1992 and 1980 to 1988, with average annual rates of 1.4% and -0.1%, respectively. The number of small commercial customers in Glennallen is projected to grow at 0.8% annually over the forecast period. This is a higher growth rate than 0.1% experienced between 1980 and 1992 and the annual rate of -0.5% experienced between 1980 and 1988. The projected rate of growth in the short term of 1992 to 1997 is 2.0% annually, which is higher than the historical rates of 1.3% and 1.5% experienced between 1989 and 1992 and 1988 and 1992, respectively.

(3) Large Commercial Class

In the short term, Valdez large commercial class sales are forecasted to increase 16.5% for both the medium-high and medium-low scenarios annually from 1992 to 1997 compared to a historical annual growth rate of 8.6% from 1988 to 1992. The large increase in large commercial energy sales between 1992 and 1993 is due to the Petro Star Refinery becoming fully operational in January 1993. The annual forecast shows growth rates of 4.2% and 4.2%, respectively, for the medium-low and medium-high scenarios for Valdez over the entire forecast period. Historically, the growth rate has been 5.0% between 1980 and 1988 and 6.0% annually between 1980 and 1992. Large commercial energy sales in Glennallen are forecasted to increase 0.3% annually over the forecast horizon. Historically, Glennallen has seen a decrease of 0.3% annually between 1980 and 1992 and a decrease of 0.9% annually between 1988 and 1992. This forecast incorporates relatively constant Alyeska energy purchases.

b. CVEA Total Energy Sales

CVEA's estimated annual energy sales in the Valdez/Copper River service area are determined by summing the projected retail energy sales for Valdez and Glennallen in each of the projected years. Under the medium case scenario, CVEA total energy sales increase from an estimated 54,602 MWh in 1992 to 92,873 MWh in 2013. This represents approximately a 70% increase of total energy sales over that 21-year period and indicates an average compounded growth rate of 2.6% annually.

c. CVEA Energy Requirements

CVEA energy requirements follow the growth of energy sales with adjustments for system losses (see Table VIII-2 and Figure VIII-5). CVEA total energy requirements in the Valdez/Copper River service areas are projected to increase by approximately 49% between 1992 and 1997. This is based on the increases in system energy sales plus CVEA system losses estimated at 8.0% of total energy requirements in each year of the forecast. Energy losses associated with sales to Petro Star are assumed to be 2.0% of the refinery's energy requirement. Overall, total energy requirements are projected to increase during the next 20 years in CVEA's service area, from 59,227 MWh in 1992 to 99,543 MWh in 2013 for the medium case. As previously mentioned, the medium-high and medium-low cases are the same until 2018 at which time they diverge.




Figure VIII-5: Energy Requirements

d. Peak Demand Requirements

CVEA peak demand requirements for the Valdez/Copper River service area in the medium-high case scenario are projected to increase by 6,304 kW during the next 21 years to 17,204 kW in 2013, representing an average 2.2% annual rate of increase through 2013 (see Table VIII-3 and Figure VIII-6). For the medium-low case scenario, peak demand in 2013 is projected to be 17,204 kW, representing an average annual increase of 2.2% from 1992.




Figure VIII-6: Peak Demand

2. High Case Scenario

A high case scenario was developed based on the assumptions summarized in Table VIII-1 which are consistent with the assumption of continued activity in the petroleum industry in the Valdez and Copper River areas, along with steady development of fish processing and tourism-related activities through the year 2013. The continued activity of the petroleum industry includes the population and employment increases due to TAGS construction, as well as increased population and employment in the operational phase.

Projections in the high case scenario indicate CVEA's energy sales increasing significantly in both the near and long term. CVEA energy sales are projected to increase at a 10.3% annual rate from 1992 to 1997 in the high case scenario, and at approximately a 1.8% annual rate over the following 16 years (see Table VIII-2 and Figure VIII-5). In conjunction with these higher energy requirements, CVEA's peak demand requirements are projected to increase rapidly from 10,900 kW in 1992 to 21,969 kW in 2013, representing approximately a 3.4% average rate of growth per year during the next 21 years in the high case scenario (see Table VIII-3 and Figure VIII-6).

**Table VIII-2
Historical and Projected
CVEA Energy Requirements (MWh)**

| <u>Fiscal Year</u> | <u>High Case</u> | <u>Medium-High Case(1)</u> | <u>Medium-Low Case(1)</u> | <u>Low Case</u> |
|--------------------|------------------|----------------------------|---------------------------|-----------------|
| 1980 | 43,982 | 43,982 | 43,982 | 43,982 |
| 1985 | 50,500 | 50,500 | 50,500 | 50,500 |
| 1992 | 59,227 | 59,227 | 59,227 | 59,227 |
| 1997 | 95,107 | 88,141 | 88,141 | 79,215 |
| 2002 | 104,492 | 92,400 | 92,400 | 77,734 |
| 2013 | 126,369 | 99,453 | 99,453 | 49,360 |

Compounded Annual Growth Rates:

| | | | | |
|-----------|------|------|------|-------|
| 1980-1992 | 2.5% | 2.5% | 2.5% | 2.5% |
| 1988-1992 | 4.7% | 4.7% | 4.7% | 4.7% |
| 1992-1997 | 9.8% | 8.3% | 8.3% | 6.0% |
| 1997-2002 | 1.9% | 1.0% | 1.0% | -0.4% |
| 2002-2013 | 1.7% | 0.7% | 0.7% | -4.0% |
| 1992-2013 | 3.7% | 2.5% | 2.5% | -0.9% |

(1) The medium-high and medium-low case scenarios vary only in the assumed level of power sales to the Petro Star refinery beginning in 2018.

**Table VIII-3
Historical and Projected
CVEA Peak Demand (kW)**

| Fiscal Year | High Case | Medium-High Case(1) | Medium-Low Case(1) | Low Case |
|--------------------|------------------|----------------------------|---------------------------|-----------------|
| 1980 | 8,180 | 8,180 | 8,180 | 8,180 |
| 1985 | 9,350 | 9,350 | 9,350 | 9,350 |
| 1992 | 10,900 | 10,900 | 10,900 | 10,900 |
| 1997 | 16,398 | 15,234 | 15,234 | 13,844 |
| 2002 | 18,072 | 15,976 | 15,976 | 13,576 |
| 2013 | 21,969 | 17,204 | 17,204 | 9,449 |

Compounded Annual Growth Rates:

| | | | | |
|-----------|------|------|------|-------|
| 1980-1992 | 2.4% | 2.4% | 2.4% | 2.4% |
| 1988-1992 | 3.2% | 3.2% | 3.2% | 3.2% |
| 1992-1997 | 8.5% | 6.9% | 6.9% | 4.9% |
| 1997-2002 | 2.0% | 1.0% | 1.0% | -0.4% |
| 2002-2013 | 1.8% | 0.7% | 0.7% | -3.2% |
| 1992-2013 | 3.4% | 2.2% | 2.2% | -0.7% |

(1) The medium-high and medium-low case scenarios vary only in the assumed level of power sales to the Petro Star refinery beginning in 2018.

3. Low Case Scenario

Under the assumptions of the low case scenario, economic development in the Valdez and Copper River areas is affected by declines in the petroleum industry and only slow growth in fish processing and tourism. Consequently, population and employment is assumed to decrease at an average annual level of -0.3% and -1.8%, respectively, during the forecast period in the low case scenario.

CVEA energy sales under the low case scenario continue to decrease during the 20-year forecast period. CVEA energy requirements are projected to decrease from 59,227 MWh in 1992 to 49,360 MWh in 2013, representing a -0.9% average annual growth rate. Energy requirements are projected to increase between 1992 and 1996, however, with estimated increases in sales to Petro Star during that time period. The low case scenario projects CVEA peak demand to increase from 10,900 kW in 1992 to 14,035 kW in 1996 before decreasing gradually to 9,449 kW in 2013 with the assumed shutdown of the Trans-Alaska oil pipeline (see Table VIII-3 and Figure VIII-6). Much of this decrease is due to the assumed significant decrease in loads after 2010 in Glennallen of Alyeska Pump Station 12, and in Valdez of the Petro Star Refinery.

F. CONSIDERATIONS AND LIMITATIONS

The load projections developed in this study are based primarily on historical trends, causal relationships, and expectations of future conditions. We have not conducted an independent economic analysis of the Valdez and Copper River areas and of future development potential. Although demographic and economic relationships can be expected to remain relatively stable in the long term, the current economic transition in the Valdez and Copper River areas could distort these historical relationships.

The uncertainty inherent in this forecasting effort, as in any forecast, along with the specific limitations inherent in making the assumptions that underlie the forecast, should be recognized and considered in using the forecast results. For example, the future development in Valdez and in the Copper River Valley is dependent on numerous local conditions (e.g., commercial fisheries, petroleum products, etc.) and national and international conditions (e.g., supplies and costs of alternative petroleum resources, demand and price of fish products, etc.).

For these and other reasons, the existing data do not provide a precise indication of the magnitude of future load growth in the Valdez and Copper River areas. We have attempted to develop a range of load projections for CVEA that encompass the likely range of future events as they now appear to be developing. Alternative high and low case scenario projections are provided in an attempt to bracket the expected range of future load growth, but even these projections do not account for all possible load conditions that CVEA might experience. Also, we have assumed rate projections for the next five years based in part on information provided to us by CVEA, as well as on the current outlook for world fuel prices. Alternative rate levels resulting from possible increases in future fuel prices or other factors could significantly affect the load forecast projections.

Consideration should also be given to the nature of the forecasting procedure used. The primary purpose of this load forecasting effort was to develop long-term projections of future CVEA load requirements in the Valdez/Copper River service area for the evaluation of the proposed Intertie. As such, the procedures selected in this forecast have been used in an attempt to capture long-term historical relationships and to use them in projecting future load requirements. Short-term results may not be as accurate as could have been achieved using alternative forecasting techniques more appropriate to short-term applications.

G. CONCLUSIONS

Based on the medium case assumptions and analyses presented herein, it appears that CVEA can anticipate moderate growth in energy requirements during the next 20-year period in the Valdez/Copper River service areas. As discussed herein, the Valdez/Copper River service areas have significant economic development potential, as well as possibilities of a slow down in petroleum related industries. However, considerable uncertainty exists both as to the magnitude of certain large electric loads and to the overall pace that economic development in the area will take. Significant variance either in the assumptions used in preparation of this load forecast or in the experienced near-term load growth from that presented herein would warrant a re-examination of the area's load growth potential.

TABLE A-1
CVEA
HISTORICAL OPERATING RESULTS

| CALENDAR YEAR | VALDEZ | | | | | | GLENNALLEN | | | | | | CVEA SYSTEM SALES | LINE LOSSES | ENERGY REQUIREMENT | LOSSES AS % OF RQT | VALDEZ PEAK DEMAND (kW) | GLENN PEAK DEMAND (kW) | TOTAL PEAK DEMAND (kW) | TOTAL SYSTEM LOAD FACTOR |
|---------------------------------|------------|-----------|------------|---------|---------|--------------|------------|-----------|------------|---------|---------|--------------|-------------------|-------------|--------------------|--------------------|-------------------------|------------------------|------------------------|--------------------------|
| | RES | SM.COM | LG.COM | PUB.STL | PUB.BLG | RETAIL SALES | RES | SM.COM | LG.COM | PUB.STL | PUB.BLG | RETAIL SALES | | | | | | | | |
| 1978 | 6,455,372 | 3,543,857 | 10,678,293 | 158,307 | 264,713 | 21,100,542 | 3,089,948 | 2,849,197 | 10,791,904 | 23,800 | 380,193 | 17,135,042 | 38,235,584 | | | | | | | |
| 1979 | 6,392,547 | 3,530,621 | 10,622,719 | 225,117 | 292,018 | 21,063,022 | 2,961,325 | 3,125,852 | 8,901,392 | 27,199 | 445,085 | 15,460,853 | 36,523,875 | | | | | | | |
| 1980 | 6,914,452 | 3,905,942 | 9,877,970 | 307,004 | 353,009 | 21,358,377 | 2,905,351 | 3,371,945 | 9,218,992 | 20,080 | 527,435 | 16,043,803 | 37,402,180 | 6,579,420 | 43,981,600 | 15.0% | 4,650 | 3,530 | 8,180 | 61.4% |
| 1981 | 7,702,426 | 4,622,280 | 10,405,178 | 329,501 | 507,300 | 23,566,685 | 2,899,849 | 3,437,683 | 8,906,444 | 11,730 | 530,978 | 15,786,684 | 39,353,369 | 5,921,905 | 45,275,274 | 13.1% | 4,850 | 3,600 | 8,450 | 61.2% |
| 1982 | 8,354,892 | 4,017,084 | 12,048,254 | 315,300 | 327,220 | 25,062,750 | 3,136,898 | 3,710,893 | 9,296,716 | 22,680 | 541,018 | 16,708,205 | 41,770,955 | 6,974,219 | 48,745,174 | 14.3% | 5,400 | 3,500 | 8,900 | 62.5% |
| 1983 | 8,399,233 | 4,604,367 | 13,080,884 | 343,773 | 500,299 | 26,928,556 | 3,277,765 | 4,232,231 | 9,028,522 | 21,979 | 460,430 | 17,020,927 | 43,949,483 | 6,167,562 | 50,117,045 | 12.3% | 6,000 | 3,500 | 9,500 | 60.2% |
| 1984 | 8,717,285 | 4,354,435 | 14,285,543 | 396,803 | 607,689 | 28,361,755 | 3,652,189 | 4,567,910 | 8,764,840 | 25,435 | 442,547 | 17,452,921 | 45,814,676 | 4,883,492 | 50,698,168 | 9.6% | 5,900 | 3,400 | 9,300 | 62.2% |
| 1985 | 8,616,912 | 4,607,880 | 14,194,065 | 398,954 | 634,620 | 28,452,431 | 3,621,581 | 4,481,415 | 8,416,403 | 24,220 | 403,907 | 16,947,526 | 45,399,957 | 5,099,955 | 50,499,912 | 10.1% | 5,600 | 3,750 | 9,350 | 61.7% |
| 1986 | 8,266,039 | 4,372,927 | 14,020,550 | 97,721 | 604,150 | 27,361,387 | 3,485,285 | 4,085,264 | 8,685,045 | 86,970 | 371,193 | 16,713,757 | 44,075,144 | 4,553,995 | 48,629,139 | 9.4% | 5,400 | 3,800 | 9,200 | 60.3% |
| 1987 | 8,151,267 | 4,197,380 | 14,114,555 | 87,080 | 596,621 | 27,146,903 | 3,729,388 | 3,997,960 | 8,207,376 | 85,049 | 333,554 | 16,353,327 | 43,500,230 | 6,486,357 | 49,986,587 | 13.0% | 5,850 | 3,900 | 9,750 | 58.5% |
| 1988 | 8,324,873 | 3,791,857 | 14,570,794 | 67,499 | 634,738 | 27,389,761 | 3,701,597 | 4,428,468 | 8,586,975 | 96,366 | 371,266 | 17,184,672 | 44,574,433 | 4,740,417 | 49,314,850 | 9.6% | 5,900 | 3,700 | 9,600 | 58.6% |
| 1989 | 9,580,096 | 5,855,911 | 18,402,943 | 63,087 | 729,296 | 34,631,333 | 3,866,082 | 4,345,817 | 8,527,840 | 105,801 | 357,256 | 17,202,796 | 51,834,129 | 2,717,682 | 54,551,811 | 5.0% | 7,500 | 3,900 | 11,400 | 54.6% |
| 1990 | 10,078,636 | 4,968,635 | 19,093,835 | 58,309 | 669,808 | 34,869,223 | 4,217,374 | 4,580,776 | 8,832,240 | 43,777 | 381,405 | 18,055,572 | 52,924,795 | 4,295,813 | 57,220,608 | 7.5% | 6,800 | 4,200 | 11,000 | 59.4% |
| 1991 | 10,197,755 | 5,151,949 | 19,339,091 | 58,315 | 642,522 | 35,389,632 | 4,213,861 | 4,572,468 | 8,409,360 | 36,623 | 390,689 | 17,623,001 | 53,012,633 | 5,504,320 | 58,516,953 | 9.4% | 7,300 | 3,800 | 11,100 | 60.2% |
| 1992 | 10,357,519 | 4,951,406 | 20,259,252 | 69,648 | 693,079 | 36,330,904 | 4,342,066 | 4,600,078 | 8,891,200 | 35,936 | 401,978 | 18,271,258 | 54,602,162 | 4,625,014 | 59,227,176 | 7.8% | 7,200 | 3,700 | 10,900 | 62.0% |
| Average: | | | | | | | | | | | | | | | | 10.5% | Average: | | 60.2% | |
| COMPOUNDED ANNUAL GROWTH RATES: | | | | | | | | | | | | | | | | | | | | |
| 1980-92: | 3.4% | 2.0% | 6.2% | -11.6% | 5.8% | 4.5% | 3.4% | 2.6% | -0.3% | 5.0% | -2.2% | 1.1% | 3.2% | -2.9% | 2.5% | -5.3% | 3.7% | 0.4% | 2.4% | |
| 1980-88: | 2.3% | -0.4% | 5.0% | -17.2% | 7.6% | 3.2% | 3.1% | 3.5% | -0.9% | 21.7% | -4.3% | 0.9% | 2.2% | -4.0% | 1.4% | -5.4% | 3.0% | 0.6% | 2.0% | |
| 1988-92: | 5.6% | 6.9% | 8.6% | 0.8% | 2.2% | 7.3% | 4.1% | 1.0% | 0.9% | -21.9% | 2.0% | 1.5% | 5.2% | -0.6% | 4.7% | -5.1% | 5.1% | -0.0% | 3.2% | |
| 1989-92: | 2.6% | -5.4% | 3.3% | 3.4% | -1.7% | 1.6% | 3.9% | 1.9% | 1.4% | -30.2% | 4.0% | 2.0% | 1.7% | 19.4% | 2.8% | 16.2% | -1.3% | -1.7% | -1.5% | |

TABLE A-1
CVEA
HISTORICAL OPERATING RESULTS

AVERAGE ANNUAL NUMBER OF CUSTOMER ACCOUNTS

| CALENDAR YEAR | VALDEZ | | | | | TOTAL RETAIL | GLENNALLEN | | | | | TOTAL RETAIL | TOTAL | | | |
|---------------|--------|-------|--------|---------|---------|--------------|------------|-------|--------|---------|---------|--------------|-------|-----|-----|-------|
| | RES | SMCOM | LG COM | PUB STL | PUB BLG | | RES | SMCOM | LG COM | PUB STL | PUB BLG | | RES | COM | PUB | TOTAL |
| 1978 | | | | | | | | | | | | | | | | |
| 1979 | | | | | | | | | | | | | | | | |
| 1980 | 1,066 | 196 | 33 | 10 | 21 | 1,326 | 642 | 209 | 18 | 4 | 32 | 905 | 1,708 | 456 | 67 | 2,231 |
| 1981 | 1,160 | 206 | 34 | 10 | 24 | 1,434 | 652 | 203 | 20 | 4 | 31 | 910 | 1,812 | 463 | 69 | 2,344 |
| 1982 | 1,187 | 205 | 42 | 10 | 23 | 1,467 | 660 | 212 | 19 | 4 | 31 | 926 | 1,847 | 478 | 68 | 2,393 |
| 1983 | 1,113 | 203 | 43 | 11 | 27 | 1,397 | 716 | 172 | 19 | 5 | 31 | 943 | 1,829 | 437 | 74 | 2,340 |
| 1984 | 1,089 | 199 | 45 | 11 | 26 | 1,370 | 732 | 173 | 18 | 5 | 30 | 959 | 1,821 | 436 | 72 | 2,329 |
| 1985 | 1,078 | 203 | 44 | 11 | 28 | 1,364 | 733 | 176 | 17 | 5 | 28 | 959 | 1,812 | 440 | 72 | 2,323 |
| 1986 | 1,068 | 200 | 45 | 8 | 28 | 1,350 | 735 | 176 | 17 | 5 | 27 | 961 | 1,804 | 438 | 69 | 2,311 |
| 1987 | 1,086 | 195 | 46 | 8 | 28 | 1,362 | 760 | 187 | 16 | 5 | 29 | 997 | 1,846 | 444 | 69 | 2,359 |
| 1988 | 1,116 | 195 | 51 | 9 | 30 | 1,400 | 782 | 200 | 12 | 6 | 31 | 1,030 | 1,898 | 458 | 75 | 2,430 |
| 1989 | 1,203 | 212 | 56 | 9 | 30 | 1,509 | 798 | 205 | 11 | 8 | 30 | 1,052 | 2,001 | 484 | 77 | 2,562 |
| 1990 | 1,291 | 220 | 57 | 9 | 29 | 1,606 | 823 | 208 | 11 | 9 | 30 | 1,080 | 2,114 | 496 | 77 | 2,686 |
| 1991 | 1,327 | 227 | 57 | 9 | 29 | 1,649 | 842 | 206 | 11 | 9 | 30 | 1,098 | 2,169 | 501 | 77 | 2,747 |
| 1992 | 1,363 | 231 | 60 | 9 | 29 | 1,692 | 872 | 213 | 11 | 9 | 31 | 1,135 | 2,234 | 515 | 78 | 2,827 |

COMPOUNDED ANNUAL GROWTH RATES:

| | | | | | | | | | | | | | | | | |
|----------|------|-------|------|-------|-------|------|------|-------|-------|-------|-------|------|------|------|------|------|
| 1980-92: | 2.1% | 1.4% | 5.2% | -0.9% | 2.7% | 2.1% | 2.6% | 0.1% | -4.0% | 7.0% | -0.4% | 1.9% | 2.3% | 1.0% | 1.2% | 2.0% |
| 1980-88: | 0.6% | -0.1% | 5.6% | -2.0% | 4.5% | 0.7% | 2.5% | -0.5% | -5.1% | 4.5% | -0.6% | 1.6% | 1.3% | 0.1% | 1.3% | 1.1% |
| 1988-92: | 5.1% | 4.3% | 4.2% | 1.4% | -0.7% | 4.8% | 2.7% | 1.5% | -1.8% | 12.3% | 0.1% | 2.4% | 4.2% | 3.0% | 1.0% | 3.9% |
| 1989-92: | 4.3% | 2.9% | 2.5% | 0.0% | -1.1% | 3.9% | 3.0% | 1.3% | 0.0% | 2.9% | 0.7% | 2.6% | 3.7% | 2.1% | 0.2% | 3.3% |

TABLE A-1
CVEA
HISTORICAL OPERATING RESULTS

USAGE (KWh) PER CUSTOMER ACCOUNT

| CALENDAR YEAR | VALDEZ | | | | | TOTAL RETAIL | GLENNALLEN | | | | | TOTAL RETAIL | TOTAL | | | |
|---------------|--------|--------|---------|---------|---------|--------------|------------|--------|---------|---------|---------|--------------|-------|--------|--------|-----------------|
| | RES | SM.COM | LG.COM | PUB.STL | PUB.BLG | | RES | SM.COM | LG.COM | PUB.STL | PUB.BLG | | RES | COM | PUB | TOTAL CUSTOMERS |
| 1978 | | | | | | | | | | | | | | | | |
| 1979 | | | | | | | | | | | | | | | | |
| 1980 | 6,486 | 19,928 | 299,332 | 30,700 | 16,810 | 16,107 | 4,525 | 16,134 | 512,166 | 5,020 | 16,482 | 17,728 | 5,749 | 57,840 | 18,023 | 16,765 |
| 1981 | 6,640 | 22,438 | 306,035 | 32,950 | 21,138 | 16,434 | 4,448 | 16,934 | 445,322 | 2,933 | 17,128 | 17,348 | 5,851 | 59,118 | 19,993 | 16,789 |
| 1982 | 7,039 | 19,596 | 286,863 | 31,530 | 14,227 | 17,084 | 4,753 | 17,504 | 489,301 | 5,670 | 17,452 | 18,043 | 6,222 | 60,822 | 17,739 | 17,455 |
| 1983 | 7,546 | 22,682 | 304,207 | 31,252 | 18,530 | 19,276 | 4,578 | 24,606 | 475,185 | 4,396 | 14,853 | 18,050 | 6,384 | 70,815 | 17,925 | 18,782 |
| 1984 | 8,009 | 21,863 | 316,870 | 36,073 | 23,150 | 20,702 | 4,988 | 26,379 | 478,082 | 5,087 | 14,670 | 18,201 | 6,794 | 73,374 | 20,333 | 19,672 |
| 1985 | 7,991 | 22,718 | 321,983 | 37,112 | 22,665 | 20,860 | 4,940 | 25,511 | 492,667 | 4,844 | 14,425 | 17,674 | 6,756 | 72,100 | 20,372 | 19,544 |
| 1986 | 7,737 | 21,910 | 308,709 | 11,845 | 21,706 | 20,275 | 4,740 | 23,168 | 510,885 | 17,394 | 13,539 | 17,392 | 6,515 | 71,096 | 16,935 | 19,076 |
| 1987 | 7,505 | 21,571 | 308,515 | 10,885 | 21,630 | 19,930 | 4,907 | 21,370 | 505,069 | 18,225 | 11,704 | 16,409 | 6,435 | 68,784 | 16,034 | 18,443 |
| 1988 | 7,462 | 19,470 | 284,771 | 7,941 | 21,276 | 19,565 | 4,733 | 22,115 | 725,660 | 17,006 | 12,173 | 16,679 | 6,337 | 68,511 | 15,703 | 18,342 |
| 1989 | 7,966 | 27,666 | 328,136 | 7,010 | 24,310 | 22,944 | 4,844 | 21,225 | 775,258 | 12,824 | 11,909 | 16,350 | 6,720 | 76,799 | 16,252 | 20,235 |
| 1990 | 7,807 | 22,559 | 337,446 | 6,479 | 22,834 | 21,711 | 5,124 | 22,049 | 802,931 | 4,864 | 12,893 | 16,713 | 6,763 | 75,619 | 14,994 | 19,701 |
| 1991 | 7,687 | 22,663 | 339,282 | 6,479 | 22,156 | 21,462 | 5,005 | 22,187 | 764,487 | 4,069 | 12,915 | 16,045 | 6,646 | 74,734 | 14,604 | 19,297 |
| 1992 | 7,601 | 21,458 | 335,789 | 7,739 | 23,899 | 21,475 | 4,981 | 21,630 | 808,291 | 3,993 | 13,108 | 16,098 | 6,579 | 75,186 | 15,459 | 19,316 |

COMPOUNDED ANNUAL GROWTH RATES:

| | | | | | | | | | | | | | | | | |
|----------|-------|-------|-------|--------|-------|-------|------|-------|------|--------|-------|-------|-------|-------|-------|-------|
| 1980-92: | 1.3% | 0.6% | 1.0% | -10.8% | 3.0% | 2.4% | 0.8% | 2.5% | 3.9% | -1.9% | -1.9% | -0.8% | 1.1% | 2.2% | -1.3% | 1.2% |
| 1980-88: | 1.8% | -0.3% | -0.6% | -15.6% | 3.0% | 2.5% | 0.6% | 4.0% | 4.5% | 16.5% | -3.7% | -0.8% | 1.2% | 2.1% | -1.7% | 1.1% |
| 1988-92: | 0.5% | 2.5% | 4.2% | -0.6% | 2.9% | 2.4% | 1.3% | -0.6% | 2.7% | -30.4% | 1.9% | -0.9% | 0.9% | 2.4% | -0.4% | 1.3% |
| 1989-92: | -1.6% | -8.1% | 0.8% | 3.4% | -0.6% | -2.2% | 0.9% | 0.6% | 1.4% | -32.2% | 3.3% | -0.5% | -0.7% | -0.7% | -1.7% | -1.5% |

TABLE A-1
CVEA
HISTORICAL OPERATING RESULTS

RETAIL PAYMENTS FOR ENERGY SALES (\$)

| CALENDAR YEAR | RES | SM.COM | LG.COM | TOTAL COM | PUB STL | PUB BLG | TOTAL RETAIL REVENUES | VALDEZ RES | GLENN RES | Total Res | VALDEZ SM.COM | GLENN SM.COM | LG Com | Tot Com | TOTAL RETAIL REVENUES |
|---------------|-----------|-----------|-----------|-----------|---------|---------|-----------------------|------------|-----------|-----------|---------------|--------------|-----------|-----------|-----------------------|
| 1978 | | 775,517 | 2,171,250 | 2,946,767 | 18,857 | 72,790 | 4,138,342 | 710,363 | 389,565 | 1,099,928 | 372,891 | 402,626 | | | 4,138,342 |
| 1979 | | 887,866 | 2,271,941 | 3,159,807 | 29,834 | 93,385 | 4,512,890 | 812,247 | 417,617 | 1,229,863 | 422,668 | 465,197 | | | 4,512,890 |
| 1980 | 1,605,545 | 1,176,132 | 2,791,409 | 3,967,541 | 47,978 | 137,404 | 5,758,468 | 1,073,895 | 531,650 | 1,605,545 | 577,804 | 598,327 | | | 5,758,468 |
| 1981 | 1,917,709 | 1,403,276 | 3,153,250 | 4,556,526 | 54,804 | 176,324 | 6,705,363 | 1,289,385 | 628,324 | 1,917,709 | 752,387 | 650,889 | | | 6,705,363 |
| 1982 | 1,716,676 | 1,125,134 | 2,722,812 | 3,847,946 | 46,147 | 128,465 | 5,739,234 | 1,130,059 | 586,617 | 1,716,676 | 546,924 | 578,210 | | | 5,739,234 |
| 1983 | 1,711,118 | 1,197,722 | 2,773,279 | 3,971,002 | 48,166 | 136,219 | 5,887,532 | 1,120,066 | 612,079 | 1,732,145 | 610,665 | 601,775 | 2,807,359 | 3,418,024 | 5,887,532 |
| 1984 | 1,760,014 | | | 3,999,439 | 52,232 | 143,406 | 5,914,979 | 1,069,463 | 650,439 | 1,719,902 | 545,268 | 610,034 | 2,752,991 | 3,298,259 | 5,914,979 |
| 1985 | 2,102,865 | | | 4,878,291 | 61,650 | 169,335 | 7,162,286 | 1,319,651 | 733,359 | 2,053,010 | 845,495 | 840,104 | | | 7,162,286 |
| 1986 | 2,110,307 | | | 4,789,614 | 32,457 | 162,906 | 7,077,262 | 1,379,692 | 712,593 | 2,092,285 | 790,634 | 894,433 | 3,263,996 | 4,054,630 | 7,077,262 |
| 1987 | 2,151,517 | | | 4,812,076 | 27,810 | 157,451 | 7,161,715 | 1,393,833 | 770,545 | 2,164,378 | 775,369 | 891,262 | 3,351,108 | 4,126,477 | 7,161,715 |
| 1988 | 2,138,535 | | | 4,819,625 | 28,637 | 165,790 | 7,188,960 | 1,412,382 | 762,526 | 2,174,908 | 612,010 | 879,681 | 3,405,617 | 4,017,627 | 7,188,960 |
| 1989 | 2,329,784 | 5,338,437 | 115,506 | 5,453,943 | 30,505 | 175,367 | 7,998,036 | 1,566,764 | 771,457 | 2,338,221 | 868,558 | 853,506 | 3,758,585 | 4,627,144 | 7,998,036 |
| 1990 | 2,516,398 | 5,410,717 | 170,145 | 5,580,862 | 20,171 | 171,542 | 8,334,311 | 1,705,022 | 856,713 | 2,561,736 | 782,347 | 908,723 | 4,023,085 | 4,805,432 | 8,334,311 |
| 1991 | 2,663,282 | 5,697,793 | 187,439 | 5,885,232 | 19,704 | 176,824 | 8,737,952 | 1,774,315 | 881,878 | 2,656,192 | 831,540 | 878,838 | 4,137,859 | 4,969,398 | 8,737,952 |
| 1992 | 2,644,890 | 1,672,962 | 4,209,525 | 5,882,487 | 20,872 | 179,886 | 8,781,505 | 1,792,901 | 905,359 | 2,698,260 | 801,064 | 933,563 | 4,288,087 | 5,089,151 | 8,781,505 |

COMPOUNDED ANNUAL GROWTH RATES:

| | | | | | | | | | | | | | | | |
|----------|------|------|------|------|--------|------|------|------|------|------|-------|------|--|--|------|
| 1980-92: | 4.2% | 3.0% | 3.5% | 3.3% | -6.7% | 2.3% | 3.6% | 4.4% | 4.5% | 4.4% | 2.8% | 3.8% | | | 3.6% |
| 1980-88: | 3.6% | | | 2.5% | -6.2% | 2.4% | 2.8% | 3.5% | 4.6% | 3.9% | 0.7% | 4.9% | | | 2.8% |
| 1988-92: | 5.5% | | | 5.1% | -7.6% | 2.1% | 5.1% | 6.1% | 4.4% | 5.5% | 7.0% | 1.5% | | | 5.1% |
| 1989-92: | 4.3% | | | 2.6% | -11.9% | 0.9% | 3.2% | 4.6% | 5.5% | 4.9% | -2.7% | 3.0% | | | 3.2% |

TABLE A-1
CVEA
HISTORICAL OPERATING RESULTS

| CALENDAR YEAR | NOMINAL COST OF ELECTRICITY (CENTS/KWH - NOMINAL) | | | | | | | | | REAL COST OF ELECTRICITY (CENTS/KWH - CONSTANT 1992 DOLLARS) | | | | | | | | | |
|---------------|---|------------|-----------|---------------|--------------|-------|---------|---------|-----------------|--|-------|------------|-----------|---------------|--------------|-------|---------|---------|-----------------|
| | RES | Valdez RES | Glenn RES | Valdez SM.COM | Glenn SM.COM | COM | PUB STL | PUB BLG | OVERALL AVERAGE | CPI | RES | Valdez RES | Glenn RES | Valdez SM.COM | Glenn SM.COM | COM | PUB STL | PUB BLG | OVERALL AVERAGE |
| 1978 | 11.52 | 11.00 | 12.61 | 10.52 | 14.13 | 10.58 | 10.35 | 11.29 | 10.82 | 71.0 | 21.94 | 20.95 | 24.01 | 20.04 | 26.91 | 20.14 | 19.72 | 21.49 | 20.61 |
| 1979 | 13.15 | 12.71 | 14.10 | 11.97 | 14.88 | 12.07 | 11.82 | 12.67 | 12.36 | 77.0 | 23.09 | 22.31 | 24.76 | 21.02 | 26.13 | 21.19 | 20.76 | 22.25 | 21.70 |
| 1980 | 16.35 | 15.53 | 18.30 | 14.79 | 17.74 | 15.04 | 14.67 | 15.61 | 15.40 | 84.7 | 26.10 | 24.79 | 29.21 | 23.61 | 28.32 | 24.01 | 23.41 | 24.91 | 24.58 |
| 1981 | 18.09 | 16.74 | 21.67 | 16.28 | 18.93 | 16.65 | 16.06 | 16.98 | 17.04 | 92.0 | 26.58 | 24.60 | 31.84 | 23.92 | 27.82 | 24.46 | 23.60 | 24.96 | 25.04 |
| 1982 | 14.94 | 13.53 | 18.70 | 13.61 | 15.58 | 13.24 | 13.65 | 14.80 | 13.74 | 96.3 | 20.97 | 18.99 | 26.25 | 19.11 | 21.88 | 18.58 | 19.17 | 20.77 | 19.29 |
| 1983 | 14.83 | 13.34 | 18.67 | 13.26 | 14.22 | 12.83 | 13.17 | 14.18 | 13.40 | 99.9 | 20.08 | 18.05 | 25.27 | 17.95 | 19.24 | 17.37 | 17.82 | 19.19 | 18.13 |
| 1984 | 13.90 | 12.27 | 17.81 | 12.52 | 13.35 | 12.51 | 12.37 | 13.65 | 12.91 | 103.8 | 18.11 | 15.98 | 23.20 | 16.31 | 17.39 | 16.29 | 16.11 | 17.79 | 16.82 |
| 1985 | 16.78 | 15.31 | 20.25 | 18.35 | 18.75 | 15.39 | 14.57 | 16.31 | 15.78 | 107.5 | 21.10 | 19.26 | 25.47 | 23.08 | 23.58 | 19.35 | 18.32 | 20.51 | 19.84 |
| 1986 | 17.80 | 16.69 | 20.45 | 18.08 | 21.89 | 15.37 | 17.57 | 16.70 | 16.06 | 111.2 | 21.65 | 20.29 | 24.86 | 21.98 | 26.62 | 18.69 | 21.37 | 20.31 | 19.52 |
| 1987 | 18.22 | 17.10 | 20.66 | 18.47 | 22.29 | 15.77 | 16.16 | 16.93 | 16.46 | 114.4 | 21.53 | 20.21 | 24.42 | 21.83 | 26.35 | 18.64 | 19.09 | 20.00 | 19.46 |
| 1988 | 18.08 | 16.97 | 20.60 | 16.14 | 19.86 | 15.36 | 17.48 | 16.48 | 16.13 | 117.0 | 20.90 | 19.60 | 23.80 | 18.65 | 22.95 | 17.75 | 20.19 | 19.04 | 18.64 |
| 1989 | 17.39 | 16.35 | 19.95 | 14.83 | 19.64 | 14.69 | 18.06 | 16.14 | 15.43 | 121.4 | 19.37 | 18.21 | 22.22 | 16.52 | 21.87 | 16.36 | 20.12 | 17.97 | 17.18 |
| 1990 | 17.92 | 16.92 | 20.31 | 15.75 | 19.84 | 14.89 | 19.76 | 16.32 | 15.75 | 127.5 | 19.00 | 17.94 | 21.54 | 16.70 | 21.04 | 15.79 | 20.95 | 17.30 | 16.70 |
| 1991 | 18.43 | 17.40 | 20.93 | 16.14 | 19.22 | 15.71 | 20.75 | 17.11 | 16.48 | 131.6 | 18.94 | 17.88 | 21.50 | 16.58 | 19.75 | 16.13 | 21.32 | 17.58 | 16.93 |
| 1992 | 18.36 | 17.31 | 20.85 | 16.18 | 20.29 | 15.20 | 19.77 | 16.43 | 16.08 | 135.2 | 18.36 | 17.31 | 20.85 | 16.18 | 20.29 | 15.20 | 19.77 | 16.43 | 16.08 |

COMPOUNDED ANNUAL GROWTH RATES:

| | | | | | | | | | | | | | | | | | | | |
|----------|------|------|------|------|------|-------|------|-------|-------|------|-------|-------|-------|-------|-------|-------|-------|-------|-------|
| 1980-92: | 1.0% | 0.9% | 1.1% | 0.7% | 1.1% | 0.1% | 2.5% | 0.4% | 0.4% | 4.0% | -2.9% | -2.9% | -2.8% | -3.1% | -2.7% | -3.7% | -1.4% | -3.4% | -3.5% |
| 1980-88: | 1.3% | 1.1% | 1.5% | 1.1% | 1.4% | 0.3% | 2.2% | 0.7% | 0.6% | 4.1% | -2.7% | -2.9% | -2.5% | -2.9% | -2.6% | -3.7% | -1.8% | -3.3% | -3.4% |
| 1988-92: | 0.4% | 0.5% | 0.3% | 0.1% | 0.5% | -0.3% | 3.1% | -0.1% | -0.1% | 3.7% | -3.2% | -3.1% | -3.3% | -3.5% | -3.0% | -3.8% | -0.5% | -3.6% | -3.6% |
| 1989-92: | 1.8% | 1.9% | 1.5% | 2.9% | 1.1% | 1.1% | 3.1% | 0.6% | 1.4% | 3.7% | -1.8% | -1.7% | -2.1% | -0.7% | -2.5% | -2.4% | -0.6% | -3.0% | -2.2% |

TABLE A-1
CVEA
HISTORICAL ECONOMIC & DEMOGRAPHIC DATA

ECONOMIC & DEMOGRAPHIC DATA

| CALENDAR YEAR | VALDEZ AND COPPER RIVER VALLEY | | | | | | HDD (VALDEZ) | HDD (GULKANA) | CPI | PER CAPITA INCOME (VLDZ/CRDV) | REAL PER CAP. INCOME | SALMON HARVEST (PWSMA) | ANS PRODUCTION mil bb/day |
|---------------|--------------------------------|------------------------|-----------|------------|------------------------|-----------|--------------|---------------|-------|-------------------------------|----------------------|------------------------|---------------------------|
| | VALDEZ POP | COPPER RIVE POPULATION | TOTAL POP | VALDEZ EMP | COPPER RIVE EMPLOYMENT | TOTAL EMP | | | | | | | |
| 1978 | | | | | | | | | | | | | 0.702 |
| 1979 | | | | | | | | | | | | | 1.197 |
| 1980 | 3,079 | 2,721 | 5,800 | 1,746 | 935 | 2,681 | 9,726 | 13,500 | 84.7 | 14,038 | 22,408 | NA | 1.422 |
| 1981 | 3,279 | 2,580 | 5,859 | 1,848 | 956 | 2,804 | 9,123 | 12,579 | 92.0 | 16,243 | 23,870 | NA | 1.511 |
| 1982 | 3,698 | 2,439 | 6,137 | 1,884 | 908 | 2,792 | 10,156 | 14,535 | 96.3 | 16,780 | 23,558 | 24,684 | 1.570 |
| 1983 | 3,687 | 2,298 | 5,985 | 1,822 | 885 | 2,707 | 9,550 | 13,523 | 99.9 | 16,414 | 22,214 | 16,495 | 1.627 |
| 1984 | 3,388 | 2,913 | 6,301 | 1,906 | 845 | 2,751 | 9,275 | 13,152 | 103.8 | 17,536 | 22,841 | 25,301 | 1.657 |
| 1985 | 3,271 | 2,943 | 6,214 | 1,850 | 561 | 2,411 | 10,136 | 13,553 | 107.5 | 20,982 | 26,389 | 29,108 | 1.694 |
| 1986 | 3,263 | 2,768 | 6,031 | 1,696 | 602 | 2,298 | 9,403 | 13,138 | 111.2 | 21,061 | 25,607 | 14,868 | 1.802 |
| 1987 | 3,288 | 2,629 | 5,917 | 1,712 | 566 | 2,278 | 9,087 | 12,218 | 114.4 | 20,842 | 24,631 | 33,105 | 1.849 |
| 1988 | 3,313 | 2,489 | 5,802 | 1,789 | 609 | 2,398 | 9,340 | 13,238 | 117.0 | 21,868 | 25,270 | 14,941 | 2.005 |
| 1989 | 3,238 | 2,626 | 5,864 | 2,887 | 600 | 3,487 | 9,615 | 13,431 | 121.4 | 26,257 | 29,242 | 24,520 | 1.960 |
| 1990 | 4,068 | 2,763 | 6,831 | 2,200 | 609 | 2,809 | 9,806 | 13,619 | 127.5 | 24,523 | 26,004 | 46,591 | 1.853 |
| 1991 | 4,279 | 2,801 | 7,080 | 2,146 | 728 | 2,874 | 9,223 | 13,243 | 131.6 | 25,392 | 26,087 | 39,900 | 1.799 |
| 1992 | 4,326 | 2,832 | 7,158 | 2,247 | 762 | 3,009 | 9,623 | 13,861 | 135.2 | 27,050 | 27,050 | 11,404 | 1.791 |

COMPOUNDED ANNUAL GROWTH RATES:

12 YR AVG : 9,543
HDD NORM 9,711 13,353 14,004

Avg: 25,538

| | | | | | | | | | | | | | |
|----------|-------|-------|------|-------|-------|-------|--|--|------|------|-------|--------|-------|
| 1980-92: | 2.9% | 0.3% | 1.8% | 2.1% | -1.7% | 1.0% | | | 4.0% | 5.6% | 1.6% | NA | 1.9% |
| 1980-88: | 0.9% | -1.1% | 0.0% | 0.3% | -5.2% | -1.4% | | | 4.1% | 5.7% | 1.5% | NA | 4.4% |
| 1988-92: | 6.9% | 3.3% | 5.4% | 5.9% | 5.8% | 5.8% | | | 3.7% | 5.5% | 1.7% | -6.5% | -2.8% |
| 1989-92: | 10.1% | 2.5% | 6.9% | -8.0% | 8.3% | -4.8% | | | 3.7% | 1.0% | -2.6% | -22.5% | -3.0% |

TABLE B-1
CVEA
PROJECTED OPERATING RESULTS

MEDIUM_HIGH CASE
Full PetroStar Expansion

ENERGY SALES AND REQUIREMENTS (kWh)

| CALENDAR YEAR | VALDEZ | | | | | | GLENNALLEN | | | | | | CVEA SYSTEM SALES | LINE LOSSES | ENERGY REQUIREMENT | LOSSES AS % OF RQT | VALDEZ PEAK DEMAND (kW) | GLENN PEAK DEMAND (kW) | TOTAL PEAK DEMAND (kW) | TOTAL SYSTEM LOAD FACTOR |
|---------------|------------|-----------|------------|---------|---------|--------------|------------|-----------|-----------|---------|---------|--------------|-------------------|-------------|--------------------|--------------------|-------------------------|------------------------|------------------------|--------------------------|
| | RES | SM.COM | LG.COM | PUB.STL | PUB.BLG | RETAIL SALES | RES | SM.COM | LG.COM | PUB.STL | PUB.BLG | RETAIL SALES | | | | | | | | |
| 1992 | 10,357,519 | 4,951,406 | 20,259,252 | 69,648 | 693,079 | 36,330,904 | 4,342,066 | 4,600,078 | 8,891,200 | 35,936 | 401,978 | 18,271,258 | 54,602,162 | 4,625,014 | 59,227,176 | 7.8% | 7,200 | 3,700 | 10,900 | 62.0% |
| 1993 | 10,851,968 | 5,211,333 | 30,940,840 | 72,400 | 678,683 | 47,755,224 | 4,712,240 | 4,752,999 | 9,132,377 | 37,911 | 445,671 | 19,081,197 | 66,836,421 | 5,000,580 | 71,837,001 | 7.0% | 8,793 | 3,890 | 12,682 | 64.7% |
| 1994 | 11,279,336 | 5,273,455 | 33,591,219 | 73,378 | 680,499 | 50,897,888 | 5,027,837 | 4,857,251 | 9,149,779 | 38,166 | 447,175 | 19,520,209 | 70,418,096 | 5,152,678 | 75,570,775 | 6.8% | 9,234 | 4,052 | 13,286 | 64.9% |
| 1995 | 11,684,571 | 5,380,677 | 39,294,451 | 74,368 | 682,321 | 57,116,388 | 5,276,289 | 4,960,466 | 9,171,918 | 38,424 | 448,685 | 19,895,781 | 77,012,169 | 5,437,509 | 82,449,678 | 6.6% | 10,131 | 4,206 | 14,337 | 65.6% |
| 1996 | 12,041,191 | 5,444,818 | 41,937,872 | 75,372 | 684,147 | 60,183,400 | 5,530,830 | 5,062,706 | 9,190,044 | 38,683 | 450,199 | 20,272,461 | 80,455,861 | 5,579,560 | 86,035,421 | 6.5% | 10,560 | 4,366 | 14,927 | 65.8% |
| 1997 | 12,376,691 | 5,509,724 | 43,404,705 | 76,390 | 685,978 | 62,063,487 | 5,629,727 | 5,083,380 | 9,208,520 | 38,945 | 451,718 | 20,412,290 | 82,465,778 | 5,675,635 | 88,141,413 | 6.4% | 10,837 | 4,397 | 15,234 | 66.1% |
| 1998 | 12,705,338 | 5,575,403 | 43,661,604 | 77,421 | 687,814 | 62,707,580 | 5,730,392 | 5,104,140 | 9,227,221 | 39,207 | 453,243 | 20,554,203 | 83,261,783 | 5,744,853 | 89,006,636 | 6.5% | 10,958 | 4,427 | 15,385 | 66.0% |
| 1999 | 13,034,511 | 5,641,865 | 43,922,758 | 78,466 | 689,655 | 63,367,256 | 5,832,857 | 5,124,984 | 9,246,279 | 39,472 | 454,773 | 20,698,364 | 84,065,620 | 5,814,752 | 89,880,372 | 6.5% | 11,079 | 4,458 | 15,537 | 66.0% |
| 2000 | 13,368,064 | 5,709,120 | 44,188,251 | 79,525 | 691,501 | 64,036,461 | 5,937,154 | 5,145,913 | 9,265,700 | 39,739 | 456,307 | 20,844,813 | 84,881,273 | 5,885,679 | 90,766,952 | 6.5% | 11,202 | 4,490 | 15,692 | 66.0% |
| 2001 | 13,708,052 | 5,777,176 | 44,458,166 | 80,599 | 693,352 | 64,717,345 | 6,043,316 | 5,166,928 | 9,285,491 | 40,007 | 457,847 | 20,993,589 | 85,710,935 | 5,957,823 | 91,668,758 | 6.5% | 11,328 | 4,522 | 15,850 | 66.0% |
| 2002 | 13,946,651 | 5,846,044 | 44,732,593 | 81,687 | 695,207 | 65,302,182 | 6,088,188 | 5,188,028 | 9,305,661 | 40,277 | 459,393 | 21,081,546 | 86,383,728 | 6,016,327 | 92,400,055 | 6.5% | 11,436 | 4,541 | 15,976 | 66.0% |
| 2003 | 14,134,478 | 5,882,979 | 45,011,618 | 82,790 | 697,068 | 65,808,934 | 6,133,393 | 5,209,215 | 9,326,216 | 40,549 | 460,943 | 21,170,315 | 86,979,249 | 6,068,111 | 93,047,360 | 6.5% | 11,529 | 4,560 | 16,089 | 66.0% |
| 2004 | 14,297,446 | 5,920,147 | 45,295,335 | 83,908 | 698,934 | 66,295,769 | 6,178,933 | 5,230,488 | 9,347,164 | 40,822 | 462,499 | 21,259,906 | 87,555,675 | 6,118,235 | 93,673,911 | 6.5% | 11,619 | 4,579 | 16,198 | 66.0% |
| 2005 | 14,448,639 | 5,957,551 | 45,583,835 | 85,040 | 700,805 | 66,775,869 | 6,224,812 | 5,251,848 | 9,368,513 | 41,098 | 464,060 | 21,350,330 | 88,126,199 | 6,167,846 | 94,294,045 | 6.5% | 11,707 | 4,599 | 16,306 | 66.0% |
| 2006 | 14,594,626 | 5,995,190 | 45,877,214 | 86,188 | 702,680 | 67,255,899 | 6,271,031 | 5,273,295 | 9,390,270 | 41,375 | 465,626 | 21,441,597 | 88,697,496 | 6,217,524 | 94,915,020 | 6.6% | 11,796 | 4,618 | 16,414 | 66.0% |
| 2007 | 14,738,699 | 6,033,068 | 46,175,569 | 87,352 | 704,561 | 67,739,249 | 6,317,593 | 5,294,830 | 9,412,444 | 41,655 | 467,197 | 21,533,719 | 89,272,968 | 6,267,565 | 95,540,533 | 6.6% | 11,885 | 4,638 | 16,523 | 66.0% |
| 2008 | 14,882,504 | 6,071,185 | 46,479,001 | 88,531 | 706,447 | 68,227,667 | 6,364,501 | 5,316,453 | 9,435,042 | 41,936 | 468,774 | 21,626,706 | 89,854,373 | 6,318,122 | 96,172,496 | 6.6% | 11,975 | 4,658 | 16,633 | 66.0% |
| 2009 | 15,026,870 | 6,109,542 | 46,787,611 | 89,726 | 708,337 | 68,722,087 | 6,411,758 | 5,338,164 | 9,458,074 | 42,219 | 470,356 | 21,720,570 | 90,442,658 | 6,369,277 | 96,811,935 | 6.6% | 12,066 | 4,678 | 16,744 | 66.0% |
| 2010 | 15,172,217 | 6,148,142 | 47,101,504 | 90,938 | 710,233 | 69,223,035 | 6,459,365 | 5,359,963 | 9,481,546 | 42,504 | 471,944 | 21,815,322 | 91,038,357 | 6,421,077 | 97,459,434 | 6.6% | 12,158 | 4,699 | 16,857 | 66.0% |
| 2011 | 15,318,762 | 6,186,986 | 47,420,786 | 92,165 | 712,134 | 69,730,833 | 6,507,326 | 5,381,852 | 9,505,470 | 42,791 | 473,537 | 21,910,976 | 91,641,808 | 6,473,551 | 98,115,359 | 6.6% | 12,252 | 4,719 | 16,971 | 66.0% |
| 2012 | 15,466,617 | 6,226,075 | 47,745,567 | 93,410 | 714,040 | 70,245,709 | 6,555,643 | 5,403,830 | 9,529,852 | 43,080 | 475,135 | 22,007,539 | 92,253,248 | 6,526,720 | 98,779,968 | 6.6% | 12,347 | 4,740 | 17,087 | 66.0% |
| 2013 | 15,615,848 | 6,265,411 | 48,075,957 | 94,671 | 715,951 | 70,767,839 | 6,604,318 | 5,425,898 | 9,554,702 | 43,370 | 476,738 | 22,105,027 | 92,872,866 | 6,580,600 | 99,453,466 | 6.6% | 12,443 | 4,761 | 17,204 | 66.0% |

COMPOUNDED ANNUAL GROWTH RATES:

| | | | | | | | | | | | | | | | | | | | |
|------------|-------|-------|--------|-------|--------|--------|-------|-------|-------|-------|-------|-------|-------|-------|-------|--------|-------|-------|-------|
| 1992-1997: | 3.63% | 2.16% | 16.46% | 1.87% | -0.21% | 11.30% | 5.33% | 2.02% | 0.70% | 1.62% | 2.36% | 2.24% | 8.60% | 4.18% | 8.28% | -3.78% | 8.52% | 3.51% | 6.92% |
| 1997-2002: | 2.42% | 1.19% | 0.60% | 1.35% | 0.27% | 1.03% | 1.58% | 0.41% | 0.21% | 0.67% | 0.34% | 0.65% | 0.93% | 1.17% | 0.95% | 0.22% | 1.08% | 0.65% | 0.96% |
| 2002-2013: | 1.03% | 0.63% | 0.66% | 1.35% | 0.27% | 0.73% | 0.74% | 0.41% | 0.24% | 0.68% | 0.34% | 0.43% | 0.66% | 0.82% | 0.67% | 0.15% | 0.77% | 0.43% | 0.68% |
| 1992-2013: | 1.97% | 1.13% | 4.20% | 1.47% | 0.15% | 3.23% | 2.02% | 0.79% | 0.34% | 0.90% | 0.82% | 0.91% | 2.56% | 1.69% | 2.50% | -0.79% | 2.64% | 1.21% | 2.20% |

TABLE B-1
CVEA
PROJECTED OPERATING RESULTS

MEDIUM_HIGH CASE
Full PetroStar Expansion

AVERAGE ANNUAL NUMBER OF CUSTOMER ACCOUNTS

| CALENDAR YEAR | VALDEZ | | | | | | TOTAL RETAIL | GLENNALLEN | | | | | TOTAL RETAIL | TOTAL | | | | |
|---------------|--------|--------|--------|---------|---------|-------|--------------|------------|--------|---------|---------|-------|--------------|-------|-----|-------|-----|--|
| | RES | SM.COM | LG.COM | PUB.STL | PUB.BLG | RES | | SM.COM | LG.COM | PUB.STL | PUB.BLG | RES | | COM | PUB | TOTAL | | |
| 1992 | 1,363 | 231 | 60 | 9 | 29 | 1,692 | 872 | 213 | 11 | 9 | 31 | 1,135 | 2,234 | 515 | 78 | 2,827 | 5.0 | |
| 1993 | 1,380 | 233 | 61 | 9 | 30 | 1,713 | 924 | 220 | 12 | 9 | 34 | 1,200 | 2,304 | 526 | 82 | 2,912 | 5.1 | |
| 1994 | 1,383 | 233 | 62 | 9 | 30 | 1,718 | 961 | 225 | 12 | 10 | 34 | 1,241 | 2,344 | 532 | 83 | 2,959 | 5.1 | |
| 1995 | 1,396 | 235 | 63 | 10 | 30 | 1,734 | 998 | 229 | 12 | 10 | 34 | 1,284 | 2,395 | 539 | 83 | 3,017 | 5.2 | |
| 1996 | 1,410 | 236 | 65 | 10 | 30 | 1,750 | 1,036 | 234 | 12 | 10 | 34 | 1,326 | 2,445 | 547 | 84 | 3,076 | 5.2 | |
| 1997 | 1,423 | 238 | 66 | 10 | 30 | 1,767 | 1,043 | 235 | 12 | 10 | 34 | 1,335 | 2,467 | 550 | 84 | 3,102 | 5.2 | |
| 1998 | 1,437 | 239 | 67 | 10 | 31 | 1,784 | 1,051 | 236 | 12 | 10 | 35 | 1,344 | 2,488 | 554 | 85 | 3,127 | 5.2 | |
| 1999 | 1,451 | 241 | 68 | 10 | 31 | 1,800 | 1,059 | 237 | 12 | 10 | 35 | 1,353 | 2,510 | 558 | 86 | 3,153 | 5.3 | |
| 2000 | 1,465 | 243 | 69 | 10 | 31 | 1,817 | 1,067 | 238 | 12 | 10 | 35 | 1,362 | 2,532 | 561 | 86 | 3,179 | 5.3 | |
| 2001 | 1,479 | 244 | 70 | 10 | 31 | 1,835 | 1,075 | 239 | 12 | 10 | 35 | 1,371 | 2,554 | 565 | 87 | 3,205 | 5.3 | |
| 2002 | 1,493 | 246 | 71 | 11 | 31 | 1,852 | 1,083 | 240 | 12 | 10 | 35 | 1,380 | 2,576 | 569 | 87 | 3,232 | 5.3 | |
| 2003 | 1,508 | 247 | 72 | 11 | 32 | 1,869 | 1,091 | 241 | 12 | 10 | 35 | 1,389 | 2,598 | 572 | 88 | 3,258 | 5.3 | |
| 2004 | 1,522 | 249 | 73 | 11 | 32 | 1,887 | 1,099 | 242 | 12 | 10 | 35 | 1,398 | 2,621 | 576 | 88 | 3,285 | 5.3 | |
| 2005 | 1,537 | 251 | 74 | 11 | 32 | 1,905 | 1,107 | 243 | 12 | 10 | 35 | 1,408 | 2,644 | 580 | 89 | 3,312 | 5.4 | |
| 2006 | 1,552 | 252 | 75 | 11 | 32 | 1,923 | 1,115 | 244 | 12 | 10 | 36 | 1,417 | 2,667 | 583 | 89 | 3,339 | 5.4 | |
| 2007 | 1,567 | 254 | 76 | 11 | 32 | 1,941 | 1,124 | 245 | 12 | 10 | 36 | 1,426 | 2,690 | 587 | 90 | 3,367 | 5.4 | |
| 2008 | 1,582 | 256 | 77 | 11 | 33 | 1,959 | 1,132 | 246 | 12 | 11 | 36 | 1,436 | 2,714 | 591 | 90 | 3,395 | 5.4 | |
| 2009 | 1,597 | 257 | 78 | 12 | 33 | 1,977 | 1,140 | 247 | 12 | 11 | 36 | 1,446 | 2,737 | 594 | 91 | 3,423 | 5.4 | |
| 2010 | 1,612 | 259 | 79 | 12 | 33 | 1,996 | 1,149 | 248 | 12 | 11 | 36 | 1,455 | 2,761 | 598 | 92 | 3,451 | 5.4 | |
| 2011 | 1,628 | 261 | 80 | 12 | 33 | 2,014 | 1,157 | 249 | 12 | 11 | 36 | 1,465 | 2,785 | 602 | 92 | 3,479 | 5.5 | |
| 2012 | 1,644 | 263 | 81 | 12 | 34 | 2,033 | 1,166 | 250 | 12 | 11 | 36 | 1,475 | 2,810 | 606 | 93 | 3,508 | 5.5 | |
| 2013 | 1,659 | 264 | 82 | 12 | 34 | 2,052 | 1,175 | 251 | 12 | 11 | 36 | 1,485 | 2,834 | 610 | 93 | 3,537 | 5.5 | |

COMPOUNDED ANNUAL GROWTH RATES:

| | | | | | | | | | | | | | | | | |
|------------|-------|-------|-------|-------|-------|-------|-------|-------|-------|-------|-------|-------|-------|-------|-------|-------|
| 1992-1997: | 0.87% | 0.60% | 1.68% | 1.87% | 0.93% | 0.87% | 3.66% | 2.02% | 1.76% | 1.62% | 2.36% | 3.29% | 2.00% | 1.35% | 1.69% | 1.87% |
| 1997-2002: | 0.96% | 0.67% | 1.55% | 1.35% | 0.68% | 0.94% | 0.74% | 0.41% | 0.00% | 0.67% | 0.34% | 0.67% | 0.87% | 0.65% | 0.62% | 0.82% |
| 2002-2013: | 0.96% | 0.67% | 1.38% | 1.35% | 0.67% | 0.94% | 0.74% | 0.41% | 0.00% | 0.68% | 0.34% | 0.67% | 0.87% | 0.64% | 0.63% | 0.82% |
| 1992-2013: | 0.94% | 0.65% | 1.50% | 1.47% | 0.74% | 0.92% | 1.43% | 0.79% | 0.42% | 0.90% | 0.82% | 1.29% | 1.14% | 0.81% | 0.88% | 1.07% |

TABLE B-1

CVEA
PROJECTED OPERATING RESULTS

MEDIUM HIGH CASE
Full PetroStar Expansion

USAGE (KWh) PER CUSTOMER ACCOUNT

| CALENDAR YEAR | VALDEZ | | | | | GLENNALLEN | | | | | | TOTAL | | | | |
|---------------|--------|--------|---------|---------|---------|--------------|-------|--------|---------|---------|---------|--------------|-------|---------|--------|-----------------|
| | RES | SM.COM | LG.COM | PUB.STL | PUB.BLG | TOTAL RETAIL | RES | SM.COM | LG.COM | PUB.STL | PUB.BLG | TOTAL RETAIL | RES | COM | PUB | TOTAL CUSTOMERS |
| 1992 | 7,601 | 21,458 | 335,789 | 7,739 | 23,899 | 21,475 | 4,981 | 21,630 | 808,291 | 3,993 | 13,108 | 16,098 | 6,579 | 75,186 | 15,459 | 19,316 |
| 1993 | 7,866 | 22,392 | 504,049 | 7,739 | 22,949 | 39,025 | 5,098 | 21,630 | 761,031 | 3,993 | 13,108 | 15,907 | 6,755 | 95,155 | 14,980 | 29,502 |
| 1994 | 8,157 | 22,623 | 538,011 | 7,739 | 22,857 | 40,997 | 5,231 | 21,630 | 762,482 | 3,993 | 13,108 | 15,724 | 6,957 | 99,365 | 14,943 | 30,394 |
| 1995 | 8,369 | 22,930 | 618,935 | 7,739 | 22,764 | 44,416 | 5,285 | 21,630 | 764,326 | 3,993 | 13,108 | 15,501 | 7,083 | 109,010 | 14,907 | 32,116 |
| 1996 | 8,542 | 23,050 | 649,812 | 7,739 | 22,672 | 45,967 | 5,340 | 21,630 | 765,837 | 3,993 | 13,108 | 15,290 | 7,186 | 112,718 | 14,871 | 32,745 |
| 1997 | 8,696 | 23,171 | 661,761 | 7,739 | 22,580 | 46,674 | 5,395 | 21,630 | 767,377 | 3,993 | 13,108 | 15,294 | 7,300 | 114,839 | 14,835 | 33,170 |
| 1998 | 8,842 | 23,292 | 655,176 | 7,739 | 22,489 | 46,683 | 5,451 | 21,630 | 768,935 | 3,993 | 13,108 | 15,298 | 7,409 | 114,748 | 14,799 | 33,199 |
| 1999 | 8,984 | 23,414 | 648,859 | 7,739 | 22,398 | 46,693 | 5,508 | 21,630 | 770,523 | 3,993 | 13,108 | 15,304 | 7,517 | 114,665 | 14,763 | 33,228 |
| 2000 | 9,126 | 23,536 | 642,798 | 7,739 | 22,307 | 46,705 | 5,565 | 21,630 | 772,142 | 3,993 | 13,108 | 15,310 | 7,625 | 114,589 | 14,727 | 33,258 |
| 2001 | 9,269 | 23,659 | 636,983 | 7,739 | 22,217 | 46,721 | 5,623 | 21,630 | 773,791 | 3,993 | 13,108 | 15,317 | 7,734 | 114,522 | 14,691 | 33,292 |
| 2002 | 9,340 | 23,783 | 631,405 | 7,739 | 22,127 | 46,648 | 5,623 | 21,630 | 775,472 | 3,993 | 13,108 | 15,279 | 7,778 | 114,463 | 14,655 | 33,255 |
| 2003 | 9,375 | 23,775 | 626,053 | 7,739 | 22,038 | 46,531 | 5,623 | 21,630 | 777,185 | 3,993 | 13,108 | 15,242 | 7,800 | 114,354 | 14,619 | 33,193 |
| 2004 | 9,393 | 23,767 | 620,920 | 7,739 | 21,948 | 46,403 | 5,623 | 21,630 | 778,930 | 3,993 | 13,108 | 15,205 | 7,812 | 114,254 | 14,583 | 33,124 |
| 2005 | 9,402 | 23,759 | 615,998 | 7,739 | 21,860 | 46,270 | 5,623 | 21,630 | 780,709 | 3,993 | 13,108 | 15,168 | 7,819 | 114,161 | 14,547 | 33,053 |
| 2006 | 9,406 | 23,751 | 611,278 | 7,739 | 21,771 | 46,136 | 5,623 | 21,630 | 782,523 | 3,993 | 13,108 | 15,132 | 7,824 | 114,076 | 14,512 | 32,981 |
| 2007 | 9,408 | 23,743 | 606,754 | 7,739 | 21,683 | 46,003 | 5,623 | 21,630 | 784,370 | 3,993 | 13,108 | 15,096 | 7,827 | 113,999 | 14,476 | 32,909 |
| 2008 | 9,409 | 23,735 | 602,420 | 7,739 | 21,595 | 45,872 | 5,623 | 21,630 | 786,254 | 3,993 | 13,108 | 15,061 | 7,830 | 113,930 | 14,441 | 32,839 |
| 2009 | 9,410 | 23,727 | 598,268 | 7,739 | 21,508 | 45,743 | 5,623 | 21,630 | 788,173 | 3,993 | 13,108 | 15,026 | 7,832 | 113,869 | 14,405 | 32,770 |
| 2010 | 9,410 | 23,719 | 594,293 | 7,739 | 21,421 | 45,616 | 5,623 | 21,630 | 790,129 | 3,993 | 13,108 | 14,991 | 7,834 | 113,816 | 14,369 | 32,702 |
| 2011 | 9,410 | 23,711 | 590,489 | 7,739 | 21,334 | 45,492 | 5,623 | 21,630 | 792,122 | 3,993 | 13,108 | 14,957 | 7,836 | 113,771 | 14,334 | 32,635 |
| 2012 | 9,410 | 23,703 | 586,851 | 7,739 | 21,248 | 45,370 | 5,623 | 21,630 | 794,154 | 3,993 | 13,108 | 14,923 | 7,838 | 113,733 | 14,299 | 32,570 |
| 2013 | 9,410 | 23,695 | 583,373 | 7,739 | 21,162 | 45,251 | 5,623 | 21,630 | 796,225 | 3,993 | 13,108 | 14,889 | 7,840 | 113,704 | 14,263 | 32,507 |

COMPOUNDED ANNUAL GROWTH RATES:

| | | | | | | | | | | | | | | | | |
|------------|-------|--------|--------|-------|--------|--------|-------|-------|--------|-------|-------|--------|-------|--------|--------|--------|
| 1992-1997: | 2.73% | 1.55% | 14.53% | 0.00% | -1.13% | 16.80% | 1.61% | 0.00% | -1.03% | 0.00% | 0.00% | -1.02% | 2.10% | 8.84% | -0.82% | 11.42% |
| 1997-2002: | 1.44% | 0.52% | -0.93% | 0.00% | -0.40% | -0.01% | 0.83% | 0.00% | 0.21% | 0.00% | 0.00% | -0.02% | 1.28% | -0.07% | -0.24% | 0.05% |
| 2002-2013: | 0.07% | -0.03% | -0.72% | 0.00% | -0.40% | -0.28% | 0.00% | 0.00% | 0.24% | 0.00% | 0.00% | -0.23% | 0.07% | -0.06% | -0.25% | -0.21% |
| 1992-2013: | 1.02% | 0.47% | 2.67% | 0.00% | -0.58% | 3.61% | 0.58% | 0.00% | -0.07% | 0.00% | 0.00% | -0.37% | 0.84% | 1.99% | -0.38% | 2.51% |

TABLE B-1

CVEA
PROJECTED OPERATING RESULTS

MEDIUM_HIGH CASE
Full PetroStar Expansion

NOMINAL COST OF ELECTRICITY
(CENTS/KWH - NOMINAL)

REAL COST OF ELECTRICITY
(CENTS/KWH - CONSTANT 1992 DOLLARS)

| CALENDAR YEAR | NOMINAL COST OF ELECTRICITY (CENTS/KWH - NOMINAL) | | | | | | | | | CPI | REAL COST OF ELECTRICITY (CENTS/KWH - CONSTANT 1992 DOLLARS) | | | | | | | | |
|---------------|---|------------|-----------|---------------|--------------|-------|---------|---------|-----------------|-------|--|------------|-----------|---------------|--------------|-------|---------|---------|-----------------|
| | RES | Valdez RES | Glenn RES | Valdez SM.COM | Glenn SM.COM | COM | PUB.STL | PUB.BLG | OVERALL AVERAGE | | RES | Valdez RES | Glenn RES | Valdez SM.COM | Glenn SM.COM | COM | PUB.STL | PUB.BLG | OVERALL AVERAGE |
| 1992 | 18.36 | 17.31 | 20.85 | 16.18 | 20.29 | 15.20 | 19.77 | 16.43 | 16.08 | 135.2 | 18.36 | 17.31 | 20.85 | 16.18 | 20.29 | 15.20 | 19.77 | 16.43 | 16.08 |
| 1993 | 18.36 | 17.31 | 20.85 | 16.18 | 20.29 | 15.20 | 19.77 | 16.43 | 16.08 | 139.9 | 17.74 | 16.72 | 20.15 | 15.63 | 19.61 | 14.69 | 19.10 | 15.87 | 15.54 |
| 1994 | 17.44 | 16.44 | 19.81 | 15.37 | 19.28 | 14.44 | 18.78 | 15.61 | 15.28 | 144.8 | 16.28 | 15.35 | 18.49 | 14.35 | 18.00 | 13.48 | 17.53 | 14.57 | 14.26 |
| 1995 | 17.44 | 16.44 | 19.81 | 15.37 | 19.28 | 14.44 | 18.78 | 15.61 | 15.28 | 149.9 | 15.73 | 14.83 | 17.87 | 13.86 | 17.39 | 13.02 | 16.94 | 14.08 | 13.78 |
| 1996 | 17.44 | 16.44 | 19.81 | 15.37 | 19.28 | 14.44 | 18.78 | 15.61 | 15.28 | 155.1 | 15.20 | 14.33 | 17.26 | 13.39 | 16.80 | 12.58 | 16.37 | 13.60 | 13.31 |
| 1997 | 17.44 | 16.44 | 19.81 | 15.37 | 19.28 | 14.44 | 18.78 | 15.61 | 15.28 | 160.6 | 14.68 | 13.85 | 16.68 | 12.94 | 16.23 | 12.16 | 15.81 | 13.14 | 12.86 |
| 1998 | 17.44 | 16.44 | 19.81 | 15.37 | 19.28 | 14.44 | 18.78 | 15.61 | 15.28 | 166.2 | 14.19 | 13.38 | 16.11 | 12.50 | 15.68 | 11.75 | 15.28 | 12.70 | 12.43 |
| 1999 | 17.44 | 16.44 | 19.81 | 15.37 | 19.28 | 14.44 | 18.78 | 15.61 | 15.28 | 172.0 | 13.71 | 12.93 | 15.57 | 12.08 | 15.15 | 11.35 | 14.76 | 12.27 | 12.01 |
| 2000 | 17.44 | 16.44 | 19.81 | 15.37 | 19.28 | 14.44 | 18.78 | 15.61 | 15.28 | 178.0 | 13.24 | 12.49 | 15.04 | 11.67 | 14.64 | 10.97 | 14.26 | 11.85 | 11.60 |
| 2001 | 17.44 | 16.44 | 19.81 | 15.37 | 19.28 | 14.44 | 18.78 | 15.61 | 15.28 | 184.3 | 12.79 | 12.07 | 14.53 | 11.28 | 14.15 | 10.59 | 13.78 | 11.45 | 11.21 |
| 2002 | 18.05 | 17.02 | 20.50 | 15.91 | 19.95 | 14.94 | 19.44 | 16.15 | 15.81 | 190.7 | 12.79 | 12.07 | 14.53 | 11.28 | 14.15 | 10.59 | 13.78 | 11.45 | 11.21 |
| 2003 | 18.68 | 17.62 | 21.22 | 16.46 | 20.65 | 15.47 | 20.12 | 16.72 | 16.37 | 197.4 | 12.79 | 12.07 | 14.53 | 11.28 | 14.15 | 10.59 | 13.78 | 11.45 | 11.21 |
| 2004 | 19.33 | 18.23 | 21.96 | 17.04 | 21.38 | 16.01 | 20.82 | 17.30 | 16.94 | 204.3 | 12.79 | 12.07 | 14.53 | 11.28 | 14.15 | 10.59 | 13.78 | 11.45 | 11.21 |
| 2005 | 20.01 | 18.87 | 22.73 | 17.64 | 22.12 | 16.57 | 21.55 | 17.91 | 17.53 | 211.4 | 12.79 | 12.07 | 14.53 | 11.28 | 14.15 | 10.59 | 13.78 | 11.45 | 11.21 |
| 2006 | 20.71 | 19.53 | 23.53 | 18.25 | 22.90 | 17.15 | 22.30 | 18.53 | 18.15 | 218.8 | 12.79 | 12.07 | 14.53 | 11.28 | 14.15 | 10.59 | 13.78 | 11.45 | 11.21 |
| 2007 | 21.44 | 20.21 | 24.35 | 18.89 | 23.70 | 17.75 | 23.09 | 19.18 | 18.78 | 226.5 | 12.79 | 12.07 | 14.53 | 11.28 | 14.15 | 10.59 | 13.78 | 11.45 | 11.21 |
| 2008 | 22.19 | 20.92 | 25.20 | 19.55 | 24.53 | 18.37 | 23.89 | 19.85 | 19.44 | 234.4 | 12.79 | 12.07 | 14.53 | 11.28 | 14.15 | 10.59 | 13.78 | 11.45 | 11.21 |
| 2009 | 22.96 | 21.65 | 26.08 | 20.24 | 25.39 | 19.01 | 24.73 | 20.55 | 20.12 | 242.6 | 12.79 | 12.07 | 14.53 | 11.28 | 14.15 | 10.59 | 13.78 | 11.45 | 11.21 |
| 2010 | 23.77 | 22.41 | 27.00 | 20.95 | 26.28 | 19.68 | 25.59 | 21.27 | 20.82 | 251.1 | 12.79 | 12.07 | 14.53 | 11.28 | 14.15 | 10.59 | 13.78 | 11.45 | 11.21 |
| 2011 | 24.60 | 23.20 | 27.94 | 21.68 | 27.20 | 20.37 | 26.49 | 22.01 | 21.55 | 259.9 | 12.79 | 12.07 | 14.53 | 11.28 | 14.15 | 10.59 | 13.78 | 11.45 | 11.21 |
| 2012 | 25.46 | 24.01 | 28.92 | 22.44 | 28.15 | 21.08 | 27.42 | 22.78 | 22.31 | 269.0 | 12.79 | 12.07 | 14.53 | 11.28 | 14.15 | 10.59 | 13.78 | 11.45 | 11.21 |
| 2013 | 26.35 | 24.85 | 29.93 | 23.22 | 29.13 | 21.82 | 28.38 | 23.58 | 23.09 | 278.4 | 12.79 | 12.07 | 14.53 | 11.28 | 14.15 | 10.59 | 13.78 | 11.45 | 11.21 |

COMPOUNDED ANNUAL GROWTH RATES:

| | | | | | | | | | | | | | | | | | | | | |
|------------|--------|--------|--------|--------|--------|--------|--------|--------|--------|-------|--------|--------|--------|--------|--------|--------|--------|--------|--------|--------|
| 1992-1997: | -1.02% | -1.02% | -1.02% | -1.02% | -1.02% | -1.02% | -1.02% | -1.02% | -1.02% | 3.50% | -4.37% | -4.37% | -4.37% | -4.37% | -4.37% | -4.37% | -4.37% | -4.37% | -4.37% | -4.37% |
| 1997-2002: | 0.69% | 0.69% | 0.69% | 0.69% | 0.69% | 0.69% | 0.69% | 0.69% | 0.69% | 3.50% | -2.71% | -2.71% | -2.71% | -2.71% | -2.71% | -2.71% | -2.71% | -2.71% | -2.71% | -2.71% |
| 2002-2013: | 3.50% | 3.50% | 3.50% | 3.50% | 3.50% | 3.50% | 3.50% | 3.50% | 3.50% | 3.50% | 0.00% | 0.00% | 0.00% | 0.00% | 0.00% | 0.00% | 0.00% | 0.00% | 0.00% | 0.00% |
| 1992-2013: | 1.74% | 1.74% | 1.74% | 1.74% | 1.74% | 1.74% | 1.74% | 1.74% | 1.74% | 3.50% | -1.70% | -1.70% | -1.70% | -1.70% | -1.70% | -1.70% | -1.70% | -1.70% | -1.70% | -1.70% |

TABLE B-1

CVEA
ECONOMIC & DEMOGRAPHIC DATA PROJECTIONS

MEDIUM_HIGH CASE
Full PetroStar Expansion

ECONOMIC & DEMOGRAPHIC DATA

VALDEZ AND COPPER RIVER VALLEY

| CALENDAR YEAR | VALDEZ POP | COPPER RIVER POPULATION | TOTAL POP | VALDEZ EMP | COPPER RIVER EMPLOYMENT | TOTAL EMP | HDD (VALDEZ) | HDD (GULKANA) | CPI | PER CAPITA INCOME (VLDZ/CRDV) | REAL PER CAP. INCOME | SALMON HARVEST (PWSMA) | ANS PRODUCTION mil bbl/day | PetroStar Energy Sales (kWh) |
|---------------|------------|-------------------------|-----------|------------|-------------------------|-----------|--------------|---------------|-------|-------------------------------|----------------------|------------------------|----------------------------|------------------------------|
| 1992 | 4,326 | 2,832 | 7,158 | 2,247 | 762 | 3,009 | 9,623 | 13,861 | 135.2 | 27,050 | 27,050 | 11,404 | 1.791 | 2,362,992 |
| 1993 | 4,497 | 2,987 | 7,484 | 2,313 | 821 | 3,134 | 9,711 | 14,004 | 139.9 | 27,997 | 27,050 | 25,538 | 1.683 | 12,190,880 |
| 1994 | 4,558 | 3,008 | 7,565 | 2,336 | 827 | 3,162 | 9,711 | 14,004 | 144.8 | 28,976 | 27,050 | 25,538 | 1.661 | 14,585,400 |
| 1995 | 4,619 | 3,028 | 7,647 | 2,359 | 832 | 3,191 | 9,711 | 14,004 | 149.9 | 29,991 | 27,050 | 25,538 | 1.682 | 18,921,600 |
| 1996 | 4,682 | 3,048 | 7,730 | 2,383 | 838 | 3,220 | 9,711 | 14,004 | 155.1 | 31,040 | 27,050 | 25,538 | 1.612 | 21,286,800 |
| 1997 | 4,745 | 3,069 | 7,814 | 2,406 | 844 | 3,250 | 9,711 | 14,004 | 160.6 | 32,127 | 27,050 | 25,538 | 1.587 | 22,469,400 |
| 1998 | 4,809 | 3,090 | 7,898 | 2,430 | 849 | 3,280 | 9,711 | 14,004 | 166.2 | 33,251 | 27,050 | 25,538 | 1.499 | 22,469,400 |
| 1999 | 4,874 | 3,110 | 7,984 | 2,455 | 855 | 3,310 | 9,711 | 14,004 | 172.0 | 34,415 | 27,050 | 25,538 | 1.409 | 22,469,400 |
| 2000 | 4,940 | 3,131 | 8,071 | 2,479 | 861 | 3,340 | 9,711 | 14,004 | 178.0 | 35,619 | 27,050 | 25,538 | 1.268 | 22,469,400 |
| 2001 | 5,006 | 3,153 | 8,159 | 2,504 | 867 | 3,371 | 9,711 | 14,004 | 184.3 | 36,866 | 27,050 | 25,538 | 1.147 | 22,469,400 |
| 2002 | 5,074 | 3,174 | 8,248 | 2,529 | 872 | 3,401 | 9,711 | 14,004 | 190.7 | 38,156 | 27,050 | 25,538 | 1.069 | 22,469,400 |
| 2003 | 5,142 | 3,195 | 8,338 | 2,554 | 878 | 3,433 | 9,711 | 14,004 | 197.4 | 39,492 | 27,050 | 25,538 | 0.984 | 22,469,400 |
| 2004 | 5,212 | 3,217 | 8,429 | 2,580 | 884 | 3,464 | 9,711 | 14,004 | 204.3 | 40,874 | 27,050 | 25,538 | 0.877 | 22,469,400 |
| 2005 | 5,282 | 3,239 | 8,521 | 2,606 | 890 | 3,496 | 9,711 | 14,004 | 211.4 | 42,305 | 27,050 | 25,538 | 0.832 | 22,469,400 |
| 2006 | 5,353 | 3,260 | 8,614 | 2,632 | 896 | 3,528 | 9,711 | 14,004 | 218.8 | 43,785 | 27,050 | 25,538 | 0.739 | 22,469,400 |
| 2007 | 5,426 | 3,282 | 8,708 | 2,658 | 902 | 3,560 | 9,711 | 14,004 | 226.5 | 45,318 | 27,050 | 25,538 | 0.652 | 22,469,400 |
| 2008 | 5,499 | 3,305 | 8,804 | 2,684 | 908 | 3,593 | 9,711 | 14,004 | 234.4 | 46,904 | 27,050 | 25,538 | 0.582 | 22,469,400 |
| 2009 | 5,573 | 3,327 | 8,900 | 2,711 | 915 | 3,626 | 9,711 | 14,004 | 242.6 | 48,546 | 27,050 | 25,538 | 0.524 | 22,469,400 |
| 2010 | 5,648 | 3,349 | 8,998 | 2,738 | 921 | 3,659 | 9,711 | 14,004 | 251.1 | 50,245 | 27,050 | 25,538 | 0.472 | 22,469,400 |
| 2011 | 5,725 | 3,372 | 9,097 | 2,766 | 927 | 3,693 | 9,711 | 14,004 | 259.9 | 52,003 | 27,050 | 25,538 | 0.472 | 22,469,400 |
| 2012 | 5,802 | 3,395 | 9,197 | 2,793 | 933 | 3,726 | 9,711 | 14,004 | 269.0 | 53,823 | 27,050 | 25,538 | 0.472 | 22,469,400 |
| 2013 | 5,880 | 3,418 | 9,298 | 2,821 | 939 | 3,761 | 9,711 | 14,004 | 278.4 | 55,707 | 27,050 | 25,538 | 0.472 | 22,469,400 |

COMPOUNDED ANNUAL GROWTH RATES:

| | | | | | | | | | | | |
|------------|-------|-------|-------|-------|-------|-------|-------|-------|-------|--------|--------|
| 1992-1997: | 1.87% | 1.62% | 1.77% | 1.38% | 2.05% | 1.55% | 3.50% | 3.50% | 0.00% | -2.39% | 56.90% |
| 1997-2002: | 1.35% | 0.67% | 1.09% | 1.00% | 0.67% | 0.92% | 3.50% | 3.50% | 0.00% | -7.60% | 0.00% |
| 2002-2013: | 1.35% | 0.68% | 1.10% | 1.00% | 0.67% | 0.92% | 3.50% | 3.50% | 0.00% | -7.16% | 0.00% |
| 1992-2013: | 1.47% | 0.90% | 1.25% | 1.09% | 1.00% | 1.07% | 3.50% | 3.50% | 0.00% | -6.15% | 11.32% |

TABLE B-3
CVEA
PROJECTED OPERATING RESULTS

HIGH CASE

ENERGY SALES AND REQUIREMENTS (kWh)

| CALENDAR YEAR | VALDEZ | | | | | | GLENNALLEN | | | | | | CVEA SYSTEM SALES | LINE LOSSES | ENERGY REQUIREMENT | LOSSES AS % OF RPT. | VALDEZ PEAK DEMAND (kW) | GLENN PEAK DEMAND (kW) | TOTAL PEAK DEMAND (kW) | TOTAL SYSTEM LOAD FACTOR |
|---------------|------------|------------|------------|---------|-----------|--------------|------------|-----------|------------|---------|---------|--------------|-------------------|-------------|--------------------|---------------------|-------------------------|------------------------|------------------------|--------------------------|
| | RES | SM.COM | LG.COM | PUB.STL | PUB.BLG | RETAIL SALES | RES | SM.COM | LG.COM | PUB.STL | PUB.BLG | RETAIL SALES | | | | | | | | |
| 1992 | 10,357,519 | 4,951,406 | 20,259,252 | 69,648 | 693,079 | 36,330,904 | 4,342,066 | 4,600,078 | 8,891,200 | 35,936 | 401,978 | 18,271,258 | 54,602,162 | 4,625,014 | 59,227,176 | 7.8% | 7,200 | 3,700 | 10,900 | 62.0% |
| 1993 | 10,875,602 | 5,184,854 | 31,234,010 | 72,400 | 681,763 | 48,048,628 | 4,725,860 | 4,752,999 | 9,871,268 | 37,911 | 445,671 | 19,833,708 | 67,882,336 | 5,091,529 | 72,973,865 | 7.0% | 8,847 | 4,043 | 12,890 | 64.6% |
| 1994 | 11,408,691 | 5,291,030 | 34,143,367 | 73,993 | 690,185 | 51,607,266 | 5,132,286 | 4,897,753 | 10,165,830 | 38,328 | 448,122 | 20,682,319 | 72,289,585 | 5,315,416 | 77,605,002 | 6.8% | 9,365 | 4,293 | 13,658 | 64.9% |
| 1995 | 11,934,456 | 5,444,264 | 40,121,846 | 75,621 | 698,711 | 58,274,899 | 5,476,706 | 5,040,801 | 10,473,627 | 38,749 | 450,587 | 21,480,469 | 79,755,368 | 5,676,048 | 85,431,416 | 6.6% | 10,345 | 4,541 | 14,885 | 65.5% |
| 1996 | 12,422,540 | 5,555,753 | 43,068,972 | 77,285 | 707,343 | 61,831,892 | 5,832,764 | 5,182,293 | 10,786,214 | 39,175 | 453,065 | 22,293,513 | 84,125,405 | 5,898,651 | 90,024,056 | 6.6% | 10,864 | 4,802 | 15,666 | 65.6% |
| 1997 | 12,898,900 | 5,669,525 | 46,829,457 | 78,985 | 716,081 | 66,192,947 | 5,981,850 | 5,216,782 | 11,108,181 | 39,606 | 455,557 | 22,801,976 | 88,994,923 | 6,112,220 | 95,107,144 | 6.4% | 11,487 | 4,911 | 16,398 | 66.2% |
| 1998 | 13,377,321 | 5,785,627 | 47,381,107 | 80,722 | 724,927 | 67,349,704 | 6,134,747 | 5,251,499 | 11,439,485 | 40,042 | 458,063 | 23,323,836 | 90,673,540 | 6,258,187 | 96,931,727 | 6.5% | 11,700 | 5,024 | 16,723 | 66.2% |
| 1999 | 13,865,200 | 5,904,106 | 47,950,510 | 82,498 | 733,883 | 68,536,196 | 6,291,551 | 5,286,448 | 11,780,705 | 40,483 | 460,582 | 23,859,768 | 92,395,964 | 6,407,963 | 98,803,927 | 6.5% | 11,918 | 5,139 | 17,058 | 66.1% |
| 2000 | 14,366,635 | 6,025,011 | 48,538,366 | 84,313 | 742,949 | 69,757,275 | 6,452,363 | 5,321,629 | 12,132,136 | 40,928 | 463,115 | 24,410,171 | 94,167,446 | 6,562,005 | 100,729,451 | 6.5% | 12,143 | 5,258 | 17,401 | 66.1% |
| 2001 | 14,884,039 | 6,148,393 | 49,145,409 | 86,168 | 752,127 | 71,016,136 | 6,617,286 | 5,357,045 | 12,494,086 | 41,378 | 465,662 | 24,975,457 | 95,991,593 | 6,720,627 | 102,712,220 | 6.5% | 12,375 | 5,379 | 17,755 | 66.0% |
| 2002 | 15,266,178 | 6,274,301 | 49,772,406 | 88,064 | 761,419 | 72,162,368 | 6,697,355 | 5,392,696 | 12,866,871 | 41,833 | 468,224 | 25,466,978 | 97,629,346 | 6,863,040 | 104,492,386 | 6.6% | 12,587 | 5,485 | 18,072 | 66.0% |
| 2003 | 15,580,813 | 6,357,464 | 50,420,158 | 90,001 | 770,825 | 73,219,261 | 6,778,393 | 5,428,584 | 13,250,815 | 42,293 | 470,799 | 25,970,884 | 99,190,145 | 6,998,761 | 106,188,906 | 6.6% | 12,781 | 5,594 | 18,375 | 66.0% |
| 2004 | 15,863,134 | 6,441,730 | 51,089,505 | 91,981 | 780,347 | 74,266,697 | 6,860,412 | 5,464,711 | 13,646,253 | 42,759 | 473,388 | 26,487,523 | 100,754,220 | 7,134,768 | 107,888,988 | 6.6% | 12,974 | 5,705 | 18,679 | 65.9% |
| 2005 | 17,926,754 | 8,936,155 | 51,781,326 | 108,939 | 902,653 | 79,655,826 | 7,836,913 | 5,892,523 | 14,053,532 | 48,291 | 504,016 | 28,335,276 | 107,991,102 | 7,764,062 | 115,755,164 | 6.7% | 13,967 | 6,103 | 20,070 | 65.8% |
| 2006 | 20,473,884 | 11,076,766 | 52,496,539 | 131,050 | 995,420 | 85,173,639 | 9,049,793 | 6,394,099 | 14,473,005 | 55,086 | 539,473 | 30,511,457 | 115,685,095 | 8,433,105 | 124,118,200 | 6.8% | 14,984 | 6,572 | 21,556 | 65.7% |
| 2007 | 20,479,721 | 11,076,766 | 53,236,108 | 131,050 | 1,002,101 | 85,925,746 | 9,049,793 | 6,394,099 | 14,905,041 | 55,086 | 539,473 | 30,943,492 | 116,869,237 | 8,536,074 | 125,405,311 | 6.8% | 15,123 | 6,665 | 21,788 | 65.7% |
| 2008 | 20,482,612 | 11,076,766 | 54,001,039 | 131,050 | 1,008,828 | 86,700,294 | 9,049,793 | 6,394,099 | 15,350,014 | 55,086 | 539,473 | 31,388,466 | 118,088,760 | 8,642,119 | 126,730,879 | 6.8% | 15,265 | 6,761 | 22,026 | 65.7% |
| 2009 | 19,411,444 | 10,039,551 | 54,792,389 | 121,564 | 974,094 | 85,339,043 | 8,263,185 | 6,088,423 | 15,808,316 | 50,733 | 518,158 | 30,728,815 | 116,067,858 | 8,466,389 | 124,534,246 | 6.8% | 15,015 | 6,619 | 21,633 | 65.7% |
| 2010 | 18,762,269 | 7,926,511 | 55,611,263 | 115,917 | 887,052 | 83,303,013 | 7,194,949 | 5,655,523 | 16,280,344 | 44,771 | 487,710 | 29,663,297 | 112,966,310 | 8,196,689 | 121,162,999 | 6.8% | 14,639 | 6,389 | 21,028 | 65.8% |
| 2011 | 18,829,694 | 7,951,599 | 56,458,820 | 116,497 | 894,205 | 84,250,815 | 7,274,093 | 5,689,739 | 16,766,513 | 45,218 | 490,149 | 30,265,713 | 114,516,527 | 8,331,490 | 122,848,018 | 6.8% | 14,814 | 6,519 | 21,333 | 65.7% |
| 2012 | 18,897,199 | 7,976,766 | 57,336,274 | 117,079 | 901,415 | 85,228,733 | 7,354,108 | 5,724,162 | 17,267,248 | 45,671 | 492,600 | 30,883,788 | 116,112,520 | 8,470,272 | 124,582,793 | 6.8% | 14,994 | 6,652 | 21,646 | 65.7% |
| 2013 | 18,984,865 | 8,002,013 | 58,244,896 | 117,665 | 908,683 | 86,238,122 | 7,435,003 | 5,758,793 | 17,782,984 | 46,127 | 495,063 | 31,517,971 | 117,756,092 | 8,613,192 | 126,369,284 | 6.8% | 15,180 | 6,789 | 21,969 | 65.7% |

COMPOUNDED ANNUAL GROWTH RATES:

| | | | | | | | | | | | | | | | | | | |
|------------|-------|-------|--------|-------|-------|--------|-------|-------|-------|-------|-------|-------|--------|-------|-------|-------|-------|-------|
| 1992-1997: | 4.48% | 2.75% | 18.24% | 2.55% | 0.66% | 12.75% | 6.62% | 2.55% | 4.55% | 1.96% | 2.53% | 4.53% | 10.26% | 5.73% | 9.94% | 9.79% | 5.83% | 8.51% |
| 1997-2002: | 3.43% | 2.05% | 1.23% | 2.20% | 1.24% | 1.74% | 2.29% | 0.67% | 2.98% | 1.10% | 0.55% | 2.24% | 1.87% | 2.34% | 1.90% | 1.85% | 2.24% | 1.96% |
| 2002-2013: | 1.99% | 2.24% | 1.44% | 2.67% | 1.62% | 1.63% | 0.95% | 0.60% | 2.99% | 0.89% | 0.51% | 1.96% | 1.72% | 2.09% | 1.74% | 1.72% | 1.96% | 1.79% |
| 1992-2013: | 2.92% | 2.31% | 5.16% | 2.53% | 1.30% | 4.20% | 2.59% | 1.08% | 3.36% | 1.20% | 1.00% | 2.63% | 3.73% | 3.01% | 3.67% | 3.62% | 2.93% | 3.39% |

TABLE B-3
CVEA
PROJECTED OPERATING RESULTS

HIGH CASE

AVERAGE ANNUAL NUMBER OF CUSTOMER ACCOUNTS

| CALENDAR YEAR | VALDEZ | | | | | TOTAL RETAIL | GLENNALLEN | | | | | TOTAL RETAIL | TOTAL | | | | |
|---------------|--------|--------|--------|---------|---------|--------------|------------|--------|--------|---------|---------|--------------|-------|-----|-----|-------|-----|
| | RES | SM.COM | LG.COM | PUB.STL | PUB.BLG | | RES | SM.COM | LG.COM | PUB.STL | PUB.BLG | | RES | COM | PUB | TOTAL | |
| 1992 | 1,363 | 231 | 60 | 9 | 29 | 1,692 | 872 | 213 | 11 | 9 | 31 | 1,135 | 2,234 | 515 | 78 | 2,827 | 5.0 |
| 1993 | 1,380 | 233 | 62 | 9 | 30 | 1,713 | 924 | 220 | 12 | 9 | 34 | 1,200 | 2,304 | 526 | 82 | 2,913 | 5.1 |
| 1994 | 1,391 | 234 | 63 | 10 | 30 | 1,728 | 976 | 226 | 12 | 10 | 34 | 1,258 | 2,367 | 536 | 83 | 2,986 | 5.1 |
| 1995 | 1,413 | 237 | 65 | 10 | 30 | 1,754 | 1,027 | 233 | 12 | 10 | 34 | 1,316 | 2,440 | 546 | 84 | 3,071 | 5.2 |
| 1996 | 1,435 | 239 | 66 | 10 | 31 | 1,781 | 1,080 | 240 | 12 | 10 | 35 | 1,376 | 2,515 | 557 | 85 | 3,157 | 5.3 |
| 1997 | 1,458 | 242 | 67 | 10 | 31 | 1,808 | 1,093 | 241 | 12 | 10 | 35 | 1,391 | 2,551 | 562 | 86 | 3,199 | 5.3 |
| 1998 | 1,481 | 244 | 69 | 10 | 31 | 1,835 | 1,106 | 243 | 12 | 10 | 35 | 1,406 | 2,587 | 568 | 87 | 3,241 | 5.3 |
| 1999 | 1,504 | 247 | 70 | 11 | 32 | 1,863 | 1,119 | 244 | 12 | 10 | 35 | 1,421 | 2,623 | 574 | 88 | 3,284 | 5.3 |
| 2000 | 1,527 | 250 | 72 | 11 | 32 | 1,891 | 1,133 | 246 | 12 | 10 | 35 | 1,437 | 2,660 | 579 | 88 | 3,328 | 5.4 |
| 2001 | 1,551 | 252 | 73 | 11 | 32 | 1,920 | 1,147 | 248 | 12 | 10 | 36 | 1,452 | 2,698 | 585 | 89 | 3,372 | 5.4 |
| 2002 | 1,576 | 255 | 74 | 11 | 33 | 1,949 | 1,161 | 249 | 12 | 10 | 36 | 1,468 | 2,736 | 591 | 90 | 3,417 | 5.4 |
| 2003 | 1,600 | 258 | 76 | 12 | 33 | 1,979 | 1,175 | 251 | 12 | 11 | 36 | 1,484 | 2,775 | 597 | 91 | 3,463 | 5.5 |
| 2004 | 1,626 | 261 | 77 | 12 | 33 | 2,009 | 1,189 | 253 | 12 | 11 | 36 | 1,500 | 2,814 | 602 | 92 | 3,509 | 5.5 |
| 2005 | 1,835 | 284 | 79 | 14 | 36 | 2,248 | 1,358 | 272 | 12 | 12 | 38 | 1,693 | 3,193 | 647 | 101 | 3,941 | 5.7 |
| 2006 | 2,094 | 312 | 80 | 17 | 40 | 2,543 | 1,568 | 296 | 12 | 14 | 41 | 1,931 | 3,663 | 699 | 112 | 4,474 | 6.0 |
| 2007 | 2,094 | 312 | 81 | 17 | 40 | 2,544 | 1,568 | 296 | 12 | 14 | 41 | 1,931 | 3,663 | 701 | 112 | 4,475 | 6.0 |
| 2008 | 2,094 | 312 | 83 | 17 | 40 | 2,546 | 1,568 | 296 | 12 | 14 | 41 | 1,931 | 3,663 | 702 | 112 | 4,477 | 6.0 |
| 2009 | 1,985 | 300 | 84 | 16 | 39 | 2,424 | 1,432 | 281 | 12 | 13 | 40 | 1,778 | 3,417 | 678 | 107 | 4,201 | 5.9 |
| 2010 | 1,918 | 293 | 86 | 15 | 38 | 2,350 | 1,247 | 261 | 12 | 11 | 37 | 1,569 | 3,165 | 652 | 101 | 3,919 | 5.7 |
| 2011 | 1,925 | 294 | 87 | 15 | 38 | 2,359 | 1,261 | 263 | 12 | 11 | 37 | 1,584 | 3,186 | 656 | 102 | 3,943 | 5.7 |
| 2012 | 1,932 | 295 | 88 | 15 | 38 | 2,368 | 1,274 | 265 | 12 | 11 | 38 | 1,600 | 3,206 | 660 | 102 | 3,968 | 5.7 |
| 2013 | 1,939 | 296 | 90 | 15 | 38 | 2,378 | 1,288 | 266 | 12 | 12 | 38 | 1,616 | 3,227 | 664 | 103 | 3,994 | 5.7 |

COMPOUNDED ANNUAL GROWTH RATES:

| | | | | | | | | | | | | | | | | |
|------------|-------|-------|-------|-------|-------|-------|-------|-------|-------|-------|-------|-------|-------|-------|-------|-------|
| 1992-1997: | 1.36% | 0.94% | 2.22% | 2.55% | 1.27% | 1.34% | 4.63% | 2.55% | 1.76% | 1.96% | 2.53% | 4.15% | 2.68% | 1.78% | 2.01% | 2.50% |
| 1997-2002: | 1.57% | 1.08% | 2.00% | 2.20% | 1.10% | 1.52% | 1.21% | 0.67% | 0.00% | 1.10% | 0.55% | 1.09% | 1.42% | 0.99% | 1.01% | 1.33% |
| 2002-2013: | 1.90% | 1.35% | 1.73% | 2.67% | 1.41% | 1.82% | 0.95% | 0.60% | 0.00% | 0.89% | 0.51% | 0.88% | 1.51% | 1.06% | 1.18% | 1.43% |
| 1992-2013: | 1.69% | 1.19% | 1.91% | 2.53% | 1.30% | 1.63% | 1.88% | 1.08% | 0.42% | 1.20% | 1.00% | 1.70% | 1.77% | 1.22% | 1.33% | 1.66% |

TABLE B-3
CVEA
PROJECTED OPERATING RESULTS

HIGH CASE

USAGE (KWh) PER CUSTOMER ACCOUNT

| CALENDAR YEAR | VALDEZ | | | | | TOTAL RETAIL | GLENNALLEN | | | | | TOTAL RETAIL | TOTAL | | | |
|---------------|--------|--------|---------|---------|---------|--------------|------------|--------|-----------|---------|---------|--------------|-------|---------|--------|-----------------|
| | RES | SMCOM | LG.COM | PUB.STL | PUB.BLG | | RES | SMCOM | LG.COM | PUB.STL | PUB.BLG | | RES | COM | PUB | TOTAL CUSTOMERS |
| 1992 | 7,601 | 21,458 | 335,789 | 7,739 | 23,899 | 21,475 | 4,981 | 21,630 | 808,291 | 3,993 | 13,108 | 16,098 | 6,579 | 75,186 | 15,459 | 19,316 |
| 1993 | 7,883 | 22,278 | 505,936 | 7,739 | 23,054 | 39,628 | 5,113 | 21,630 | 822,606 | 3,993 | 13,108 | 16,534 | 6,772 | 97,003 | 15,017 | 30,116 |
| 1994 | 8,201 | 22,605 | 540,784 | 7,739 | 23,084 | 41,840 | 5,261 | 21,630 | 847,153 | 3,993 | 13,108 | 16,444 | 6,989 | 101,745 | 15,023 | 31,141 |
| 1995 | 8,446 | 23,010 | 621,673 | 7,739 | 23,115 | 45,468 | 5,331 | 21,630 | 872,802 | 3,993 | 13,108 | 16,317 | 7,135 | 111,831 | 15,030 | 32,970 |
| 1996 | 8,656 | 23,230 | 653,152 | 7,739 | 23,146 | 47,240 | 5,402 | 21,630 | 898,851 | 3,993 | 13,108 | 16,205 | 7,259 | 116,031 | 15,036 | 33,714 |
| 1997 | 8,849 | 23,451 | 695,399 | 7,739 | 23,177 | 49,226 | 5,474 | 21,630 | 925,682 | 3,993 | 13,108 | 16,396 | 7,403 | 122,402 | 15,042 | 34,952 |
| 1998 | 9,035 | 23,675 | 689,244 | 7,739 | 23,208 | 49,404 | 5,546 | 21,630 | 953,290 | 3,993 | 13,108 | 16,591 | 7,543 | 123,010 | 15,048 | 35,172 |
| 1999 | 9,220 | 23,901 | 683,588 | 7,739 | 23,239 | 49,590 | 5,620 | 21,630 | 981,725 | 3,993 | 13,108 | 16,789 | 7,684 | 123,650 | 15,054 | 35,397 |
| 2000 | 9,406 | 24,129 | 678,412 | 7,739 | 23,271 | 49,785 | 5,695 | 21,630 | 1,011,011 | 3,993 | 13,108 | 16,992 | 7,826 | 124,323 | 15,060 | 35,630 |
| 2001 | 9,594 | 24,359 | 673,698 | 7,739 | 23,302 | 49,992 | 5,771 | 21,630 | 1,041,174 | 3,993 | 13,108 | 17,198 | 7,969 | 125,031 | 15,065 | 35,870 |
| 2002 | 9,688 | 24,592 | 669,430 | 7,739 | 23,333 | 50,086 | 5,771 | 21,630 | 1,072,239 | 3,993 | 13,108 | 17,347 | 8,027 | 125,772 | 15,071 | 36,021 |
| 2003 | 9,735 | 24,651 | 665,594 | 7,739 | 23,364 | 50,127 | 5,771 | 21,630 | 1,104,235 | 3,993 | 13,108 | 17,499 | 8,057 | 126,473 | 15,076 | 36,144 |
| 2004 | 9,758 | 24,710 | 662,177 | 7,739 | 23,395 | 50,159 | 5,771 | 21,630 | 1,137,188 | 3,993 | 13,108 | 17,655 | 8,074 | 127,209 | 15,082 | 36,262 |
| 2005 | 9,770 | 31,481 | 659,168 | 7,739 | 24,778 | 48,042 | 5,771 | 21,630 | 1,171,128 | 3,993 | 13,108 | 16,737 | 8,069 | 124,705 | 15,476 | 34,593 |
| 2006 | 9,775 | 35,553 | 656,557 | 7,739 | 24,807 | 45,492 | 5,771 | 21,630 | 1,206,084 | 3,993 | 13,108 | 15,803 | 8,061 | 120,781 | 15,365 | 32,678 |
| 2007 | 9,778 | 35,553 | 654,336 | 7,739 | 24,974 | 45,932 | 5,771 | 21,630 | 1,242,087 | 3,993 | 13,108 | 16,026 | 8,062 | 122,211 | 15,424 | 33,029 |
| 2008 | 9,780 | 35,553 | 652,496 | 7,739 | 25,141 | 46,386 | 5,771 | 21,630 | 1,279,168 | 3,993 | 13,108 | 16,257 | 8,063 | 123,691 | 15,484 | 33,391 |
| 2009 | 9,780 | 33,431 | 651,032 | 7,739 | 25,187 | 47,891 | 5,771 | 21,630 | 1,317,360 | 3,993 | 13,108 | 17,286 | 8,100 | 127,930 | 15,612 | 34,941 |
| 2010 | 9,781 | 27,019 | 649,937 | 7,739 | 23,482 | 48,071 | 5,771 | 21,630 | 1,356,695 | 3,993 | 13,108 | 18,910 | 8,201 | 131,016 | 15,176 | 36,397 |
| 2011 | 9,781 | 27,038 | 649,207 | 7,739 | 23,612 | 48,541 | 5,771 | 21,630 | 1,397,209 | 3,993 | 13,108 | 19,104 | 8,194 | 132,399 | 15,211 | 36,715 |
| 2012 | 9,781 | 27,057 | 648,839 | 7,739 | 23,743 | 49,027 | 5,771 | 21,630 | 1,438,937 | 3,993 | 13,108 | 19,302 | 8,187 | 133,832 | 15,246 | 37,042 |
| 2013 | 9,781 | 27,076 | 648,829 | 7,739 | 23,875 | 49,528 | 5,771 | 21,630 | 1,481,915 | 3,993 | 13,108 | 19,504 | 8,180 | 135,316 | 15,280 | 37,379 |

COMPOUNDED ANNUAL GROWTH RATES:

| | | | | | | | | | | | | | | | | |
|------------|-------|-------|--------|-------|--------|--------|-------|-------|-------|-------|-------|-------|-------|--------|--------|--------|
| 1992-1997: | 3.09% | 1.79% | 15.67% | 0.00% | -0.61% | 18.05% | 1.90% | 0.00% | 2.75% | 0.00% | 0.00% | 0.37% | 2.39% | 10.24% | -0.55% | 12.59% |
| 1997-2002: | 1.83% | 0.95% | -0.76% | 0.00% | 0.13% | 0.35% | 1.06% | 0.00% | 2.98% | 0.00% | 0.00% | 1.13% | 1.63% | 0.54% | 0.04% | 0.60% |
| 2002-2013: | 0.09% | 0.88% | -0.28% | 0.00% | 0.21% | -0.10% | 0.00% | 0.00% | 2.99% | 0.00% | 0.00% | 1.07% | 0.17% | 0.67% | 0.13% | 0.34% |
| 1992-2013: | 1.21% | 1.11% | 3.19% | 0.00% | -0.00% | 4.06% | 0.70% | 0.00% | 2.93% | 0.00% | 0.00% | 0.92% | 1.04% | 2.84% | -0.06% | 3.19% |

TABLE B-3
CVEA
PROJECTED OPERATING RESULTS

HIGH CASE

NOMINAL COST OF ELECTRICITY
(CENTS/KWH - NOMINAL)

REAL COST OF ELECTRICITY
(CENTS/KWH - CONSTANT 1992 DOLLARS)

| CALENDAR YEAR | RES | Valdez RES | Glenn RES | Valdez SM.COM | Glenn SM.COM | COM | PUB.STL | PUB.BLG | OVERALL AVERAGE |
|---------------|-------|------------|-----------|---------------|--------------|-------|---------|---------|-----------------|
| 1992 | 18.36 | 17.31 | 20.85 | 16.18 | 20.29 | 15.20 | 19.77 | 16.43 | 16.08 |
| 1993 | 18.36 | 17.31 | 20.85 | 16.18 | 20.29 | 15.20 | 19.77 | 16.43 | 16.08 |
| 1994 | 17.44 | 16.44 | 19.81 | 15.37 | 19.28 | 14.44 | 18.78 | 15.61 | 15.28 |
| 1995 | 17.44 | 16.44 | 19.81 | 15.37 | 19.28 | 14.44 | 18.78 | 15.61 | 15.28 |
| 1996 | 17.44 | 16.44 | 19.81 | 15.37 | 19.28 | 14.44 | 18.78 | 15.61 | 15.28 |
| 1997 | 17.44 | 16.44 | 19.81 | 15.37 | 19.28 | 14.44 | 18.78 | 15.61 | 15.28 |
| 1998 | 17.44 | 16.44 | 19.81 | 15.37 | 19.28 | 14.44 | 18.78 | 15.61 | 15.28 |
| 1999 | 17.44 | 16.44 | 19.81 | 15.37 | 19.28 | 14.44 | 18.78 | 15.61 | 15.28 |
| 2000 | 17.44 | 16.44 | 19.81 | 15.37 | 19.28 | 14.44 | 18.78 | 15.61 | 15.28 |
| 2001 | 17.44 | 16.44 | 19.81 | 15.37 | 19.28 | 14.44 | 18.78 | 15.61 | 15.28 |
| 2002 | 18.22 | 17.18 | 20.70 | 16.06 | 20.15 | 15.09 | 19.62 | 16.31 | 15.97 |
| 2003 | 19.04 | 17.96 | 21.63 | 16.78 | 21.05 | 15.77 | 20.51 | 17.04 | 16.68 |
| 2004 | 19.90 | 18.77 | 22.60 | 17.54 | 22.00 | 16.48 | 21.43 | 17.81 | 17.44 |
| 2005 | 20.80 | 19.61 | 23.62 | 18.33 | 22.99 | 17.22 | 22.40 | 18.61 | 18.22 |
| 2006 | 21.73 | 20.49 | 24.68 | 19.15 | 24.03 | 17.99 | 23.40 | 19.45 | 19.04 |
| 2007 | 22.71 | 21.42 | 25.80 | 20.02 | 25.11 | 18.80 | 24.46 | 20.32 | 19.90 |
| 2008 | 23.73 | 22.38 | 26.96 | 20.92 | 26.24 | 19.65 | 25.56 | 21.24 | 20.79 |
| 2009 | 24.80 | 23.39 | 28.17 | 21.86 | 27.42 | 20.53 | 26.71 | 22.19 | 21.73 |
| 2010 | 25.91 | 24.44 | 29.44 | 22.84 | 28.65 | 21.46 | 27.91 | 23.19 | 22.71 |
| 2011 | 27.08 | 25.54 | 30.76 | 23.87 | 29.94 | 22.42 | 29.16 | 24.24 | 23.73 |
| 2012 | 28.30 | 26.69 | 32.15 | 24.94 | 31.29 | 23.43 | 30.48 | 25.33 | 24.79 |
| 2013 | 29.57 | 27.89 | 33.59 | 26.06 | 32.70 | 24.49 | 31.85 | 26.47 | 25.91 |

| CPI | RES | Valdez RES | Glenn RES | Valdez SM.COM | Glenn SM.COM | COM | PUB.STL | PUB.BLG | OVERALL AVERAGE |
|-------|-------|------------|-----------|---------------|--------------|-------|---------|---------|-----------------|
| 135.2 | 18.36 | 17.31 | 20.85 | 16.18 | 20.29 | 15.20 | 19.77 | 16.43 | 16.08 |
| 141.3 | 17.57 | 16.56 | 19.95 | 15.48 | 19.42 | 14.54 | 18.92 | 15.72 | 15.39 |
| 147.6 | 15.97 | 15.06 | 18.14 | 14.07 | 17.66 | 13.22 | 17.20 | 14.29 | 13.99 |
| 154.3 | 15.28 | 14.41 | 17.36 | 13.47 | 16.89 | 12.65 | 16.46 | 13.68 | 13.39 |
| 161.2 | 14.62 | 13.79 | 16.61 | 12.89 | 16.17 | 12.11 | 15.75 | 13.09 | 12.81 |
| 168.5 | 13.99 | 13.20 | 15.90 | 12.33 | 15.47 | 11.59 | 15.07 | 12.52 | 12.26 |
| 176.1 | 13.39 | 12.63 | 15.21 | 11.80 | 14.80 | 11.09 | 14.42 | 11.98 | 11.73 |
| 184.0 | 12.81 | 12.08 | 14.56 | 11.29 | 14.17 | 10.61 | 13.80 | 11.47 | 11.23 |
| 192.3 | 12.26 | 11.56 | 13.93 | 10.81 | 13.56 | 10.15 | 13.21 | 10.97 | 10.74 |
| 200.9 | 11.73 | 11.07 | 13.33 | 10.34 | 12.97 | 9.72 | 12.64 | 10.50 | 10.28 |
| 210.0 | 11.73 | 11.07 | 13.33 | 10.34 | 12.97 | 9.72 | 12.64 | 10.50 | 10.28 |
| 219.4 | 11.73 | 11.07 | 13.33 | 10.34 | 12.97 | 9.72 | 12.64 | 10.50 | 10.28 |
| 229.3 | 11.73 | 11.07 | 13.33 | 10.34 | 12.97 | 9.72 | 12.64 | 10.50 | 10.28 |
| 239.6 | 11.73 | 11.07 | 13.33 | 10.34 | 12.97 | 9.72 | 12.64 | 10.50 | 10.28 |
| 250.4 | 11.73 | 11.07 | 13.33 | 10.34 | 12.97 | 9.72 | 12.64 | 10.50 | 10.28 |
| 261.7 | 11.73 | 11.07 | 13.33 | 10.34 | 12.97 | 9.72 | 12.64 | 10.50 | 10.28 |
| 273.4 | 11.73 | 11.07 | 13.33 | 10.34 | 12.97 | 9.72 | 12.64 | 10.50 | 10.28 |
| 285.7 | 11.73 | 11.07 | 13.33 | 10.34 | 12.97 | 9.72 | 12.64 | 10.50 | 10.28 |
| 298.6 | 11.73 | 11.07 | 13.33 | 10.34 | 12.97 | 9.72 | 12.64 | 10.50 | 10.28 |
| 312.0 | 11.73 | 11.07 | 13.33 | 10.34 | 12.97 | 9.72 | 12.64 | 10.50 | 10.28 |
| 326.1 | 11.73 | 11.07 | 13.33 | 10.34 | 12.97 | 9.72 | 12.64 | 10.50 | 10.28 |
| 340.7 | 11.73 | 11.07 | 13.33 | 10.34 | 12.97 | 9.72 | 12.64 | 10.50 | 10.28 |

COMPOUNDED ANNUAL GROWTH RATES:

| | | | | | | | | | | | | | | | | | | | |
|------------|--------|--------|--------|--------|--------|--------|--------|--------|--------|-------|--------|--------|--------|--------|--------|--------|--------|--------|--------|
| 1992-1997: | -1.02% | -1.02% | -1.02% | -1.02% | -1.02% | -1.02% | -1.02% | -1.02% | -1.02% | 4.50% | -5.28% | -5.28% | -5.28% | -5.28% | -5.28% | -5.28% | -5.28% | -5.28% | -5.28% |
| 1997-2002: | 0.88% | 0.88% | 0.88% | 0.88% | 0.88% | 0.88% | 0.88% | 0.88% | 0.88% | 4.50% | -3.46% | -3.46% | -3.46% | -3.46% | -3.46% | -3.46% | -3.46% | -3.46% | -3.46% |
| 2002-2013: | 4.50% | 4.50% | 4.50% | 4.50% | 4.50% | 4.50% | 4.50% | 4.50% | 4.50% | 4.50% | -0.00% | -0.00% | -0.00% | -0.00% | -0.00% | -0.00% | -0.00% | -0.00% | -0.00% |
| 1992-2013: | 2.30% | 2.30% | 2.30% | 2.30% | 2.30% | 2.30% | 2.30% | 2.30% | 2.30% | 4.50% | -2.11% | -2.11% | -2.11% | -2.11% | -2.11% | -2.11% | -2.11% | -2.11% | -2.11% |

CVEA
ECONOMIC & DEMOGRAPHIC DATA PROJECTIONS

HIGH CASE

ECONOMIC & DEMOGRAPHIC DATA

| CALENDAR YEAR | VALDEZ AND COPPER RIVER VALLEY | | | | | | HDD (VALDEZ) | HDD (GULKANA) | PER CAPITA INCOME (VLDZ/GRDV) | REAL PER CAP. INCOME | SALMON HARVEST (FWSMA) | ANS PRODUCTION mil bb/day | PetroStar Energy Sales (KWh) |
|---------------|--------------------------------|-------------------------|-----------|------------|-------------------------|-----------|--------------|---------------|-------------------------------|----------------------|------------------------|---------------------------|------------------------------|
| | VALDEZ POP | COPPER RIVER POPULATION | TOTAL POP | VALDEZ EMP | COPPER RIVER EMPLOYMENT | TOTAL EMP | | | | | | | |
| 1992 | 4,326 | 2,832 | 7,158 | 2,247 | 762 | 3,009 | 9,623 | 135.2 | 27,050 | 27,050 | 11,404 | 1.791 | 2,362,992 |
| 1993 | 4,497 | 2,987 | 7,484 | 2,294 | 821 | 3,115 | 9,711 | 141.3 | 28,832 | 27,591 | 25,538 | 1.683 | 12,190,880 |
| 1994 | 4,596 | 3,020 | 7,616 | 2,342 | 830 | 3,172 | 9,711 | 147.6 | 30,732 | 28,143 | 25,538 | 1.661 | 14,585,400 |
| 1995 | 4,697 | 3,053 | 7,751 | 2,391 | 839 | 3,231 | 9,711 | 154.3 | 32,758 | 28,705 | 25,538 | 1.682 | 18,921,600 |
| 1996 | 4,800 | 3,087 | 7,887 | 2,442 | 849 | 3,290 | 9,711 | 161.2 | 34,916 | 29,280 | 25,538 | 1.612 | 21,286,800 |
| 1997 | 4,906 | 3,121 | 8,027 | 2,493 | 858 | 3,351 | 9,711 | 168.5 | 37,217 | 29,865 | 25,538 | 1.744 | 24,440,400 |
| 1998 | 5,014 | 3,155 | 8,169 | 2,545 | 867 | 3,413 | 9,711 | 176.1 | 39,670 | 30,462 | 25,538 | 1.609 | 24,440,400 |
| 1999 | 5,124 | 3,190 | 8,314 | 2,599 | 877 | 3,476 | 9,711 | 184.0 | 42,284 | 31,072 | 25,538 | 1.649 | 24,440,400 |
| 2000 | 5,237 | 3,225 | 8,462 | 2,653 | 887 | 3,540 | 9,711 | 192.3 | 45,071 | 31,693 | 25,538 | 1.489 | 24,440,400 |
| 2001 | 5,352 | 3,261 | 8,613 | 2,709 | 896 | 3,605 | 9,711 | 200.9 | 48,041 | 32,327 | 25,538 | 1.350 | 24,440,400 |
| 2002 | 5,470 | 3,297 | 8,766 | 2,766 | 906 | 3,672 | 9,711 | 210.0 | 51,207 | 32,974 | 25,538 | 1.265 | 24,440,400 |
| 2003 | 5,590 | 3,333 | 8,923 | 2,824 | 916 | 3,740 | 9,711 | 219.4 | 54,581 | 33,633 | 25,538 | 1.169 | 24,440,400 |
| 2004 | 5,713 | 3,369 | 9,083 | 2,883 | 926 | 3,809 | 9,711 | 229.3 | 58,178 | 34,306 | 25,538 | 1.081 | 24,440,400 |
| 2005 | 6,767 | 3,805 | 10,572 | 4,833 | 1,397 | 6,231 | 9,711 | 239.6 | 62,012 | 34,992 | 25,538 | 1.014 | 24,440,400 |
| 2006 | 8,140 | 4,341 | 12,481 | 6,783 | 1,765 | 8,548 | 9,711 | 250.4 | 66,099 | 35,692 | 25,538 | 0.914 | 24,440,400 |
| 2007 | 8,140 | 4,341 | 12,481 | 6,783 | 1,765 | 8,548 | 9,711 | 261.7 | 70,455 | 36,405 | 25,538 | 0.832 | 24,440,400 |
| 2008 | 8,140 | 4,341 | 12,481 | 6,783 | 1,765 | 8,548 | 9,711 | 273.4 | 75,098 | 37,134 | 25,538 | 0.761 | 24,440,400 |
| 2009 | 7,551 | 3,998 | 11,549 | 5,808 | 1,529 | 7,338 | 9,711 | 285.7 | 80,047 | 37,876 | 25,538 | 0.691 | 24,440,400 |
| 2010 | 7,200 | 3,528 | 10,728 | 4,000 | 980 | 4,980 | 9,711 | 298.6 | 85,322 | 38,634 | 25,538 | 0.627 | 24,440,400 |
| 2011 | 7,236 | 3,563 | 10,799 | 4,020 | 991 | 5,011 | 9,711 | 312.0 | 90,944 | 39,406 | 25,538 | 0.627 | 24,440,400 |
| 2012 | 7,272 | 3,599 | 10,871 | 4,040 | 1,002 | 5,042 | 9,711 | 326.1 | 96,938 | 40,195 | 25,538 | 0.627 | 24,440,400 |
| 2013 | 7,309 | 3,635 | 10,943 | 4,060 | 1,013 | 5,073 | 9,711 | 340.7 | 103,326 | 40,998 | 25,538 | 0.627 | 24,440,400 |

COMPOUNDED ANNUAL GROWTH RATES:

| | | | | | | | | | | | | |
|------------|-------|-------|-------|-------|-------|-------|--|-------|-------|-------|--------|--------|
| 1992-1997: | 2.55% | 1.96% | 2.32% | 2.10% | 2.39% | 2.17% | | 4.50% | 6.59% | 2.00% | -0.53% | 59.56% |
| 1997-2002: | 2.20% | 1.10% | 1.78% | 2.10% | 1.10% | 1.85% | | 4.50% | 6.59% | 2.00% | -6.22% | 0.00% |
| 2002-2013: | 2.67% | 0.89% | 2.04% | 3.55% | 1.02% | 2.98% | | 4.50% | 6.59% | 2.00% | -6.18% | 0.00% |
| 1992-2013: | 2.53% | 1.20% | 2.04% | 2.86% | 1.36% | 2.52% | | 4.50% | 6.59% | 2.00% | -4.88% | 11.77% |

TABLE B-4
CVEA
PROJECTED OPERATING RESULTS

LOW CASE

ENERGY SALES AND REQUIREMENTS (kWh)

| CALENDAR YEAR | VALDEZ | | | | | | GLENNALLEN | | | | | | CVEA SYSTEM SALES | LINE LOSSES | ENERGY REQUIREMENT | LOSSES AS % OF RQT | VALDEZ PEAK DEMAND (kW) | GLENN PEAK DEMAND (kW) | TOTAL PEAK DEMAND (kW) | TOTAL SYSTEM LOAD FACTOR |
|---------------|------------|-----------|------------|---------|---------|--------------|------------|-----------|-----------|---------|---------|--------------|-------------------|-------------|--------------------|--------------------|-------------------------|------------------------|------------------------|--------------------------|
| | RES | SM.COM | LG.COM | PUB.STL | PUB.BLG | RETAIL SALES | RES | SM.COM | LG.COM | PUB.STL | PUB.BLG | RETAIL SALES | | | | | | | | |
| 1992 | 10,357,519 | 4,951,406 | 20,259,252 | 69,648 | 693,079 | 36,330,904 | 4,342,066 | 4,600,078 | 8,891,200 | 35,936 | 401,978 | 18,271,258 | 54,602,162 | 4,625,014 | 59,227,176 | 7.8% | 7,200 | 3,700 | 10,900 | 62.0% |
| 1993 | 10,828,156 | 5,211,333 | 30,725,619 | 72,400 | 676,383 | 47,513,891 | 4,698,528 | 4,752,999 | 9,123,482 | 37,911 | 445,671 | 19,058,591 | 66,572,482 | 4,977,628 | 71,550,111 | 7.0% | 8,748 | 3,885 | 12,633 | 64.7% |
| 1994 | 11,014,957 | 5,202,657 | 33,134,311 | 71,531 | 672,475 | 50,095,932 | 4,926,787 | 4,818,187 | 8,927,363 | 38,024 | 446,340 | 19,156,701 | 69,252,633 | 5,051,334 | 74,303,967 | 6.8% | 9,086 | 3,976 | 13,063 | 64.9% |
| 1995 | 11,161,769 | 5,237,171 | 38,591,259 | 70,673 | 668,591 | 55,729,463 | 5,084,597 | 4,882,875 | 8,740,832 | 38,138 | 447,009 | 19,193,451 | 74,922,913 | 5,255,835 | 80,178,748 | 6.6% | 9,876 | 4,057 | 13,933 | 65.7% |
| 1996 | 11,248,535 | 5,228,452 | 38,807,374 | 69,825 | 664,728 | 55,818,914 | 5,244,884 | 4,947,080 | 8,554,964 | 38,253 | 447,680 | 19,232,860 | 75,051,774 | 5,267,040 | 80,318,813 | 6.6% | 9,892 | 4,143 | 14,035 | 65.3% |
| 1997 | 11,305,267 | 5,219,748 | 37,667,051 | 68,987 | 660,888 | 54,921,940 | 5,301,337 | 4,956,059 | 8,370,223 | 38,368 | 448,351 | 19,114,338 | 74,036,278 | 5,178,736 | 79,215,014 | 6.5% | 9,727 | 4,117 | 13,844 | 65.3% |
| 1998 | 11,347,084 | 5,211,058 | 36,727,676 | 68,159 | 657,070 | 54,011,047 | 5,358,397 | 4,965,054 | 8,190,301 | 38,483 | 449,024 | 19,001,258 | 73,012,305 | 5,089,695 | 78,102,000 | 6.5% | 9,559 | 4,093 | 13,651 | 65.3% |
| 1999 | 11,381,535 | 5,202,382 | 36,746,634 | 67,341 | 653,274 | 54,051,167 | 5,416,072 | 4,974,065 | 8,018,888 | 38,598 | 449,697 | 18,897,321 | 72,948,488 | 5,084,145 | 78,032,633 | 6.5% | 9,566 | 4,070 | 13,637 | 65.3% |
| 2000 | 11,412,369 | 5,193,721 | 36,766,523 | 66,533 | 649,501 | 54,088,646 | 5,474,368 | 4,983,093 | 7,852,061 | 38,714 | 450,372 | 18,798,608 | 72,887,254 | 5,078,821 | 77,966,075 | 6.5% | 9,573 | 4,049 | 13,622 | 65.3% |
| 2001 | 11,441,445 | 5,185,074 | 36,787,334 | 65,735 | 645,749 | 54,125,336 | 5,533,291 | 4,992,138 | 7,689,707 | 38,830 | 451,047 | 18,705,014 | 72,830,350 | 5,073,872 | 77,904,223 | 6.5% | 9,580 | 4,029 | 13,609 | 65.3% |
| 2002 | 11,405,787 | 5,176,442 | 36,809,059 | 64,946 | 642,018 | 54,098,252 | 5,551,551 | 5,001,198 | 7,531,719 | 38,947 | 451,724 | 18,575,138 | 72,673,390 | 5,060,224 | 77,733,614 | 6.5% | 9,575 | 4,001 | 13,576 | 65.4% |
| 2003 | 11,338,491 | 5,147,271 | 36,831,691 | 64,167 | 638,309 | 54,019,928 | 5,569,871 | 5,010,276 | 7,377,988 | 39,063 | 452,402 | 18,449,600 | 72,469,528 | 5,042,497 | 77,512,025 | 6.5% | 9,561 | 3,974 | 13,534 | 65.4% |
| 2004 | 11,256,049 | 5,118,264 | 36,855,223 | 63,397 | 634,622 | 53,927,554 | 5,588,252 | 5,019,369 | 7,228,413 | 39,181 | 453,080 | 18,328,295 | 72,255,849 | 5,023,916 | 77,279,765 | 6.5% | 9,543 | 3,948 | 13,491 | 65.4% |
| 2005 | 11,166,600 | 5,089,420 | 36,879,648 | 62,636 | 630,956 | 53,829,259 | 5,606,693 | 5,028,479 | 7,082,893 | 39,298 | 453,760 | 18,211,123 | 72,040,382 | 5,005,180 | 77,045,562 | 6.5% | 9,525 | 3,922 | 13,448 | 65.4% |
| 2006 | 11,074,140 | 5,060,739 | 36,904,959 | 61,884 | 627,311 | 53,729,033 | 5,625,195 | 5,037,606 | 6,941,328 | 39,416 | 454,440 | 18,097,985 | 71,827,018 | 4,986,626 | 76,813,644 | 6.5% | 9,507 | 3,898 | 13,405 | 65.4% |
| 2007 | 10,980,624 | 5,032,220 | 36,931,150 | 61,142 | 623,687 | 53,628,822 | 5,643,758 | 5,046,749 | 6,803,623 | 39,534 | 455,122 | 17,988,787 | 71,617,609 | 4,968,417 | 76,586,026 | 6.5% | 9,488 | 3,875 | 13,363 | 65.4% |
| 2008 | 10,887,007 | 5,003,861 | 36,958,215 | 60,408 | 620,084 | 53,529,575 | 5,662,383 | 5,055,909 | 6,669,685 | 39,653 | 455,805 | 17,883,434 | 71,413,009 | 4,950,625 | 76,363,635 | 6.5% | 9,470 | 3,852 | 13,322 | 65.4% |
| 2009 | 10,793,752 | 4,975,662 | 36,986,148 | 59,683 | 616,502 | 53,431,748 | 5,681,068 | 5,065,086 | 6,539,423 | 39,772 | 456,489 | 17,781,837 | 71,213,585 | 4,933,284 | 76,146,869 | 6.5% | 9,452 | 3,830 | 13,282 | 65.4% |
| 2010 | 10,701,083 | 4,788,387 | 37,014,944 | 58,967 | 604,489 | 53,167,870 | 5,699,818 | 5,074,279 | 6,412,748 | 39,891 | 457,173 | 17,683,907 | 70,851,777 | 4,901,823 | 75,753,600 | 6.5% | 9,404 | 3,809 | 13,212 | 65.5% |
| 2011 | 10,609,105 | 4,598,497 | 36,779,126 | 58,259 | 592,183 | 52,637,170 | 5,718,625 | 5,083,489 | 3,764,566 | 40,011 | 457,859 | 15,064,549 | 67,701,719 | 4,627,905 | 72,329,624 | 6.4% | 9,306 | 3,245 | 12,550 | 65.8% |
| 2012 | 10,517,866 | 4,405,707 | 36,683,533 | 57,560 | 579,546 | 52,244,213 | 5,737,497 | 5,092,715 | 2,445,429 | 40,131 | 458,546 | 13,774,317 | 66,018,530 | 4,481,540 | 70,500,070 | 6.4% | 9,233 | 2,967 | 12,200 | 66.0% |
| 2013 | 10,427,388 | 4,209,689 | 17,666,848 | 56,869 | 566,532 | 32,927,326 | 5,756,431 | 5,101,958 | 1,126,386 | 40,251 | 459,234 | 12,484,260 | 45,411,586 | 3,948,834 | 49,360,420 | 8.0% | 6,760 | 2,689 | 9,449 | 59.6% |

COMPOUNDED ANNUAL GROWTH RATES:

| | | | | | | | | | | | | | | | | | | |
|------------|--------|--------|--------|--------|--------|--------|-------|-------|---------|-------|-------|--------|--------|--------|--------|--------|--------|--------|
| 1992-1997: | 1.77% | 1.06% | 13.21% | -0.19% | -0.95% | 8.62% | 4.07% | 1.50% | -1.20% | 1.32% | 2.21% | 0.91% | 6.28% | 2.29% | 5.99% | 6.20% | 2.16% | 4.90% |
| 1997-2002: | 0.18% | -0.17% | -0.46% | -1.20% | -0.58% | -0.30% | 0.93% | 0.18% | -2.09% | 0.30% | 0.15% | -0.57% | -0.37% | 0.46% | -0.38% | -0.31% | -0.57% | -0.39% |
| 2002-2013: | -0.81% | -1.86% | -6.46% | -1.20% | -1.13% | -4.41% | 0.33% | 0.18% | -15.86% | 0.30% | 0.15% | -3.55% | -4.18% | -2.23% | -4.04% | -3.11% | -3.55% | -3.24% |
| 1992-2013: | 0.03% | -0.77% | -0.65% | -0.96% | -0.96% | -0.47% | 1.35% | 0.49% | -9.37% | 0.54% | 0.64% | -1.80% | -0.87% | -0.75% | -0.86% | -0.30% | -1.51% | -0.68% |

TABLE B-4
CVEA
PROJECTED OPERATING RESULTS

LOW CASE

AVERAGE ANNUAL NUMBER OF CUSTOMER ACCOUNTS

| CALENDAR YEAR | VALDEZ | | | | | TOTAL RETAIL | GLENNALLEN | | | | | TOTAL RETAIL | TOTAL | | | | |
|---------------|--------|-------|--------|---------|---------|--------------|------------|-------|--------|---------|---------|--------------|-------|-----|-----|-------|-----|
| | RES | SMCOM | LG.COM | PUB.STL | PUB.BLG | | RES | SMCOM | LG.COM | PUB.STL | PUB.BLG | | RES | COM | PUB | TOTAL | |
| 1992 | 1,363 | 231 | 60 | 9 | 29 | 1,692 | 872 | 213 | 11 | 9 | 31 | 1,135 | 2,234 | 515 | 78 | 2,827 | 5.0 |
| 1993 | 1,380 | 233 | 62 | 9 | 30 | 1,713 | 924 | 220 | 12 | 9 | 34 | 1,200 | 2,304 | 526 | 82 | 2,912 | 5.1 |
| 1994 | 1,358 | 230 | 61 | 9 | 29 | 1,688 | 947 | 223 | 12 | 10 | 34 | 1,226 | 2,305 | 526 | 82 | 2,914 | 5.1 |
| 1995 | 1,346 | 229 | 61 | 9 | 29 | 1,674 | 971 | 226 | 12 | 10 | 34 | 1,252 | 2,317 | 527 | 82 | 2,926 | 5.1 |
| 1996 | 1,335 | 227 | 60 | 9 | 29 | 1,661 | 994 | 229 | 12 | 10 | 34 | 1,278 | 2,328 | 529 | 82 | 2,939 | 5.1 |
| 1997 | 1,323 | 226 | 60 | 9 | 29 | 1,647 | 997 | 229 | 12 | 10 | 34 | 1,282 | 2,320 | 527 | 82 | 2,929 | 5.1 |
| 1998 | 1,312 | 225 | 60 | 9 | 29 | 1,634 | 1,000 | 230 | 12 | 10 | 34 | 1,286 | 2,312 | 526 | 81 | 2,919 | 5.1 |
| 1999 | 1,300 | 223 | 59 | 9 | 29 | 1,620 | 1,004 | 230 | 12 | 10 | 34 | 1,290 | 2,304 | 525 | 81 | 2,910 | 5.1 |
| 2000 | 1,289 | 222 | 59 | 9 | 28 | 1,607 | 1,007 | 230 | 12 | 10 | 34 | 1,293 | 2,296 | 523 | 81 | 2,901 | 5.1 |
| 2001 | 1,278 | 221 | 59 | 8 | 28 | 1,594 | 1,010 | 231 | 12 | 10 | 34 | 1,297 | 2,288 | 522 | 81 | 2,891 | 5.1 |
| 2002 | 1,267 | 219 | 58 | 8 | 28 | 1,581 | 1,014 | 231 | 12 | 10 | 34 | 1,301 | 2,281 | 521 | 81 | 2,882 | 5.1 |
| 2003 | 1,256 | 218 | 58 | 8 | 28 | 1,568 | 1,017 | 232 | 12 | 10 | 35 | 1,305 | 2,273 | 520 | 80 | 2,873 | 5.1 |
| 2004 | 1,245 | 217 | 58 | 8 | 28 | 1,556 | 1,020 | 232 | 12 | 10 | 35 | 1,309 | 2,266 | 519 | 80 | 2,864 | 5.0 |
| 2005 | 1,235 | 216 | 57 | 8 | 28 | 1,543 | 1,024 | 232 | 12 | 10 | 35 | 1,313 | 2,258 | 517 | 80 | 2,856 | 5.0 |
| 2006 | 1,224 | 214 | 57 | 8 | 27 | 1,531 | 1,027 | 233 | 12 | 10 | 35 | 1,316 | 2,251 | 516 | 80 | 2,847 | 5.0 |
| 2007 | 1,214 | 213 | 57 | 8 | 27 | 1,518 | 1,030 | 233 | 12 | 10 | 35 | 1,320 | 2,244 | 515 | 80 | 2,839 | 5.0 |
| 2008 | 1,203 | 212 | 56 | 8 | 27 | 1,506 | 1,034 | 234 | 12 | 10 | 35 | 1,324 | 2,237 | 514 | 80 | 2,830 | 5.0 |
| 2009 | 1,193 | 211 | 56 | 8 | 27 | 1,494 | 1,037 | 234 | 12 | 10 | 35 | 1,328 | 2,230 | 513 | 79 | 2,822 | 5.0 |
| 2010 | 1,182 | 209 | 56 | 8 | 27 | 1,482 | 1,041 | 235 | 12 | 10 | 35 | 1,332 | 2,223 | 511 | 79 | 2,814 | 5.0 |
| 2011 | 1,172 | 208 | 55 | 8 | 27 | 1,470 | 1,044 | 235 | 12 | 10 | 35 | 1,336 | 2,216 | 510 | 79 | 2,806 | 5.0 |
| 2012 | 1,162 | 207 | 55 | 7 | 26 | 1,458 | 1,048 | 235 | 12 | 10 | 35 | 1,340 | 2,210 | 509 | 79 | 2,798 | 5.0 |
| 2013 | 1,152 | 206 | 55 | 7 | 26 | 1,446 | 1,051 | 236 | 12 | 10 | 35 | 1,344 | 2,203 | 508 | 79 | 2,790 | 5.0 |

COMPOUNDED ANNUAL GROWTH RATES:

| | | | | | | | | | | | | | | | | |
|------------|--------|--------|--------|--------|--------|--------|-------|-------|-------|-------|-------|-------|--------|--------|--------|--------|
| 1992-1997: | -0.59% | -0.40% | -0.09% | -0.19% | -0.09% | -0.53% | 2.72% | 1.50% | 1.76% | 1.32% | 2.21% | 2.46% | 0.76% | 0.48% | 0.99% | 0.71% |
| 1997-2002: | -0.86% | -0.59% | -0.60% | -1.20% | -0.60% | -0.81% | 0.33% | 0.18% | 0.00% | 0.30% | 0.15% | 0.30% | -0.34% | -0.24% | -0.24% | -0.32% |
| 2002-2013: | -0.86% | -0.59% | -0.60% | -1.20% | -0.60% | -0.81% | 0.33% | 0.18% | 0.00% | 0.30% | 0.15% | 0.30% | -0.31% | -0.23% | -0.22% | -0.30% |
| 1992-2013: | -0.80% | -0.55% | -0.48% | -0.96% | -0.48% | -0.74% | 0.89% | 0.49% | 0.42% | 0.54% | 0.64% | 0.81% | -0.07% | -0.06% | 0.06% | -0.06% |

TABLE B-4
CVEA
PROJECTED OPERATING RESULTS

LOW CASE

USAGE (KWh) PER CUSTOMER ACCOUNT

| CALENDAR YEAR | VALDEZ | | | | | GLENNALLEN | | | | | | TOTAL | | | | |
|---------------|--------|--------|---------|----------|---------|--------------|-------|--------|---------|----------|---------|--------------|-------|---------|--------|-----------------|
| | RES | SMCOM | LG.COM | PUB.STIL | PUB.BLG | TOTAL RETAIL | RES | SMCOM | LG.COM | PUB.STIL | PUB.BLG | TOTAL RETAIL | RES | COM | PUB | TOTAL CUSTOMERS |
| 1992 | 7,601 | 21,458 | 335,789 | 7,739 | 23,899 | 21,475 | 4,981 | 21,630 | 808,291 | 3,993 | 13,108 | 16,098 | 6,579 | 75,186 | 15,459 | 19,316 |
| 1993 | 7,849 | 22,392 | 499,397 | 7,739 | 22,872 | 38,868 | 5,083 | 21,630 | 760,290 | 3,993 | 13,108 | 15,888 | 6,739 | 94,704 | 14,952 | 29,402 |
| 1994 | 8,112 | 22,601 | 541,798 | 7,739 | 22,877 | 41,031 | 5,200 | 21,630 | 743,947 | 3,993 | 13,108 | 15,629 | 6,915 | 98,997 | 14,941 | 30,344 |
| 1995 | 8,292 | 22,887 | 634,836 | 7,739 | 22,882 | 44,754 | 5,239 | 21,630 | 728,403 | 3,993 | 13,108 | 15,331 | 7,013 | 108,943 | 14,931 | 32,165 |
| 1996 | 8,429 | 22,985 | 638,935 | 7,739 | 22,887 | 45,198 | 5,278 | 21,630 | 712,914 | 3,993 | 13,108 | 15,047 | 7,084 | 108,471 | 14,920 | 32,084 |
| 1997 | 8,545 | 23,084 | 627,136 | 7,739 | 22,892 | 44,951 | 5,317 | 21,630 | 697,519 | 3,993 | 13,108 | 14,910 | 7,158 | 106,605 | 14,910 | 31,803 |
| 1998 | 8,651 | 23,183 | 615,187 | 7,739 | 22,897 | 44,692 | 5,357 | 21,630 | 682,525 | 3,993 | 13,108 | 14,779 | 7,226 | 104,738 | 14,899 | 31,518 |
| 1999 | 8,752 | 23,283 | 619,220 | 7,739 | 22,902 | 45,018 | 5,397 | 21,630 | 668,241 | 3,993 | 13,108 | 14,654 | 7,291 | 104,703 | 14,888 | 31,563 |
| 2000 | 8,852 | 23,383 | 623,295 | 7,739 | 22,908 | 45,348 | 5,437 | 21,630 | 654,338 | 3,993 | 13,108 | 14,535 | 7,354 | 104,676 | 14,877 | 31,609 |
| 2001 | 8,952 | 23,484 | 627,412 | 7,739 | 22,913 | 45,684 | 5,477 | 21,630 | 640,809 | 3,993 | 13,108 | 14,420 | 7,418 | 104,657 | 14,866 | 31,658 |
| 2002 | 9,001 | 23,584 | 631,572 | 7,739 | 22,918 | 45,958 | 5,477 | 21,630 | 627,643 | 3,993 | 13,108 | 14,278 | 7,435 | 104,646 | 14,855 | 31,658 |
| 2003 | 9,026 | 23,592 | 635,775 | 7,739 | 22,923 | 46,204 | 5,477 | 21,630 | 614,832 | 3,993 | 13,108 | 14,139 | 7,438 | 104,604 | 14,844 | 31,643 |
| 2004 | 9,038 | 23,599 | 640,021 | 7,739 | 22,928 | 46,444 | 5,477 | 21,630 | 602,368 | 3,993 | 13,108 | 14,005 | 7,435 | 104,569 | 14,832 | 31,624 |
| 2005 | 9,044 | 23,606 | 644,311 | 7,739 | 22,933 | 46,684 | 5,477 | 21,630 | 590,241 | 3,993 | 13,108 | 13,874 | 7,427 | 104,542 | 14,821 | 31,604 |
| 2006 | 9,047 | 23,613 | 648,645 | 7,739 | 22,938 | 46,926 | 5,477 | 21,630 | 578,444 | 3,993 | 13,108 | 13,748 | 7,418 | 104,522 | 14,809 | 31,585 |
| 2007 | 9,048 | 23,620 | 653,024 | 7,739 | 22,944 | 47,172 | 5,477 | 21,630 | 566,969 | 3,993 | 13,108 | 13,624 | 7,409 | 104,509 | 14,798 | 31,567 |
| 2008 | 9,049 | 23,627 | 657,447 | 7,739 | 22,949 | 47,421 | 5,477 | 21,630 | 555,807 | 3,993 | 13,108 | 13,505 | 7,398 | 104,504 | 14,786 | 31,552 |
| 2009 | 9,049 | 23,635 | 661,915 | 7,739 | 22,954 | 47,675 | 5,477 | 21,630 | 544,952 | 3,993 | 13,108 | 13,388 | 7,388 | 104,506 | 14,774 | 31,538 |
| 2010 | 9,050 | 22,881 | 666,429 | 7,739 | 22,643 | 47,821 | 5,477 | 21,630 | 534,396 | 3,993 | 13,108 | 13,275 | 7,377 | 104,204 | 14,656 | 31,466 |
| 2011 | 9,050 | 22,105 | 666,181 | 7,739 | 22,315 | 46,068 | 5,477 | 21,630 | 313,714 | 3,993 | 13,108 | 11,276 | 7,367 | 98,432 | 14,533 | 29,500 |
| 2012 | 9,050 | 21,305 | 668,460 | 7,739 | 21,971 | 45,289 | 5,477 | 21,630 | 203,786 | 3,993 | 13,108 | 10,279 | 7,356 | 95,513 | 14,405 | 28,521 |
| 2013 | 9,050 | 20,478 | 323,875 | 7,739 | 21,607 | 31,407 | 5,477 | 21,630 | 93,866 | 3,993 | 13,108 | 9,289 | 7,346 | 55,926 | 14,271 | 20,752 |

COMPOUNDED ANNUAL GROWTH RATES:

| | | | | | | | | | | | | | | | | |
|------------|-------|--------|--------|-------|--------|--------|-------|-------|---------|-------|-------|--------|--------|--------|--------|--------|
| 1992-1997: | 2.37% | 1.47% | 13.31% | 0.00% | -0.86% | 15.92% | 1.31% | 0.00% | -2.90% | 0.00% | 0.00% | -1.52% | 1.70% | 7.23% | -0.72% | 10.49% |
| 1997-2002: | 1.05% | 0.43% | 0.14% | 0.00% | 0.02% | 0.44% | 0.59% | 0.00% | -2.09% | 0.00% | 0.00% | -0.86% | 0.76% | -0.37% | -0.07% | -0.09% |
| 2002-2013: | 0.05% | -1.28% | -5.89% | 0.00% | -0.53% | -3.40% | 0.00% | 0.00% | -15.86% | 0.00% | 0.00% | -3.83% | -0.11% | -5.63% | -0.36% | -3.77% |
| 1992-2013: | 0.83% | -0.22% | -0.17% | 0.00% | -0.48% | 1.83% | 0.45% | 0.00% | -9.74% | 0.00% | 0.00% | -2.58% | 0.53% | -1.45% | -0.38% | 0.34% |

TABLE B-4

CVEA
PROJECTED OPERATING RESULTS

LOW CASE

| CALENDAR YEAR | NOMINAL COST OF ELECTRICITY (CENTS/KWH - NOMINAL) | | | | | | | | | CPI | REAL COST OF ELECTRICITY (CENTS/KWH - CONSTANT 1992 DOLLARS) | | | | | | | | |
|---------------|--|------------|-----------|---------------|--------------|-------|---------|---------|-----------------|-------|---|------------|-----------|---------------|--------------|-------|---------|---------|-----------------|
| | RES | Valdez RES | Glenn RES | Valdez SM.COM | Glenn SM.COM | COM | PUB.STL | PUB.BLG | OVERALL AVERAGE | | RES | Valdez RES | Glenn RES | Valdez SM.COM | Glenn SM.COM | COM | PUB.STL | PUB.BLG | OVERALL AVERAGE |
| 1992 | 18.36 | 17.31 | 20.85 | 16.18 | 20.29 | 15.20 | 19.77 | 16.43 | 16.08 | 135.2 | 18.36 | 17.31 | 20.85 | 16.18 | 20.29 | 15.20 | 19.77 | 16.43 | 16.08 |
| 1993 | 18.36 | 17.31 | 20.85 | 16.18 | 20.29 | 15.20 | 19.77 | 16.43 | 16.08 | 138.6 | 17.91 | 16.89 | 20.34 | 15.78 | 19.80 | 14.83 | 19.29 | 16.03 | 15.69 |
| 1994 | 17.44 | 16.44 | 19.81 | 15.37 | 19.28 | 14.44 | 18.78 | 15.61 | 15.28 | 142.0 | 16.60 | 15.65 | 18.85 | 14.63 | 18.35 | 13.74 | 17.87 | 14.85 | 14.54 |
| 1995 | 17.44 | 16.44 | 19.81 | 15.37 | 19.28 | 14.44 | 18.78 | 15.61 | 15.28 | 145.6 | 16.19 | 15.27 | 18.39 | 14.27 | 17.90 | 13.41 | 17.44 | 14.49 | 14.19 |
| 1996 | 17.44 | 16.44 | 19.81 | 15.37 | 19.28 | 14.44 | 18.78 | 15.61 | 15.28 | 149.2 | 15.80 | 14.90 | 17.95 | 13.92 | 17.47 | 13.08 | 17.01 | 14.14 | 13.84 |
| 1997 | 17.44 | 16.44 | 19.81 | 15.37 | 19.28 | 14.44 | 18.78 | 15.61 | 15.28 | 153.0 | 15.41 | 14.53 | 17.51 | 13.58 | 17.04 | 12.76 | 16.60 | 13.79 | 13.50 |
| 1998 | 17.44 | 16.44 | 19.81 | 15.37 | 19.28 | 14.44 | 18.78 | 15.61 | 15.28 | 156.8 | 15.04 | 14.18 | 17.08 | 13.25 | 16.62 | 12.45 | 16.19 | 13.46 | 13.17 |
| 1999 | 17.44 | 16.44 | 19.81 | 15.37 | 19.28 | 14.44 | 18.78 | 15.61 | 15.28 | 160.7 | 14.67 | 13.83 | 16.66 | 12.93 | 16.22 | 12.15 | 15.80 | 13.13 | 12.85 |
| 2000 | 17.44 | 16.44 | 19.81 | 15.37 | 19.28 | 14.44 | 18.78 | 15.61 | 15.28 | 164.7 | 14.31 | 13.50 | 16.26 | 12.61 | 15.82 | 11.85 | 15.41 | 12.81 | 12.54 |
| 2001 | 17.44 | 16.44 | 19.81 | 15.37 | 19.28 | 14.44 | 18.78 | 15.61 | 15.28 | 168.8 | 13.96 | 13.17 | 15.86 | 12.31 | 15.44 | 11.56 | 15.04 | 12.50 | 12.23 |
| 2002 | 17.87 | 16.86 | 20.30 | 15.75 | 19.76 | 14.80 | 19.25 | 16.00 | 15.66 | 173.1 | 13.96 | 13.17 | 15.86 | 12.31 | 15.44 | 11.56 | 15.04 | 12.50 | 12.23 |
| 2003 | 18.32 | 17.28 | 20.81 | 16.15 | 20.26 | 15.17 | 19.73 | 16.40 | 16.05 | 177.4 | 13.96 | 13.17 | 15.86 | 12.31 | 15.44 | 11.56 | 15.04 | 12.50 | 12.23 |
| 2004 | 18.78 | 17.71 | 21.33 | 16.55 | 20.76 | 15.55 | 20.22 | 16.81 | 16.45 | 181.8 | 13.96 | 13.17 | 15.86 | 12.31 | 15.44 | 11.56 | 15.04 | 12.50 | 12.23 |
| 2005 | 19.25 | 18.15 | 21.86 | 16.97 | 21.28 | 15.94 | 20.73 | 17.23 | 16.86 | 186.4 | 13.96 | 13.17 | 15.86 | 12.31 | 15.44 | 11.56 | 15.04 | 12.50 | 12.23 |
| 2006 | 19.73 | 18.61 | 22.41 | 17.39 | 21.81 | 16.34 | 21.25 | 17.66 | 17.29 | 191.0 | 13.96 | 13.17 | 15.86 | 12.31 | 15.44 | 11.56 | 15.04 | 12.50 | 12.23 |
| 2007 | 20.22 | 19.07 | 22.97 | 17.82 | 22.36 | 16.75 | 21.78 | 18.10 | 17.72 | 195.8 | 13.96 | 13.17 | 15.86 | 12.31 | 15.44 | 11.56 | 15.04 | 12.50 | 12.23 |
| 2008 | 20.73 | 19.55 | 23.55 | 18.27 | 22.92 | 17.16 | 22.32 | 18.55 | 18.16 | 200.7 | 13.96 | 13.17 | 15.86 | 12.31 | 15.44 | 11.56 | 15.04 | 12.50 | 12.23 |
| 2009 | 21.25 | 20.04 | 24.13 | 18.73 | 23.49 | 17.59 | 22.88 | 19.01 | 18.62 | 205.7 | 13.96 | 13.17 | 15.86 | 12.31 | 15.44 | 11.56 | 15.04 | 12.50 | 12.23 |
| 2010 | 21.78 | 20.54 | 24.74 | 19.19 | 24.08 | 18.03 | 23.45 | 19.49 | 19.08 | 210.9 | 13.96 | 13.17 | 15.86 | 12.31 | 15.44 | 11.56 | 15.04 | 12.50 | 12.23 |
| 2011 | 22.32 | 21.05 | 25.36 | 19.67 | 24.68 | 18.48 | 24.04 | 19.98 | 19.56 | 216.1 | 13.96 | 13.17 | 15.86 | 12.31 | 15.44 | 11.56 | 15.04 | 12.50 | 12.23 |
| 2012 | 22.88 | 21.58 | 25.99 | 20.17 | 25.30 | 18.95 | 24.64 | 20.48 | 20.05 | 221.5 | 13.96 | 13.17 | 15.86 | 12.31 | 15.44 | 11.56 | 15.04 | 12.50 | 12.23 |
| 2013 | 23.45 | 22.12 | 26.64 | 20.67 | 25.93 | 19.42 | 25.26 | 20.99 | 20.55 | 227.1 | 13.96 | 13.17 | 15.86 | 12.31 | 15.44 | 11.56 | 15.04 | 12.50 | 12.23 |

COMPOUNDED ANNUAL GROWTH RATES:

| | | | | | | | | | | | | | | | | | | | | |
|------------|--------|--------|--------|--------|--------|--------|--------|--------|--------|-------|--------|--------|--------|--------|--------|--------|--------|--------|--------|--------|
| 1992-1997: | -1.02% | -1.02% | -1.02% | -1.02% | -1.02% | -1.02% | -1.02% | -1.02% | -1.02% | 2.50% | -3.43% | -3.43% | -3.43% | -3.43% | -3.43% | -3.43% | -3.43% | -3.43% | -3.43% | -3.43% |
| 1997-2002: | 0.50% | 0.50% | 0.50% | 0.50% | 0.50% | 0.50% | 0.50% | 0.50% | 0.50% | 2.50% | -1.96% | -1.96% | -1.96% | -1.96% | -1.96% | -1.96% | -1.96% | -1.96% | -1.96% | -1.96% |
| 2002-2013: | 2.50% | 2.50% | 2.50% | 2.50% | 2.50% | 2.50% | 2.50% | 2.50% | 2.50% | 2.50% | 0.00% | -0.00% | 0.00% | 0.00% | 0.00% | 0.00% | 0.00% | 0.00% | 0.00% | 0.00% |
| 1992-2013: | 1.17% | 1.17% | 1.17% | 1.17% | 1.17% | 1.17% | 1.17% | 1.17% | 1.17% | 2.50% | -1.29% | -1.29% | -1.29% | -1.29% | -1.29% | -1.29% | -1.29% | -1.29% | -1.29% | -1.29% |

TABLE B-4
CVEA
ECONOMIC & DEMOGRAPHIC DATA PROJECTIONS

LOW CASE

ECONOMIC & DEMOGRAPHIC DATA

| CALENDAR YEAR | VALDEZ AND COPPER RIVER VALLEY | | | | | | HDD (VALDEZ) | HDD (GULKANA) | CPI | PER CAPITA INCOME (VLDZ/CRDV) | REAL PER CAP. INCOME | SALMON HARVEST (PWSMA) | ANS PRODUCTION mil bb/day | PetroStar Energy Sales (kWh) |
|---------------|--------------------------------|-------------------------|-----------|------------|-------------------------|-----------|--------------|---------------|-------|-------------------------------|----------------------|------------------------|---------------------------|------------------------------|
| | VALDEZ POP | COPPER RIVER POPULATION | TOTAL POP | VALDEZ EMP | COPPER RIVER EMPLOYMENT | TOTAL EMP | | | | | | | | |
| 1992 | 4,326 | 2,832 | 7,158 | 2,247 | 762 | 3,009 | 9,623 | 13,861 | 135.2 | 27,050 | 27,050 | 11,404 | 1.791 | 2,362,992 |
| 1993 | 4,497 | 2,987 | 7,484 | 2,313 | 749 | 3,062 | 9,711 | 14,004 | 138.6 | 27,449 | 26,779 | 25,538 | 1.683 | 12,190,880 |
| 1994 | 4,443 | 2,996 | 7,439 | 2,292 | 737 | 3,029 | 9,711 | 14,004 | 142.0 | 27,854 | 26,511 | 25,538 | 1.660 | 14,585,400 |
| 1995 | 4,390 | 3,005 | 7,395 | 2,272 | 724 | 2,996 | 9,711 | 14,004 | 145.6 | 28,264 | 26,246 | 25,538 | 1.682 | 18,921,600 |
| 1996 | 4,337 | 3,014 | 7,351 | 2,252 | 712 | 2,963 | 9,711 | 14,004 | 149.2 | 28,681 | 25,984 | 25,538 | 1.612 | 18,921,600 |
| 1997 | 4,285 | 3,023 | 7,308 | 2,232 | 700 | 2,931 | 9,711 | 14,004 | 153.0 | 29,104 | 25,724 | 25,538 | 1.520 | 18,921,600 |
| 1998 | 4,234 | 3,032 | 7,266 | 2,212 | 688 | 2,899 | 9,711 | 14,004 | 156.8 | 29,534 | 25,467 | 25,538 | 1.414 | 18,921,600 |
| 1999 | 4,183 | 3,042 | 7,224 | 2,192 | 676 | 2,868 | 9,711 | 14,004 | 160.7 | 29,969 | 25,212 | 25,538 | 1.307 | 18,921,600 |
| 2000 | 4,133 | 3,051 | 7,183 | 2,173 | 665 | 2,837 | 9,711 | 14,004 | 164.7 | 30,411 | 24,960 | 25,538 | 1.176 | 18,921,600 |
| 2001 | 4,083 | 3,060 | 7,143 | 2,153 | 653 | 2,807 | 9,711 | 14,004 | 168.8 | 30,860 | 24,710 | 25,538 | 1.064 | 18,921,600 |
| 2002 | 4,034 | 3,069 | 7,103 | 2,134 | 642 | 2,776 | 9,711 | 14,004 | 173.1 | 31,315 | 24,463 | 25,538 | 0.980 | 18,921,600 |
| 2003 | 3,986 | 3,078 | 7,064 | 2,115 | 631 | 2,746 | 9,711 | 14,004 | 177.4 | 31,777 | 24,219 | 25,538 | 0.897 | 18,921,600 |
| 2004 | 3,938 | 3,087 | 7,025 | 2,096 | 620 | 2,717 | 9,711 | 14,004 | 181.8 | 32,246 | 23,977 | 25,538 | 0.820 | 18,921,600 |
| 2005 | 3,891 | 3,097 | 6,987 | 2,078 | 610 | 2,688 | 9,711 | 14,004 | 186.4 | 32,721 | 23,737 | 25,538 | 0.745 | 18,921,600 |
| 2006 | 3,844 | 3,106 | 6,950 | 2,059 | 600 | 2,659 | 9,711 | 14,004 | 191.0 | 33,204 | 23,499 | 25,538 | 0.659 | 18,921,600 |
| 2007 | 3,798 | 3,115 | 6,913 | 2,041 | 589 | 2,630 | 9,711 | 14,004 | 195.8 | 33,694 | 23,264 | 25,538 | 0.581 | 18,921,600 |
| 2008 | 3,752 | 3,125 | 6,877 | 2,023 | 579 | 2,602 | 9,711 | 14,004 | 200.7 | 34,191 | 23,032 | 25,538 | 0.521 | 18,921,600 |
| 2009 | 3,707 | 3,134 | 6,841 | 2,005 | 569 | 2,574 | 9,711 | 14,004 | 205.7 | 34,695 | 22,801 | 25,538 | 0.469 | 18,921,600 |
| 2010 | 3,663 | 3,143 | 6,806 | 1,987 | 560 | 2,447 | 9,711 | 14,004 | 210.9 | 35,207 | 22,573 | 25,538 | 0.421 | 18,921,600 |
| 2011 | 3,619 | 3,153 | 6,772 | 1,770 | 550 | 2,321 | 9,711 | 14,004 | 216.1 | 35,726 | 22,348 | 25,538 | 0.421 | 18,921,600 |
| 2012 | 3,575 | 3,162 | 6,738 | 1,655 | 541 | 2,196 | 9,711 | 14,004 | 221.5 | 36,253 | 22,124 | 25,538 | 0.421 | 18,921,600 |
| 2013 | 3,532 | 3,172 | 6,704 | 1,540 | 532 | 2,072 | 9,711 | 14,004 | 227.1 | 36,788 | 21,903 | 25,538 | 0.421 | 0 |

COMPOUNDED ANNUAL GROWTH RATES:

| | | | | | | | | | | | | | |
|------------|--------|-------|--------|--------|--------|--------|--|--|-------|-------|--------|--------|----------|
| 1992-1997: | -0.19% | 1.32% | 0.42% | -0.14% | -1.70% | -0.52% | | | 2.50% | 1.47% | -1.00% | -3.23% | 51.60% |
| 1997-2002: | -1.20% | 0.30% | -0.57% | -0.89% | -1.70% | -1.08% | | | 2.50% | 1.48% | -1.00% | -8.40% | 0.00% |
| 2002-2013: | -1.20% | 0.30% | -0.52% | -2.92% | -1.70% | -2.63% | | | 2.50% | 1.47% | -1.00% | -7.39% | -100.00% |
| 1992-2013: | -0.96% | 0.54% | -0.31% | -1.78% | -1.70% | -1.76% | | | 2.50% | 1.47% | -1.00% | -6.66% | -100.00% |

COPPER VALLEY ELECTRIC ASSOCIATION
Electric System Load Forecast
Econometric Model Variable Listing

Energy Sales

| | |
|------------|--|
| VRKWHLN | Natural log of Valdez Residential Class Energy Sales (Annual) |
| VSCKWHLN | Natural log of Valdez Small Commercial Class Energy Sales (Annual) |
| VLCKWHLN | Natural log of Valdez Large Commercial Class Energy Sales (Annual) |
| VPSKWHLN | Natural log of Valdez Public Streetlight Class Energy Sales (Annual) |
| VPBKWHLN | Natural log of Valdez Public Building Class Energy Sales (Annual) |
| VTKWHLN | Natural log of Valdez Total Classes Energy Sales (Annual) |
| GRKWHLN | Natural log of Glennallen Residential Class Energy Sales (Annual) |
| GSCKWHLN | Natural log of Glennallen Small Commercial Class Energy Sales (Annual) |
| GLCKWHLN | Natural log of Glennallen Large Commercial Class Energy Sales (Annual) |
| GPSKWHLN | Natural log of Glennallen Public Streetlight Class Energy Sales (Annual) |
| GPBKWHLN | Natural log of Glennallen Public Building Class Energy Sales (Annual) |
| GTKWHLN | Natural log of Glennallen Total Classes Energy Sales (Annual) |
| TLCXKWHLN | Natural log of Total Large Commercial Class Energy Sales (Annual) |
| TLCXTKWHLN | Natural log of Total Large Commercial excluding the Top 15 Customers Energy Sales (Annual) |
| TKWHLN | Natural log of Total Combined Classes Energy Sales (Annual) |

Customer Accounts (i.e., Meters)

| | |
|----------|---|
| VRCUSLN | Natural log of Valdez Residential Customer Accts. (annual average) |
| VSCCUSLN | Natural log of Valdez Small Commercial Customer Accts. (annual average) |
| VLCCUSLN | Natural log of Valdez Large Commercial Customer Accts. (annual average) |
| VPCUSLN | Natural log of Valdez Public Streetlight Customer Accts. (annual average) |
| VPBCUSLN | Natural log of Valdez Public Building Customer Accts. (annual average) |
| VTCUSLN | Natural log of Valdez Total Customer Accts. (annual average) |
| GRCUSLN | Natural log of Glennallen Residential Customer Accts. (annual average) |
| GSCCUSLN | Natural log of Glennallen Small Commercial Customer Accts. (annual average) |
| GLCCUSLN | Natural log of Glennallen Large Commercial Customer Accts. (annual average) |
| GPCUSLN | Natural log of Glennallen Public Streetlight Customer Accts. (annual average) |
| GPBCUSLN | Natural log of Glennallen Public Building Customer Accts. (annual average) |
| GTCUSLN | Natural log of Glennallen Total Customer Accts. (annual average) |

Energy Usage per Customer Account

| | |
|----------|--|
| VRUPCLN | Natural log of Valdez Residential Energy Sales per Customer Account |
| VSCUPCLN | Natural log of Valdez Small Commercial Energy Sales per Customer Account |
| VLCUPCLN | Natural log of Valdez Large Commercial Energy Sales per Customer Account |
| VPSUPCLN | Natural log of Valdez Public Streetlight Energy Sales per Customer Account |
| VPBUPCLN | Natural log of Valdez Public Building Energy Sales per Customer Account |
| VTUPCLN | Natural log of Valdez Total Energy Sales per Customer Account |
| GRUPCLN | Natural log of Glennallen Residential Energy Sales per Customer Account |
| GSCUPCLN | Natural log of Glennallen Small Commercial Energy Sales per Customer Account |
| GLCUPCLN | Natural log of Glennallen Large Commercial Energy Sales per Customer Account |
| GPSUPCLN | Natural log of Glennallen Public Streetlight Energy Sales per Customer Account |
| GPBUPCLN | Natural log of Glennallen Public Building Energy Sales per Customer Account |
| GTUPCLN | Natural log of Glennallen Total Energy Sales per Customer Account |

Average Revenue per kWh of Energy Sales (i.e., Average Rate)

(Note: Real implies corrected for inflation by CPI Index.)

| | |
|----------|--|
| VRRATLN | Natural Log of Real Valdez Residential Electric Rate (calculated) |
| VSCRATLN | Natural Log of Real Valdez Small Commercial Electric Rate (calculated) |
| GRRATLN | Natural Log of Real Glennallen Residential Electric Rate (calculated) |
| GSCRATLN | Natural Log of Real Glennallen Small Commercial Electric Rate (calculated) |
| TCRATLN | Natural Log of Real Total Commercial Electric Rate (calculated) |

Demographic/Economic/Other Variables

| | |
|---------|---|
| VPOP | Natural Log of Valdez Population (Annual Average) |
| CRPOP | Natural Log of Copper River Population (Annual Average) |
| TPOP | Natural Log of Total Area Population (Annual Average) |
| VEMP | Natural Log of Valdez Total Employment (Annual Average) |
| CREMP | Natural Log of Copper River Total Employment (Annual Average) |
| TEMP | Natural Log of Total Area Employment (Annual Average) |
| PCY | Natural Log of Estimated per Capita Income for Valdez/Cordova Area |
| CPI | Natural Log of Anchorage Consumer Price Index without Shelter |
| RPCY | Natural Log of Real per Capita Income (PCY adjusted by CPI) |
| VHDD | Natural Log of Valdez Heating Degree Days (Annual) |
| GHDD | Natural Log of Gulkana Heating Degree Days (Annual) |
| SALHARV | Natural Log of Total Commercial Salmon Harvest, Prince William Sound |
| ANSPROD | Natural Log of Millions of Barrels per Day Produced by the Alaska North Slope |
| DUM89 | Dummy Variable for 1989 |
| DUM89 | Dummy Variable for 1989 and 1990 |
| YEAR | Year |

(Note: CVEA data is maintained on a January 1 to December 31 calendar year basis. All variables have been adjusted to correspond to this time period.)

LS // Dependent Variable is VRCUSLN
 Date: 10-12-1993 / Time: 10:53
 SMPL range: 1980 - 1992
 Number of observations: 13

| VARIABLE | COEFFICIENT | STD. ERROR | T-STAT. | 2-TAIL SIG. |
|--------------------|-------------|-----------------------|-----------|-------------|
| C | 1.2012986 | 0.6847911 | 1.7542557 | 0.1099 |
| VPOP | 0.7158322 | 0.0837455 | 8.5477067 | 0.0000 |
| DUM89 | 0.1051328 | 0.0345252 | 3.0451023 | 0.0124 |
| R-squared | 0.881447 | Mean of dependent var | | 7.057084 |
| Adjusted R-squared | 0.857736 | S.D. of dependent var | | 0.085649 |
| S.E. of regression | 0.032305 | Sum of squared resid | | 0.010436 |
| Log likelihood | 27.88212 | F-statistic | | 37.17522 |
| Durbin-Watson stat | 1.201906 | Prob(F-statistic) | | 0.000023 |

| Residual Plot | | obs | RESIDUAL | ACTUAL | FITTED |
|---------------|---|------|----------|---------|---------|
| : | * | 1980 | 0.02055 | 6.97167 | 6.95112 |
| : | : | 1981 | 0.06000 | 7.05618 | 6.99617 |
| : | * | 1982 | -0.00307 | 7.07918 | 7.08225 |
| * | : | 1983 | -0.06531 | 7.01481 | 7.08012 |
| : | * | 1984 | -0.02702 | 6.99256 | 7.01958 |
| : | : | 1985 | -0.01125 | 6.98317 | 6.99442 |
| : | * | 1986 | -0.01874 | 6.97393 | 6.99267 |
| : | * | 1987 | -0.00772 | 6.99041 | 6.99813 |
| : | : | 1988 | 0.01365 | 7.01721 | 7.00355 |
| : | * | 1989 | -1.4E-17 | 7.09230 | 7.09230 |
| : | : | 1990 | 0.01259 | 7.16311 | 7.15051 |
| : | * | 1991 | 0.00365 | 7.19036 | 7.18671 |
| : | : | 1992 | 0.02266 | 7.21720 | 7.19454 |

LS // Dependent Variable is VRUPCLN
 Date: 10-12-1993 / Time: 10:55
 SMPL range: 1981 - 1992
 Number of observations: 12

| VARIABLE | COEFFICIENT | STD. ERROR | T-STAT. | 2-TAIL SIG. |
|--------------------|-------------|-----------------------|------------|-------------|
| C | 4.3934525 | 2.2998367 | 1.9103324 | 0.0925 |
| VRUPCLN(-1) | 0.4934919 | 0.1138851 | 4.3332427 | 0.0025 |
| VRRATLN | -0.2262485 | 0.0778397 | -2.9065958 | 0.0197 |
| VHDD | 0.0876054 | 0.2002460 | 0.4374890 | 0.6733 |
| R-squared | 0.862397 | Mean of dependent var | | 8.932236 |
| Adjusted R-squared | 0.810795 | S.D. of dependent var | | 0.054893 |
| S.E. of regression | 0.023877 | Sum of squared resid | | 0.004561 |
| Log likelihood | 30.22358 | F-statistic | | 16.71269 |
| Durbin-Watson stat | 1.733705 | Prob(F-statistic) | | 0.000832 |

| Residual Plot | | | obs | RESIDUAL | ACTUAL | FITTED |
|---------------|---|---|------|----------|---------|---------|
| : | : | * | 1981 | 0.00160 | 8.80087 | 8.79927 |
| : | * | : | 1982 | -0.01962 | 8.85917 | 8.87879 |
| : | : | * | 1983 | 0.01515 | 8.92884 | 8.91369 |
| : | : | * | 1984 | 0.01522 | 8.98826 | 8.97304 |
| : | : | * | 1985 | 0.01818 | 8.98607 | 8.96789 |
| : | : | * | 1986 | 0.00532 | 8.95373 | 8.94841 |
| : | * | : | 1987 | -0.00713 | 8.92327 | 8.93041 |
| : | * | : | 1988 | -0.00709 | 8.91755 | 8.92464 |
| : | : | * | 1989 | 0.04188 | 8.98290 | 8.94102 |
| : | * | : | 1990 | -0.01561 | 8.96282 | 8.97843 |
| : | * | : | 1991 | -0.01664 | 8.94732 | 8.96396 |
| * | : | : | 1992 | -0.03126 | 8.93602 | 8.96729 |

LS // Dependent Variable is GRUPCLN
 Date: 10-19-1993 / Time: 13:11
 SMPL range: 1980 - 1992
 Number of observations: 13

| VARIABLE | COEFFICIENT | STD. ERROR | T-STAT. | 2-TAIL SIG. |
|----------|-------------|------------|------------|-------------|
| C | 9.4379162 | 0.1756665 | 53.726341 | 0.0000 |
| GRRATLN | -0.3001454 | 0.0548993 | -5.4671966 | 0.0002 |

| | | | |
|--------------------|----------|-----------------------|----------|
| R-squared | 0.730987 | Mean of dependent var | 8.478163 |
| Adjusted R-squared | 0.706531 | S.D. of dependent var | 0.043000 |
| S.E. of regression | 0.023294 | Sum of squared resid | 0.005969 |
| Log likelihood | 31.51390 | F-statistic | 29.89024 |
| Durbin-Watson stat | 2.441587 | Prob(F-statistic) | 0.000196 |

| Residual Plot | | | | obs | RESIDUAL | ACTUAL | FITTED |
|---------------|---|---|---|------|----------|---------|---------|
| | : | * | | 1980 | -0.00760 | 8.41748 | 8.42508 |
| | : | * | | 1981 | 0.00095 | 8.40012 | 8.39918 |
| | : | | * | 1982 | 0.00942 | 8.46651 | 8.45709 |
| | * | : | | 1983 | -0.03954 | 8.42899 | 8.46854 |
| | : | : | * | 1984 | 0.02046 | 8.51472 | 8.49425 |
| | : | : | : | * | 1985 | 0.03882 | 8.50505 |
| | : | * | : | 1986 | -0.00964 | 8.46385 | 8.47349 |
| | : | : | * | 1987 | -0.01947 | 8.49833 | 8.47885 |
| | * | : | : | 1988 | -0.02418 | 8.46231 | 8.48649 |
| | * | : | : | 1989 | -0.02170 | 8.48543 | 8.50713 |
| | : | : | * | 1990 | 0.02528 | 8.54177 | 8.51649 |
| | : | * | : | 1991 | 0.00106 | 8.51811 | 8.51705 |
| | : | * | : | 1992 | -0.01280 | 8.51345 | 8.52626 |

LS // Dependent Variable is VSCKWHLN
 Date: 10-12-1993 / Time: 10:57
 SMPL range: 1980 - 1992
 Number of observations: 13

| VARIABLE | COEFFICIENT | STD. ERROR | T-STAT. | 2-TAIL SIG. |
|--------------------|-------------|-----------------------|------------|-------------|
| C | 10.997718 | 1.2750310 | 8.6254518 | 0.0000 |
| VEMP | 0.6335839 | 0.1378553 | 4.5960051 | 0.0010 |
| TCRATLN(-1) | -0.1613899 | 0.1429910 | -1.1286719 | 0.2854 |
| R-squared | 0.762197 | Mean of dependent var | | 15.32800 |
| Adjusted R-squared | 0.714636 | S.D. of dependent var | | 0.121280 |
| S.E. of regression | 0.064787 | Sum of squared resid | | 0.041974 |
| Log likelihood | 18.83555 | F-statistic | | 16.02577 |
| Durbin-Watson stat | 2.717740 | Prob(F-statistic) | | 0.000760 |

| Residual Plot | | | obs | RESIDUAL | ACTUAL | FITTED |
|---------------|-----|--|------|----------|---------|---------|
| | :* | | 1980 | -0.05664 | 15.1780 | 15.2347 |
| | : | | 1981 | 0.09594 | 15.3464 | 15.2505 |
| | :* | | 1982 | -0.05361 | 15.2061 | 15.2597 |
| | : | | 1983 | 0.05966 | 15.3425 | 15.2829 |
| | : * | | 1984 | -0.03563 | 15.2867 | 15.3223 |
| | : | | 1985 | 0.02954 | 15.3433 | 15.3137 |
| | : | | 1986 | 0.06006 | 15.2909 | 15.2309 |
| | : | | 1987 | 0.00747 | 15.2500 | 15.2425 |
| | * | | 1988 | -0.12245 | 15.1484 | 15.2708 |
| | : | | 1989 | 0.00108 | 15.5830 | 15.5819 |
| | : | | 1990 | -0.00423 | 15.4187 | 15.4229 |
| | : | | 1991 | 0.04207 | 15.4549 | 15.4128 |
| | : | | 1992 | -0.02326 | 15.4152 | 15.4384 |

LS // Dependent Variable is VPBKWHLN
 Date: 10-12-1993 / Time: 11:00
 SMPL range: 1984 - 1992
 Number of observations: 9

| VARIABLE | COEFFICIENT | STD. ERROR | T-STAT. | 2-TAIL SIG. |
|--------------------|-------------|-----------------------|-----------|-------------|
| C | 7.8974732 | 1.3873734 | 5.6923920 | 0.0013 |
| VEMP | 0.2688922 | 0.0664161 | 4.0485971 | 0.0067 |
| RPCY | 0.3378168 | 0.1690507 | 1.9983167 | 0.0926 |
| R-squared | 0.921962 | Mean of dependent var | | 13.37627 |
| Adjusted R-squared | 0.895949 | S.D. of dependent var | | 0.067195 |
| S.E. of regression | 0.021675 | Sum of squared resid | | 0.002819 |
| Log likelihood | 23.53854 | F-statistic | | 35.44280 |
| Durbin-Watson stat | 2.902209 | Prob(F-statistic) | | 0.000475 |

| Residual Plot | | obs | RESIDUAL | ACTUAL | FITTED |
|---------------|---|------|----------|---------|---------|
| : | * | 1984 | -0.00136 | 13.3174 | 13.3188 |
| : | * | 1985 | 0.00124 | 13.3608 | 13.3595 |
| : | * | 1986 | -0.01443 | 13.3116 | 13.3260 |
| : | * | 1987 | -0.01638 | 13.2990 | 13.3154 |
| : | * | 1988 | 0.02508 | 13.3610 | 13.3359 |
| : | * | 1989 | -0.01405 | 13.4998 | 13.5139 |
| : | * | 1990 | -0.01357 | 13.4147 | 13.4012 |
| * | | 1991 | -0.02241 | 13.3732 | 13.3956 |
| : | | 1992 | 0.02874 | 13.4489 | 13.4202 |

POWER SUPPLY EVALUATION

A. OVERVIEW

Presently, CVEA's primary source of power supply is hydroelectric power from the Solomon Gulch Hydroelectric Project (the "Solomon Gulch Project") owned by the State of Alaska. Diesel generators and an oil-fired combustion turbine provide the balance of CVEA's generation and reserve requirements. CVEA provides electric service to the communities of Valdez and the Copper Basin, which includes the town of Glennallen. The Copper Basin load center is referred to as Glennallen in this section and in Section X of this report. These service districts are interconnected by a 106 mile-long 138-kV transmission line owned by the State of Alaska and operated and maintained by CVEA under a long-term contract with the State.

As previously described in this report, the proposed Intertie consists of an approximately 135 mile-long 138-kV transmission line connecting CVEA to the systems of the electric utilities in Alaska's Railbelt. The Intertie would provide CVEA access to generation from the Anchorage area utilities to offset the use of CVEA's diesel generation, and reduce the need to build additional generating resources in the CVEA area. In the future, the Intertie would expand the territory in which generating resources could be developed to supply additional energy to the entire Railbelt region.

To determine the cost-effectiveness of the Intertie, an economic evaluation was prepared to compare the lifecycle power supply costs for CVEA with the Intertie to the lifecycle power supply costs with other power supply alternatives available to CVEA. In evaluating the lifecycle power supply costs, only the costs that are subject to change from case to case are included, e.g., the fixed costs of depreciation of CVEA's existing generating units, and costs associated with purchased power from the Solomon Gulch Project, are not included.

This section of the report provides a description of the various power supply alternatives and the assumptions used in the economic analysis. The alternative power supply resources identified for CVEA include two hydroelectric projects, diesel generation, and a coal-fired generating plant. CVEA could also implement demand-side management (DSM) or conservation measures to reduce demand and energy requirements. Various conservation measures have been identified for CVEA and are included in the analysis as a separate "Conservation Case."

A description of CVEA's existing system and CVEA's planning reserve criteria are discussed first followed by a presentation of future power supply needs based on the results of the load forecast included in Section VIII of this report. CVEA's reserve planning criteria are applied in the derivation of future power supply needs. Descriptions of the alternative resources identified for CVEA's future power supply requirements are provided including the expected capacity and energy from each resource, and the capital costs and operating and maintenance costs for each resource. Reports previously prepared for CVEA and the Authority were relied on for the costs and operating characteristics for the alternative hydroelectric projects. The costs and operating characteristics for the coal-fired generating project are based primarily on information provided by the project's private developer; however, the cost estimates have been reviewed as a part of this study and were adjusted as deemed appropriate to reflect the expected development cost.

B. CVEA'S EXISTING POWER SUPPLY SYSTEM

CVEA's primary source of power generation is the Solomon Gulch Project. Diesel generators located in each of the service districts and a combustion turbine located in Valdez provide the balance of CVEA's generation and reserve requirements.

1. Solomon Gulch Project

The Solomon Gulch Project became operational in 1982 and is owned by the State of Alaska and operated by CVEA, under a long-term contract with the State. All of the output from this project is sold to CVEA. The project consists of two Francis-type turbines with a nominal rating of 6,000 kW each. The Solomon Gulch Project has limited storage capability, and historically, energy production in the winter and early spring has been limited due to very low inflows to the reservoir during the winter. At the same time, inflows to the reservoir from melting snows in the late spring and summer coupled with summer precipitation have in the past exceeded CVEA's power needs and water has been spilled from the project reservoir in the summer months. With increasing power requirements in the summer months, CVEA will be able to more fully utilize the energy generation capability of the Solomon Gulch Project. The historical energy generation and estimated spill energy for the Solomon Gulch Project as provided by CVEA is summarized below:

Table IX-1
Solomon Gulch Hydroelectric Project
Estimated Available Energy Generation

| Year | Spill Days | Estimated Spill Energy (kWh) | Annual Energy Generation (kWh) | Total Available Energy (kWh) |
|------|------------|------------------------------------|--------------------------------------|------------------------------------|
| 1987 | 103 | 15,015,868 | 42,440,000 | 57,455,868 |
| 1988 | 104 | 15,161,653 | 40,843,679 | 56,005,332 |
| 1989 | 100 | 14,578,512 | 39,600,000 | 54,178,512 |
| 1990 | 95 | 13,849,587 | 46,262,000 | 60,111,587 |
| 1991 | 43 | 6,268,760 | 39,634,000 | 45,902,760 |
| 1992 | 68 | 9,913,388 | 40,880,000 | 50,793,388 |

Based on CVEA's historical operation of the Solomon Gulch Project, the annual generation available from the project provides most of CVEA's energy requirements for nine to ten months of the year. Late in the winter season, the reservoir is exhausted and diesel generation is required to provide CVEA's energy requirements until the spring water run-off from snow melt begins. As CVEA's energy requirements increase, the project would potentially run out of water earlier in the winter and more diesel generation would be expected to be required, especially in the late winter. CVEA has indicated that the current dispatching method for Solomon Gulch may be modified and a minimum water level may be maintained throughout the winter and spring in the reservoir for reserves.

Based on historical stream flow data, the total annual gross generation available from the Solomon Gulch Project is estimated by the Authority to be 54,500 MWh for an average water year. This annual generation value includes approximately 25,900 MWh of generation during the winter period (October through May) and approximately 28,600 MWh of generation during the summer period (June through

September). During the summer period, the maximum gross generating capacity of the Solomon Gulch Project is assumed to be 12 MW. The maximum gross generating capacity is assumed to be reduced to 5 MW during the winter season, based on maintaining a minimum water level of 620 feet in the reservoir. Although CVEA has not typically operated the Solomon Gulch Project so that it is available to provide firm capacity throughout the winter, it is expected that in the future the reservoir will not be drawn down completely each winter as it has been in the past. Transmission losses from the Solomon Gulch Project to CVEA's electric system in Valdez and station use are assumed to be 2.5% and 1%, respectively, of total annual generation.

Power is sold from the Solomon Gulch Project to CVEA pursuant to a contract called the Four Dam Pool Power Sales Agreement. This contract also applies to the sales of power from three other State-owned hydroelectric projects. The cost of the Solomon Gulch Project output to CVEA includes both a debt service component and an operations and maintenance (O&M) component. The O&M component is adjusted annually to reflect actual O&M costs while the debt service component remains constant except for periodic changes as identified in the contract. Since the cost of power from the Solomon Gulch Project to CVEA is the same for all of the alternative resource plans evaluated as part of this analysis and CVEA is obligated to use the output of the Solomon Gulch Project prior to the use of any other resource, the cost of power from the Solomon Gulch Project is not included in this analysis.

With the Intertie, any surplus generation available from the Solomon Gulch Project could be sold to the Railbelt utilities. For the purpose of this analysis, the estimated surplus energy capability of the Solomon Gulch Project is assumed to be sold to utilities other than CVEA. This surplus energy will most likely reduce thermal generation in the Anchorage area. Consequently, the power is assumed to be valued at a rate equivalent to the economy energy rate discussed under the Intertie section below.

2. Existing Diesel Generation Capacity

CVEA currently has 14,500 kW of diesel generation installed, including 8,600 kW located at the Valdez Diesel plant and 5,900 kW located at the Glennallen Diesel plant. The type of units include several models of diesel generators and one oil-fired combustion turbine, all of which are fueled with #2 diesel fuel. Units 6 and 7 in Glennallen had until recently used #4 fuel, a heavier grade oil. Selected operating characteristics and the on-line dates for the units are summarized below:

Table IX-2
CVEA Generating Resources
Valdez Plant

| Unit Name | Capacity Rating (kW) | Operating Capacity (kW) | Fuel Efficiency (kWh/gal) | On-line Date |
|-------------------------|-----------------------------|--------------------------------|----------------------------------|---------------------|
| Unit 1: Fairbanks Morse | 600 | 500 | 12.3 | 1966 |
| Unit 2: Fairbanks Morse | 600 | 500 | 12.3 | 1966 |
| Unit 3: Fairbanks Morse | 600 | 500 | 12.3 | 1966 |
| Unit 4: Enterprise | 1700 | 1500 | 14.9 | 1972 |
| Unit 5: Enterprise | 2500 | 2200 | 13.9 | 1975 |
| Unit 6: Enterprise | 950 | 900 | 13.6 | 1975 |
| Unit 7: Solar Turbine | 2800 | 2500 | 8.0 | 1976 |

**Table IX-3
CVEA Generating Resources
Glennallen Plant**

| Unit Name | Capacity Rating (kW) | Operating Capacity (kW) | Fuel Efficiency (kWh/gal) | On-line Date |
|-------------------------|----------------------------|-------------------------------|---------------------------------|-----------------|
| Unit 1: Fairbanks Morse | 300 | Out of Service | -- | 1959 |
| Unit 2: Fairbanks Morse | 300 | Out of Service | -- | 1959 |
| Unit 3: Fairbanks Morse | 600 | 500 | 12.2 | 1963 |
| Unit 4: Fairbanks Morse | 600 | 500 | 12.5 | 1966 |
| Unit 5: Fairbanks Morse | 600 | 500 | 12.5 | 1966 |
| Unit 6: Enterprise | 2500 | 2200 | 14.5 | 1975 |
| Unit 7: Enterprise | 2500 | 2200 | 13.3 | 1975 |

The variable operating and maintenance costs for CVEA's existing diesel generators are estimated as 3.0 cents per kWh (in 1993 dollars), based on information provided by CVEA. Fixed operating and maintenance costs for the units include capital recovery costs and labor related costs. The capital recovery costs for the existing plants are assumed not to change with the various alternative resource plans, and therefore are not included in the analysis. The labor related costs will vary depending on how the diesel generating facilities are operated. Operation of the diesel facilities to provide base load generation will require that CVEA maintains at least its existing staff level. However, if the facilities are operated on a standby basis, CVEA could reduce its current staffing levels.

CVEA's annual labor costs are estimated to decrease by \$560,000 per year if the diesel units are used for standby purposes only, as would be the case if the Intertie were to be constructed. This assumes that the existing diesel operations and maintenance staffing level is reduced from 3 employees in Valdez and 6 employees in Glennallen to 1.5 employees per site. The average cost per employee in Glennallen is \$94,000 per year and the average cost per employee in Valdez is \$97,000 per year based on CVEA's 1993 payroll budget. Presently, CVEA has a staff of three operators at its Valdez diesel plant, a staff size sufficient only for day time operation of the plant. It is assumed that if significant levels of diesel generation are needed in Valdez, as is required if the Intertie is not constructed, a night shift of three operators will be added.

Based on CVEA's August 1992 generation report, all of the units are in excellent to good condition, except for the two Fairbanks Morse units, Units 1 and 2, at Glennallen which are no longer operational. Most of the generating units are over 20 years old and require major overhauls every 15,000 hours of operation. CVEA has indicated that the retirement of units will depend on the cost of replacement. A separate evaluation of the expected life of these units was not included as part of this study; however, based on discussions with CVEA staff, it is assumed that the diesel generating units will be replaced in the future rather than overhauled if a major overhaul is projected to be required during the study period.

Currently, CVEA is not required to limit the operation of the existing diesel units for pollution control purposes. As described below, new diesel generators are expected to be operated to limit air pollution emissions pursuant to current regulations. In addition, the new diesel generators are projected to generate the majority of CVEA's diesel generation once they are installed. It is expected that the existing diesel generators will be required to limit air pollution emissions at some time in the future, using techniques subsequently described for the new diesel generators.

C. PLANNING RESERVE CRITERIA

The planning reserve criteria for CVEA's system is an important assumption in this analysis. CVEA is currently an isolated system, with its two load districts interconnected by a 106 mile transmission line. This transmission line crosses over Thompson Pass and is subject to avalanche danger which has caused two major outages in its ten-year life. The most recent long-term outage on the line occurred in December 1988 and lasted nine months. Because of the possibility of an outage of the transmission line, CVEA's two load districts must maintain sufficient generation capacity to provide for their own power requirements. In addition, the potentially long outage time of the existing transmission line necessitates that CVEA maintain generation reserves in each load center. It is important to note that the firm generation capacity of the Solomon Gulch Project is limited by water availability during the winter and is estimated to be 5,000 kW under operating conditions assumed to be implemented by CVEA. With the Intertie and other resource alternatives, except diesel, CVEA is assumed to be able to increase the firm winter capacity of the Solomon Gulch Project to 6,500 kW. Each of the two Solomon Gulch Project turbine generators is capable of generating approximately this amount of power, consequently, the Solomon Gulch Project provides its own backup under peak load conditions.

With the Intertie, the Glennallen load center will be interconnected to both Valdez and the Railbelt utilities. It is still assumed that Glennallen would maintain sufficient diesel generation capacity to meet its full load but it will not be necessary under these circumstances to have surplus generation capacity in Glennallen. In the event of an outage of the existing CVEA transmission line and the unavailability of one of the diesel generating units in Glennallen, CVEA would rely upon power purchases over the Intertie to supply Glennallen power requirements. The planning reserve criteria for each load center is summarized in the following table.

Table IX-4
Generation Reserve Criteria

| Load District | With Intertie | Without Intertie |
|----------------------|--|--|
| Valdez | Peak Load plus Largest Generating Unit | Peak Load plus Largest Generating Unit |
| Glennallen | Peak Load | Peak Load plus Largest Generating Unit |

The actual level of reserve capacity required for the CVEA system depends on the resource mix and the location of the resources. The Intertie could provide generation reserves to Glennallen depending on the purchase arrangement. However, any new generation located at Glennallen (including the Intertie) will not provide any additional capacity reserves for Valdez because of the possibility of a transmission outage between Glennallen and Valdez. Similarly, any new generation located in Valdez will not provide reserves for Glennallen.

D. PROJECTED POWER SUPPLY REQUIREMENTS

The peak load requirements as compared to the existing generation resources for the peak load period, which occurs in the winter, is summarized in Figure IX-1 below for Valdez and in Figure IX-2 for Glennallen. The three load growth alternatives, high, medium and low, shown in Figure IX-1 represent the load projections provided in Section VIII of this report plus the generation reserve requirement for each load district. The reserve requirements are based on providing backup for the largest diesel generator located at each load district, specifically 2,200 kW in Valdez and 2,200 kW in Glennallen. As shown in Figure IX-1, CVEA has sufficient reserves in the Valdez area for the medium and low projected levels of load growth. If CVEA experiences the projected high load growth, CVEA will need to add additional capacity in Valdez in 2002. As shown in Figure IX-2, Glennallen does not currently have sufficient generation capacity to supply its peak load requirement and maintain necessary backup generation.




Figure IX-1: Peak Load Requirements and Existing Generation Capacity
Valdez Load Center, Winter Peak (MW)




Figure IX-2: Peak Load Requirements and Existing Generation Capacity
Glennallen Load Center, Winter Peak (MW)

CVEA's energy requirements were separated into two periods based on typical hydroelectric generation availability. The winter period includes the eight months October through May and the summer period includes the four months June through September. The projected annual energy requirements for CVEA were allocated to these two periods based on a 70% and 30% split for the winter and summer seasons, respectively, as typically experienced by CVEA in the past. The energy resources projected to supply CVEA's total system energy requirements, without the Intertie or any other alternative resources, are summarized in Figure IX-3 for the winter period and in Figure IX-4 for the summer period. As shown in Figure IX-3, diesel generation is required during the winter period for all three of the load forecasts. During the summer period, the Solomon Gulch Project is projected to have surplus energy available under the medium and low load growth projections. The Solomon Gulch Project is projected to be fully utilized by 1999 under the high load growth projection, and additional diesel generation is projected to be required at that time.




Figure IX-3: Projected Energy Requirements and Resources, Winter Period (MWh 000)




Figure IX-4: Projected Energy Requirements and Resources, Summer Period (MWh 000)

E. USE OF THE INTERTIE

The Intertie will connect the isolated CVEA electric system to the Railbelt utilities. CVEA will most likely purchase energy from the Railbelt utilities and offset its own diesel generation. Additionally, the Intertie would provide a market for CVEA's surplus hydroelectric generation and in the future could allow the Railbelt utilities to participate in the development and the use of cost effective generating resources which may be located near CVEA's electric system. In the event that electricity requirements in CVEA's system increase significantly in the future, CVEA may be able to avoid the cost of installing new base load generating facilities by purchasing power from the Railbelt utilities. CVEA will not need to replace its existing diesel generators in the near future if the Intertie is installed since these generators will be used only if interruptions occur in the delivery of power from the Railbelt utilities.

There are several possible arrangements to purchase power from the Anchorage area that can be envisioned for CVEA although power will most likely be purchased from either Chugach Electric Association (CEA) or Anchorage Municipal Light & Power (ML&P), the two largest power producers in the Railbelt region. Economy energy could be purchased to offset diesel energy generation. This type of purchase is assumed to be similar to that made by the Golden Valley Electric Association (GVEA) and would be on a non-firm basis, i.e. if immediate power needs in the Anchorage area were high or a generating unit went down in the Anchorage area the purchase could be curtailed. Economy energy sold to GVEA is generally considered to be surplus generation by CEA and ML&P and is usually priced at a rate that recovers the cost of fuel and variable operations and maintenance costs plus a small margin. It is not known whether or not power will continue to be available to CVEA at economy energy rates once the power requirements of CEA's and ML&P's own customers increase to fully utilize the installed generation capacity these two utilities presently have.

Fixed energy and capacity purchases may be arranged whereby CVEA could expect to have the power it purchases from CEA or ML&P available at all times. This type of contract arrangement would require CVEA to pay a rate that includes all allocated fixed and variable costs for the amount purchased, including capital recovery costs for the generating resources used to generate the power. Fixed power purchases from CEA or ML&P would probably be priced at a rate similar to what Matanuska Electric Association and the City of Seward presently pay for power purchased from CEA.

For the purpose of this analysis, an economy energy purchase was assumed to be made by CVEA and estimated to include only the variable cost of generation. The projected cost of economy energy is based on the provisions of the economy energy sales agreement between GVEA and CEA and includes only the cost of fuel and no operating margin for CEA. The estimated price of this energy is estimated to be 2.35 cents per kWh in 1993. In the future, the fuel cost component of economy energy is estimated to increase at the same level of increase assumed in this report for oil fuel prices. Although CEA and ML&P both use natural gas as their primary generation fuel, the gas prices paid by ML&P and CEA are adjusted by contract relative to oil prices.

Table IX-5
Projected Cost of Power from CEA⁽¹⁾
 (1993 cents per kWh)

| | Fuel Price⁽²⁾ | O&M Component⁽³⁾ | Margin⁽⁴⁾ | Total |
|------|---------------------------------|--|-----------------------------|--------------|
| 1999 | 2.41 | 0.17 | 0.00 | 2.59 |
| 2000 | 2.45 | 0.17 | 0.00 | 2.63 |
| 2001 | 2.50 | 0.17 | 0.00 | 2.67 |
| 2002 | 2.54 | 0.17 | 0.00 | 2.71 |
| 2003 | 2.58 | 0.17 | 0.00 | 2.76 |
| 2004 | 2.63 | 0.17 | 0.00 | 2.80 |
| 2005 | 2.67 | 0.17 | 0.00 | 2.85 |
| 2006 | 2.72 | 0.17 | 0.00 | 2.89 |
| 2007 | 2.77 | 0.17 | 0.00 | 2.94 |
| 2008 | 2.81 | 0.17 | 0.00 | 2.99 |
| 2009 | 2.86 | 0.17 | 0.00 | 3.04 |
| 2010 | 2.91 | 0.17 | 0.00 | 3.09 |
| 2011 | 2.96 | 0.17 | 0.00 | 3.14 |
| 2012 | 3.01 | 0.17 | 0.00 | 3.19 |
| 2013 | 3.07 | 0.17 | 0.00 | 3.24 |

- (1) Based on provisions similar to those identified in the contract for the sale of economy energy by CEA to GVEA which is currently in effect.
- (2) Includes base fuel cost, taxes and royalties. Base fuel costs are adjusted relative to changes in fuel oil prices. Assumes fuel prices increase at the high fuel cost escalation.
- (3) Estimated operations and maintenance component.
- (4) The margin is not included in this analysis since it represents a transfer between CVEA and CEA rather than a net increase in Alaska costs. These costs will not change as a result of a sale of economy energy to CVEA.

Transmission losses for power generated in the Anchorage area and delivered to CVEA's electric system in Glennallen are estimated to be approximately 9.7% of the amount generated. These losses are 5.0% on CEA's transmission system, 2.0% on the MEA system, and 3.0% over the Intertie. CEA indicates that it typically includes in its power sales contracts an allowance of 5% for transmission losses over its transmission system regardless of the source of generation and the point of delivery. No wheeling costs are included in the economic analysis for the energy transmitted over the CEA or MEA transmission systems since these costs represent fixed operating costs of CEA and MEA that do not vary with or without the Intertie.

Surplus Solomon Gulch Project energy generation, if it is projected to be available, is assumed to be sold to the Anchorage area at a rate equivalent to the assumed economy energy rate.

F. ALTERNATIVE RESOURCE OPTIONS TO MEET FUTURE CVEA POWER SUPPLY NEEDS

Three types of generating resources have been identified for CVEA to meet future load growth as an alternative to constructing the Intertie. These resources include new diesel generators, two hydroelectric facilities located near Valdez, and a coal-fired generating plant to be located in Valdez. In addition, CVEA could implement certain conservation programs to reduce its power requirements. The following provides a description of these resource alternatives.

1. New Diesel Generation

Diesel generators have been used to provide reserve and generating requirements for isolated communities throughout Alaska. Diesel generators typically require relatively low initial capital investment, however, the price of fuel for diesel generators is subject to the price volatility of fuel costs and transportation costs. Diesel generation also negatively impacts air quality by the combustion of diesel fuel which produces various air pollutants.

For the purpose of this analysis, the costs and operating characteristics for new diesel generating units are based on the 1,650 kW and the 2,200 kW Caterpillar, 3600 series diesel engines. The largest diesel unit that CVEA currently owns and operates is 2,200 kW. It is assumed that CVEA would not add diesel units larger than this. Although, the cost of installation per unit of output is lower for larger units, smaller units allow more flexibility in meeting incremental load growth. Also, relying on larger units to serve load could increase the required reserve capacity for the CVEA system.

The capital cost of a new diesel generator in 1993 dollars is assumed to vary between \$940 per kW for a 1,650 kW unit and \$820 per kW for a 2,200 kW unit. The costs of new diesel generators summarized in the following table are based on estimates provided by vendors.

Table IX-6
Estimated Costs for New Diesel Generators
(1993 Dollars)

| | <u>Series 3606</u> | <u>Series 3608</u> |
|---|--------------------|--------------------|
| Continuous Capacity Rating, kW | 1,650 | 2,200 |
| Net Output, kW | 1,610 | 2,150 |
| Cost Estimate | | |
| Engine Generator Set..... | \$830,060 | \$991,375 |
| Cooling Components | 50,930 | 67,540 |
| Exhaust Components | 10,230 | 12,210 |
| Air Start Components | 26,400 | 26,400 |
| Fuel System Components..... | 27,500 | 27,500 |
| Station Battery Components..... | 7,700 | 7,700 |
| Switch Gear Components..... | 110,000 | 110,000 |
| Total Equipment..... | <u>\$1,062,820</u> | <u>\$1,242,725</u> |
| Permitting, Site Preparation, | | |
| Engineering and Installation (24%) | \$255,077 | \$298,254 |
| Delivery (3%) | 31,885 | 37,281 |
| Contingency (15%)..... | 159,423 | 186,409 |
| Total Cost Estimate..... | <u>\$1,509,205</u> | <u>\$1,764,669</u> |
| Cost per Unit of Output (\$/kW)..... | 937 | 821 |

The variable operating and maintenance costs including lube oil costs for new diesel generators are estimated to be \$.01 per kWh and fixed operating costs, including labor, are assumed to be \$12.00 per kW per year, both in 1993 cost levels. New diesel generators are estimated to operate at a fuel efficiency of 16.0 kWh per gallon, which has been adjusted to account for a less efficient heat rate because of timing retardation as is subsequently discussed.

Based on discussions with CVEA, it is assumed that one additional diesel generator unit could be added to the existing Glennallen power plant. The addition of more than one unit at the Glennallen site would require the construction of a new building to house the additional units or generating units presently in place would need to be removed. The addition of any units to the Valdez site would require the construction of a new building to house the units. The cost of a new building is assumed to be \$500,000. A new building constructed at either site is assumed to be constructed to a sufficient size to house all additional units required at the site. A detailed evaluation of the need for additional fuel storage tanks or improvements needed for switching gear with new diesel generators has not been conducted as part of this study; however, provisions for these additions and improvements are included in the analysis based on assumed costs for typical equipment needs. The assumed cost for a 300,000 gallon storage tank which may be needed in Valdez in the future if more diesel generation is required, is \$1.5 million. An allowance of \$550,000 for substation and other improvements is included if diesel generation is expanded.

Although CVEA's current operation of its existing diesel generation units does not include any pollution control measures, it is assumed that new diesel units will trigger Prevention of Significant

Deterioration (PSD) review and the associated best available control technology (BACT) for pollution control, especially for the emission of nitrous oxides (NO_x). There are several types of pollution control and it is currently not known what type will be required as BACT determinations are made on a case-by-case basis. The production of NO_x in a diesel engine is primarily a function of the combustion temperature. One method to control the emission of NO_x involves delaying the ignition timing to reduce the peak firing pressure and temperature. Since the efficiency of the unit is also directly proportional to the combustion temperature, reduction in the combustion temperature also reduces the efficiency of the unit.

Other forms of pollution control include selective catalytic reduction (SCR) and water/fuel emulsification. SCR requires additional equipment which is estimated to cost approximately \$400 to \$500 per kW installed. The operation costs would also increase by approximately 0.3 to 0.5 cents per kWh for ammonia consumption and catalyst replacement. In addition, SCR requires the onsite storage and use of ammonia, and the spent catalyst can be a potential hazardous waste. Although SCR technology has been used commonly on recent natural gas-fired combined cycle combustion turbine generating units, it is a relatively new application to diesel generators. Water/fuel emulsification includes injecting water into the fuel to improve the combustion efficiency and lower the combustion temperature.

The required BACT will be determined when CVEA applies for permits to install a new diesel generator unit. For the purpose of this analysis, it is assumed that NO_x emission will be controlled through the delay of the fuel injection. This type of emission control has been recommended recently to other remote Alaskan utilities as the BACT. Further, the United States Environmental Protection Agency (EPA) approved timing retard as BACT in May 1993 for a 20-MW diesel generating station. The actual pollution control technology required at the time of construction of new diesel units may differ. The most costly control technology is SCR. For additional information on air permitting issues regarding new diesel generators, see Appendix G.

2. New Hydroelectric Facilities

Hydroelectric facilities are typically capital intensive projects; however, they offer a relatively stable cost of power over the life of the project, which can extend to 50 years or more. The two sites identified in previous studies conducted by the Authority for new hydroelectric facilities located near CVEA's service territory include Allison Lake and Silver Lake. Alternative designs have been proposed for each site. The proposed Allison Lake Project as included in this analysis would supplement the winter energy generation currently available from the Solomon Gulch Project and provide CVEA with a small level of additional capacity. The Silver Lake Project would provide additional capacity and generation, and also would provide substantial storage capability from which to regulate the output of CVEA's combined hydroelectric generation system.

Construction costs and operating costs for the hydroelectric facilities included in this analysis are based on information provided in other reports. Construction costs for the two hydroelectric facilities were originally provided in 1992 dollars and have been increased 4.12% to adjust the costs to 1993 dollars based on the Handy-Whitman Index of Public Utility Construction Costs. O&M costs were adjusted 3.2% from 1992 dollars to 1993 dollars.

a. Allison Lake Project

Allison Lake is located west of the Solomon Gulch Reservoir and is formed by small creeks and melt water from glaciers on Mount Kate. As previously discussed, the Solomon Gulch Project reservoir

typically runs out of water around March, under current operating practices. The Allison Lake Project would divert water from Allison Lake to the Solomon Gulch Reservoir during the winter in order to provide additional generation at the Solomon Gulch Project. Several design options at Allison Lake were reviewed in the Allison Lake Reconnaissance Study (Allison Lake Study), prepared by HDR Engineering, Inc. (HDR) in September 1992 for the Authority. The preferred option identified in the Allison Lake Study consists of an 11,950 foot-long tunnel from Allison Lake to the Solomon Gulch Reservoir, a lake tap approximately 100 feet below the surface of Allison Lake, and a 3,145 kW hydroelectric generation facility located at the discharge from the tunnel at the Solomon Gulch reservoir. Water would be withdrawn from Allison Lake, flow through the tunnel, and then pass through the generating facility at the discharge to the Solomon Gulch Reservoir. This water from Allison Lake would then be available to provide additional generation at the existing Solomon Gulch Project generating facility.

The construction cost for the Allison Lake project is assumed to be approximately \$32,240,000 in 1993 dollars, not including interest during construction. Annual operating and maintenance costs are assumed to be \$284,000 in 1993 dollars. The earliest commercial operation date for this project, assuming project development would begin in July 1994, is assumed to be January 2000, which represents a 5½ year development schedule. These assumptions are based on information included in the Allison Lake Study which includes a more detailed description of the project. The Allison Lake Study was a reconnaissance level study and further review is required for several issues including the minimum water flow required for fish habitat needs in the natural outlet of the lake.

The optimal operation of the preliminary design of the Allison Lake Project described in the Allison Lake Study involves discharging water into the Solomon Gulch reservoir at a 100% capacity factor. This operation would generate approximately 2,300 MWh per month over a six month operating period, November through April, as identified in the Allison Lake Study. This mode of operation would provide the CVEA system an additional 3,145 kW of firm capacity in the winter months and 27,300 MWh of gross generation also in the winter months. The additional generation includes both the generation from Allison Lake of 13,775 MWh and the increase in generation from the Solomon Gulch Project of 13,621 MWh. Station use and transmission losses for the additional generation provided by the Allison Lake Project are assumed to be approximately 3.5%, the same level as assumed for generation from the Solomon Gulch Project.

The Allison Lake Study included comments provided by several State and federal agencies regarding the proposed Allison Lake Project. Several issues were raised which, according to HDR, would require additional study to fully determine the impact on the proposed development. These issues included insufficient identification of the expected impacts to fish and wildlife, and inadequate allowances for reserved streamflows in Allison Creek for fish habitat. These and other issues could affect the cost and operating characteristics of the Allison Lake Project.

b. Silver Lake Project

Silver Lake is located approximately 15 miles southwest of Valdez. The lake is approximately 3 miles long and up to 0.7 miles wide. The outlet from the lake forms Duck River which flows into Galena Bay. Several alternative configurations for a hydroelectric facility at Silver Lake have been proposed and two primary options were reviewed in the Allison Lake Study. The two options reviewed in the Allison Lake Study are summarized as follows:

(1) Design A

This design option was studied by Stone & Webster in 1982 and 1983. The project includes a 125-foot-high roller-compacted concrete (RCC) dam, 6,000-feet of 108-inch pipeline, and a 15 MW powerhouse located at elevation 65 on the Duck River. The powerhouse would be equipped with three 5 MW Francis turbines. Transmission to the Solomon Gulch Project would be accomplished with an approximately 22 mile-long overhead transmission line. The project would require a minimum water release of 5 cubic feet per second (cfs) at all times which would produce approximately 300 MWh of generation a month. Generation in excess of the minimum release could be regulated. Annual generation is estimated to be about 44,800 MWh per year. The capital cost for the project is estimated to be \$54,185,000 in 1993 dollars. The fixed O&M costs are estimated to be \$593,000 per year in 1993 dollars.

(2) Design B

This option is based on a design proposed by Whitewater Engineering in 1992. The project would consist of a 110-foot-high RCC dam, 10,000 feet of 108-inch diameter pipeline along the access road and a 14 MW powerhouse located at elevation 10 on Reverse Creek providing a higher head than Design A. The powerhouse would be equipped with two 7 MW Francis turbines. Transmission would be via 2.2 miles of overhead transmission line to Galena bay and then by a 18-mile submarine cable to Valdez. Design B is estimated to produce an energy generation capability of approximately 48,000 MWh per year. This includes the generation from the 5 cfs minimum water release, estimated to be approximately 600 MWh a month for the Design B configuration. HDR's cost estimates for the project, adjusted to 1993 dollars, includes \$60,703,000 for capital cost and \$593,000 per year for O&M costs.

Both design options for the Silver Lake Project are assumed to be operated as fully regulated projects, because of the large storage capacity. The reservoir storage and the sizing of the generator units would allow the project to serve as a backup to the Solomon Gulch Project. The estimated generation from the Silver Lake Project is based on historical water flow data and the net generation could actually be closer to 50,000 MWh per year. Further review is required for more detailed analysis and to address certain issues including fishery needs.

Whitewater Engineering ("Whitewater"), an independent power project development company, is still interested in developing a project at Silver Lake similar to design Option B described above. As an independent power producer, Whitewater would construct the project and sell the output to CVEA. Whitewater has recently estimated that the cost to construct the Silver Lake Project would be \$25 million, not including land rights. An additional \$8.0 million for construction of the submarine transmission cable is estimated to be needed by Whitewater. Significant differences in HDR's estimate and Whitewater's estimate include the following:

- (1) HDR proposes to purchase the land and Whitewater proposes to lease the land at a cost based on the output from the project.
- (2) HDR proposes to line the dam face with concrete and Whitewater proposes to line the dam with a pre-fab lining at a significant savings.
- (3) HDR proposes to bury the penstock and Whitewater proposes to construct the penstock above ground.

A detailed review of the various Silver Lake Project development alternatives has not been included as a part of this study. For the purpose of the economic analysis, the costs of the Silver Lake Project are assumed to be those as provided in the Allison Lake Study for both Design Option A and Design Option B.

3. Valdez Coal-Fired Generation Plant

Hobbs Industries, Inc. ("Hobbs") had proposed to construct and operate an 11-MW coal-fired generation project in Glennallen. Since release of the draft feasibility study report, Hobbs has withdrawn its proposal for the Glennallen coal project and Alaska Cogeneration Systems, Inc. (ACSI) has proposed to construct and operate a 22-MW coal-fired cogeneration project in Valdez. ACSI has proposed to generate electrical power for sale to CVEA and produce steam for district heating of various public facilities in Valdez. The Valdez coal project is proposed as an independent power project that will be independently constructed and financed.

Certain components of the coal project, namely the boilers and turbine generators, have been previously used elsewhere but are expected to be fully refurbished before installation in the new facility. The project is proposed to be constructed adjacent to CVEA's Valdez diesel power plant. Coal fuel is expected to be provided from a mine located in the Matanuska Valley near Sutton that Hobbs has previously proposed to operate. Coal would be delivered to the power plant via truck, railroad and barge in containers. Water supplies and wastewater discharge services are expected by ACSI to be supplied locally. The coal project will incorporate several measures to control the emission of pollutants. It is estimated that the earliest the coal project would be operational is early 1998 if contractual agreements between CVEA and ACSI could be negotiated by the end of 1994.

ACSI proposes to operate the coal project in integration with CVEA's other generators. At times when the Solomon Gulch Project is generating at or near full capacity, the coal project will most likely not be generating. ACSI anticipates that the coal project will be shutdown for 2 months during the summer for annual maintenance although the coal project may be used only sparingly for generation for a longer period of time each year depending on the level of Solomon Gulch generation. A staff of 16 full-time employees is estimated to be required to operate and maintain the coal project.

A cost estimate for the Valdez coal project has been provided by ACSI and we have reviewed the estimate. Based on our review, it is estimated that the cost of development and construction of the coal project is \$36,600,000 in 1993 dollars. This amount is significantly higher than presently estimated by ACSI. Included in the cost estimate are the estimated costs of installing a district heating system in Valdez and the costs associated with initial startup of the coal mine.

It is estimated that the coal project should be capable of producing approximately 160,000 MWh per year assuming 85% annual availability. Its actual generation will depend on the actual power requirements of CVEA as well as the energy generation of the Solomon Gulch Project. Generation from the coal project will be used to offset diesel generation and would not offset energy generation from the Solomon Gulch Project on an annual basis. Operations and maintenance expenses are estimated to be \$.01 per kWh for variable costs and approximately \$1.8 million per year for fixed costs including labor costs for the 16 employees expected to be employed at the project. The cost of fuel is proposed by ACSI to be \$50 per ton delivered in 1993 dollars and the cost of fuel is expected to increase at the assumed rate of general inflation.

As an independent power project, ACSI has proposed that power from the coal project be sold to CVEA with a monthly fixed charge plus a per kWh energy charge. The rate to be charged will allow for the repayment of the capital costs of the project, operations and maintenance costs and fuel costs. For the purpose of this analysis, the nature of the actual contractual payment requirements is not important. Rather, the costs of operation have been estimated and are included in the economic analysis used to compare the costs of the various resource alternatives. Estimated revenues from the sale of district heating are assumed to be credited towards the costs of operation of the coal project. These revenues are assumed to be related to the value of the heating fuel displaced with the district heat system.

In reviewing the proposed coal project as outlined by ACSI, we have identified several issues which could significantly impact the costs of constructing and operating the project. It is not unusual that many of these issues would be unresolved at this stage of project development. They will need to be addressed before the project can be expected to proceed much farther and would almost undoubtedly need to be resolved before financing for the project can be secured. In addition, CVEA would need to be fully satisfied that these issues can be resolved before committing to purchase power from the project, particularly if the project is to provide firm power whereby CVEA forgoes development of other resource options. For additional information on the proposed Valdez coal project, see Appendix H, attached to this report.

4. Conservation Potential

In addition to generating resources, the resource analysis included an evaluation of the potential conservation or DSM programs that CVEA could implement to offset the cost of diesel generation and possibly delay the need to add new generating facilities. The potential DSM programs considered and the related assumptions are based on the results of the Final Report on Least-Cost Planning Demonstration Study prepared by Stone & Webster Management Consultants, Inc. in 1991 (Stone & Webster Study).

The evaluation of DSM potential is generally based on the premise that a utility can "invest" in conservation measures to reduce its customer's needs for electricity. Although CVEA can expect some of its customers to implement conservation measures on their own, to fully realize conservation benefits on a larger scale CVEA would need to pay for a portion if not all of the costs of implementation. The estimated savings and costs provided in the Stone & Webster Study were adjusted to include the impact of CVEA customers that would have implemented the DSM measures without any financial incentive offered by CVEA.

In evaluating the electricity conservation potential in CVEA's service territory it is important to note that a significant amount of electricity conservation potential has already been realized due to the high cost of electricity to consumers. For instance, the use of electricity for space heating is essentially non-existent and many of CVEA's customers use fuels other than electricity for water heating purposes. If electricity is used to heat water, some customers have installed timers on their electric water heaters to limit electricity use for this purpose. Because of these and other measures taken by CVEA's customers in the past, the amount of additional conservation savings that can be realized is less than may be expected by many electric utilities in general.

Based on the Stone & Webster Study the three cost effective residential DSM programs identified for CVEA include (1) high efficiency refrigerators, (2) high efficiency freezers, and (3) compact fluorescent lighting. In addition, the two commercial programs found to be cost effective include (1) high efficiency fluorescent lamps and ballasts and (2) compact fluorescent lighting.

The Stone & Webster Study included a review of over 27 potential DSM programs which were reduced to the five programs listed above, based on the cost effectiveness of the programs. Because there is little or no electric heat and very few electric hot water heaters in use by CVEA customers, weatherization programs or programs designed to provide energy efficient water heating are of no value to CVEA.

A survey of commercial customers to determine the end-use energy use by building type and to identify the appropriate high efficiency DSM replacement technologies was included as part of the Stone & Webster Study. In addition, Stone & Webster relied on information provided in previous studies prepared for the Alaska Railbelt area and other information available from other utilities.

The following summarizes the selected programs in the Stone & Webster study:

a. High Efficiency Refrigerator Program

The high efficiency refrigerator program is designed to encourage the purchase of more efficient refrigerators through financial incentives to customers and also by CVEA working with local appliance distributors to stock the more efficient units. The utility incentives would be provided to customers who are buying new or replacement refrigerators. It was estimated that the total number of new refrigerators purchased each year (for either new applications or replacements) represents approximately 5% of the total refrigerators in the CVEA service area. The utility would pay for the incremental cost between the purchase of a high efficiency refrigerator as compared to the purchase cost of an average efficiency refrigerator. It was estimated that approximately 10% of the eligible customers would participate in the first year. This participation rate would increase to 40% per year by the fourth year and remain at that level through the end of the study period. The per unit energy savings were estimated as 112 kWh per year. The per unit peak demand savings were estimated as 0.014 kW. The incremental cost of purchasing the high efficiency units was estimated as \$32.00 per unit. The per unit cost was increased 60% for utility administrative costs.

b. High Efficiency Freezer Program

The high efficiency freezer program would be very similar to the high efficiency refrigerator program. Approximately 5% of the total freezers in the CVEA service area were assumed to represent the total number of new freezers purchased in a year. Of the eligible purchases approximately 10% were estimated to participate in the first year of the program. The participation level was estimated to increase to 40% by the fourth year of the program and remain at that level through the end of the study. The per unit energy savings and demand savings were estimated as 94 kWh per year and 0.010 kW per year, respectively. The incremental cost of purchasing the more efficient units was estimated as \$20.00 per unit. The per unit cost to be incurred by the utility was increased 60% to include administrative costs for the utility.

c. Compact Fluorescent Lighting Program

The compact fluorescent lighting program is designed to introduce compact fluorescent lighting technologies as replacements for standard incandescent lamps. The utility is assumed to purchase the compact fluorescent bulbs in bulk and provide them to customers at no cost. Half of the estimated 2.6 bulbs per household that could be replaced are assumed to be replaced. The estimated energy savings per household is 142 kWh per year. The per unit cost of the compact fluorescent bulb is assumed to be \$15.00. The per unit cost to be incurred by the utility was increased 60% to include administrative costs for the utility.

The cost effective DSM programs identified for the commercial customers included two lighting efficiency programs (1) high efficiency fluorescent lamps and ballasts, and (2) compact fluorescent lighting. Based on the survey data, the total lighting load for each building type was estimated. This was further broken down to the percent fluorescent and incandescent for each building type. This was combined with the estimated per unit savings to determine the total savings in the lighting load. The estimated peak demand savings were based on an assumed annual lighting load factor of 36% , or 3,200 hours per year. The estimated per unit cost for the high efficiency fluorescent lamps and ballasts was \$20. The compact fluorescents were estimated to cost \$15 per fixture. The program is assumed to reach 50% of the technical potential over 20 years. The program is assumed to reach 27% of the technical potential over 12 years. The per unit cost was increased by 60% for utility administrative costs.

The following table summarizes the estimated energy savings and costs for the selected conservation programs.

Table IX-7
CVEA Conservation Program Assessment
Total Estimated Energy and Demand Savings
and Total Estimated Costs

| Description of Programs | Total Annual Savings for CVEA ⁽¹⁾ | | Annual Program Costs ⁽²⁾ (1993 \$000) |
|-------------------------------|---|----------------|---|
| | Energy (MWh) | Demand (kW) | |
| RESIDENTIAL | | | |
| High Efficiency Refrigerators | 143 | 18 | 3 |
| High Efficiency Freezers | 75 | 8 | 1 |
| Compact Fluorescent Lighting | 172 | 64 | 7 |
| COMMERCIAL | | | |
| High Efficiency Fluorescents | 1,081 | 375 | 32 |
| Compact Fluorescent Lighting | 244 | 85 | 11 |
| Total for All Programs | 1,715 | 550 | 54 |

(1) Total annual savings which are estimated to be achieved in 2017 for all conservation measures projected to have been implemented by that year. The conservation measures are projected to be implemented gradually over time beginning in 1994.

(2) Costs of implementing the incremental increase in conservation measures in 2017. There are no assumed O&M costs associated with the conservation programs.

G. SAFETY AND RELIABILITY ISSUES

While a safety evaluation of the various resources has not been conducted as a part of this study, it is not expected that the general public and worker safety would be appreciably different among the resource alternatives. The electric resources addressed in this report are all of relatively standard technology and each type of resource has shown many years of safe and reliable operation if properly maintained and operated. Electric utility installations of any type can present hazards if proper precautions are not taken. It is assumed that all resources will be constructed and operated to utility standards and that all applicable

codes and regulations will be strictly adhered to. For more information on safety and health issues related to the Intertie, including a discussion of health impacts related to electro-magnetic field issues, see the Environmental Review in Appendix N.

In general, transmission lines are more reliable than generating plants, i.e. they are subject to fewer failure conditions and have less downtime. For the purposes of this study, power supply reliability has been addressed through the application of generating reserves that are comparable among all the resource alternatives and with the Electric System Analysis included as Appendix M. It is not clear what impact the Intertie would have on the reliability of CVEA's electric service to its customers and how this impact would vary from the present situation. The CVEA system could be subject to disturbances caused by problems in the Railbelt electric systems if the Intertie is constructed. Alternatively, the Intertie would provide another source of emergency power in the event of a failure of CVEA's own generating resources. It will be necessary for CVEA to operate its electric system so as to minimize electric service interruptions.

The differences in reliability among the various resource alternatives that may occur have not been estimated at this time. Hydroelectric resources are generally highly reliable whereas diesel generators and coal-fired generating plants are less reliable as individual units. The availability of hydroelectric resources is typically close to 100% on an annual basis. Coal-fired generating plants are typically available in the range 90%. The reliability of various generating resources is usually factored in to the amount of backup generation that a utility maintains. It will be necessary for CVEA to consider reliability issues with regard to its future operation, with or without the Intertie.

EVALUATION OF ALTERNATIVE POWER SUPPLY PLANS AND ECONOMIC ANALYSIS

A. OVERVIEW

The primary use of the Intertie will be to offset CVEA's diesel generation with purchased power from the Railbelt area. In order to evaluate the economic benefits of the Intertie, alternative resource plans were developed which provide equivalent amounts of power to CVEA over the study period. These plans were then evaluated based on the cumulative present value of comparable annual costs over the expected life of the Intertie.

This section of the report provides a summary of the alternative resource plans and includes a description of the model used to develop and evaluate the resource plans and conduct the economic analysis. A list of the principal assumptions used in the analysis is also provided. Detailed descriptions of the various generating alternatives, which include new hydroelectric projects, diesel generators, conservation programs, and a coal-fired generation plant, are provided in Section IX of this report.

Many assumptions have been used in developing the resource plans and economic analysis. Among these are the projected power requirements of CVEA and the projected cost of oil which is reflected in the cost of generation fuel. Because these variables can greatly influence the results of the economic analysis, a range of assumptions has been made to evaluate the impact that these variables have on the bottom line results.

B. METHODOLOGY

An analytical model was developed to evaluate the alternative resource plans (the "Resource Model"). The Resource Model is divided into three sections: (1) peak load requirements and generation capacity (2) energy requirements and energy resources and (3) the economic analysis. The need for and specification of new generation additions are developed in the first section of the Resource Model since the capacity needs for CVEA form the basis for each alternative resource plan. The use of CVEA's resources to serve projected energy requirements is simulated in the second section of the Resource Model. This section indicates the source and quantities of energy generation by resource. The third section of the Resource Model shows the projected annual costs and the cumulative present value of the annual costs.

1. Resource Plans and Energy Generation

The alternative resource plans are based on CVEA's projected power requirements, the planning reserve criteria for each of CVEA's service districts, the existing resources available to serve the load and the alternative new resources, previously described in Section IX of this report. Diesel generators are estimated to be installed in all cases if capacity requirements are not met with existing resources or the alternative new resources. To determine when new diesel resources would be needed, the total firm capacity in each service district was compared to the projected peak load for the respective district. For

each case, diesel units were then added to the system, as required, to provide the appropriate level of reserves in each year of the study period.

The Resource Model then simulates an economic dispatch of CVEA's resources for CVEA's system on a seasonal basis. The two seasons include the winter season defined as October through May and the summer season defined as June through September. Based on historical load data, CVEA's winter season energy requirements are assumed to represent approximately 70% of CVEA's total annual energy requirements and CVEA's summer season energy requirements are assumed to represent the remaining 30%. The available generation from the Solomon Gulch Project and from each of the alternative resources is defined in the Resource Model for each season, except for diesel generation which is defined on a total annual basis. CVEA is assumed to dispatch resources to serve the service district that the generation resource is located nearest first, with any surplus generation then available to be used to serve the other service district. Any generation produced in one service district to serve the energy requirements of the other service district is adjusted for transmission losses over existing Glennallen to Valdez transmission line.

The basic order of use of the generating resources to serve the projected load is the same for all of the alternative resource plans. The projected energy requirements are first reduced by any projected conservation savings for the Conservation Case. The Solomon Gulch Project is assumed to be used next to serve load, followed by any alternative new hydroelectric resources, namely the Allison Lake Project or the Silver Lake Project. New diesel generators followed by existing diesel generators are assumed to provide the balance of energy requirements. Power purchased over the Intertie or power generated by the coal project is assumed to offset diesel generation. As previously mentioned in Section IX of this report, power purchased over the Intertie is assumed to be purchased from Anchorage area utilities.

The coal facility is assumed to operate only during the winter season to offset diesel generation. The coal project is presumed to operate at a minimum level of 3 MW during the period in which it operates. Consequently, CVEA's minimum load requirements must be in excess of 3 MW on a continuous daily basis before the coal project is started up for the winter season. During the winter season, the coal project would be expected to operate at a fairly consistent level of output from hour-to-hour.

The use of CVEA's existing diesel units is based on the average fuel efficiency for each unit with the more efficient diesel generator units assumed to be used first. In Valdez, the Enterprise Units 4 and 5 are used first to serve load. Because of its remote control capability, the Solar Turbine is assumed to be used when load requirements exceed the combined capacity of Units 4 and 5. The usage order for the remaining units is Unit 6, Unit 2, Unit 3, and Unit 1, in that order. It is further assumed that the use of the existing diesel generating units is limited to a 35% load factor on an annual basis and that 5% of the diesel generation estimated to be needed in Valdez is supplied by the Solar Turbine.

The existing diesel generators assumed to be used first in Glennallen are the Enterprise Units 6 and 7. The usage order for the remaining Glennallen diesel units is Unit 4, Unit 5, and Unit 3, in that order.

2. Economic Analysis

The economic analysis performed determines the cumulative present value of the costs for each of the alternative resource plans over the expected economic life of the Intertie. Costs included in the analysis have no inflation applied in the future; however real escalation in fuel costs are assumed in the future. The

cumulative present value for each alternative plan is calculated using an inflation free discount rate of 4.5%, as presently defined by the Authority.

Each resource plan is defined to provide similar levels of electric capacity and energy to CVEA over the analysis period. The costs for this power supply will vary for each case depending on the specific resources involved. The analysis period is the economic lifetime of the Intertie, an assumed 50 year period beginning in 1999. Costs included in the analysis are the annual capital recovery costs for new generation and transmission additions, operation and maintenance costs for new resource options and operation, maintenance and fuel costs of new and existing diesel generators. Excluded from the analysis are certain fixed operating and capital recovery costs related to CVEA's existing generation plant and the cost of power purchased by CVEA from the Solomon Gulch Project. These costs do not affect the outcome of the analysis because they will be incurred no matter what case is being evaluated. With the Intertie, CVEA anticipates that it would reduce the number of diesel generator operations and maintenance staff and a fixed cost credit is applied to the Intertie case to account for this reduction in labor costs. To a smaller degree, diesel generation labor costs are also assumed to be reduced if new hydroelectric plants or the coal project are included.

C. PRINCIPAL ASSUMPTIONS

Principal assumptions critical to the evaluation of alternative power supply plans are summarized as follows:

1. The expected initial year of commercial operation for the Intertie is 1999.
2. The initial study period begins in 1993 and extends through 2018, i.e., 20 years from the expected commercial operation date of the Intertie. Costs are then projected through an extended study period from 2019 through 2048. This covers the expected 50-year economic lifetime of the Intertie. All costs and electric load requirements are held constant after the 20-year initial study period.
3. All costs are stated in unescalated 1993 dollars and are assumed to have 0% per year real escalation, except for fuel costs which are assumed to escalate at a real rate corresponding to the oil price projections identified herein.
4. Estimated future annual costs are discounted to year end 1993 using an inflation free discount rate of 4.5% as provided by the Division
5. The base price of diesel fuel in 1993 is based on CVEA's 1993 mid-year reported purchase price as shown below:

| | | |
|------------|-------------|---------------------|
| Valdez | #2 Fuel Oil | 70 cents per gallon |
| Glennallen | #2 Fuel Oil | 75 cents per gallon |

6. High average annual escalation rates of fuel costs are based on the escalation trends identified in the Alaska Energy Authority's recommended World Oil Price Forecast, medium scenario, dated December 22, 1992. Low average annual escalation rates of fuel costs are based on projections of the WTI oil price, mid scenario, as provided by the Alaska Depart-

ment of Revenue in its Revenue Sources Book dated November 15, 1993. Both high and low fuel cost forecasts are shown below in constant 1992 dollars per barrel.

| | <u>Low</u> | <u>High</u> |
|------|------------|-------------|
| 1995 | 18.07 | 21.35 |
| 2000 | 20.22 | 24.16 |
| 2005 | 20.73 | 26.74 |
| 2010 | 21.26 | 29.35 |

7. The real price of diesel fuel for CVEA is estimated to increase at two-thirds the rate of the increase in assumed world or WTI oil prices to account for handling and transportation cost components, which should increase with inflation only, included in the price of fuel. The average annual rates of increase for the high and low projections are 1.73% and 0.66%, respectively.

8. The economic lives for the various resource alternatives are as follows:

| | |
|------------------------------------|----------|
| Intertie | 50 years |
| New Diesel Generators | 20 years |
| New Hydroelectric Facilities | 50 years |
| Coal-fired Power Plant | 30 years |

9. CVEA's total energy requirements are assumed to be seasonally shaped as approximately 70% during the winter period October-May and approximately 30% during the summer period June-September.

10. The capital costs of the Intertie and the other new resource alternatives are assumed to be recovered over a period equivalent to each resource's respective economic lifetime at an annual interest rate equivalent to the assumed discount rate.

11. The estimated capital cost of the Intertie, as shown in Table VI-5, is \$47,604,000 in 1993 dollars. Annual operations and maintenance costs of the Intertie are as shown in Table VI-6 and average \$230,000 per year over the first 15 years of Intertie operation.

12. The estimated capacity, energy generation capability, installed cost and annual operation and maintenance costs for each of the alternative generating resources are as described in Section IX of this report and are summarized in the following table.

Table X-1
Estimated Costs and Operating Characteristics
of Resource Options

| Resource | Available Capacity (kW) ⁽¹⁾ | | Annual Energy Capability (MWh) ⁽¹⁾ | | | Installed Cost (1993 \$000) | Annual O&M Costs ⁽⁶⁾ (1993 \$000) |
|-----------------------|--|----------------------|---|------------------------|-----------------------|-----------------------------|--|
| | Summer | Winter | Summer | Winter | Total | | |
| Diesel Generator | 1,610 | 1,610 | 3,385 | 7,898 | 11,283 ⁽²⁾ | 1,509 ⁽⁷⁾ | 132 |
| Diesel Generator | 2,150 | 2,150 | 4,520 | 10,547 | 15,067 ⁽²⁾ | 1,765 ⁽⁷⁾ | 176 |
| Allison Lake | 0 | 6,255 ⁽³⁾ | 0 | 27,396 | 27,396 ⁽⁴⁾ | 32,240 | 284 |
| Silver Lake -Option A | 0 | 15,000 | 1,176 | 43,576 | 44,752 ⁽⁴⁾ | 54,185 | 593 |
| -Option B | 0 | 14,000 | 2,376 | 46,376 | 48,752 ⁽⁴⁾ | 60,703 | 593 |
| Valdez Coal Facility | 6,000 ⁽⁹⁾ | 22,000 | 30,000 | 122,000 ⁽⁵⁾ | 152,000 | 36,600 | 2,200 ⁽⁸⁾ |

(1) Summer period is June through September and the winter period is October through May.

(2) Energy generation is based on 80% annual capacity factor for illustrative purposes. Actual generation levels would vary.

(3) Includes 3,045 kW from the Allison Lake Project and 3,110 additional capacity at the Solomon Gulch Project.

(4) Based on assumed average water conditions.

(5) Assumes 95% availability during the winter period, October through May. Actual energy generation would vary.

(6) Excludes fuel costs.

(7) Costs shown do not include estimated additional costs for power plant building, fuel storage tank and switchyard improvements which would be needed for increasing base load diesel generation in Valdez. These costs are added directly as inputs to the economic analysis model.

(8) Includes variable and fixed operations and maintenance costs at an assumed generation level of 40,000 mWh annually. Includes estimated costs for insurance, administrative and general expenses and renewals and replacements. Excludes operations and maintenance costs associated with the district heating system.

(9) Only the smaller of the two turbines to be installed in the coal project is assumed to be available in the summer months.

13. Existing diesel generators are assumed to be replaced rather than overhauled if a major overhaul is estimated to be needed during the study period. The estimated time between overhauls is 15,000 hours, based on information provided by CVEA. When a diesel generator is replaced, CVEA's fixed diesel operation and maintenance costs will not increase.

14. Station use power requirements for diesel generating plants is estimated to be 3.66% of net diesel generation.

15. Current staffing levels at CVEA's diesel power plants will change depending on the nature of the resource alternatives and the expected amount of diesel generation. The following table indicates the staffing level changes with respect to current staffing levels:

| Case | Valdez Power Plant | Glennallen Power Plant | Year of Adjustment | Estimated Adjusted Labor Cost (1993\$) |
|-------------------|-----------------------|---------------------------|-----------------------|--|
| All Diesel | +3 | 0 | 1997 | \$291,000 |
| Intertie | -1.5 | -4.5 | 1999 | \$(560,000) |
| Allison Lake | -1.5 | 0 | 1999 | \$(146,000) |
| Silver Lake (A&B) | -1.5 | 0 | 1999 | \$(146,000) |
| Coal Project | -1.5 | -1.5 | 1998 | \$(291,000) |
| Conservation | +3 | 0 | 1997 | \$291,000 |

16. Variable operations and maintenance expenses for diesel generators is 3.0 cents per kWh for existing diesel generators and 1.0 cents per kWh for new diesel generators. Fixed operation and maintenance expenses for new diesel generators is \$12 per kW-year.
17. Transmission losses over the Intertie and the existing Valdez to Glennallen transmission line are 3% of the power transmitted over each line.
18. For the Intertie Case, energy to be purchased from the Anchorage area by CVEA will be priced at an economy energy rate comparable to that presently paid by Golden Valley Electric Association. (See Table IX-5).
19. For the Intertie Case, energy generation at the Solomon Gulch Project surplus to the needs of CVEA is assumed to be sold to Anchorage utilities at the same rate CVEA is assumed to pay for power, i.e., an economy energy rate.

In reviewing the results of the analysis, it is important to keep in mind that this analysis is prepared from an overall perspective of the State and not from the perspective of CVEA or its customers. For example, if the Intertie is constructed and CVEA purchases power from the Anchorage area, CVEA may be assessed wheeling charges from MEA over that system. However, since MEA had no actual increase in costs to provide access to CVEA this cost is not included in the analysis. Another example is the capital cost of the Intertie itself. The Intertie cost is not reduced by an assumed level of State government contribution because the full cost of the Intertie will be borne by Alaskans.

D. DESCRIPTION OF ALTERNATIVE RESOURCE SCENARIOS

Several alternative resource scenarios have been developed which provide equivalent amounts of power to CVEA over the study period. Each of these scenarios has a specific list of resource additions and retirements based on the assumptions and operating criteria previously described. The resource scenarios have been developed for each of the four load forecast scenarios; high, medium-high, medium-low and low. As previously mentioned in Section VIII - Electric Load Forecast, the only difference between the two medium load forecast scenarios is with regard to the level of projected energy requirements at the Petro Star refinery beginning in 2018. The following subsections provide a description of each of the resource scenarios indicating what new resources are projected to be needed for each scenario and the years in which they will be added. Table X-2 provides a summary of the resource additions and retirements for each of the scenarios.

Tables are provided in Appendix J for each of the resource scenarios providing the results of the Resource Model for the low, medium low, medium-high and high load growth scenarios. These tables show the capacity and energy loads and resources and the estimated "comparable costs" of operation for each year of the study period. The results of the Resource Model for each resource scenario is six pages long. The present value of comparable costs for each scenario are accumulated for both the initial study period, 1993 through 2018, and the full study period, 1993 through 2048. These cumulative present values serve as the basis for the comparison of the various resource scenarios.

1. All Diesel Case

The All Diesel Case assumes that the Intertie is not constructed and that diesel generators are added as needed to provide CVEA's projected reserve and generation requirements. The reserve requirements are based on the ability to meet the peak load in each load center with an outage on the Valdez to Glennallen transmission line and an outage on the largest diesel generator located at each load center (which is currently 2,200 kW at each site). The Solomon Gulch Project and the existing diesel generators provide the firm capacity at Valdez. During the winter, the firm capacity available from the Solomon Gulch Project is assumed to be 5,000 kW and the Valdez diesel plant is assumed to provide 9,750 kW. The firm capacity located in Glennallen includes 6,800 kW from the existing diesel generators.

Based on the generation requirements for the medium-high and medium-low load forecasts, the next scheduled major diesel generator overhaul is assumed to be required for the Valdez diesel generators, Unit 4, Unit 6 and Unit 5, in 1997, 1998 and 2000 respectively. These units are assumed to be retired rather than overhauled at that time and replaced with new 2,150 kW units. A new diesel power plant building is assumed to be constructed in Valdez in 2004 also. A new 2,150 kW diesel generator is assumed to be added in Glennallen in 1996 and Glennallen Unit 6 is retired and replaced in 1999.

To accommodate the increase in diesel generation, a night crew of three people is assumed to be added to the Valdez plant in 1999 at a cost of \$291,000 per year. Also, a new fuel storage tank and switchyard improvements are assumed to be added in 1999.

Under the low load forecast, the existing Valdez diesel generators, Unit 4 and Unit 6, are assumed to be retired and replaced with new 2,150 kW diesel units in 1997 and 1998, respectively, instead of being overhauled. A new 2,150 kW diesel generator is assumed to be added in Glennallen in 1996. The projected annual amount of diesel generation for the low load forecast does not increase above existing levels so no changes in operating staff are included. Also, the new fuel storage tank and new switchyard are not included.

Based on the high load forecast, two existing Valdez diesel generators, Unit 4 and Unit 5, are assumed to be retired and replaced in 1997, with two new 2,150 kW diesel generators. Unit 6 is retired and replaced in 1998. Two additional diesel generators are assumed to be required in Valdez, one each in 2005 and 2018. Glennallen Unit 6 is assumed to be retired and replaced in 1998 with a new 2,150 kW diesel generator. In addition, two new 2,150 kW diesel generators are assumed to be added in Glennallen, one each in 1996 and 2005. A night crew of 3 people is assumed to be added in Valdez in 1997 to accommodate the increased amounts of diesel generation. Also a new fuel storage tank and switchyard improvements are assumed to be added in 1999 and a new power plant building is to be added in 2004.

The total cumulative present value of the annual costs for the All Diesel Case under the medium-high load growth projection is \$84,771,000. The medium-low, high and the low load growth projections resulted in total cumulative net present values of \$67,853,000, \$121,562,000 and \$39,565,000, respectively.

2. Intertie Case

The Intertie Case assumes that the Intertie is constructed and becomes operable by 1999. The reserve requirements for Valdez are based on the ability to provide peak load with an outage on the transmission line between Glennallen and Valdez and an outage on the largest diesel generator located in Valdez which is currently 2,200 kW. The ability to purchase economy energy over the Intertie is assumed to allow CVEA to adjust its management of the Solomon Gulch Project reservoir and increase the firm winter peak capability to 6,500 kW. The Valdez diesel plant is assumed to provide 9,750 kW. With the construction of the Intertie, Glennallen would be interconnected to the generating facilities in the Anchorage area as well as those in Valdez. The reserve requirement for Glennallen is assumed to be based on the ability to provide peak load with an outage on one of the transmission lines. Glennallen is assumed to maintain sufficient generation to meet its own peak load.

Based on the projected medium-high, medium-low and low load growth scenarios, no new generation in Valdez is assumed to be required during the study period. Although the Glennallen load center is slightly deficient in generation requirements prior to energization of the Intertie, no new diesel generators are assumed to be installed.

Economy energy purchases over the Intertie are assumed to displace all CVEA diesel generation. The existing operating staff at the Glennallen Power Plant and the Valdez Power Plant are assumed to be reduced to 1.5 employees per plant for an estimated savings of \$560,000 per year compared to current operating staff labor costs. Also, no new fuel storage tank or switchyard improvements at the power plants are assumed to be required.

Under the medium-high, medium-low and low load growth projections, no new diesel generator units are to be added at Valdez or Glennallen. For the high load growth scenario, one new 2,150 kW unit is to be added in Valdez in 2005 and one new unit is to be added in Glennallen in 2014. These new diesel generators are needed in the Intertie Case to maintain appropriate reserve capabilities in both load centers.

For all of the load growth scenarios, surplus generation from the Solomon Gulch Project is assumed to be sold over the Intertie and sold at the economy energy purchase rate.

The total cumulative net present value of the annual costs for the Intertie Cases for the medium-high and medium-low scenarios is \$72,604,000 and \$63,415,000, respectively. The high and low growth projections resulted in total cumulative net present values of \$91,227,000 and \$50,042,000, respectively.

3. Allison Lake Case

The Allison Lake Case assumes that the Allison Lake hydroelectric project is constructed and operable by 2000. This case also assumes that the Intertie is not constructed and diesel generators are added as required to meet future power requirements not met by the Allison Lake Project. The reserve requirements

for each load center are based on the ability to provide peak load with an outage on the transmission line between Glennallen and Valdez and an outage on the largest diesel generator which is currently 2,500 kW for each load center. The Allison Lake project is assumed to provide 3,145 kW of firm capacity during the winter peak. Also, the additional hydro energy available from Allison Lake is assumed to allow CVEA to operate the Solomon Gulch Project reservoir to provide 6,500 kW of firm capacity during the winter peak period. The existing diesel generators in Valdez are assumed to provide 9,750 kW of firm capacity. The existing diesel generators in Glennallen provide 6,800 kW of firm capacity.

The current staffing level at the Valdez power plant is assumed to be reduced from 3 to 1.5 employees providing an annual savings of \$145,500 when the Allison Lake Project comes on-line for the low and medium-low load forecast scenarios. No change in the existing staffing levels is assumed to occur at the Glennallen power plant because diesel generation is still required.

Under the projected medium-high and medium-low load growth cases, the next major overhaul for Valdez Unit 4 is assumed to be required in 1997. It is assumed that the unit would be retired and replaced with a 2,150 kW unit at that time. Valdez Unit 6 is also expected to be retired and replaced in 1998. The Glennallen Unit 6 would be retired and replaced at the time of its next scheduled overhaul in 1999. One new 2,150-kW unit is added in Glennallen in 1996. For the high load growth scenario, an additional new diesel generator is needed in Glennallen in 2006.

The total cumulative net present value of the annual costs for the Allison Lake Case for the medium-high load growth scenario is \$71,989,000 and \$60,596,000, \$108,298,000 and \$44,808,000 for the medium-low, high and low load forecasts, respectively.

4. Silver Lake Case

The Silver Lake Case assumes that the Silver Lake hydroelectric project is constructed and begins operation in 2001. This case also assumes that the Intertie is not constructed and that diesel generators are added as required to meet future power requirements. The reserve requirements for each load center are based on the ability to serve peak load with an outage on the transmission line between Glennallen and Valdez and an outage on the largest diesel generator which is currently 2,500 kW for each load center. Because of the long submarine transmission line interconnecting the Silver Lake Project to Valdez, the Silver Lake project is not assumed to provide firm capacity to CVEA. The Solomon Gulch Project and local diesel generators provide firm capacity. With the additional hydro energy available from Silver Lake, CVEA is assumed to be able to operate the Solomon Gulch Project reservoir to provide 6,500 kW during the winter peak period. The existing diesel generators in Glennallen provide 6,800 kW of firm capacity.

The current staffing level at the Valdez plant is assumed to be reduced to 1.5 employees providing an annual savings of \$145,500 when the Silver Lake Project comes on-line. No change in the existing staffing levels is assumed to occur at the Glennallen plant because diesel generation is still required.

Under the projected high load growth case, Valdez Units 4 and 6 are retired and replaced in 1997 and 1998, respectively. Two new 2,150 kW diesel generators are projected to be added in Glennallen, one each in 1996 and 2006 for the high case. Unit 6 in Glennallen is retired and replaced in 1998 in the high load case. For the medium-high and medium-low cases, two units are retired and replaced in Valdez, one each in 1997 and 1998 and one unit is retired and replaced in Glennallen in 1999. A new unit is to be added in Glennallen in 1996 for these two scenarios and for the low load growth scenario.

The total cumulative net present value of the annual costs for the Silver Lake Case Option A project configuration is \$74,929,000, \$70,508,000, \$108,298,000, and \$67,992,000 for the medium-high, medium-low, high, and low load forecast scenarios, respectively. For the Option B configuration, the cumulative net present values are \$76,720,000, \$74,233,000, \$108,600,000 and \$67,992,000 for the medium-high, medium-low, and high and low load growth scenarios, respectively.

5. Glennallen Coal Project Case

The Coal Case assumes that a 22,000 kW coal facility is constructed in Valdez and begins operation by 1998. This case also assumes that the Intertie is not constructed and diesel generators would be added as required to meet any additional future power requirements. The reserve requirements for each load center are based on the ability to serve peak load with an outage on the transmission line between Glennallen and Valdez and an outage on the largest diesel generator which is currently 2,500 kW for each load center.

The current staffing levels at the Valdez and Glennallen plant are assumed to be reduced by 1.5 employees in 1998 at each site providing an annual savings of \$291,000.

Under all load growth cases, no new diesel generators are projected to be added in Valdez. One new unit is added in Glennallen in 1996 in all cases and a second, 2,150 kW unit is added in Glennallen in 2006 in the high case.

The total cumulative net present value of the annual costs for the Coal Case is \$76,567,000, \$77,062,000, \$98,898,000 and \$61,432,000 for the medium-high, medium-low, high, and low load forecast scenarios, respectively. Since the net annual costs of the coal facility are partially dependent on revenues received from the sale of district heating, the value of which is tied to oil prices, the cumulative present value for the medium-low load forecast scenario is lower than that for the medium-high load forecast scenario. Low oil price escalation is assumed in conjunction with the medium-low load forecast scenario.

6. Conservation Case

The Conservation Case assumes that the Intertie is not constructed and that conservation measures are implemented and diesel generators are added as needed to provide CVEA's power requirements. The conservation measures could be included in each case. However, a separate case has been developed to highlight the conservation impacts. The reserve requirements are the same as for the Diesel Case. During the winter peak, the firm capacity available from the Solomon Gulch Project is assumed to be 5,000 kW and the Valdez diesel plant is assumed to provide 9,750 kW. The Glennallen diesel plant is assumed to provide 6,800 kW.

The conservation programs identified in Section IX of this report are projected to be implemented beginning in 1994. The residential programs include (1) incentive payments for purchases of high-efficiency refrigerators and freezers and (2) the replacement of selected existing incandescent lights with compact fluorescent lights. The commercial programs include two lighting programs. The full implementation of these programs is expected to be completed over a 20-year period. Consequently, the

total energy savings realized from the conservation measures are projected to gradually increase over time. The cost of the programs are also projected to be paid over the same period of time.

The retirement and replacement schedule for diesel generators and related facilities are the same as for the All Diesel Case for all load growth scenarios. This indicates that the conservation case does not provide enough capacity or energy reduction to delay the scheduled additions of new generating units.

The total cumulative present value of the annual costs for the Conservation Case under the medium-high and medium-low load growth scenarios is \$84,098,000 and \$67,777,000, respectively, representing only a slight savings from the costs of the All-Diesel Case. The Conservation Case was not run for the other resource alternatives, however, we would expect to see only minimal savings in the total cumulative present worth as is seen for the All Diesel Case.

Table X-2
Year of Generation Additions and Retirements
for the Alternative Resource Plans

| | Load Forecast Scenario | | | |
|-------------------------------------|---------------------------|------------------|------------------|------------|
| | High | Medium-High | Medium-Low | Low |
| ALL-DIESEL CASE | | | | |
| <u>Retirements</u> | | | | |
| Valdez Unit 4..... | 1997 | 1997 | 1997 | 1997 |
| Valdez Unit 5..... | 1997 | 2000 | 2000 | - |
| Valdez Unit 6..... | 1998 | 1998 | 1998 | 1998 |
| Glennallen Unit 6..... | 1998 | 1999 | 1999 | - |
| <u>Replacements & Additions</u> | | | | |
| Valdez - 2,150 kW Diesel | 1997(2), 1998, 2005, 2018 | 1997, 1998, 2000 | 1997, 1998, 2000 | 1997, 1998 |
| Glennallen - 2,150 kW Diesel | 1996, 1998, 2005 | 1996, 1999 | 1996, 1999 | 1996 |
| INTERTIE CASE | | | | |
| <u>Retirements (None)</u> | | | | |
| <u>Replacements & Additions</u> | | | | |
| Intertie..... | 1999 | 1999 | 1999 | 1999 |
| Valdez - 2,150 kW Diesel | 2005 | | | |
| Glennallen - 2,150 kW Diesel | 2014 | | | |
| ALLISON LAKE CASE | | | | |
| <u>Retirements</u> | | | | |
| Valdez Unit 4..... | 1997 | 1997 | 1997 | 1997 |
| Valdez Unit 5..... | | | | |
| Valdez Unit 6..... | 1998 | 1998 | 1998 | |
| Glennallen Unit 6..... | 1998 | 1999 | 1999 | |
| <u>Replacements & Additions</u> | | | | |
| Allison Lake Project | 2000 | 2000 | 2000 | 2000 |
| Valdez - 2,150 kW Diesel | 1997, 1998 | 1997, 1998 | 1997, 1998 | 1997 |
| Glennallen - 2,150 kW Diesel | 1996,1998, 2006 | 1996, 1999 | 1996, 1999 | 1996 |

Table X-2
Year of Generation Additions and Retirements
for the Alternative Resource Plans
(continued)

| | Load Forecast Scenario | | | |
|-------------------------------------|------------------------|-------------|------------|------|
| | High | Medium-High | Medium-Low | Low |
| SILVER LAKE CASE | | | | |
| <u>Retirements</u> | | | | |
| Valdez Unit 4..... | 1997 | 1997 | 1997 | 1997 |
| Valdez Unit 5..... | | | | |
| Valdez Unit 6..... | 1998 | 1998 | 1998 | |
| Glennallen Unit 6..... | 1998 | 1999 | 1999 | |
| <u>Replacements & Additions</u> | | | | |
| Silver Lake Project | 2001 | 2001 | 2001 | 2001 |
| Valdez - 2,150 kW Diesel | 1997, 1998, | 1997, 1998 | 1997, 1998 | 1997 |
| Glennallen - 2,150 kW Diesel | 1996, 1998, 2006 | 1996, 1999 | 1996, 1999 | 1996 |
| GLENNALLEN COAL PROJECT | | | | |
| <u>Retirements (None)</u> | | | | |
| <u>Replacements & Additions</u> | | | | |
| Coal Project | 1998 | 1998 | 1998 | 1998 |
| Glennallen - 2,150 kW Diesel | 1996, 2006 | 1996 | 1996 | 1996 |

E. COMPARISON OF ECONOMIC ANALYSIS RESULTS

Table X-3 provides a comparison of the cumulative present value of the comparable system costs over the full study period for the various resource scenarios for the high, medium-high, medium-low and low load growth scenarios. The high and medium-high load forecast cases shown in Table X-3 were evaluated assuming high escalation in fuel costs and the low and medium-low load forecast cases assumed low escalation in fuel costs. These cumulative present values can be compared within each column of the table, with the lowest value indicating the resource scenario which provides the greatest economic benefit relative to the other scenarios. As can be seen in Table X-3, the Intertie Case provides the lowest cumulative present value of all the resource scenarios for the high load growth scenario.

For the medium-high and medium-low load growth scenarios, the Allison Lake Case is the lowest cost resource scenario. For the low load growth scenario, the All Diesel Case is the lowest resource scenario. It should be noted that the cumulative present values for the Allison Lake and Intertie resource scenarios are very close for the medium-high and medium-low load growth scenarios. The Conservation Case shows only a slight benefit over the All Diesel Case in all load growth scenarios.

Table X-3
Summary of Economic Analysis
Cumulative Present Value of Comparable System Costs
(\$000)

| Resource Scenario | Load Forecast/Fuel Price Scenario(1) | | | |
|--------------------|--------------------------------------|----------------|---------------|--------|
| | High | Medium-High(2) | Medium-Low(2) | Low |
| All Diesel Case | 121,562 | 84,771 | 67,853 | 39,565 |
| Intertie Case | 91,227 | 72,604 | 63,415 | 50,042 |
| Allison Lake Case | 108,298 | 71,989 | 60,596 | 44,808 |
| Silver Lake A Case | 108,376 | 74,929 | 70,508 | 63,462 |
| Silver Lake B Case | 108,600 | 76,720 | 74,233 | 67,992 |
| Coal Facility Case | 98,898 | 76,567 | 77,062 | 61,432 |
| Conservation Case | 120,690 | 84,098 | 67,777 | 39,775 |

- (1) The high and medium-high load forecast scenarios are combined with the high fuel price scenario and the low and medium-low load forecast scenarios are combined with the low fuel price scenario in the economic analysis.
- (2) The medium-high and medium-low cases vary only in the estimated energy requirements of the Petro Star refinery beginning in 2018 and in the fuel price scenario assumed.

A factor which is commonly used to quickly evaluate the relative costs of various resource alternatives is the benefit/cost ratio. This index divides the cumulative present value of the benefits of an alternative by the cumulative present value of the costs of the alternative. In the case of evaluating the various resource alternatives included in this study, the All Diesel case represents the benefits of an option and the specific option represents the costs. The All Diesel case is to be offset by the implementation of the resource option, therefore it represents the benefits. A benefit/cost ratio greater than 1.0 indicates that the benefits of the option exceed the costs. The following table shows the benefit cost ratios for the various resource options for each of the load forecast scenarios.

Table X-4
Comparison of Benefits and Costs
Benefit/Cost Ratios(1)

| Resource Scenario | Load Forecast/Fuel Price Scenario(2) | | | |
|--------------------|--------------------------------------|----------------|---------------|------|
| | High | Medium-High(3) | Medium-Low(3) | Low |
| All Diesel Case | 1.00 | 1.00 | 1.00 | 1.00 |
| Intertie Case | 1.33 | 1.17 | 1.07 | 0.79 |
| Allison Lake Case | 1.12 | 1.18 | 1.12 | 0.88 |
| Silver Lake A Case | 1.12 | 1.13 | 0.96 | 0.62 |
| Silver Lake B Case | 1.12 | 1.10 | 0.91 | 0.58 |
| Coal Facility Case | 1.23 | 1.11 | 0.88 | 0.64 |
| Conservation Case | 1.01 | 1.01 | 1.00 | 0.99 |

- (1) Benefit/cost ratios are calculated as the cumulative present value of the diesel alternative divided by the cumulative present value of the respective resource alternative. Benefit/cost ratios are calculated independently for each load forecast scenario.
- (2) The high and medium-high load forecast scenarios are combined with the high fuel price scenario and the low and medium-low load forecast scenarios are combined with the low fuel price scenario.
- (3) The medium-high and medium-low cases vary only in the estimated energy requirements of the Petro Star refinery beginning in 2018 and in the fuel price scenario assumed.

The results of the economic analysis are highly sensitive to adjustments in the forecasted load growth in CVEA's service area. Many assumptions and estimates have been used in developing the economic analysis and it must be acknowledged that if conditions are different than those that were assumed, the outcome of the analysis would be different. In addition to load growth, other factors which could significantly affect the economic analysis include the capital cost estimates of the various resources including the Intertie, the cost of fuel, the cost of power to be purchased by CVEA from Anchorage utilities and the amount of energy available from the Solomon Gulch Project.

Alternative capital cost scenarios were not included as part of this analysis. It is important to note when reviewing the results of the economic analysis that the level of detail employed in the development of the cost estimates for the various resources varies significantly. For instance, the cost estimates for the Allison Lake and Silver Lake projects that were used in this analysis were derived from previous reconnaissance level studies. Further, the costs associated with the Valdez coal project are considered very preliminary at this time and could vary significantly from the cost estimates used in this report. Although we have no indication whether the cost estimates for the diesel, coal and hydro projects are either high or low, we would attach a higher level of confidence to the Intertie cost estimate because it has been reviewed and developed in considerably greater detail.

F. COST OF POWER AND FINANCE CONSIDERATIONS

In Chapter 19, SLA 1993, the Alaska legislature appropriated \$35.0 million to the Department of Community and Regional Affairs for payment as a loan to participating utilities for the design, and construction of a Sutton-Glennallen intertie. In addition, the legislation provides:

- a. that the appropriation "is contingent upon the completion of a feasibility study and finance plan satisfactory to the Department of Community and Regional Affairs as set out in former AS 44.83.181," and
- b. that the appropriation "is contingent on the participating utility or utilities and the Department of Community and Regional Affairs entering into an agreement for a loan at zero interest for a term of 50 years."

The 1993 Alaska legislature also authorized (in Chapter 18, Sec. 32) the issuance of up to \$25.0 million in bonds by the Alaska Industrial Development and Export Authority "to finance the acquisition, design and construction of a power transmission intertie of at least 138 kilovolts between Sutton and Glennallen and owned, for the benefit of all of the utilities participating in the Intertie, by Copper Valley Electric Association."

For purposes of the economic analysis of this feasibility study, the value of the \$35.0 million, zero interest, 50-year State loan is not deducted from the cost of the Intertie nor from any of the other resource alternatives per direction from the Division of Energy. The Division's reasoning is that, although a benefit-cost analysis conducted solely from the perspective of CVEA consumers would be limited to comparison of expected benefits and costs to CVEA, a benefit-cost analysis conducted from the perspective of the State of Alaska must consider all benefits and costs that would be borne by Alaskans. This would necessarily include any costs expected to be paid from the State treasury as well as costs expected to be paid directly by CVEA consumers.

In addition to the requirements for an overall economic analysis, regulations with respect to former AS 44.83.181 require that the feasibility study include "the estimated cost of power [for the proposed project] based on hypothetical financing conditions." Further, the regulations state (3 AAC 94.060(c)(6) and (7)):

1. that "various combinations of alternatives and timing will be evaluated to formulate plans which cost the least," and
2. that "cost of power" will be among the indicators used to evaluate each plan.

For this feasibility study, "cost of power" is assumed to mean the annual nominal wholesale cost per kWh to CVEA of generating and/or purchasing power delivered to the CVEA distribution system under each power supply scenario considered in the feasibility study, under hypothetical financing conditions, excluding costs that are common to all scenarios such as the purchase of Solomon Gulch energy, or depreciation of existing equipment. For example, the "cost of power" under the Intertie scenario is estimated by adding the following:

1. The sum of Intertie debt service, Intertie operation and maintenance expenses, and labor cost for maintenance of back-up diesel generation, divided by the number of kWh to be purchased over the Intertie.

2. The expected price per kWh to be paid to the Anchorage utility supplying the power to be purchased by CVEA, including estimated margins.

The cost of power has also been estimated for the Allison Lake scenario and the Glennallen Coal Project scenario. For each of these scenarios, the cost of power includes the cost of generation for the same amount of power as would be purchased over the Intertie. This amount of power is equal to CVEA's total energy requirement, less generation by the Solomon Gulch Project. If a scenario's primary resource is not large enough to supply the necessary net energy requirement, diesel generation is used to fulfill the remaining energy needs. The cost of power for each scenario includes all costs of generation and purchased power for that scenario.

A variant of the Allison Lake "cost of power" estimate is also presented based on the possibility that additional energy generated by the existing Solomon Gulch turbines due to the provision of additional water from Allison Lake will be assessed an additional wholesale charge of 6.4 cents per kWh, the existing wholesale power rate for the Four Dam Pool.

Additional discussions on the application of the \$35.0 million state loan and the Four Dam Pool power cost is provided in Appendix L, attached to this report.

For this feasibility study, "cost of power" estimates have been developed to compare the various resource alternatives. These cost of power estimates are considered preliminary. A finance plan, presently being prepared for the Division, is expected to examine potential wholesale power costs for the different power supply alternatives in greater depth and detail. Certain additional assumptions and parameters should be noted for the "cost of power" estimates presented below:

1. Cost of power estimates are presented in this report only for two separate years; 2000 and 2010. In general, the difference between the cost of power estimates over time is related to the forecasted power requirements of CVEA and inflation impacts on fuel and other operating costs.
2. The cost of power estimates are highly sensitive to assumed load growth in the Copper Valley service territory. Cost of power is therefore estimated for all four load growth scenarios. As previously described for the economic analysis, the low and medium-low load forecast scenarios are combined with low fuel cost escalation and the high and medium-high load forecast scenarios are combined with the high fuel cost escalation.
3. The hypothetical financing conditions assumed for this analysis are as follows:
 - a. The \$35.0 million, zero interest, 50-year loan is used to finance the Intertie.

While additional legislative action would be needed to use the \$35.0 million appropriation for a project other than the Intertie, cases have been developed whereby the \$35.0 million, zero-interest loan is used to finance the other capital intensive alternatives as well. The term of the state loan is reduced to 25 years for the proposed coal plant to correspond with its assumed repayment period. The full 50-year term is assumed to apply to Allison Lake. Diesel generators are not assumed to be financed with state loans in any scenario.

- b. All supplemental financing is assumed to occur through issuance of debt at 7.5 percent interest and with repayment terms of 30 years for the Intertie and the hydroelectric projects, 20 years for diesel generators and 25 years for the coal project.
- c. Costs are shown in nominal dollars based on an assumed 3.5 percent annual inflation rate.
- d. Supplemental borrowed funds, if needed to fund capital costs, are assumed to be retained only after state loan monies are fully used. The estimated amount of these supplemental borrowings includes capitalized interest from the date of borrowing to the commercial operation date and a financing expense of 2.0% of the borrowed amount. Funds are assumed to be borrowed periodically as needed throughout construction.

The cost of power estimates have been developed using nominal costs (i.e., including inflation) as opposed to the use of constant dollar costs for the economic analysis. The cost of power includes all related fuel, operation and maintenance, applicable purchased power costs, and annual debt service costs. A critical element of the cost of power analysis is the estimation of annual debt service costs based on the estimated financing requirements of each resource alternative. For the Intertie, the estimated cost of construction of \$47,604,000 in 1993 dollars is increased to \$53,827,000 with assumed inflation during construction. It is further assumed that proceeds from the state loan would be used before supplemental debt is issued. The estimated supplemental borrowing would be \$21,262,000 to cover remaining construction costs not funded with the state loan, pay interest during construction on the debt and pay the costs of issuance.

Total supplemental borrowing financing requirements for the Allison Lake Project, assuming a \$35,000,000 state loan is available, are \$2,518,000. Without the state loan, financing requirements for the Allison Lake Project are estimated to be \$46,595,000. If the coal project could be funded with a \$35,000,000 state loan, additional financing requirements would be \$6,522,000. Without the state loan, the total financing requirements of the coal project would be \$47,408,000.

The following table summarizes the cost of power projections for the resource alternatives under various load forecast and financing assumptions.

Table X-5
Estimated Cost of Power
 (nominal cents/kWh)

| Resource Option | Load Forecast/Fuel Forecast Scenario(1) | | | | | | | |
|---|---|------|-------------|------|------------|------|------|------|
| | High | | Medium-High | | Medium-Low | | Low | |
| | 2000 | 2010 | 2000 | 2010 | 2000 | 2010 | 2000 | 2010 |
| ALL DIESEL (2) | 11.7 | 17.1 | 12.6 | 17.7 | 12.0 | 15.5 | 10.6 | 14.6 |
| INTERTIE (3) | 9.5 | 11.1 | 10.7 | 12.2 | 10.3 | 11.0 | 12.0 | 13.6 |
| ALLISON LAKE | | | | | | | | |
| State Loan (4) | | | | | | | | |
| With Payment for Additional Solomon Gulch Energy (5) | 10.1 | 13.6 | 10.1 | 12.5 | 9.9 | 11.6 | 9.2 | 10.4 |
| Without Payment for Solomon Gulch Energy (6) | 8.1 | 12.0 | 7.6 | 10.0 | 7.4 | 9.0 | 6.0 | 6.4 |
| No State Loan (7) | | | | | | | | |
| With Payment for Additional Solomon Gulch Energy (5) | 16.4 | 18.1 | 18.0 | 19.3 | 17.8 | 18.3 | 19.5 | 21.3 |
| Without Payment for Solomon Gulch Energy (6) | 14.4 | 16.4 | 15.5 | 16.7 | 15.3 | 15.8 | 16.3 | 17.3 |
| SILVER LAKE (8) | | | | | | | | |
| State Loan (9) | 10.0 | 11.8 | 11.2 | 10.3 | 11.2 | 10.3 | 13.5 | 14.0 |
| No State Loan (10) | 17.0 | 16.9 | 20.1 | 18.1 | 20.1 | 18.0 | 25.4 | 26.5 |
| VALDEZ COAL PROJECT | | | | | | | | |
| State Loan (11) | 10.3 | 11.3 | 11.3 | 11.8 | 14.1 | 15.2 | 16.9 | 20.3 |
| No State Loan (12) | 15.2 | 14.6 | 17.3 | 16.9 | 17.7 | 18.3 | 21.6 | 25.3 |

- (1) The high and medium load forecast scenarios assume the high fuel price scenario while the low and medium-low load forecast scenarios assume the low fuel price scenario.
- (2) Assumes new diesel generating units are financed with revenue bonds. Includes estimated costs of new fuel storage system and switchyard improvements in 1999.
- (3) Assumes capital cost of Intertie is financed with \$35.0 million zero-interest state loan and \$21.3 million of supplemental debt. Includes cost of power purchased from Anchorage utilities and estimated charges of 0.2 cent per kWh (1993 dollars) for transmission over MEA and CEA transmission lines.
- (4) Assumes \$35.0 million state loan is applied towards construction costs. Remaining capital costs of \$2.5 million assumed to be financed with supplemental debt. It is assumed that the project comes on-line in 2000.
- (5) Includes payments of 6.4 cents per kWh (pursuant to Four Dam Pool Power Sales Agreement) for additional energy generated at the Solomon Gulch Project resulting from water released into the Solomon Gulch reservoir from Allison Lake. Debt service component of 4.0 cents per kWh is held constant whereas O&M component is adjusted annually for inflation.
- (6) Assumes additional power generated at the Solomon Gulch Project does not require any additional payment.
- (7) Assumes Allison Lake Project is financed with \$46.6 million of debt financing and no state loan is made available.
- (8) Cost of power shown in the year 2000 column is for 2001, the first year of operation of the Silver Lake Project.
- (9) Assumes \$35.0 million state loan is applied towards construction costs. Remaining capital costs of \$33.1 million assumed to be financed with supplemental debt.
- (10) Assumes project is financed with \$82.5 million of debt financing and that no state loan is made available.
- (11) Assumes Coal Project is financed with \$35.0 million zero-interest state loan and \$6.5 million of supplemental debt.
- (12) Assumes Coal Project is financed with \$47.4 million of debt financing and that no state loan is made available.

BIBLIOGRAPHY

- [1] Sutton to Glennallen 138 kV Transmission Intertie Project, Volumes 1 and 2, Final Report, prepared by Power Engineers, Inc. for Copper Valley Electric Association, January 1993.
- [2] Railbelt Intertie Reconnaissance Study, Volumes 8a and 8b, Northeast Transmission Intertie Project, prepared by Power Engineers, Inc. for the Alaska Power Authority, June 1989.
- [3] Meteorological Evaluation of the Proposed Palmer to Glennallen Transmission Line Route, No. MRI 82 FR-1868, prepared by Meteorological Research, Inc., for LEMCO Engineers in conjunction with the Cordova Power Supply Feasibility Study performed by Stone & Webster Engineering Corporation for the Alaska Power Authority, April 1982.
- [4] Interim Report - Tyee Lake 138 kV Transmission Line Conductor, Structures & Foundations, Wrangell to Petersburg, prepared by Dryden & LaRue for the Alaska Energy Authority, December 1991.
- [5] Guidelines for Electrical Transmission Line Structural Loading, ASCE Manuals and Reports on Engineering Practice No. 74, American Society of Civil Engineers, 1991.
- [6] Cordova Power Supply Feasibility Study, prepared by Stone & Webster Engineering Corporation, for the Alaska Power Authority, 1982-1985.
- [7] Design Review of Glennallen-Valdez 138-kV Transmission Line, Executive Summary, prepared by International Engineering Company for the Copper Valley Electric Association, 1985.
- [8] Report on Problems on Anchorage-Fairbanks Intertie, letter report prepared by H. Brian White for the Alaska Energy Authority, February 1991.
- [9] Design Manual for High Voltage Transmission Lines, Rural Electrification Administration Bulletin 1724E-2000, September 1992.
- [10] Bradley 115 kV Transmission Lines, Basic Design Manual, prepared by Dryden & LaRue, Inc. for Stone & Webster Engineering Corporation, February 1986, revised November 1987.
- [11] Draft Preliminary Market and Financial Assessment of the Lake Tyee to Swan Lake Intertie, by RSA Engineering, Inc. and R. W. Beck and Associates for the Alaska Energy Authority, December 27, 1990.

[12] Suggested Practices for Raptor Protection on Power Lines - The State of the Art in 1981, Raptor Research Report No. 4, Raptor Research Foundation, Inc. 1981.

[13] Anchorage-Fairbanks Transmission Intertie Structure Study for Alaska Power Authority, prepared by Commonwealth Associates, Inc. September 1981.

[14] Rental Rate Blue Book for Construction Equipment, DataQuest, January 1993.

[15] Feasibility Study of Transmission Line System Bradley Lake Hydroelectric Power Project, prepared for Alaska Power Authority by Dryden & LaRue, 1983.

[16] Bulletin No. 138. The Handy Whitman Index of Public Utility Construction Costs, Whitman, Requardt and Associates, July 1993.

Appendix A

ROUTE SELECTION EVALUATION DOCUMENTATION

Exhibit A-1 Transmission Line Routing Evaluation Criteria

Exhibit A-2 Routing Evaluation Scores and Ranking

| | |
|------------------|-------------------------------------|
| Table S-1 | Equal Weighting |
| Table S-2 | High Financial Weighting |
| Table S-3 | High Construction Weighting |
| Table S-4 | High Land Use Weighting |
| Table S-5 | High Environmental Weighting |

Exhibit A-3 Route Evaluation Matrices

| | |
|----------------------------|----------------------------|
| Tables A-1 thru A-4 | Route Alternative A |
| Tables B-1 thru B-4 | Route Alternative B |
| Tables C-1 thru C-4 | Route Alternative C |
| Tables D-1 thru D-4 | Route Alternative D |

ALASKA ENERGY AUTHORITY**Copper Valley Intertie****Transmission Line Routing Evaluation Criteria****ENVIRONMENTAL CONSIDERATIONS****E-1 Potential Construction Impacts (Dust, Traffic, Noise)**

Transmission line construction will create short-term construction impacts such as increased noise levels and generation of dust. Those traveling through the area where construction of the line is occurring may be affected by traffic disruption, and may be annoyed by short-term delays. Each 1,000-foot segment of line length adjacent to residences or roads represents one unit of measure. Because the impact will be temporary, a weight of 1 has been assigned to this criterion.

Construction-related traffic will occur all along the Glenn Highway and will result in short-term construction impacts even where the line is distant. All route alternatives have the same number of road crossings. These impacts, considered common to all route segments, were not evaluated separately.

E-2 Potential Habitat Damage or Need for Restoration

Areas with steep slopes are susceptible to erosion and gullying when vegetation is removed and machinery operates on the cleared areas. Effects from the resulting sedimentation are likely to affect adjacent habitat or water bodies. Special restoration measures are likely to be required to re-establish vegetative cover. Each 1,000-foot segment of line length that passes through steep terrain, defined for the purpose of this study as a 15° (27%) slope, and does not parallel paved roads represents one unit of measure. A weight of 3 has been assigned to this criterion.

E-3 Clearing in Wetland/Riparian Areas

Some clearing in wetlands or riparian areas may be necessary to provide access even though no structures would be placed in such areas. Any permanent clearing will reduce the amount of such habitat available to wildlife. Wetlands and riparian areas provide habitat of value to a large number of species, including a number of sensitive species. Each 1,000-foot segment of line length which may require some clearing in riparian or wetland areas represents one unit of measure. A weight of 5 has been assigned to this criterion, reflecting the high value of the habitat that may be affected.

E-4 Clearing in Treed Lands

The corridor has no significant commercial-value forest resources. West of Sheep Mountain in the Matanuska River Valley forests are dominated by cottonwood, birch, alder, and white spruce. East of Tahnetta Pass forest cover is intermittent and dominated by relatively stunted black spruce. A bark beetle infestation is known to threaten the spruce stands, especially white spruce. Special right-of-way treatment will be required to prevent the spread of the bark beetle.

Clearing of trees on treed lands may cause significant impact due to habitat loss as well as aesthetic and recreational losses. The cleared right-of-way will, in some cases, provide another access trail for off-road vehicles with the possibility of increased hunting pressure and noise. In addition, reliability concerns may require clearing of a wider area to remove trees which could interfere with line operation. It is

recognized that cleared lands may improve the habitat for certain species, e.g., moose. Each 1,000-foot segment of line length which may require clearing of trees represents one unit of measure. A weight of 5 has been assigned to this criterion.

E-5 Cultural Resource High Conflict Areas

Mapping indicates the majority of the study area has a high probability of including archaeological or historic resources. Siting of the line away from roads, other power lines, or developed areas increases the potential for impacts. Areas where archaeological or historic resources are known or likely to be present, such as along known historical trails, should be avoided if possible. Even if a site can be spanned, increased activity in an area increases risk of damage to the resources present. Each 1,000-foot segment through areas with high potential for cultural resource will represent one unit of measure. Where the line passes within 0.5 mile of a known trail will be counted as a conflict. A weight of 4 has been assigned to this criterion.

E-6 Residences Affected by Prominent Visual Intrusion

Where the line passes within 1,000 feet of a residence, it was considered to be an adverse impact on the aesthetic setting, except in cases where an existing utility line is present. Each residence within 1,000 feet of the transmission line center line represents one unit of measure. A weight of 5 has been assigned to this criterion.

E-7 Line Visually Prominent within Scenic Viewshed

Portions of the study area includes scenic viewsheds where the new transmission line could noticeably change the aesthetics of the visual environment and quality of the wilderness experience. Scenic viewsheds include back country valleys and trails used by snowmobilers and hikers. On trails in forested areas the line will generally not be visible except where the right-of-way crosses the trail or where the line is situated high up adjacent slopes above the trail user's line of sight. The line of sight down the right-of-way can be broken by line angles as one mitigation measure. On trails in broad, open valleys, such as Boulder and Squaw Creeks, the line will probably be visible for the entire length of trail. Each 1,000-foot segment of the line in visually sensitive areas represents one unit of measure. A weight of 5 has been assigned to this criterion.

E-8 Line Visually Prominent from Highway or Major Arterial

Travelers along the Glenn Highway, Lake Louise Road, and local roads in Sutton, Chickaloon, and other communities will be able to see the line where it crosses the road, where it parallels the road at close distance, or from some high vantage points where it appears in the viewshed. Each major road crossing is counted as three units and each 1,000-foot segment where the line route is judged to be probably visible from the road is counted as one unit. Where an existing line is present, the degradation of the visual environment was judged to be relatively minor and each 1,000-foot segment is counted as 0.5 units in this case. A weight of 5 has been assigned to this criterion.

E-9 Special Mitigation Requirements

Stream crossings will require special consideration to preserve spawning habitat and avoid siltation due to erosion. Eagles, peregrine falcons, trumpeter swans, and other waterfowl species will require special consideration during construction and in design to mitigate electrocution and line-bird strikes. Each eagle nest within 0.5 mile of a route segment is counted as one unit of measure; each 1,000-foot segment of line in a known migratory flyway will count as three units; each stream crossing will count as one unit of measure. A weight of 4 has been assigned to this criterion.

No flyway paths were identified explicitly for this study and a raptor survey is required to identify existing raptor nests.

E-10 Exposure to Electromagnetic Fields (EMF)

Power lines produce electromagnetic fields which, as a result of increased media attention and ongoing research regarding possible health affects, need to be addressed due to the public perception of possible impacts. This criterion is based upon distance from the line since the strength of the fields drops off rapidly and significantly. Where the transmission line passes within 600 feet of a known occupied structure it was considered to be a perceived impact and represents one unit of measure. A weight of 5 has been assigned to this criterion.

LAND USE CONSIDERATIONS

L-1 Private Land Parcels Affected by Acquisition

The effort to acquire right-of-way and any impact on land ownership is directly related to the number of private land parcels affected and the extent of right-of-way on private land. Each private land parcel crossed by the proposed right-of-way will represent one unit of measure and each 1,000-foot segment of right-of-way in private lands will represent an additional unit of measure. A weight of 5 has been assigned to this criterion.

Late in the study period it became evident that some estimated 100-200 unpatented mining claims exist in the Boulder Creek, Caribou Creek, Chitna Pass and Alfred Creek areas. Each claim holder would have to be dealt with individually.

L-2 Native Lands Affected by Acquisition

Some line route segments will pass through lands belonging to regional (Cook Inlet, Ahtna) and village (Chickaloon Moose Creek, Tazlina) native corporations. The effort to acquire right-of-way easements and any impact on land-ownership is related to the number of native corporations affected and the extent of right-of-way on native lands. Each separate, non-contiguous parcel occupied by the right-of-way and belonging to native corporations or similar groups will count as one unit of measure and each 1,000-foot segment on native lands as an additional unit of measure. BLM lands which have been selected by native corporations are included in this category, although some selected lands are part of an overselection and may not, ultimately, be conveyed to the native corporations. A weight of 5 has been assigned to this criterion.

L-3 State Lands

Study route alternatives pass through significant blocks of State land (about 70% of total length) and up to 13 miles of Mental Health Trust Lands. Discussions with ADNR Division of Lands staff indicated that obtaining right-of-way agreements in the Mental Health Trust Lands should not be an obstacle to proceeding with the Intertie as long as standard permitting procedures are followed and an equitable use fee is negotiated reflecting fair market values of the land in question. For the purposes of evaluating this criterion, Mental Health Trust Lands can be considered State land. Some BLM lands have been selected by the State and native groups but conveyance is pending. Any proposed development on these parcels will require approval of BLM as well as the selecting party. Each 1,000 ft segment of State land crossed by the right-of-way will count as one unit of measure. Each 1,000 ft segment of land currently belonging to BLM but selected by the State will count as two units of measure. A weight of 1 has been assigned to this criterion.

L-4 Land Use Impacts

In some areas the construction of a transmission line would have impacts to the existing or future land use. An example of conflict would be construction of a transmission line in an area that does not currently have roads or existing utility lines. A line, its right-of-way and associated access roads may increase public access to lands off Glenn Highway. Hunting pressure and noise impacts could increase. These impacts would be significantly less in areas with extensive access in place. Mining activities could be prohibited or limited in the right-of-way. Each 1,000-foot segment of line length represents one unit of measure. Other specific conflicts relate to the siting of the line adjacent to relatively high public use areas such as parks and schools. Each instance of this type would represent three units of measure but no such instance occurs for any of the route alternatives. A weight of 5 has been assigned to this criterion.

L-5 New Right-of-Way Requirements

A transmission line occupies space and can limit use of land within its designated right-of-way. Routing of lines can minimize this land use conflict by paralleling existing defined roadways or utilizing public lands to the maximum extent possible. Also, single pole structures, as opposed to multi-pole structures, minimize the quantity of land utilized. Each acre of new right-of-way required represents one unit of measure. A weight of 3 has been assigned to this criterion.

L-6 Special Restoration Efforts

Some areas characterized by steep terrain, with easily eroded soils, require special measures to ensure a successful revegetation effort if disturbed. Each 1,000-foot segment of line length with a slope of 15° (27%) or greater, i.e. in which special restoration efforts may be required represents one unit of measure. A weight of 1 has been assigned to this criterion.

CONSTRUCTION/ENGINEERING CONSIDERATIONS

C-1 Difficult Access (Construction/Maintenance)

Vehicle access is typically required to build and maintain a transmission line. Access can be divided into (1) access to the right-of-way and (2) access along the right-of-way. Difficult or poor access requires special construction techniques, extended construction time and complicated future maintenance. Due to

the limited number of existing roads which intersect the right-of-way and the sensitive nature of the lands in the corridor, it is assumed that no new access roads will be pushed into the right-of-way. In Loading Zone 1 and portions of Loading Zone 3 it is assumed that a few access trails or roads could be upgraded. No new access roads in Loading Zone 4 were assumed.

Before the decision was made to abandon the notion of additional new access roads, we laid out a preliminary access road plan by which to evaluate this criterion. Each 1,000-foot length of estimated additional access road (not including access roads in the right-of-way) was counted as one unit of measure. East of Syncline Mountain no new access roads are assumed along with winter construction. This will, however, complicate maintenance during non-winter periods. A weight of 3 was applied to this criterion.

C-2 Remote Access

Some study route segments are too distant and remote to consider road construction as practical. These areas will rely almost exclusively on helicopter-assisted construction and maintenance. Each 1,000-foot segment of line length in Loading Zones 3 and 4 represents one unit of measure. A weight of 5 has been assigned to this criterion.

C-3 Travel Distance from Glenn Highway

The travel distance of a line segment from the Glenn Highway will affect costs to build and maintain the Intertie. Travel distances to the right-of-way were estimated and each 1,000-foot length of travel distance was counted as one unit of measure with a weight of 1.

C-4 Engineering Constraints (Terrain)

Line segments located in terrain with extreme change in elevation, along irregular alignments, in areas susceptible to avalanche damage, and across major streams or rivers will require special engineering considerations and structure types/design. Each 1,000-foot segment of line length represents one unit of measure; each occurrence of a known avalanche chute and major stream or river crossing will count as three units of measure. A weight of 3 has been assigned to this criterion.

C-5 Road/Utility Crossings

The crossing of a major arterial or electric transmission line often complicates design, permitting, construction, and maintenance of the line since this may involve non-standard structures, greater electrical clearances, and special construction methods. Each crossing represents one unit of measure. A weight of 2 has been assigned to this criterion.

C-6 Line Angles (PIs)

Angles structures will be guyed, resulting in greater construction and maintenance costs. Special features in the terrain, such as extreme elevation changes, may also result in a need to dead-end or add guys. Each of these conditions adds to the complexity of design, construction, and maintenance. Each structure represents one unit of measure. A weight of 2 has been assigned to this criterion.

C-7 Line Reliability

Line segments at high elevations and subject to microclimates of unknown severity must carry a higher risk of failure and outages than line segments whose loading conditions are better known. Areas of

permafrost may subject structures to jacking forces which would not, however, be expected to cause an unscheduled outage. Each 1,000-foot segment above El 2000 and below El 3000 is counted as one unit of measure; above El 3000 is counted as three units of measure. A weight of 4 has been assigned to this criterion.

C-8 Service to Future MEA Substation

MEA has considered plans to install a distribution substation in the vicinity of mile 100 on Glenn Highway. Routes that pass far to the north (e.g., Segment S 4-7, etc.) make feeding a future substation difficult. This impact is not considered. A weight of 0 has been assigned to this criterion.

FINANCIAL CONSIDERATIONS

F-1 Construction Cost - Loading Zone 1

This accounts directly for the cost to develop and construct the Intertie in Loading Zone 1, assumed at \$300,000 per mile. A weight of 0.2 was used to obtain results on the same order of magnitude as other categories.

F-2 Construction Cost - Loading Zone 2

This accounts directly for the cost to develop and construct the Intertie in Loading Zone 2, assumed at \$300,000 per mile. A weight of 0.2 was used to obtain results on the same order of magnitude as other categories.

F-3 Construction Cost - Loading Zone 3

This accounts directly for the cost to develop and construct the Intertie in Loading Zone 3, assumed at \$375,000 per mile. A weight of 0.2 was used to obtain results on the same order of magnitude as other categories.

F-4 Construction Cost - Loading Zone 4

This accounts directly for the cost to develop and construct the Intertie in Loading Zone 4, assumed at \$425,000 per mile. A weight of 0.2 was used to obtain results on the same order of magnitude as other categories.

**ALASKA ENERGY AUTHORITY
COPPER VALLEY INTERTIE FEASIBILITY STUDY**

TABLE S-1

ROUTING EVALUATION SCORES AND RANKING

| ROUTE ALTERNATIVE | ENVIRONMENTAL | | LAND USE | | CONSTRUCTION | | FINANCIAL | |
|----------------------|---------------|----------|-----------|----------|--------------|----------|-----------|----------|
| | Weight= 2 | | Weight= 2 | | Weight= 2 | | Weight= 2 | |
| | SCORE | WT INDEX | SCORE | WT INDEX | SCORE | WT INDEX | SCORE | WT INDEX |
| A | 6241 | 2.14 | 7388 | 2.00 | 6809 | 2.51 | 8866 | 2.070 |
| B | 7106 | 2.43 | 7471 | 2.02 | 5417 | 2.00 | 8565 | 2.000 |
| C | 7451 | 2.55 | 7607 | 2.06 | 5939 | 2.19 | 8832 | 2.062 |
| D | 5838 | 2.00 | 7402 | 2.00 | 6398 | 2.36 | 8669 | 2.024 |

| SCORE TOTAL | | |
|-------------|-------|------|
| ROUTE | SCORE | RANK |
| A | 29304 | 3 |
| B | 28559 | 2 |
| C | 29829 | 4 |
| D | 28307 | 1 |

| INDEX TOTAL | | |
|-------------|-------|------|
| ROUTE | INDEX | RANK |
| A | 8.72 | 3 |
| B | 8.46 | 2 |
| C | 8.87 | 4 |
| D | 8.39 | 1 |

**ALASKA ENERGY AUTHORITY
COPPER VALLEY INTERTIE FEASIBILITY STUDY**

TABLE S-2

ROUTING EVALUATION SCORES AND RANKING

| ROUTE ALTERNATIVE | ENVIRONMENTAL | | LAND USE | | CONSTRUCTION | | FINANCIAL | |
|----------------------|---------------|----------|------------|----------|--------------|----------|------------|----------|
| | Weight = 2 | | Weight = 2 | | Weight = 2 | | Weight = 5 | |
| | SCORE | WT INDEX | SCORE | WT INDEX | SCORE | WT INDEX | SCORE | WT INDEX |
| A | 6241 | 2.14 | 7388 | 2.00 | 6809 | 2.51 | 8866 | 5.176 |
| B | 7106 | 2.43 | 7471 | 2.02 | 5417 | 2.00 | 8565 | 5.000 |
| C | 7451 | 2.55 | 7607 | 2.06 | 5939 | 2.19 | 8832 | 5.156 |
| D | 5838 | 2.00 | 7402 | 2.00 | 6398 | 2.36 | 8669 | 5.061 |

| SCORE TOTAL | | |
|-------------|-------|------|
| ROUTE | SCORE | RANK |
| A | 29304 | 3 |
| B | 28559 | 2 |
| C | 29829 | 4 |
| D | 28307 | 1 |

| INDEX TOTAL | | |
|-------------|-------|------|
| ROUTE | INDEX | RANK |
| A | 11.83 | 3 |
| B | 11.46 | 2 |
| C | 11.96 | 4 |
| D | 11.43 | 1 |

**ALASKA ENERGY AUTHORITY
COPPER VALLEY INTERTIE FEASIBILITY STUDY**

TABLE S-3

ROUTING EVALUATION SCORES AND RANKING

| ROUTE ALTERNATIVE | ENVIRONMENTAL | | LAND USE | | CONSTRUCTION | | FINANCIAL | |
|----------------------|---------------|----------|------------|----------|--------------|----------|------------|----------|
| | Weight = 2 | | Weight = 2 | | Weight = 5 | | Weight = 2 | |
| | SCORE | WT INDEX | SCORE | WT INDEX | SCORE | WT INDEX | SCORE | WT INDEX |
| A | 6241 | 2.14 | 7388 | 2.00 | 6809 | 6.28 | 8866 | 2.070 |
| B | 7106 | 2.43 | 7471 | 2.02 | 5417 | 5.00 | 8565 | 2.000 |
| C | 7451 | 2.55 | 7607 | 2.06 | 5939 | 5.48 | 8832 | 2.062 |
| D | 5838 | 2.00 | 7402 | 2.00 | 6398 | 5.90 | 8669 | 2.024 |

| SCORE TOTAL | | |
|-------------|-------|------|
| ROUTE | SCORE | RANK |
| A | 29304 | 3 |
| B | 28559 | 2 |
| C | 29829 | 4 |
| D | 28307 | 1 |

| INDEX TOTAL | | |
|-------------|-------|------|
| ROUTE | INDEX | RANK |
| A | 12.49 | 4 |
| B | 11.46 | 1 |
| C | 12.16 | 3 |
| D | 11.93 | 2 |

**ALASKA ENERGY AUTHORITY
COPPER VALLEY INTERTIE FEASIBILITY STUDY**

TABLE S-4

ROUTING EVALUATION SCORES AND RANKING

| ROUTE ALTERNATIVE | ENVIRONMENTAL | | LAND USE | | CONSTRUCTION | | FINANCIAL | |
|----------------------|---------------|----------|------------|----------|--------------|----------|------------|----------|
| | Weight = 2 | | Weight = 5 | | Weight = 2 | | Weight = 2 | |
| | SCORE | WT INDEX | SCORE | WT INDEX | SCORE | WT INDEX | SCORE | WT INDEX |
| A | 6241 | 2.14 | 7388 | 5.00 | 6809 | 2.51 | 8866 | 2.070 |
| B | 7106 | 2.43 | 7471 | 5.06 | 5417 | 2.00 | 8565 | 2.000 |
| C | 7451 | 2.55 | 7607 | 5.15 | 5939 | 2.19 | 8832 | 2.062 |
| D | 5838 | 2.00 | 7402 | 5.01 | 6398 | 2.36 | 8669 | 2.024 |

| SCORE TOTAL | | |
|-------------|-------|------|
| ROUTE | SCORE | RANK |
| A | 29304 | 3 |
| B | 28559 | 2 |
| C | 29829 | 4 |
| D | 28307 | 1 |

| INDEX TOTAL | | |
|-------------|-------|------|
| ROUTE | INDEX | RANK |
| A | 11.72 | 3 |
| B | 11.49 | 2 |
| C | 11.96 | 4 |
| D | 11.40 | 1 |

**ALASKA ENERGY AUTHORITY
COPPER VALLEY INTERTIE FEASIBILITY STUDY**

TABLE S-5

ROUTING EVALUATION SCORES AND RANKING

| ROUTE ALTERNATIVE | ENVIRONMENTAL | | LAND USE | | CONSTRUCTION | | FINANCIAL | |
|----------------------|---------------|----------|------------|----------|--------------|----------|------------|----------|
| | Weight = 5 | | Weight = 2 | | Weight = 2 | | Weight = 2 | |
| | SCORE | WT INDEX | SCORE | WT INDEX | SCORE | WT INDEX | SCORE | WT INDEX |
| A | 6241 | 5.34 | 7388 | 2.00 | 6809 | 2.51 | 8866 | 2.070 |
| B | 7106 | 6.09 | 7471 | 2.02 | 5417 | 2.00 | 8565 | 2.000 |
| C | 7451 | 6.38 | 7607 | 2.06 | 5939 | 2.19 | 8832 | 2.062 |
| D | 5838 | 5.00 | 7402 | 2.00 | 6398 | 2.36 | 8669 | 2.024 |

| SCORE TOTAL | | |
|-------------|-------|------|
| ROUTE | SCORE | RANK |
| A | 29304 | 3 |
| B | 28559 | 2 |
| C | 29829 | 4 |
| D | 28307 | 1 |

| INDEX TOTAL | | |
|-------------|-------|------|
| ROUTE | INDEX | RANK |
| A | 11.93 | 2 |
| B | 12.11 | 3 |
| C | 12.70 | 4 |
| D | 11.39 | 1 |

**ALASKA ENERGY AUTHORITY
COPPER VALLEY INTERTIE FEASIBILITY STUDY**

ROUTE ALTERNATIVE A EVALUATION MATRIX

TABLE A-1

ENVIRONMENTAL CONSIDERATIONS

| EVALUATION CRITERIA: | | E-1 | | E-2 | | E-3 | | E-4 | | E-5 | | E-6 | | E-7 | | E-8 | | E-9 | | E-10 | | SUB -TOTAL |
|----------------------|---------|-------|------|-------|------|-------|-------|-------|-------|-------|-------|------|------|-------|------|------------|------|------------|------|------|------|---------------|
| WEIGHT: | | 1 | | 3 | | 5 | | 5 | | 4 | | 5 | | 5 | | 5 | | 4 | | 5 | | |
| UNIT: | | 1000' | | 1000' | | 1000' | | 1000' | | 1000' | | Each | | 1000' | | Each/1000' | | Each/1000' | | Each | | |
| SEGMENT | LENGTH | Qty | Subt | Qty | Subt | Qty | Subt | Qty | Subt | Qty | Subt | Qty | Subt | Qty | Subt | Qty | Subt | Qty | Subt | Qty | Subt | |
| 1-2 | 29356.8 | 2 | 2.0 | 0 | 0.0 | 5 | 25.0 | 23 | 116.5 | 4 | 14.8 | 8 | 40.0 | 0 | 0 | 17 | 83.5 | 2 | 8.0 | 8 | 40 | 329.8 |
| 2-3 | 59980.8 | 1 | 1.0 | 0 | 0.0 | 4 | 18.5 | 40 | 197.5 | 5 | 21.2 | 0 | 0.0 | 23 | 114 | 0 | 0.0 | 6 | 24.0 | 0 | 0 | 375.7 |
| 3-4 | 35270.4 | 0 | 0.0 | 0 | 0.0 | 8 | 39.5 | 28 | 139.5 | 21 | 84.4 | 0 | 0.0 | 24 | 119 | 0 | 0.0 | 5 | 20.0 | 0 | 0 | 402.4 |
| 4-7 | 71438.4 | 0 | 0.0 | 0 | 0.0 | 29 | 145.0 | 31 | 155.5 | 71 | 285.6 | 0 | 0.0 | 71 | 357 | 0 | 0.0 | 10 | 40.0 | 0 | 0 | 983.1 |
| 7-8 | 66105.6 | 0 | 0.0 | 0 | 0.0 | 10 | 47.5 | 2 | 10.0 | 66 | 264.4 | 0 | 0.0 | 66 | 331 | 0 | 0.0 | 4 | 16.0 | 0 | 0 | 668.4 |
| 8-10 | 7603.2 | 0 | 0.0 | 0 | 0.0 | 5 | 25.0 | 0 | 1.0 | 8 | 30.4 | 0 | 0.0 | 8 | 38 | 0 | 0.0 | 3 | 12.0 | 0 | 0 | 106.4 |
| 10-15 | 66580.8 | 0 | 0.0 | 0 | 0.0 | 1 | 5.0 | 2 | 10.0 | 59 | 235.6 | 0 | 0.0 | 67 | 333 | 0 | 0.0 | 12 | 48.0 | 0 | 0 | 631.6 |
| 15-17 | 33052.8 | 0 | 0.0 | 0 | 0.0 | 2 | 7.5 | 0 | 0.0 | 33 | 132.4 | 0 | 0.0 | 33 | 166 | 0 | 0.0 | 6 | 24.0 | 0 | 0 | 329.4 |
| 17-19 | 47836.8 | 0 | 0.0 | 0 | 0.0 | 21 | 105.0 | 0 | 0.0 | 11 | 42.4 | 0 | 0.0 | 4 | 21 | 0 | 0.0 | 3 | 12.0 | 0 | 0 | 180.4 |
| 19-20 | 64046.4 | 0 | 0.0 | 0 | 0.0 | 26 | 129.5 | 32 | 160.0 | 0 | 0.0 | 0 | 0.0 | 0 | 0 | 0 | 0.0 | 3 | 12.0 | 0 | 0 | 301.5 |
| 20-22 | 26347.2 | 0 | 0.0 | 0 | 0.0 | 12 | 60.5 | 16 | 77.5 | 5 | 21.2 | 0 | 0.0 | 11 | 56 | 0 | 0.0 | 1 | 4.0 | 0 | 0 | 218.7 |
| 22-26 | 71596.8 | 1 | 1.0 | 0 | 0.0 | 24 | 119.0 | 63 | 315.0 | 0 | 0.0 | 0 | 0.0 | 0 | 0 | 11 | 54.5 | 8 | 32.0 | 0 | 0 | 521.5 |
| 26-27 | 42081.6 | 0 | 0.0 | 0 | 0.0 | 15 | 76.5 | 34 | 168.5 | 0 | 0.0 | 0 | 0.0 | 0 | 0 | 0 | 0.0 | 6 | 24.0 | 0 | 0 | 269.0 |
| 27-28 | 34003.2 | 0 | 0.0 | 0 | 0.0 | 24 | 117.5 | 27 | 136.0 | 0 | 0.0 | 0 | 0.0 | 0 | 0 | 0 | 0.0 | 0 | 0.0 | 0 | 0 | 253.5 |
| 28-29 | 13728.0 | 1 | 1.0 | 0 | 0.0 | 7 | 33.0 | 13 | 62.5 | 0 | 0.0 | 0 | 0.0 | 3 | 16 | 11 | 54.5 | 0 | 0.0 | 0 | 0 | 167.0 |
| 29-30 | 40656.0 | 0 | 0.0 | 0 | 0.0 | 9 | 42.5 | 24 | 119.0 | 37 | 148.0 | 0 | 0.0 | 37 | 185 | 0 | 0.0 | 2 | 8.0 | 0 | 0 | 502.5 |
| Total (ft) | 709,685 | 5.0 | 5 | 0.0 | 0 | 199.3 | 997 | 333.7 | 1669 | 320.1 | 1280 | 8.0 | 40 | 346.8 | 1734 | 38.5 | 193 | 71.0 | 284 | 8.0 | 40 | |
| Total (mi) | 134.41 | | | | | | | | | | | | | | | | | | | | | |

ENVIRONMENTAL TOTAL: 6240.9

| ENVIRONMENTAL CONSIDERATIONS | | | |
|------------------------------|---|------|--|
| E-1 | Potential Construction Impacts (Dust, Traffic, Noise) | E-6 | Residences Affected by Prominent Visual Intrusion |
| E-2 | Potential Habitat Damage or Need for Restoration | E-7 | Line Visually Prominent within Scenic Viewshed |
| E-3 | Clearing Riparian/Wetland Areas | E-8 | Line Visually Prominent from Highway or Major Arterial |
| E-4 | Clearing in Treed Lands | E-9 | Special Mitigation Requirements |
| E-5 | Cultural Resource Conflict Areas | E-10 | Exposure to Electromagnetic Fields (EMF) |

ALASKA ENERGY AUTHORITY
COPPER VALLEY INTERTIE FEASIBILITY STUDY

ROUTE ALTERNATIVE A EVALUATION MATRIX

TABLE A-2

LAND USE CONSIDERATIONS

| EVALUATION CRITERIA: | | L-1 | | L-2 | | L-3 | | L-4 | | L-5 | | L-6 | | LAND USE SUBTOTAL |
|----------------------|---------|------------|------|------------|------|-------|------|------------|------|--------|-------|---------|------|-------------------------|
| WEIGHT: | | 5 | | 5 | | 3 | | 5 | | 3 | | 1 | | |
| UNIT: | | Each/1000' | | Each/1000' | | Each | | Each/1000' | | Acres | | 1000 ft | | |
| SEGMENT | LENGTH | QTY | SUBT | QTY | SUBT | QTY | SUBT | QTY | SUBT | QTY | SUBT | QTY | SUBT | |
| 1-2 | 29356.8 | 0 | 0 | 2 | 7.5 | 3 | 9.9 | 11 | 52.8 | 84 | 252.7 | 0 | 0.0 | 322.9 |
| 2-3 | 59980.8 | 0 | 0 | 0 | 0.0 | 11 | 34.2 | 12 | 61.8 | 172 | 516.4 | 11 | 10.5 | 622.9 |
| 3-4 | 35270.4 | 0 | 0 | 0 | 0.0 | 7 | 20.1 | 12 | 58.4 | 101 | 303.6 | 5 | 4.8 | 386.9 |
| 4-7 | 71438.4 | 0 | 0 | 0 | 0.0 | 11 | 32.4 | 15 | 72.7 | 205 | 615.0 | 5 | 5.2 | 725.3 |
| 7-8 | 66105.6 | 0 | 0 | 0 | 0.0 | 13 | 37.5 | 14 | 67.6 | 190 | 569.1 | 3 | 2.6 | 676.8 |
| 8-10 | 7603.2 | 0 | 0 | 0 | 0.0 | 1 | 4.2 | 2 | 12.2 | 22 | 65.5 | 0 | 0.0 | 81.9 |
| 10-15 | 66580.8 | 0 | 0 | 0 | 0.0 | 20 | 61.2 | 14 | 68.1 | 191 | 573.2 | 2 | 1.6 | 704.0 |
| 15-17 | 33052.8 | 0 | 0 | 0 | 0.0 | 12 | 35.7 | 7 | 36.3 | 95 | 284.5 | 0 | 0.0 | 356.5 |
| 17-19 | 47836.8 | 0 | 0 | 0 | 0.0 | 9 | 27.3 | 10 | 50.3 | 137 | 411.8 | 1 | 1.3 | 490.7 |
| 19-20 | 64046.4 | 0 | 0 | 0 | 0.0 | 12 | 36.3 | 13 | 65.7 | 184 | 551.4 | 0 | 0.0 | 653.3 |
| 20-22 | 26347.2 | 0 | 0 | 0 | 0.0 | 5 | 15.0 | 6 | 30.0 | 76 | 226.8 | 0 | 0.0 | 271.8 |
| 22-26 | 71596.8 | 0 | 0 | 0 | 0.0 | 14 | 40.8 | 15 | 72.8 | 205 | 616.4 | 0 | 0.0 | 730.0 |
| 26-27 | 42081.6 | 0 | 0 | 0 | 0.0 | 8 | 24.0 | 9 | 44.9 | 121 | 362.3 | 0 | 0.0 | 431.1 |
| 27-28 | 34003.2 | 0 | 0 | 6 | 30.0 | 1 | 4.2 | 7 | 37.2 | 98 | 292.7 | 0 | 0.0 | 364.1 |
| 28-29 | 13728.0 | 0 | 0 | 4 | 18.0 | 0 | 0.0 | 4 | 18.0 | 39 | 118.2 | 0 | 0.0 | 154.2 |
| 29-30 | 40656.0 | 0 | 0 | 8 | 41.5 | 0 | 0.0 | 8 | 41.6 | 111 | 332.7 | 0 | 0.0 | 415.8 |
| Total (ft) | 709,685 | 0 | 0 | 19.4 | 97 | 127.6 | 383 | 158.0 | 790 | 2030.8 | 6092 | 26.0 | 26 | |
| Total (miles) | 134.41 | | | | | | | | | | | | | |

LAND USE TOTAL: 7388.2

| LAND USE CONSIDERATIONS | |
|-------------------------|---|
| L-1 | Private Land Parcels Affected by Aquisition |
| L-2 | Native Lands Affected by Aquisition |
| L-3 | State Lands |
| L-4 | Land Use Impacts |
| L-5 | New Right-of-Way Requirements |
| L-6 | Special Restoration Efforts |

**ALASKA ENERGY AUTHORITY
COPPER VALLEY INTERTIE FEASIBILITY STUDY**

ROUTE ALTERNATIVE A EVALUATION MATRIX

TABLE A-3

CONSTRUCTION/ENGINEERING CONSIDERATIONS

| EVALUATION CRITERIA: | | C-1 | | C-2 | | C-3 | | C-4 | | C-5 | | C-6 | | C-7 | | C-8 | | SUB -TOTAL |
|----------------------|---------|---------|------|---------|-------|---------|-------|---------|------|------|------|------|------|---------|------|------|------|---------------|
| WEIGHT: | | 4 | | 5 | | 2 | | 3 | | 2 | | 2 | | 4 | | 0 | | |
| UNIT: | | 1000 ft | | 1000 ft | | 1000 ft | | 1000 ft | | Each | | Each | | 1000 ft | | Each | | |
| SEGMENT | LENGTH | Qty | Subt | Qty | Subt | Qty | Subt | Qty | Subt | Qty | Subt | Qty | Subt | Qty | Subt | Qty | Subt | |
| 1-2 | 29356.8 | 8 | 31.2 | 0 | 0.0 | 8 | 15.8 | 9 | 26 | 1 | 2 | 6 | 12 | 1 | 4 | 0 | 0 | 90.6 |
| 2-3 | 59980.8 | 18 | 72.4 | 0 | 0.0 | 24 | 47.5 | 11 | 34 | 0 | 0 | 3 | 6 | 35 | 141 | 0 | 0 | 301.1 |
| 3-4 | 35270.4 | 11 | 44.7 | 0 | 0.0 | 24 | 47.5 | 6 | 18 | 0 | 0 | 3 | 6 | 18 | 72 | 0 | 0 | 187.8 |
| 4-7 | 71438.4 | 0 | 0.0 | 71 | 357.2 | 26 | 52.8 | 25 | 74 | 0 | 0 | 12 | 24 | 104 | 416 | 0 | 0 | 924.0 |
| 7-8 | 66105.6 | 0 | 0.0 | 66 | 330.5 | 79 | 158.4 | 44 | 133 | 0 | 0 | 9 | 18 | 159 | 636 | 0 | 0 | 1275.1 |
| 8-10 | 7603.2 | 0 | 0.0 | 8 | 38.0 | 79 | 158.4 | 0 | 0 | 0 | 0 | 1 | 2 | 7 | 30 | 0 | 0 | 228.0 |
| 10-15 | 66580.8 | 0 | 0.0 | 67 | 332.9 | 69 | 137.3 | 32 | 95 | 0 | 0 | 8 | 16 | 143 | 570 | 0 | 0 | 1151.7 |
| 15-17 | 33052.8 | 0 | 0.0 | 0 | 0.0 | 32 | 63.4 | 3 | 9 | 0 | 0 | 4 | 8 | 99 | 397 | 0 | 0 | 477.6 |
| 17-19 | 47836.8 | 0 | 0.0 | 0 | 0.0 | 32 | 63.4 | 27 | 81 | 0 | 0 | 3 | 6 | 107 | 428 | 0 | 0 | 578.8 |
| 19-20 | 64046.4 | 0 | 0.0 | 0 | 0.0 | 18 | 37.0 | 0 | 0 | 0 | 0 | 2 | 4 | 106 | 424 | 0 | 0 | 465.4 |
| 20-22 | 26347.2 | 0 | 0.0 | 0 | 0.0 | 11 | 21.1 | 0 | 0 | 0 | 0 | 3 | 6 | 26 | 106 | 0 | 0 | 132.7 |
| 22-26 | 71596.8 | 0 | 0.0 | 0 | 0.0 | 16 | 31.7 | 60 | 179 | 2 | 4 | 3 | 6 | 117 | 468 | 0 | 0 | 688.8 |
| 26-27 | 42081.6 | 0 | 0.0 | 0 | 0.0 | 21 | 42.2 | 3 | 9 | 0 | 0 | 3 | 6 | 40 | 158 | 0 | 0 | 215.6 |
| 27-28 | 34003.2 | 0 | 0.0 | 0 | 0.0 | 0 | 0.0 | 0 | 0 | 0 | 0 | 1 | 2 | 14 | 57 | 0 | 0 | 59.2 |
| 28-29 | 13728.0 | 0 | 0.0 | 0 | 0.0 | 0 | 0.0 | 0 | 0 | 1 | 2 | 1 | 2 | 0 | 0 | 0 | 0 | 4.0 |
| 29-30 | 40656.0 | 0 | 0.0 | 0 | 0.0 | 7 | 13.2 | 3 | 9 | 0 | 0 | 3 | 6 | 0 | 0 | 0 | 0 | 28.2 |
| Total (ft) | 709,685 | 37.1 | 148 | 211.7 | 1059 | 444.8 | 890 | 222 | 667 | 4 | 8 | 65 | 130 | 977 | 3907 | 0 | 0 | |
| Total (miles) | 134.41 | | | | | | | | | | | | | | | | | |

CONSTRUCTION/ENGINEERING TOTAL: 6808.5

| CONSTRUCTION/ENGINEERING CONSIDERATIONS | | | |
|---|---|--|---|
| C-1 | Difficult Access (Construction/Maintenance) | | C-5 Road/Utility Crossings |
| C-2 | Remote Access | | C-6 Line Angles over 30 Degrees or Complex Structures |
| C-3 | Joint Construction with Other Utilities | | C-7 Line Reliability |
| C-4 | Engineering Constraints | | C-8 Service to Future MEA Substations |

ALASKA ENERGY AUTHORITY
COPPER VALLEY INTERTIE FEASIBILITY STUDY

ROUTE ALTERNATIVE A EVALUATION MATRIX

TABLE A-4

FINANCIAL CONSIDERATIONS

| EVALUATION CRITERIA: | | F-1 | | F-2 | | F-3 | | F-4 | | FINANCIAL SUBTOTAL |
|----------------------|---------|----------|--------|----------|--------|----------|--------|----------|-------|-----------------------|
| WEIGHT: | | 0.2 | | 0.2 | | 0.2 | | 0.2 | | |
| UNIT: | | 300 k/mi | | 300 k/mi | | 375 k/mi | | 430 k/mi | | |
| SEGMENT | LENGTH | QTY | SUBT | QTY | SUBT | QTY | SUBT | QTY | SUBT | |
| 1-2 | 29356.8 | 5.6 | 333.6 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 333.6 |
| 10-15 | 66580.8 | 0.0 | 0.0 | 0.0 | 0.0 | 12.6 | 945.8 | 0.0 | 0.0 | 945.8 |
| 15-17 | 33052.8 | 0.0 | 0.0 | 0.0 | 0.0 | 6.3 | 469.5 | 0.0 | 0.0 | 469.5 |
| 17-17A | 16896.0 | 0.0 | 0.0 | 0.0 | 0.0 | 3.2 | 240.0 | 0.0 | 0.0 | 240.0 |
| 17A-19 | 30940.8 | 0.0 | 0.0 | 5.9 | 351.6 | 0.0 | 0.0 | 0.0 | 0.0 | 351.6 |
| 19-20 | 64046.4 | 0.0 | 0.0 | 12.1 | 727.8 | 0.0 | 0.0 | 0.0 | 0.0 | 727.8 |
| 2-3 | 59980.8 | 11.4 | 681.6 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 681.6 |
| 20-22 | 26347.2 | 0.0 | 0.0 | 5.0 | 299.4 | 0.0 | 0.0 | 0.0 | 0.0 | 299.4 |
| 22-26 | 71596.8 | 0.0 | 0.0 | 13.6 | 813.6 | 0.0 | 0.0 | 0.0 | 0.0 | 813.6 |
| 26-27 | 42081.6 | 0.0 | 0.0 | 8.0 | 478.2 | 0.0 | 0.0 | 0.0 | 0.0 | 478.2 |
| 27-28 | 34003.2 | 0.0 | 0.0 | 6.4 | 386.4 | 0.0 | 0.0 | 0.0 | 0.0 | 386.4 |
| 28-29 | 13728.0 | 0.0 | 0.0 | 2.6 | 156.0 | 0.0 | 0.0 | 0.0 | 0.0 | 156.0 |
| 29-30 | 40656.0 | 0.0 | 0.0 | 7.7 | 462.0 | 0.0 | 0.0 | 0.0 | 0.0 | 462.0 |
| 3-4 | 35270.4 | 6.7 | 400.8 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 400.8 |
| 4-4A | 15417.6 | 2.9 | 175.2 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 175.2 |
| 4A-7 | 56020.8 | 0.0 | 0.0 | 0.0 | 0.0 | 10.6 | 795.8 | 0.0 | 0.0 | 795.8 |
| 7-7A | 48945.6 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 9.3 | 797.2 | 797.2 |
| 7A-8 | 17160.0 | 0.0 | 0.0 | 0.0 | 0.0 | 3.3 | 243.8 | 0.0 | 0.0 | 243.8 |
| 8-10 | 7603.2 | 0.0 | 0.0 | 0.0 | 0.0 | 1.4 | 108.0 | 0.0 | 0.0 | 108.0 |
| Total (ft) | 709,685 | 26.5 | 1591.2 | 61.3 | 3675.0 | 37.4 | 2802.8 | 9.3 | 797.2 | |
| Total (miles) | 134.41 | | | | | | | | | |

FINANCIAL TOTAL: 8866.2

| FINANCIAL CONSIDERATIONS | |
|--------------------------|------------------------------------|
| F-1 | Construction Cost - Loading Zone 1 |
| F-2 | Construction Cost - Loading Zone 2 |
| F-3 | Construction Cost - Loading Zone 3 |
| F-4 | Construction Cost - Loading Zone 4 |

**ALASKA ENERGY AUTHORITY
COPPER VALLEY INTERTIE FEASIBILITY STUDY**

ROUTE ALTERNATIVE B EVALUATION MATRIX

TABLE B-1

ENVIRONMENTAL CONSIDERATIONS

| EVALUATION CRITERIA: | | E-1 | | E-2 | | E-3 | | E-4 | | E-5 | | E-6 | | E-7 | | E-8 | | E-9 | | E-10 | | SUB -TOTAL | |
|----------------------|---------|-------|------|-------|------|-------|-------|-------|-------|-------|-------|------|------|-------|------|------------|-------|------------|------|------|------|---------------|--|
| WEIGHT: | | 1 | | 3 | | 5 | | 5 | | 4 | | 5 | | 5 | | 5 | | 4 | | 5 | | | |
| UNIT: | | 1000' | | 1000' | | 1000' | | 1000' | | 1000' | | Each | | 1000' | | Each/1000' | | Each/1000' | | Each | | | |
| SEGMENT | LENGTH | Qty | Subt | Qty | Subt | Qty | Subt | Qty | Subt | Qty | Subt | Qty | Subt | Qty | Subt | Qty | Subt | Qty | Subt | Qty | Subt | | |
| 1-2 | 29356.8 | 2 | 2.0 | 0 | 0.0 | 5 | 25.0 | 23 | 116.5 | 4 | 14.8 | 8 | 40.0 | 0 | 0 | 17 | 83.5 | 2 | 8.0 | 8 | 40 | 329.8 | |
| 2-31 | 34742.4 | 0 | 0.0 | 0 | 0.0 | 11 | 52.5 | 30 | 152.0 | 15 | 61.2 | 0 | 0.0 | 23 | 116 | 0 | 0.0 | 4 | 16.0 | 0 | 0 | 397.7 | |
| 3-4 | 35270.4 | 0 | 0.0 | 0 | 0.0 | 8 | 39.5 | 28 | 139.5 | 21 | 84.4 | 0 | 0.0 | 24 | 119 | 0 | 0.0 | 5 | 20.0 | 0 | 0 | 402.4 | |
| 4-5 | 43084.8 | 0 | 0.0 | 0 | 0.0 | 3 | 16.0 | 19 | 94.5 | 38 | 152.4 | 0 | 0.0 | 38 | 191 | 7 | 35.5 | 5 | 20.0 | 0 | 0 | 508.9 | |
| 5-6 | 49209.6 | 0 | 0.0 | 0 | 0.0 | 7 | 37.0 | 11 | 55.0 | 7 | 27.6 | 0 | 0.0 | 12 | 58 | 11 | 53.0 | 9 | 36.0 | 0 | 0 | 266.6 | |
| 6-9 | 24868.8 | 0 | 0.0 | 0 | 0.0 | 8 | 42.0 | 13 | 66.0 | 22 | 88.8 | 0 | 0.0 | 17 | 85 | 0 | 0.0 | 3 | 12.0 | 0 | 0 | 293.3 | |
| 9-11 | 38913.6 | 0 | 0.0 | 0 | 0.0 | 8 | 40.0 | 10 | 50.5 | 8 | 31.6 | 0 | 0.0 | 4 | 20 | 0 | 0.0 | 6 | 24.0 | 0 | 0 | 166.1 | |
| 11-12 | 25027.2 | 0 | 0.0 | 0 | 0.0 | 1 | 5.0 | 9 | 42.5 | 25 | 100.0 | 0 | 0.0 | 25 | 125 | 0 | 0.0 | 7 | 28.0 | 0 | 0 | 300.5 | |
| 12-13 | 16579.2 | 0 | 0.0 | 0 | 0.0 | 1 | 5.0 | 9 | 42.5 | 11 | 44.4 | 0 | 0.0 | 11 | 56 | 8 | 40.5 | 4 | 16.0 | 0 | 0 | 203.9 | |
| 13-14 | 17424.0 | 0 | 0.0 | 0 | 0.0 | 2 | 10.0 | 1 | 2.5 | 12 | 46.4 | 0 | 0.0 | 17 | 87 | 15 | 74.0 | 2 | 8.0 | 0 | 0 | 227.9 | |
| 14-16 | 32736.0 | 0 | 0.0 | 0 | 0.0 | 2 | 10.0 | 2 | 10.0 | 3 | 10.4 | 0 | 0.0 | 13 | 64 | 33 | 163.5 | 6 | 24.0 | 0 | 0 | 281.4 | |
| 16-18 | 31099.2 | 0 | 0.0 | 0 | 0.0 | 10 | 50.0 | 2 | 9.5 | 11 | 42.4 | 0 | 0.0 | 17 | 87 | 17 | 87.0 | 3 | 12.0 | 0 | 0 | 287.9 | |
| 18-21 | 72600.0 | 0 | 0.0 | 0 | 0.0 | 22 | 111.0 | 36 | 181.5 | 0 | 0.0 | 0 | 0.0 | 0 | 0 | 12 | 58.0 | 6 | 24.0 | 0 | 0 | 374.5 | |
| 21-23 | 27403.2 | 0 | 0.0 | 0 | 0.0 | 15 | 74.0 | 18 | 90.5 | 11 | 42.4 | 0 | 0.0 | 13 | 64 | 27 | 137.0 | 1 | 4.0 | 0 | 0 | 411.4 | |
| 23-24 | 31785.6 | 1 | 1.0 | 0 | 0.0 | 10 | 47.5 | 29 | 143.0 | 0 | 0.0 | 0 | 0.0 | 27 | 135 | 35 | 174.0 | 1 | 4.0 | 0 | 0 | 504.0 | |
| 24-25 | 25766.4 | 0 | 0.0 | 0 | 0.0 | 8 | 39.5 | 10 | 48.5 | 0 | 0.0 | 0 | 0.0 | 0 | 0 | 19 | 92.5 | 1 | 4.0 | 0 | 0 | 184.5 | |
| 25-26 | 11985.6 | 0 | 0.0 | 0 | 0.0 | 8 | 39.5 | 10 | 48.0 | 0 | 0.0 | 0 | 0.0 | 0 | 0 | 12 | 60.0 | 2 | 8.0 | 0 | 0 | 155.5 | |
| 26-27 | 42081.6 | 0 | 0.0 | 0 | 0.0 | 15 | 76.5 | 34 | 168.5 | 0 | 0.0 | 0 | 0.0 | 0 | 0 | 0 | 0.0 | 6 | 24.0 | 0 | 0 | 269.0 | |
| 27-29 | 47784.0 | 1 | 1.0 | 0 | 0.0 | 40 | 198.0 | 38 | 191.0 | 31 | 122.4 | 0 | 0.0 | 25 | 123 | 11 | 54.5 | 0 | 0.0 | 0 | 0 | 689.9 | |
| 29-30 | 40656.0 | 0 | 0.0 | 0 | 0.0 | 9 | 42.5 | 24 | 119.0 | 37 | 148.0 | 0 | 0.0 | 37 | 185 | 0 | 0.0 | 2 | 8.0 | 0 | 0 | 502.5 | |
| 31-3 | 31099.2 | 0 | 0.0 | 0 | 0.0 | 0 | 0.0 | 27 | 136.0 | 13 | 52.8 | 0 | 0.0 | 31 | 156 | 0 | 0.0 | 1 | 4.0 | 0 | 0 | 348.3 | |
| Total (ft) | 709,474 | 4.0 | 4.0 | 0.0 | 0 | 192.1 | 961 | 381.4 | 1907 | 267.5 | 1070 | 8.0 | 40 | 333.5 | 1668 | 222.6 | 1113 | 76.0 | 304 | 8.0 | 40 | | |
| Total (mi) | 134.37 | | | | | | | | | | | | | | | | | | | | | | |

ENVIRONMENTAL TOTAL: 7106.0

| ENVIRONMENTAL CONSIDERATIONS | | | |
|------------------------------|---|------|--|
| E-1 | Potential Construction Impacts (Dust, Traffic, Noise) | E-6 | Residences Affected by Prominent Visual Intrusion |
| E-2 | Potential Habitat Damage or Need for Restoration | E-7 | Line Visually Prominent within Scenic Viewshed |
| E-3 | Clearing Riparian/Wetland Areas | E-8 | Line Visually Prominent from Highway or Major Arterial |
| E-4 | Clearing in Treed Lands | E-9 | Special Mitigation Requirements |
| E-5 | Cultural Resource Conflict Areas | E-10 | Exposure to Electromagnetic Fields (EMF) |

**ALASKA ENERGY AUTHORITY
COPPER VALLEY INTERTIE FEASIBILITY STUDY**

ROUTE ALTERNATIVE B EVALUATION MATRIX

TABLE B-2

LAND USE CONSIDERATIONS

| EVALUATION CRITERIA: | | L-1 | | L-2 | | L-3 | | L-4 | | L-5 | | L-6 | | LAND USE SUBTOTAL |
|----------------------|---------|------------|------|------------|------|-------|------|------------|------|--------|-------|---------|------|-------------------------|
| WEIGHT: | | 5 | | 5 | | 3 | | 5 | | 3 | | 1 | | |
| UNIT: | | Each/1000' | | Each/1000' | | Each | | Each/1000' | | Acres | | 1000 ft | | |
| SEGMENT | LENGTH | QTY | SUBT | QTY | SUBT | QTY | SUBT | QTY | SUBT | QTY | SUBT | QTY | SUBT | |
| 1-2 | 29356.8 | 0 | 0 | 2 | 7.5 | 3 | 9.9 | 11 | 52.8 | 84 | 252.7 | 0 | 0.0 | 322.9 |
| 2-31 | 34742.4 | 0 | 0 | 0 | 0.0 | 7 | 19.8 | 12 | 57.9 | 100 | 299.1 | 0 | 0.0 | 376.8 |
| 3-4 | 35270.4 | 0 | 0 | 0 | 0.0 | 7 | 20.1 | 12 | 58.4 | 101 | 303.6 | 5 | 4.8 | 386.9 |
| 4-5 | 43084.8 | 0 | 0 | 0 | 0.0 | 6 | 18.6 | 11 | 55.8 | 109 | 328.2 | 0 | 0.0 | 402.6 |
| 5-6 | 49209.6 | 0 | 0 | 3 | 13.5 | 8 | 22.8 | 10 | 50.6 | 144 | 431.6 | 15 | 14.5 | 533.0 |
| 6-9 | 24868.8 | 0 | 0 | 5 | 26.0 | 0 | 0.0 | 6 | 28.6 | 71 | 214.1 | 3 | 2.6 | 271.2 |
| 9-11 | 38913.6 | 0 | 0 | 2 | 8.5 | 7 | 20.1 | 8 | 41.9 | 112 | 335.0 | 7 | 7.1 | 412.6 |
| 11-12 | 25027.2 | 0 | 0 | 0 | 0.0 | 5 | 14.1 | 8 | 38.7 | 72 | 215.5 | 0 | 0.0 | 268.3 |
| 12-13 | 16579.2 | 0 | 0 | 0 | 0.0 | 3 | 9.3 | 4 | 20.7 | 48 | 142.7 | 0 | 0.0 | 172.7 |
| 13-14 | 17424.0 | 0 | 0 | 0 | 0.0 | 3 | 7.5 | 6 | 31.5 | 50 | 150.0 | 0 | 0.0 | 189.0 |
| 14-16 | 32736.0 | 0 | 0 | 0 | 0.0 | 12 | 37.2 | 7 | 36.0 | 94 | 281.8 | 0 | 0.0 | 355.0 |
| 16-18 | 31099.2 | 0 | 0 | 0 | 0.0 | 6 | 18.6 | 7 | 34.5 | 89 | 267.7 | 0 | 0.0 | 320.8 |
| 18-21 | 72600.0 | 0 | 0 | 0 | 0.0 | 14 | 41.4 | 15 | 73.8 | 208 | 625.0 | 0 | 0.0 | 740.2 |
| 21-23 | 27403.2 | 0 | 0 | 0 | 0.0 | 5 | 15.6 | 8 | 41.0 | 79 | 235.9 | 0 | 0.0 | 292.5 |
| 23-24 | 31785.6 | 0 | 0 | 0 | 0.0 | 6 | 18.0 | 7 | 35.1 | 91 | 273.6 | 0 | 0.0 | 326.7 |
| 24-25 | 25766.4 | 0 | 0 | 0 | 0.0 | 5 | 14.7 | 6 | 29.4 | 74 | 221.8 | 0 | 0.0 | 265.9 |
| 25-26 | 11985.6 | 0 | 0 | 0 | 0.0 | 2 | 6.9 | 3 | 16.4 | 34 | 103.2 | 0 | 0.0 | 126.4 |
| 26-27 | 42081.6 | 0 | 0 | 0 | 0.0 | 8 | 24.0 | 9 | 44.9 | 121 | 362.3 | 0 | 0.0 | 431.1 |
| 27-29 | 47784.0 | 0 | 0 | 6 | 28.5 | 4 | 13.2 | 10 | 50.3 | 137 | 411.4 | 0 | 0.0 | 503.3 |
| 29-30 | 40656.0 | 0 | 0 | 8 | 41.5 | 0 | 0.0 | 8 | 41.6 | 111 | 332.7 | 0 | 0.0 | 415.8 |
| 31-3 | 31099.2 | 1 | 6 | 3 | 13.8 | 5 | 14.7 | 11 | 54.5 | 89 | 267.7 | 0 | 0.0 | 356.9 |
| Total (ft) | 709,474 | 1 | 6 | 27.9 | 139 | 115.5 | 347 | 178.8 | 894 | 2018.6 | 6056 | 29.0 | 29 | |
| Total (miles) | 134.37 | | | | | | | | | | | | | |

LAND USE TOTAL: 7470.7

| LAND USE CONSIDERATIONS | | | |
|-------------------------|---|-----|-------------------------------|
| L-1 | Private Land Parcels Affected by Aquisition | L-4 | Land Use Impacts |
| L-2 | Native Lands Affected by Aquisition | L-5 | New Right-of-Way Requirements |
| L-3 | State Lands | L-6 | Special Restoration Efforts |

**ALASKA ENERGY AUTHORITY
COPPER VALLEY INTERTIE FEASIBILITY STUDY**

ROUTE ALTERNATIVE B EVALUATION MATRIX

TABLE B-3

CONSTRUCTION/ENGINEERING CONSIDERATIONS

| EVALUATION CRITERIA: | | C-1 | | C-2 | | C-3 | | C-4 | | C-5 | | C-6 | | C-7 | | C-8 | | SUB -TOTAL |
|----------------------|---------|---------|------|---------|-------|---------|-------|---------|------|------|------|------|------|---------|------|------|------|---------------|
| WEIGHT: | | 4 | | 5 | | 2 | | 3 | | 2 | | 2 | | 4 | | 0 | | |
| UNIT: | | 1000 ft | | 1000 ft | | 1000 ft | | 1000 ft | | Each | | Each | | 1000 ft | | Each | | |
| SEGMENT | LENGTH | Qty | Subt | Qty | Subt | Qty | Subt | Qty | Subt | Qty | Subt | Qty | Subt | Qty | Subt | Qty | Subt | |
| 1-2 | 29356.8 | 8 | 31.2 | 0 | 0.0 | 8 | 15.8 | 9 | 26 | 1 | 2 | 6 | 12 | 1 | 4 | 0 | 0 | 90.6 |
| 2-31 | 34742.4 | 9 | 36.3 | 0 | 0.0 | 13 | 26.4 | 6 | 18 | 0 | 0 | 4 | 8 | 1 | 4 | 0 | 0 | 92.7 |
| 3-4 | 35270.4 | 11 | 44.7 | 0 | 0.0 | 24 | 47.5 | 6 | 18 | 0 | 0 | 3 | 6 | 18 | 72 | 0 | 0 | 187.8 |
| 4-5 | 43084.8 | 11 | 45.3 | 0 | 0.0 | 16 | 31.7 | 11 | 34 | 0 | 0 | 3 | 6 | 46 | 186 | 0 | 0 | 302.5 |
| 5-6 | 49209.6 | 9 | 34.8 | 21 | 107.4 | 8 | 15.8 | 28 | 85 | 0 | 0 | 6 | 12 | 114 | 457 | 0 | 0 | 711.5 |
| 6-9 | 24868.8 | 5 | 20.0 | 25 | 124.3 | 11 | 21.1 | 11 | 33 | 0 | 0 | 4 | 8 | 33 | 133 | 0 | 0 | 339.6 |
| 9-11 | 38913.6 | 0 | 0.0 | 39 | 194.6 | 53 | 105.6 | 15 | 45 | 0 | 0 | 5 | 10 | 41 | 164 | 0 | 0 | 518.8 |
| 11-12 | 25027.2 | 1 | 4.0 | 25 | 125.1 | 24 | 47.5 | 0 | 0 | 0 | 0 | 5 | 10 | 25 | 99 | 0 | 0 | 285.9 |
| 12-13 | 16579.2 | 0 | 0.0 | 0 | 0.0 | 13 | 26.4 | 0 | 0 | 0 | 0 | 3 | 6 | 17 | 66 | 0 | 0 | 98.8 |
| 13-14 | 17424.0 | 0 | 0.0 | 0 | 0.0 | 13 | 26.4 | 20 | 61 | 0 | 0 | 4 | 8 | 52 | 209 | 0 | 0 | 304.4 |
| 14-16 | 32736.0 | 0 | 0.0 | 0 | 0.0 | 11 | 21.1 | 0 | 0 | 0 | 0 | 3 | 6 | 98 | 392 | 0 | 0 | 419.5 |
| 16-18 | 31099.2 | 0 | 0.0 | 0 | 0.0 | 8 | 15.8 | 0 | 0 | 0 | 0 | 0 | 0 | 73 | 293 | 0 | 0 | 309.0 |
| 18-21 | 72600.0 | 0 | 0.0 | 0 | 0.0 | 16 | 31.7 | 9 | 26 | 0 | 0 | 3 | 6 | 148 | 593 | 0 | 0 | 656.4 |
| 21-23 | 27403.2 | 0 | 0.0 | 0 | 0.0 | 8 | 15.8 | 0 | 0 | 0 | 0 | 4 | 8 | 28 | 110 | 0 | 0 | 133.8 |
| 23-24 | 31785.6 | 0 | 0.0 | 0 | 0.0 | 11 | 21.1 | 32 | 95 | 1 | 2 | 4 | 8 | 32 | 127 | 0 | 0 | 253.7 |
| 24-25 | 25766.4 | 0 | 0.0 | 0 | 0.0 | 8 | 15.8 | 26 | 77 | 0 | 0 | 1 | 2 | 26 | 103 | 0 | 0 | 198.4 |
| 25-26 | 11985.6 | 0 | 0.0 | 0 | 0.0 | 13 | 26.4 | 0 | 0 | 0 | 0 | 2 | 4 | 12 | 48 | 0 | 0 | 78.8 |
| 26-27 | 42081.6 | 0 | 0.0 | 0 | 0.0 | 21 | 42.2 | 3 | 9 | 0 | 0 | 3 | 6 | 40 | 158 | 0 | 0 | 215.6 |
| 27-29 | 47784.0 | 0 | 0.0 | 0 | 0.0 | 8 | 15.8 | 0 | 0 | 1 | 2 | 4 | 8 | 24 | 97 | 0 | 0 | 122.6 |
| 29-30 | 40656.0 | 0 | 0.0 | 0 | 0.0 | 7 | 13.2 | 3 | 9 | 0 | 0 | 3 | 6 | 0 | 0 | 0 | 0 | 28.2 |
| 31-3 | 31099.2 | 8 | 32.3 | 0 | 0.0 | 13 | 26.4 | 0 | 0 | 0 | 0 | 5 | 10 | 0 | 0 | 0 | 0 | 68.7 |
| Total (ft) | 709,474 | 62.2 | 249 | 110.3 | 551 | 304.9 | 610 | 179 | 536 | 3 | 6 | 75 | 150 | 829 | 3316 | 0 | 0 | |
| Total (miles) | 134.37 | | | | | | | | | | | | | | | | | |

CONSTRUCTION/ENGINEERING TOTAL: 5417.4

| CONSTRUCTION/ENGINEERING CONSIDERATIONS | | | | |
|---|---|--|-----|---|
| C-1 | Difficult Access (Construction/Maintenance) | | C-5 | Road/Utility Crossings |
| C-2 | Remote Access | | C-6 | Line Angles over 30 Degrees or Complex Structures |
| C-3 | Joint Construction with Other Utilities | | C-7 | Line Reliability |
| C-4 | Engineering Constraints | | C-8 | Service to Future MEA Substations |

**ALASKA ENERGY AUTHORITY
COPPER VALLEY INTERTIE FEASIBILITY STUDY**

ROUTE ALTERNATIVE B EVALUATION MATRIX

TABLE B-4

FINANCIAL CONSIDERATIONS

| EVALUATION CRITERIA: | | F-1 | | F-2 | | F-3 | | F-4 | | FINANCIAL |
|----------------------|-----------|----------|--------|----------|--------|----------|--------|----------|-------|-----------|
| WEIGHT: | | 0.2 | | 0.2 | | 0.2 | | 0.2 | | |
| UNIT: | | 300 k/mi | | 300 k/mi | | 375 k/mi | | 430 k/mi | | SUBTOTAL |
| SEGMENT | LENGTH | QTY | SUBT | QTY | SUBT | QTY | SUBT | QTY | SUBT | |
| 1-2 | 29357 | 5.6 | 333.6 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 333.6 |
| 11-12 | 25027 | 0.0 | 0.0 | 0.0 | 0.0 | 4.7 | 355.5 | 0.0 | 0.0 | 355.5 |
| 12-13 | 16579 | 0.0 | 0.0 | 3.1 | 188.4 | 0.0 | 0.0 | 0.0 | 0.0 | 188.4 |
| 13-14 | 17424 | 0.0 | 0.0 | 0.0 | 0.0 | 3.3 | 247.5 | 0.0 | 0.0 | 247.5 |
| 14-16 | 32736 | 0.0 | 0.0 | 0.0 | 0.0 | 6.2 | 465.0 | 0.0 | 0.0 | 465.0 |
| 16-18 | 31099 | 0.0 | 0.0 | 5.9 | 353.4 | 0.0 | 0.0 | 0.0 | 0.0 | 353.4 |
| 18-18A | 15840 | 0.0 | 0.0 | 3.0 | 180.0 | 0.0 | 0.0 | 0.0 | 0.0 | 180.0 |
| 18A-18B | 23496 | 0.0 | 0.0 | 0.0 | 0.0 | 4.5 | 333.8 | 0.0 | 0.0 | 333.8 |
| 18B-21 | 33264 | 0.0 | 0.0 | 6.3 | 378.0 | 0.0 | 0.0 | 0.0 | 0.0 | 378.0 |
| 2-31 | 34742 | 6.6 | 394.8 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 394.8 |
| 21-23 | 27403 | 0.0 | 0.0 | 5.2 | 311.4 | 0.0 | 0.0 | 0.0 | 0.0 | 311.4 |
| 23-24 | 31786 | 0.0 | 0.0 | 6.0 | 361.2 | 0.0 | 0.0 | 0.0 | 0.0 | 361.2 |
| 24-25 | 25766 | 0.0 | 0.0 | 4.9 | 292.8 | 0.0 | 0.0 | 0.0 | 0.0 | 292.8 |
| 25-26 | 11986 | 0.0 | 0.0 | 2.3 | 136.2 | 0.0 | 0.0 | 0.0 | 0.0 | 136.2 |
| 26-27 | 42082 | 0.0 | 0.0 | 8.0 | 478.2 | 0.0 | 0.0 | 0.0 | 0.0 | 478.2 |
| 27-29 | 47784 | 0.0 | 0.0 | 9.1 | 543.0 | 0.0 | 0.0 | 0.0 | 0.0 | 543.0 |
| 29-30 | 40656 | 0.0 | 0.0 | 7.7 | 462.0 | 0.0 | 0.0 | 0.0 | 0.0 | 462.0 |
| 3-4 | 35270 | 6.7 | 400.8 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 400.8 |
| 31-3 | 31099 | 5.9 | 353.4 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 353.4 |
| 4-4A | 15418 | 2.9 | 175.2 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 175.2 |
| 4A-5 | 27667 | 5.2 | 314.4 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 314.4 |
| 5-5A | 14203 | 2.7 | 161.4 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 161.4 |
| 5A-5B | 10613 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 2.0 | 172.9 | 172.9 |
| 5B-5C | 12038 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 2.3 | 196.1 | 196.1 |
| 5C-6 | 12355 | 2.3 | 140.4 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 140.4 |
| 6-9 | 24869 | 4.7 | 282.6 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 282.6 |
| 9-11 | 38914 | 0.0 | 0.0 | 0.0 | 0.0 | 7.4 | 552.8 | 0.0 | 0.0 | 552.8 |
| Total (ft) | 709473.60 | 42.6 | 2556.6 | 61.4 | 3684.6 | 26.1 | 1954.5 | 4.3 | 368.9 | |
| Total (miles) | 134.37 | | | | | | | | | |

FINANCIAL TOTAL: 8564.6

| FINANCIAL CONSIDERATIONS | |
|--------------------------|------------------------------------|
| F-1 | Construction Cost - Loading Zone 1 |
| F-2 | Construction Cost - Loading Zone 2 |
| F-3 | Construction Cost - Loading Zone 3 |
| F-4 | Construction Cost - Loading Zone 4 |

**ALASKA ENERGY AUTHORITY
COPPER VALLEY INTERTIE FEASIBILITY STUDY**

ROUTE ALTERNATIVE C EVALUATION MATRIX

TABLE C-1

ENVIRONMENTAL CONSIDERATIONS

| EVALUATION CRITERIA: | | E-1 | | E-2 | | E-3 | | E-4 | | E-5 | | E-6 | | E-7 | | E-8 | | E-9 | | E-10 | | SUB -TOTAL | |
|----------------------|---------|-------|------|-------|------|-------|-------|-------|-------|-------|-------|------|------|-------|------|------------|-------|------------|------|------|------|---------------|--|
| WEIGHT: | | 1 | | 3 | | 5 | | 5 | | 4 | | 5 | | 5 | | 5 | | 4 | | 5 | | | |
| UNIT: | | 1000' | | 1000' | | 1000' | | 1000' | | 1000' | | Each | | 1000' | | Each/1000' | | Each/1000' | | Each | | | |
| SEGMENT | LENGTH | Qty | Subt | Qty | Subt | Qty | Subt | Qty | Subt | Qty | Subt | Qty | Subt | Qty | Subt | Qty | Subt | Qty | Subt | Qty | Subt | | |
| 1-2 | 29356.8 | 2 | 2.0 | 0 | 0.0 | 5 | 25.0 | 23 | 116.5 | 4 | 14.8 | 8 | 40.0 | 0 | 0 | 17 | 83.5 | 2 | 8.0 | 8 | 40 | 329.8 | |
| 2-31 | 34742.4 | 0 | 0.0 | 0 | 0.0 | 11 | 52.5 | 30 | 152.0 | 15 | 61.2 | 0 | 0.0 | 23 | 116 | 0 | 0.0 | 4 | 16.0 | 0 | 0 | 397.7 | |
| 3-4 | 35270.4 | 0 | 0.0 | 0 | 0.0 | 8 | 39.5 | 28 | 139.5 | 21 | 84.4 | 0 | 0.0 | 24 | 119 | 0 | 0.0 | 5 | 20.0 | 0 | 0 | 402.4 | |
| 4-5 | 43084.8 | 0 | 0.0 | 0 | 0.0 | 3 | 16.0 | 19 | 94.5 | 38 | 152.4 | 0 | 0.0 | 38 | 191 | 7 | 35.5 | 5 | 20.0 | 0 | 0 | 508.9 | |
| 5-6 | 49209.6 | 0 | 0.0 | 0 | 0.0 | 7 | 37.0 | 11 | 55.0 | 7 | 27.6 | 0 | 0.0 | 12 | 58 | 11 | 53.0 | 9 | 36.0 | 0 | 0 | 286.6 | |
| 6-8 | 46094.4 | 0 | 0.0 | 0 | 0.0 | 6 | 31.5 | 1 | 7.0 | 48 | 184.4 | 0 | 0.0 | 48 | 231 | 0 | 0.0 | 5 | 20.0 | 0 | 0 | 473.4 | |
| 8-10 | 7603.2 | 0 | 0.0 | 0 | 0.0 | 5 | 25.0 | 0 | 1.0 | 8 | 30.4 | 0 | 0.0 | 8 | 38 | 0 | 0.0 | 3 | 12.0 | 0 | 0 | 106.4 | |
| 10-11 | 22440.0 | 0 | 0.0 | 0 | 0.0 | 0 | 0.0 | 1 | 3.5 | 22 | 89.6 | 0 | 0.0 | 22 | 112 | 0 | 0.0 | 4 | 16.0 | 0 | 0 | 221.1 | |
| 11-12 | 25027.2 | 0 | 0.0 | 0 | 0.0 | 1 | 5.0 | 9 | 42.5 | 25 | 100.0 | 0 | 0.0 | 25 | 125 | 0 | 0.0 | 7 | 28.0 | 0 | 0 | 300.5 | |
| 12-13 | 16579.2 | 0 | 0.0 | 0 | 0.0 | 1 | 5.0 | 9 | 42.5 | 11 | 44.4 | 0 | 0.0 | 11 | 56 | 8 | 40.5 | 4 | 16.0 | 0 | 0 | 203.9 | |
| 13-14 | 17424.0 | 0 | 0.0 | 0 | 0.0 | 2 | 10.0 | 1 | 2.5 | 12 | 46.4 | 0 | 0.0 | 17 | 87 | 15 | 74.0 | 2 | 8.0 | 0 | 0 | 227.9 | |
| 14-15 | 10084.8 | 0 | 0.0 | 0 | 0.0 | 0 | 0.0 | 0 | 0.0 | 10 | 40.4 | 0 | 0.0 | 10 | 51 | 0 | 0.0 | 1 | 4.0 | 0 | 0 | 94.9 | |
| 15-16 | 24129.6 | 0 | 0.0 | 0 | 0.0 | 2 | 10.0 | 1 | 3.5 | 5 | 21.2 | 0 | 0.0 | 16 | 79 | 14 | 68.5 | 2 | 8.0 | 0 | 0 | 190.2 | |
| 16-18 | 31099.2 | 0 | 0.0 | 0 | 0.0 | 10 | 50.0 | 2 | 9.5 | 11 | 42.4 | 0 | 0.0 | 17 | 87 | 17 | 87.0 | 3 | 12.0 | 0 | 0 | 287.9 | |
| 18-21 | 72600.0 | 0 | 0.0 | 0 | 0.0 | 22 | 111.0 | 36 | 181.5 | 0 | 0.0 | 0 | 0.0 | 0 | 0 | 12 | 58.0 | 6 | 24.0 | 0 | 0 | 374.5 | |
| 21-23 | 27403.2 | 0 | 0.0 | 0 | 0.0 | 15 | 74.0 | 18 | 90.5 | 11 | 42.4 | 0 | 0.0 | 13 | 64 | 27 | 137.0 | 1 | 4.0 | 0 | 0 | 411.4 | |
| 23-24 | 31785.6 | 1 | 1.0 | 0 | 0.0 | 10 | 47.5 | 29 | 143.0 | 0 | 0.0 | 0 | 0.0 | 27 | 135 | 35 | 174.0 | 1 | 4.0 | 0 | 0 | 504.0 | |
| 24-25 | 25766.4 | 0 | 0.0 | 0 | 0.0 | 8 | 39.5 | 10 | 48.5 | 0 | 0.0 | 0 | 0.0 | 0 | 0 | 19 | 92.5 | 1 | 4.0 | 0 | 0 | 184.5 | |
| 25-26 | 11985.6 | 0 | 0.0 | 0 | 0.0 | 8 | 39.5 | 10 | 48.0 | 0 | 0.0 | 0 | 0.0 | 0 | 0 | 12 | 60.0 | 2 | 8.0 | 0 | 0 | 155.5 | |
| 26-27 | 42081.6 | 0 | 0.0 | 0 | 0.0 | 15 | 76.5 | 34 | 168.5 | 0 | 0.0 | 0 | 0.0 | 0 | 0 | 0 | 0.0 | 6 | 24.0 | 0 | 0 | 269.0 | |
| 27-29 | 47784.0 | 1 | 1.0 | 0 | 0.0 | 40 | 198.0 | 38 | 191.0 | 31 | 122.4 | 0 | 0.0 | 25 | 123 | 11 | 54.5 | 0 | 0.0 | 0 | 0 | 689.9 | |
| 29-30 | 40656.0 | 0 | 0.0 | 0 | 0.0 | 9 | 42.5 | 24 | 119.0 | 37 | 148.0 | 0 | 0.0 | 37 | 185 | 0 | 0.0 | 2 | 8.0 | 0 | 0 | 502.5 | |
| 31-3 | 31099.2 | 0 | 0.0 | 0 | 0.0 | 0 | 0.0 | 27 | 136.0 | 13 | 52.8 | 0 | 0.0 | 31 | 156 | 0 | 0.0 | 1 | 4.0 | 0 | 0 | 348.3 | |
| Total (ft) | 723,307 | 4.0 | 4 | 0.0 | 0 | 187.0 | 935 | 359.1 | 1796 | 326.3 | 1305 | 8.0 | 40 | 401.9 | 2010 | 203.6 | 1018 | 76.0 | 304 | 8.0 | 40 | | |
| Total (mi) | 136.99 | | | | | | | | | | | | | | | | | | | | | | |

ENVIRONMENTAL TOTAL: 7451.2

ENVIRONMENTAL CONSIDERATIONS

| | | | |
|-----|---|------|--|
| E-1 | Potential Construction Impacts (Dust, Traffic, Noise) | E-6 | Residences Affected by Prominent Visual Intrusion |
| E-2 | Potential Habitat Damage or Need for Restoration | E-7 | Line Visually Prominent within Scenic Viewshed |
| E-3 | Clearing Riparian/Wetland Areas | E-8 | Line Visually Prominent from Highway or Major Arterial |
| E-4 | Clearing in Treed Lands | E-9 | Special Mitigation Requirements |
| E-5 | Cultural Resource Conflict Areas | E-10 | Exposure to Electromagnetic Fields (EMF) |

**ALASKA ENERGY AUTHORITY
COPPER VALLEY INTERTIE FEASIBILITY STUDY**

ROUTE ALTERNATIVE C EVALUATION MATRIX

TABLE C-2

LAND USE CONSIDERATIONS

| EVALUATION CRITERIA: | | L-1 | | L-2 | | L-3 | | L-4 | | L-5 | | L-6 | | LAND USE SUBTOTAL |
|----------------------|---------|------------|------|------------|------|-------|------|------------|------|--------|-------|---------|------|-------------------------|
| WEIGHT: | | 5 | | 5 | | 3 | | 5 | | 3 | | 1 | | |
| UNIT: | | Each/1000' | | Each/1000' | | Each | | Each/1000' | | Acres | | 1000 ft | | |
| SEGMENT | LENGTH | QTY | SUBT | QTY | SUBT | QTY | SUBT | QTY | SUBT | QTY | SUBT | QTY | SUBT | |
| 1-2 | 29356.8 | 0 | 0 | 2 | 7.5 | 3 | 9.9 | 11 | 52.8 | 84 | 252.7 | 0 | 0.0 | 322.9 |
| 2-31 | 34742.4 | 0 | 0 | 0 | 0.0 | 7 | 19.8 | 12 | 57.9 | 100 | 299.1 | 0 | 0.0 | 376.8 |
| 3-4 | 35270.4 | 0 | 0 | 0 | 0.0 | 7 | 20.1 | 12 | 58.4 | 101 | 303.6 | 5 | 4.8 | 386.9 |
| 4-5 | 43084.8 | 0 | 0 | 0 | 0.0 | 6 | 18.6 | 11 | 55.8 | 109 | 328.2 | 0 | 0.0 | 402.6 |
| 5-6 | 49209.6 | 0 | 0 | 3 | 13.5 | 8 | 22.8 | 10 | 50.6 | 144 | 431.6 | 15 | 14.5 | 533.0 |
| 6-8 | 46094.4 | 0 | 0 | 2 | 8.5 | 8 | 24.0 | 10 | 48.7 | 132 | 396.8 | 2 | 2.1 | 480.1 |
| 8-10 | 7603.2 | 0 | 0 | 0 | 0.0 | 1 | 4.2 | 2 | 12.2 | 22 | 65.5 | 0 | 0.0 | 81.9 |
| 10-11 | 22440.0 | 0 | 0 | 0 | 0.0 | 4 | 12.8 | 5 | 26.3 | 64 | 193.2 | 4 | 4.2 | 236.4 |
| 11-12 | 25027.2 | 0 | 0 | 0 | 0.0 | 5 | 14.1 | 8 | 38.7 | 72 | 215.5 | 0 | 0.0 | 268.3 |
| 12-13 | 16579.2 | 0 | 0 | 0 | 0.0 | 3 | 9.3 | 4 | 20.7 | 48 | 142.7 | 0 | 0.0 | 172.7 |
| 13-14 | 17424.0 | 0 | 0 | 0 | 0.0 | 3 | 7.5 | 6 | 31.5 | 50 | 150.0 | 0 | 0.0 | 189.0 |
| 14-15 | 10084.8 | 0 | 0 | 0 | 0.0 | 4 | 11.4 | 3 | 14.6 | 29 | 86.8 | 0 | 0.0 | 112.8 |
| 15-16 | 24129.6 | 0 | 0 | 0 | 0.0 | 9 | 27.6 | 6 | 27.9 | 69 | 207.7 | 1 | 1.3 | 264.5 |
| 16-18 | 31099.2 | 0 | 0 | 0 | 0.0 | 6 | 18.6 | 7 | 34.5 | 89 | 267.7 | 0 | 0.0 | 320.8 |
| 18-21 | 72600.0 | 0 | 0 | 0 | 0.0 | 14 | 41.4 | 15 | 73.8 | 208 | 625.0 | 0 | 0.0 | 740.2 |
| 21-23 | 27403.2 | 0 | 0 | 0 | 0.0 | 5 | 15.6 | 8 | 41.0 | 79 | 235.9 | 0 | 0.0 | 292.5 |
| 23-24 | 31785.6 | 0 | 0 | 0 | 0.0 | 6 | 18.0 | 7 | 35.1 | 91 | 273.6 | 0 | 0.0 | 326.7 |
| 24-25 | 25766.4 | 0 | 0 | 0 | 0.0 | 5 | 14.7 | 6 | 29.4 | 74 | 221.8 | 0 | 0.0 | 265.9 |
| 25-26 | 11985.6 | 0 | 0 | 0 | 0.0 | 2 | 6.9 | 3 | 16.4 | 34 | 103.2 | 0 | 0.0 | 126.4 |
| 26-27 | 42081.6 | 0 | 0 | 0 | 0.0 | 8 | 24.0 | 9 | 44.9 | 121 | 362.3 | 0 | 0.0 | 431.1 |
| 27-29 | 47784.0 | 0 | 0 | 6 | 28.5 | 4 | 13.2 | 10 | 50.3 | 137 | 411.4 | 0 | 0.0 | 503.3 |
| 29-30 | 40656.0 | 0 | 0 | 8 | 41.5 | 0 | 0.0 | 8 | 41.6 | 111 | 332.7 | 0 | 0.0 | 415.8 |
| 31-3 | 31099.2 | 1 | 6 | 3 | 13.8 | 5 | 14.7 | 11 | 54.5 | 89 | 267.7 | 0 | 0.0 | 356.9 |
| Total (ft) | 723,307 | 1 | 6 | 22.7 | 113 | 123.1 | 369 | 183.4 | 917 | 2058.3 | 6175 | 26.9 | 27 | |
| Total (miles) | 136.99 | | | | | | | | | | | | | |

LAND USE TOTAL: 7607.4

| LAND USE CONSIDERATIONS | | | | |
|-------------------------|---|--|-----|-------------------------------|
| L-1 | Private Land Parcels Affected by Aquisition | | L-4 | Land Use Impacts |
| L-2 | Native Lands Affected by Aquisition | | L-5 | New Right-of-Way Requirements |
| L-3 | State Lands | | L-6 | Special Restoration Efforts |

**ALASKA ENERGY AUTHORITY
COPPER VALLEY INTERTIE FEASIBILITY STUDY**

ROUTE ALTERNATIVE C EVALUATION MATRIX

TABLE C-3

CONSTRUCTION/ENGINEERING CONSIDERATIONS

| EVALUATION CRITERIA: | | C-1 | | C-2 | | C-3 | | C-4 | | C-5 | | C-6 | | C-7 | | C-8 | | SUB -TOTAL |
|----------------------|---------|---------|------|---------|-------|---------|-------|------------|------|------|------|------|------|---------|------|------|------|---------------|
| WEIGHT: | | 4 | | 5 | | 2 | | 3 | | 2 | | 2 | | 4 | | 0 | | |
| UNIT: | | 1000 ft | | 1000 ft | | 1000 ft | | Each/1000' | | Each | | Each | | 1000 ft | | Each | | |
| SEGMENT | LENGTH | Qty | Subt | Qty | Subt | Qty | Subt | Qty | Subt | Qty | Subt | Qty | Subt | Qty | Subt | Qty | Subt | |
| 1-2 | 29356.8 | 8 | 31.2 | 0 | 0.0 | 8 | 15.8 | 9 | 26 | 1 | 2 | 6 | 12 | 1 | 4 | 0 | 0 | 90.6 |
| 2-31 | 34742.4 | 9 | 36.3 | 0 | 0.0 | 13 | 26.4 | 6 | 18 | 0 | 0 | 4 | 8 | 1 | 4 | 0 | 0 | 92.7 |
| 3-4 | 35270.4 | 11 | 44.7 | 0 | 0.0 | 24 | 47.5 | 6 | 18 | 0 | 0 | 3 | 6 | 18 | 72 | 0 | 0 | 187.8 |
| 4-5 | 43084.8 | 11 | 45.3 | 0 | 0.0 | 16 | 31.7 | 11 | 34 | 0 | 0 | 3 | 6 | 46 | 186 | 0 | 0 | 302.5 |
| 5-6 | 49209.6 | 9 | 34.8 | 21 | 107.4 | 8 | 15.8 | 28 | 85 | 0 | 0 | 6 | 12 | 114 | 457 | 0 | 0 | 711.5 |
| 6-8 | 46094.4 | 0 | 0.0 | 46 | 230.5 | 26 | 52.8 | 3 | 9 | 0 | 0 | 6 | 12 | 118 | 470 | 0 | 0 | 774.3 |
| 8-10 | 7603.2 | 0 | 0.0 | 8 | 38.0 | 79 | 158.4 | 0 | 0 | 0 | 0 | 1 | 2 | 7 | 30 | 0 | 0 | 228.0 |
| 10-11 | 22440.0 | 0 | 0.0 | 22 | 112.2 | 53 | 105.6 | 3 | 9 | 0 | 0 | 2 | 4 | 23 | 94 | 0 | 0 | 324.4 |
| 11-12 | 25027.2 | 1 | 4.0 | 25 | 125.1 | 24 | 47.5 | 0 | 0 | 0 | 0 | 5 | 10 | 25 | 99 | 0 | 0 | 285.9 |
| 12-13 | 16579.2 | 0 | 0.0 | 0 | 0.0 | 13 | 26.4 | 0 | 0 | 0 | 0 | 3 | 6 | 17 | 66 | 0 | 0 | 98.8 |
| 13-14 | 17424.0 | 0 | 0.0 | 0 | 0.0 | 13 | 26.4 | 20 | 61 | 0 | 0 | 4 | 8 | 52 | 209 | 0 | 0 | 304.4 |
| 14-15 | 10084.8 | 0 | 0.0 | 0 | 0.0 | 13 | 26.4 | 0 | 0 | 0 | 0 | 0 | 0 | 30 | 121 | 0 | 0 | 147.6 |
| 15-16 | 24129.6 | 0 | 0.0 | 0 | 0.0 | 16 | 31.7 | 0 | 0 | 0 | 0 | 2 | 4 | 72 | 289 | 0 | 0 | 324.9 |
| 16-18 | 31099.2 | 0 | 0.0 | 0 | 0.0 | 8 | 15.8 | 0 | 0 | 0 | 0 | 0 | 0 | 73 | 293 | 0 | 0 | 309.0 |
| 18-21 | 72600.0 | 0 | 0.0 | 0 | 0.0 | 16 | 31.7 | 9 | 26 | 0 | 0 | 3 | 6 | 148 | 593 | 0 | 0 | 656.4 |
| 21-23 | 27403.2 | 0 | 0.0 | 0 | 0.0 | 8 | 15.8 | 0 | 0 | 0 | 0 | 4 | 8 | 28 | 110 | 0 | 0 | 133.8 |
| 23-24 | 31785.6 | 0 | 0.0 | 0 | 0.0 | 11 | 21.1 | 32 | 95 | 1 | 2 | 4 | 8 | 32 | 127 | 0 | 0 | 253.7 |
| 24-25 | 25766.4 | 0 | 0.0 | 0 | 0.0 | 8 | 15.8 | 26 | 77 | 0 | 0 | 1 | 2 | 26 | 103 | 0 | 0 | 198.4 |
| 25-26 | 11985.6 | 0 | 0.0 | 0 | 0.0 | 13 | 26.4 | 0 | 0 | 0 | 0 | 2 | 4 | 12 | 48 | 0 | 0 | 78.8 |
| 26-27 | 42081.6 | 0 | 0.0 | 0 | 0.0 | 21 | 42.2 | 3 | 9 | 0 | 0 | 3 | 6 | 40 | 158 | 0 | 0 | 215.6 |
| 27-29 | 47784.0 | 0 | 0.0 | 0 | 0.0 | 8 | 15.8 | 0 | 0 | 1 | 2 | 4 | 8 | 24 | 97 | 0 | 0 | 122.6 |
| 29-30 | 40656.0 | 0 | 0.0 | 0 | 0.0 | 7 | 13.2 | 3 | 9 | 0 | 0 | 3 | 6 | 0 | 0 | 0 | 0 | 28.2 |
| 31-3 | 31099.2 | 8 | 32.3 | 0 | 0.0 | 13 | 26.4 | 0 | 0 | 0 | 0 | 5 | 10 | 0 | 0 | 0 | 0 | 68.7 |
| Total (ft) | 723,307 | 57.2 | 229 | 122.7 | 613 | 418.4 | 837 | 159 | 476 | 3 | 6 | 74 | 148 | 908 | 3630 | 0 | 0 | |
| Total (miles) | 136.99 | | | | | | | | | | | | | | | | | |

CONSTRUCTION/ENGINEERING TOTAL: 5938.7

| CONSTRUCTION/ENGINEERING CONSIDERATIONS | | | |
|---|---|-----|---|
| C-1 | Difficult Access (Construction/Maintenance) | C-5 | Road/Utility Crossings |
| C-2 | Remote Access | C-6 | Line Angles over 30 Degrees or Complex Structures |
| C-3 | Joint Construction with Other Utilities | C-7 | Line Reliability |
| C-4 | Engineering Constraints | C-8 | Service to Future MEA Substations |

**ALASKA ENERGY AUTHORITY
COPPER VALLEY INTERTIE FEASIBILITY STUDY**

ROUTE ALTERNATIVE C EVALUATION MATRIX

TABLE C-4

FINANCIAL CONSIDERATIONS

| EVALUATION CRITERIA: | | F-1 | | F-2 | | F-3 | | F-4 | | FINANCIAL |
|----------------------|-----------|----------|--------|----------|--------|----------|--------|----------|-------|-----------|
| WEIGHT: | | 0.2 | | 0.2 | | 0.2 | | 0.2 | | |
| UNIT: | | 300 k/mi | | 300 k/mi | | 375 k/mi | | 430 k/mi | | SUBTOTAL |
| SEGMENT | LENGTH | QTY | SUBT | QTY | SUBT | QTY | SUBT | QTY | SUBT | |
| 1-2 | 29357 | 5.6 | 333.6 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 333.6 |
| 10-11 | 22440 | 0.0 | 0.0 | 0.0 | 0.0 | 4.3 | 318.8 | 0.0 | 0.0 | 318.8 |
| 11-12 | 25027 | 0.0 | 0.0 | 0.0 | 0.0 | 4.7 | 355.5 | 0.0 | 0.0 | 355.5 |
| 12-13 | 16579 | 0.0 | 0.0 | 3.1 | 188.4 | 0.0 | 0.0 | 0.0 | 0.0 | 188.4 |
| 13-14 | 17424 | 0.0 | 0.0 | 0.0 | 0.0 | 3.3 | 247.5 | 0.0 | 0.0 | 247.5 |
| 14-15 | 10085 | 0.0 | 0.0 | 0.0 | 0.0 | 1.9 | 143.3 | 0.0 | 0.0 | 143.3 |
| 15-16 | 24130 | 0.0 | 0.0 | 0.0 | 0.0 | 4.6 | 342.8 | 0.0 | 0.0 | 342.8 |
| 16-18 | 31099 | 0.0 | 0.0 | 5.9 | 353.4 | 0.0 | 0.0 | 0.0 | 0.0 | 353.4 |
| 18-18A | 15840 | 0.0 | 0.0 | 3.0 | 180.0 | 0.0 | 0.0 | 0.0 | 0.0 | 180.0 |
| 18A-18B | 23496 | 0.0 | 0.0 | 0.0 | 0.0 | 4.5 | 333.8 | 0.0 | 0.0 | 333.8 |
| 18B-21 | 33264 | 0.0 | 0.0 | 6.3 | 378.0 | 0.0 | 0.0 | 0.0 | 0.0 | 378.0 |
| 2-31 | 34742 | 6.6 | 394.8 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 394.8 |
| 21-23 | 27403 | 0.0 | 0.0 | 5.2 | 311.4 | 0.0 | 0.0 | 0.0 | 0.0 | 311.4 |
| 23-24 | 31786 | 0.0 | 0.0 | 6.0 | 361.2 | 0.0 | 0.0 | 0.0 | 0.0 | 361.2 |
| 24-25 | 25766 | 0.0 | 0.0 | 4.9 | 292.8 | 0.0 | 0.0 | 0.0 | 0.0 | 292.8 |
| 25-26 | 11986 | 0.0 | 0.0 | 2.3 | 136.2 | 0.0 | 0.0 | 0.0 | 0.0 | 136.2 |
| 26-27 | 42082 | 0.0 | 0.0 | 8.0 | 478.2 | 0.0 | 0.0 | 0.0 | 0.0 | 478.2 |
| 27-29 | 47784 | 0.0 | 0.0 | 9.1 | 543.0 | 0.0 | 0.0 | 0.0 | 0.0 | 543.0 |
| 29-30 | 40656 | 0.0 | 0.0 | 7.7 | 462.0 | 0.0 | 0.0 | 0.0 | 0.0 | 462.0 |
| 3-4 | 35270 | 6.7 | 400.8 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 400.8 |
| 31-3 | 31099 | 5.9 | 353.4 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 353.4 |
| 4-4A | 15418 | 2.9 | 175.2 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 175.2 |
| 4A-5 | 27667 | 5.2 | 314.4 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 314.4 |
| 5-5A | 14203 | 2.7 | 161.4 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 161.4 |
| 5A-5B | 10613 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 2.0 | 172.9 | 172.9 |
| 5B-5C | 12038 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 2.3 | 196.1 | 196.1 |
| 5C-6 | 12355 | 2.3 | 140.4 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 140.4 |
| 6-8 | 46094 | 0.0 | 0.0 | 0.0 | 0.0 | 8.7 | 654.8 | 0.0 | 0.0 | 654.8 |
| 8-10 | 7603 | 0.0 | 0.0 | 0.0 | 0.0 | 1.4 | 108.0 | 0.0 | 0.0 | 108.0 |
| Total (ft) | 723307.20 | 37.9 | 2274.0 | 61.4 | 3684.6 | 33.4 | 2504.3 | 4.3 | 368.9 | |
| Total (miles) | 136.99 | | | | | | | | | |

FINANCIAL TOTAL: 8831.8

| FINANCIAL CONSIDERATIONS | |
|--------------------------|------------------------------------|
| F-1 | Construction Cost - Loading Zone 1 |
| F-2 | Construction Cost - Loading Zone 2 |
| F-3 | Construction Cost - Loading Zone 3 |
| F-4 | Construction Cost - Loading Zone 4 |

**ALASKA ENERGY AUTHORITY
COPPER VALLEY INTERTIE FEASIBILITY STUDY**

ROUTE ALTERNATIVE D EVALUATION MATRIX

TABLE D-1

ENVIRONMENTAL CONSIDERATIONS

| EVALUATION CRITERIA: | | E-1 | | E-2 | | E-3 | | E-4 | | E-5 | | E-6 | | E-7 | | E-8 | | E-9 | | E-10 | | SUB -TOTAL |
|----------------------|----------|-------|------|-------|------|-------|-------|-------|-------|-------|-------|------|------|-------|------|------------|------|------------|------|------|------|---------------|
| WEIGHT: | | 1 | | 3 | | 5 | | 5 | | 4 | | 5 | | 5 | | 5 | | 4 | | 5 | | |
| UNIT: | | 1000' | | 1000' | | 1000' | | 1000' | | 1000' | | Each | | 1000' | | Each/1000' | | Each/1000' | | Each | | |
| SEGMENT | LENGTH | Qty | Subt | Qty | Subt | Qty | Subt | Qty | Subt | Qty | Subt | Qty | Subt | Qty | Subt | Qty | Subt | Qty | Subt | Qty | Subt | |
| 1-2 | 29356.80 | 2 | 2.0 | 0 | 0.0 | 5 | 25.0 | 23 | 116.5 | 4 | 14.8 | 8 | 40.0 | 0 | 0 | 17 | 83.5 | 2 | 8.0 | 8 | 40 | 329.8 |
| 2-3 | 59980.80 | 1 | 1.0 | 0 | 0.0 | 4 | 18.5 | 40 | 197.5 | 5 | 21.2 | 0 | 0.0 | 23 | 114 | 0 | 0.0 | 6 | 24.0 | 0 | 0 | 375.7 |
| 3-4 | 35270.40 | 0 | 0.0 | 0 | 0.0 | 8 | 39.5 | 28 | 139.5 | 21 | 84.4 | 0 | 0.0 | 24 | 119 | 0 | 0.0 | 5 | 20.0 | 0 | 0 | 402.4 |
| 4-5 | 43084.80 | 0 | 0.0 | 0 | 0.0 | 3 | 16.0 | 19 | 94.5 | 38 | 152.4 | 0 | 0.0 | 38 | 191 | 7 | 35.5 | 5 | 20.0 | 0 | 0 | 508.9 |
| 5-6 | 49209.60 | 0 | 0.0 | 0 | 0.0 | 7 | 37.0 | 11 | 55.0 | 7 | 27.6 | 0 | 0.0 | 12 | 58 | 11 | 53.0 | 9 | 36.0 | 0 | 0 | 266.6 |
| 6-8 | 46094.40 | 0 | 0.0 | 0 | 0.0 | 6 | 31.5 | 1 | 7.0 | 46 | 184.4 | 0 | 0.0 | 46 | 231 | 0 | 0.0 | 5 | 20.0 | 0 | 0 | 473.4 |
| 8-10 | 7603.20 | 0 | 0.0 | 0 | 0.0 | 5 | 25.0 | 0 | 1.0 | 8 | 30.4 | 0 | 0.0 | 8 | 38 | 0 | 0.0 | 3 | 12.0 | 0 | 0 | 106.4 |
| 10-15 | 66580.80 | 0 | 0.0 | 0 | 0.0 | 1 | 5.0 | 2 | 10.0 | 59 | 235.6 | 0 | 0.0 | 67 | 333 | 0 | 0.0 | 12 | 48.0 | 0 | 0 | 631.6 |
| 15-17 | 33052.80 | 0 | 0.0 | 0 | 0.0 | 2 | 7.5 | 0 | 0.0 | 33 | 132.4 | 0 | 0.0 | 33 | 166 | 0 | 0.0 | 6 | 24.0 | 0 | 0 | 329.4 |
| 17-19 | 47836.80 | 0 | 0.0 | 0 | 0.0 | 21 | 105.0 | 0 | 0.0 | 11 | 42.4 | 0 | 0.0 | 4 | 21 | 0 | 0.0 | 3 | 12.0 | 0 | 0 | 180.4 |
| 19-20 | 64046.40 | 0 | 0.0 | 0 | 0.0 | 26 | 129.5 | 32 | 160.0 | 0 | 0.0 | 0 | 0.0 | 0 | 0 | 0 | 0.0 | 3 | 12.0 | 0 | 0 | 301.5 |
| 20-22 | 26347.20 | 0 | 0.0 | 0 | 0.0 | 12 | 60.5 | 16 | 77.5 | 5 | 21.2 | 0 | 0.0 | 11 | 56 | 0 | 0.0 | 1 | 4.0 | 0 | 0 | 218.7 |
| 22-26 | 71596.80 | 1 | 1.0 | 0 | 0.0 | 24 | 119.0 | 63 | 315.0 | 0 | 0.0 | 0 | 0.0 | 0 | 0 | 11 | 54.5 | 8 | 32.0 | 0 | 0 | 521.5 |
| 26-27 | 42081.60 | 0 | 0.0 | 0 | 0.0 | 15 | 76.5 | 34 | 168.5 | 0 | 0.0 | 0 | 0.0 | 0 | 0 | 0 | 0.0 | 6 | 24.0 | 0 | 0 | 269.0 |
| 27-28 | 34003.20 | 0 | 0.0 | 0 | 0.0 | 24 | 117.5 | 27 | 136.0 | 0 | 0.0 | 0 | 0.0 | 0 | 0 | 0 | 0.0 | 0 | 0.0 | 0 | 0 | 253.5 |
| 28-29 | 13728.00 | 1 | 1.0 | 0 | 0.0 | 7 | 33.0 | 13 | 62.5 | 0 | 0.0 | 0 | 0.0 | 3 | 16 | 11 | 54.5 | 0 | 0.0 | 0 | 0 | 167.0 |
| 29-30 | 40656.00 | 0 | 0.0 | 0 | 0.0 | 9 | 42.5 | 24 | 119.0 | 37 | 148.0 | 0 | 0.0 | 37 | 185 | 0 | 0.0 | 2 | 8.0 | 0 | 0 | 502.5 |
| Total (ft) | 710,530 | 5.0 | 5 | 0.0 | 0 | 177.7 | 889 | 331.9 | 1660 | 273.7 | 1095 | 8.0 | 40 | 305.1 | 1526 | 56.2 | 281 | 76.0 | 304 | 8.0 | 40 | |
| Total (mi) | 134.57 | | | | | | | | | | | | | | | | | | | | | |

ENVIRONMENTAL TOTAL: 5838.3

| ENVIRONMENTAL CONSIDERATIONS | | | |
|------------------------------|---|------|--|
| E-1 | Potential Construction Impacts (Dust, Traffic, Noise) | E-6 | Residences Affected by Prominent Visual Intrusion |
| E-2 | Potential Habitat Damage or Need for Restoration | E-7 | Line Visually Prominent within Scenic Viewshed |
| E-3 | Clearing Riparian/Wetland Areas | E-8 | Line Visually Prominent from Highway or Major Arterial |
| E-4 | Clearing in Treed Lands | E-9 | Special Mitigation Requirements |
| E-5 | Cultural Resource Conflict Areas | E-10 | Exposure to Electromagnetic Fields (EMF) |

ALASKA ENERGY AUTHORITY
COPPER VALLEY INTERTIE FEASIBILITY STUDY

ROUTE ALTERNATIVE D EVALUATION MATRIX

TABLE D-2

LAND USE CONSIDERATIONS

| EVALUATION CRITERIA: | | L-1 | | L-2 | | L-3 | | L-4 | | L-5 | | L-6 | | LAND USE SUBTOTAL |
|----------------------|---------|------------|------|------------|------|-------|------|------------|------|--------|-------|---------|------|-------------------------|
| WEIGHT: | | 5 | | 5 | | 3 | | 5 | | 3 | | 1 | | |
| UNIT: | | Each/1000' | | Each/1000' | | Each | | Each/1000' | | Acres | | 1000 ft | | |
| SEGMENT | LENGTH | QTY | SUBT | QTY | SUBT | QTY | SUBT | QTY | SUBT | QTY | SUBT | QTY | SUBT | |
| 1-2 | 29356.8 | 0 | 0 | 2 | 7.5 | 3 | 9.9 | 11 | 52.8 | 84 | 252.7 | 0 | 0.0 | 322.9 |
| 2-3 | 59980.8 | 0 | 0 | 0 | 0.0 | 11 | 34.2 | 12 | 61.8 | 172 | 516.4 | 11 | 10.5 | 622.9 |
| 3-4 | 35270.4 | 0 | 0 | 0 | 0.0 | 7 | 20.1 | 12 | 58.4 | 101 | 303.6 | 5 | 4.8 | 386.9 |
| 4-5 | 43084.8 | 0 | 0 | 0 | 0.0 | 6 | 18.6 | 11 | 55.8 | 109 | 328.2 | 0 | 0.0 | 402.6 |
| 5-6 | 49209.6 | 0 | 0 | 3 | 13.5 | 8 | 22.8 | 10 | 50.6 | 144 | 431.6 | 15 | 14.5 | 533.0 |
| 6-8 | 46094.4 | 0 | 0 | 2 | 8.5 | 8 | 24.0 | 10 | 48.7 | 132 | 396.8 | 2 | 2.1 | 480.1 |
| 8-10 | 7603.2 | 0 | 0 | 0 | 0.0 | 1 | 4.2 | 2 | 12.2 | 22 | 65.5 | 0 | 0.0 | 81.9 |
| 10-15 | 66580.8 | 0 | 0 | 0 | 0.0 | 20 | 61.2 | 14 | 68.1 | 191 | 573.2 | 2 | 1.6 | 704.0 |
| 15-17 | 33052.8 | 0 | 0 | 0 | 0.0 | 12 | 35.7 | 7 | 36.3 | 95 | 284.5 | 0 | 0.0 | 356.5 |
| 17-19 | 47836.8 | 0 | 0 | 0 | 0.0 | 9 | 27.3 | 10 | 50.3 | 137 | 411.8 | 1 | 1.3 | 490.7 |
| 19-20 | 64046.4 | 0 | 0 | 0 | 0.0 | 12 | 36.3 | 13 | 65.7 | 184 | 551.4 | 0 | 0.0 | 653.3 |
| 20-22 | 26347.2 | 0 | 0 | 0 | 0.0 | 5 | 15.0 | 6 | 30.0 | 76 | 226.8 | 0 | 0.0 | 271.8 |
| 22-26 | 71596.8 | 0 | 0 | 0 | 0.0 | 14 | 40.8 | 15 | 72.8 | 205 | 616.4 | 0 | 0.0 | 730.0 |
| 26-27 | 42081.6 | 0 | 0 | 0 | 0.0 | 8 | 24.0 | 9 | 44.9 | 121 | 362.3 | 0 | 0.0 | 431.1 |
| 27-28 | 34003.2 | 0 | 0 | 6 | 30.0 | 1 | 4.2 | 7 | 37.2 | 98 | 292.7 | 0 | 0.0 | 364.1 |
| 28-29 | 13728.0 | 0 | 0 | 4 | 18.0 | 0 | 0.0 | 4 | 18.0 | 39 | 118.2 | 0 | 0.0 | 154.2 |
| 29-30 | 40656.0 | 0 | 0 | 8 | 41.5 | 0 | 0.0 | 8 | 41.6 | 111 | 332.7 | 0 | 0.0 | 415.8 |
| Total (ft) | 710,530 | 0 | 0 | 23.8 | 119 | 126.1 | 378 | 161.0 | 805 | 2021.6 | 6065 | 34.8 | 35 | |
| Total (mi) | 134.57 | | | | | | | | | | | | | |

LAND USE TOTAL: 7401.9

| LAND USE CONSIDERATIONS | |
|-------------------------|---|
| L-1 | Private Land Parcels Affected by Aquisition |
| L-2 | Native Lands Affected by Aquisition |
| L-3 | State Lands |
| L-4 | Land Use Impacts |
| L-5 | New Right-of-Way Requirements |
| L-6 | Special Restoration Efforts |

**ALASKA ENERGY AUTHORITY
COPPER VALLEY INTERTIE FEASIBILITY STUDY**

ROUTE ALTERNATIVE D EVALUATION MATRIX

TABLE D-3

CONSTRUCTION/ENGINEERING CONSIDERATIONS

| EVALUATION CRITERIA: | | C-1 | | C-2 | | C-3 | | C-4 | | C-5 | | C-6 | | C-7 | | C-8 | | SUB -TOTAL |
|----------------------|---------|---------|------|---------|-------|---------|-------|---------|------|------|------|------|------|---------|------|------|------|---------------|
| WEIGHT: | | 4 | | 5 | | 2 | | 3 | | 2 | | 2 | | 4 | | 0 | | |
| UNIT: | | 1000 ft | | 1000 ft | | 1000 ft | | 1000 ft | | Each | | Each | | 1000 ft | | Each | | |
| SEGMENT | LENGTH | Qty | Subt | Qty | Subt | Qty | Subt | Qty | Subt | Qty | Subt | Qty | Subt | Qty | Subt | Qty | Subt | |
| 1-2 | 29356.8 | 8 | 31.2 | 0 | 0.0 | 8 | 15.8 | 9 | 26 | 1 | 2 | 6 | 12 | 1 | 4 | 0 | 0 | 90.6 |
| 2-3 | 59980.8 | 18 | 72.4 | 0 | 0.0 | 24 | 47.5 | 11 | 34 | 0 | 0 | 3 | 6 | 35 | 141 | 0 | 0 | 301.1 |
| 3-4 | 35270.4 | 11 | 44.7 | 0 | 0.0 | 24 | 47.5 | 6 | 18 | 0 | 0 | 3 | 6 | 18 | 72 | 0 | 0 | 187.8 |
| 4-5 | 43084.8 | 11 | 45.3 | 0 | 0.0 | 16 | 31.7 | 11 | 34 | 0 | 0 | 3 | 6 | 46 | 186 | 0 | 0 | 302.5 |
| 5-6 | 49209.6 | 9 | 34.8 | 21 | 107.4 | 8 | 15.8 | 28 | 85 | 0 | 0 | 6 | 12 | 114 | 457 | 0 | 0 | 711.5 |
| 6-8 | 46094.4 | 0 | 0.0 | 46 | 230.5 | 26 | 52.8 | 3 | 9 | 0 | 0 | 6 | 12 | 118 | 470 | 0 | 0 | 774.3 |
| 8-10 | 7603.2 | 0 | 0.0 | 8 | 38.0 | 79 | 158.4 | 0 | 0 | 0 | 0 | 1 | 2 | 7 | 30 | 0 | 0 | 228.0 |
| 10-15 | 66580.8 | 0 | 0.0 | 67 | 332.9 | 69 | 137.3 | 32 | 95 | 0 | 0 | 8 | 16 | 143 | 570 | 0 | 0 | 1151.7 |
| 15-17 | 33052.8 | 0 | 0.0 | 0 | 0.0 | 32 | 63.4 | 3 | 9 | 0 | 0 | 4 | 8 | 99 | 397 | 0 | 0 | 477.6 |
| 17-19 | 47836.8 | 0 | 0.0 | 0 | 0.0 | 32 | 63.4 | 27 | 81 | 0 | 0 | 3 | 6 | 107 | 428 | 0 | 0 | 578.8 |
| 19-20 | 64046.4 | 0 | 0.0 | 0 | 0.0 | 18 | 37.0 | 0 | 0 | 0 | 0 | 2 | 4 | 106 | 424 | 0 | 0 | 465.4 |
| 20-22 | 26347.2 | 0 | 0.0 | 0 | 0.0 | 11 | 21.1 | 0 | 0 | 0 | 0 | 3 | 6 | 26 | 106 | 0 | 0 | 132.7 |
| 22-26 | 71596.8 | 0 | 0.0 | 0 | 0.0 | 16 | 31.7 | 60 | 179 | 2 | 4 | 3 | 6 | 117 | 468 | 0 | 0 | 688.8 |
| 26-27 | 42081.6 | 0 | 0.0 | 0 | 0.0 | 21 | 42.2 | 3 | 9 | 0 | 0 | 3 | 6 | 40 | 158 | 0 | 0 | 215.6 |
| 27-28 | 34003.2 | 0 | 0.0 | 0 | 0.0 | 0 | 0.0 | 0 | 0 | 0 | 0 | 1 | 2 | 14 | 57 | 0 | 0 | 59.2 |
| 28-29 | 13728.0 | 0 | 0.0 | 0 | 0.0 | 0 | 0.0 | 0 | 0 | 1 | 2 | 1 | 2 | 0 | 0 | 0 | 0 | 4.0 |
| 29-30 | 40656.0 | 0 | 0.0 | 0 | 0.0 | 7 | 13.2 | 3 | 9 | 0 | 0 | 3 | 6 | 0 | 0 | 0 | 0 | 28.2 |
| Total (ft) | 710,530 | 57.1 | 228 | 141.8 | 709 | 389.4 | 779 | 196 | 587 | 4 | 8 | 59 | 118 | 992 | 3968 | 0 | 0 | |
| Total (miles) | 134.57 | | | | | | | | | | | | | | | | | |

CONSTRUCTION/ENGINEERING TOTAL: 6397.6

| CONSTRUCTION/ENGINEERING CONSIDERATIONS | | | |
|---|---|-----|---|
| C-1 | Difficult Access (Construction/Maintenance) | C-5 | Road/Utility Crossings |
| C-2 | Remote Access | C-6 | Line Angles over 30 Degrees or Complex Structures |
| C-3 | Joint Construction with Other Utilities | C-7 | Line Reliability |
| C-4 | Engineering Constraints | C-8 | Service to Future MEA Substations |

ALASKA ENERGY AUTHORITY
COPPER VALLEY INTERTIE FEASIBILITY STUDY

ROUTE ALTERNATIVE D EVALUATION MATRIX

TABLE D-4

FINANCIAL CONSIDERATIONS

| EVALUATION CRITERIA: | | F-1 | | F-2 | | F-3 | | F-4 | | FINANCIAL SUBTOTAL |
|----------------------|----------|----------|--------|----------|--------|----------|--------|----------|-------|-----------------------|
| WEIGHT: | | 0.2 | | 0.2 | | 0.2 | | 0.2 | | |
| UNIT: | | 300 k/mi | | 300 k/mi | | 375 k/mi | | 430 k/mi | | |
| SEGMENT | LENGTH | QTY | SUBT | QTY | SUBT | QTY | SUBT | QTY | SUBT | |
| 1-2 | 29356.80 | 5.6 | 333.6 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 333.6 |
| 2-3 | 59980.80 | 11.4 | 681.6 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 681.6 |
| 3-4 | 35270.40 | 6.7 | 400.8 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 400.8 |
| 4-4A | 15417.60 | 2.9 | 175.2 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 175.2 |
| 4A-5 | 27667.20 | 5.2 | 314.4 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 314.4 |
| 5-5A | 14203.20 | 2.7 | 161.4 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 161.4 |
| 5A-5B | 10612.80 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 2.0 | 172.9 | 172.9 |
| 5B-5C | 12038.40 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 2.3 | 196.1 | 196.1 |
| 5C-6 | 12355.20 | 2.3 | 140.4 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 140.4 |
| 6-8 | 46094.40 | 0.0 | 0.0 | 0.0 | 0.0 | 8.7 | 654.8 | 0.0 | 0.0 | 654.8 |
| 8-10 | 7603.20 | 0.0 | 0.0 | 0.0 | 0.0 | 1.4 | 108.0 | 0.0 | 0.0 | 108.0 |
| 10-15 | 66580.80 | 0.0 | 0.0 | 0.0 | 0.0 | 12.6 | 945.8 | 0.0 | 0.0 | 945.8 |
| 15-17 | 33052.80 | 0.0 | 0.0 | 0.0 | 0.0 | 6.3 | 469.5 | 0.0 | 0.0 | 469.5 |
| 17-17A | 16896.00 | 0.0 | 0.0 | 0.0 | 0.0 | 3.2 | 240.0 | 0.0 | 0.0 | 240.0 |
| 17A-19 | 30940.80 | 0.0 | 0.0 | 5.9 | 351.6 | 0.0 | 0.0 | 0.0 | 0.0 | 351.6 |
| 19-20 | 64046.40 | 0.0 | 0.0 | 12.1 | 727.8 | 0.0 | 0.0 | 0.0 | 0.0 | 727.8 |
| 20-22 | 26347.20 | 0.0 | 0.0 | 5.0 | 299.4 | 0.0 | 0.0 | 0.0 | 0.0 | 299.4 |
| 22-26 | 71596.80 | 0.0 | 0.0 | 13.6 | 813.6 | 0.0 | 0.0 | 0.0 | 0.0 | 813.6 |
| 26-27 | 42081.60 | 0.0 | 0.0 | 8.0 | 478.2 | 0.0 | 0.0 | 0.0 | 0.0 | 478.2 |
| 27-28 | 34003.20 | 0.0 | 0.0 | 6.4 | 386.4 | 0.0 | 0.0 | 0.0 | 0.0 | 386.4 |
| 28-29 | 13728.00 | 0.0 | 0.0 | 2.6 | 156.0 | 0.0 | 0.0 | 0.0 | 0.0 | 156.0 |
| 29-30 | 40656.00 | 0.0 | 0.0 | 7.7 | 462.0 | 0.0 | 0.0 | 0.0 | 0.0 | 462.0 |
| Total (ft) | 710,530 | 36.8 | 2207.4 | 61.3 | 3675.0 | 32.2 | 2418.0 | 4.3 | 368.9 | |
| Total (miles) | 134.57 | | | | | | | | | |

FINANCIAL TOTAL: 8669.3

| FINANCIAL CONSIDERATIONS | |
|--------------------------|------------------------------------|
| F-1 | Construction Cost - Loading Zone 1 |
| F-2 | Construction Cost - Loading Zone 2 |
| F-3 | Construction Cost - Loading Zone 3 |
| F-4 | Construction Cost - Loading Zone 4 |

Appendix B

PRELIMINARY DESIGN DOCUMENTATION

- Exhibit B-1 Key Design Values
- Exhibit B-2 Sample Double-Loop Galloping Run
- Exhibit B-3 Sample Right-of-Way Width Based on Blowout for Given Span
- Exhibit B-4 Sample Right-of-Way Width Based on Blowout for 125' Width
- Exhibit B-5 Sample Right-of-Way Width Based on Danger Tree Height and Slope for H-Frame or X-Frame Structures
- Exhibit B-6 Sample Right-of-Way Width Based on Danger Tree Height and Slope for Single Pole Structures
- Exhibit B-7 Sample Maximum Right-of-Way Width Based on Blowout for Maximum Span
- Exhibit B-8 Sample Wood H-Frame Maximum Span Based on Pole Strength
- Exhibit B-9 Sample Comparison of Maximum Span Due to Clearance and Maximum Horizontal Spans
- Exhibit B-10 Sample Computation of Light Duty Steel Pole Class H-Frame Maximum Spans Using Wood Pole Computations and Steel Overload Factors
- Exhibit B-11 Sample Comparison of Maximum Span Due to Clearance and Maximum Horizontal Spans, Steel H-Frames
- Exhibit B-12 Sample Point Load Computations
- Exhibit B-13 Sample Buckling Analysis of Meyer LD Series Steel Poles
- Exhibit B-14 Sample Comparison of Maximum Spans Due to Clearance, Flat Configuration
- Exhibit B-15 Single Wood Pole Sizing and Optimum Span Selection Computation
- Exhibit B-16 Sample Pile Foundation Sizing

DATASUMM.XLS

Alaska Energy Authority
 Copper Valley Intertie Feasibility Study
 Key Conductor Design Values for Checking
 8/12/93

| | <i>Dove</i> | <i>Teal</i> | <i>Teal/SSAC</i> | <i>T2Linnet</i> | <i>37No9 AW</i> |
|-----------------------|-------------|-------------|------------------|-----------------|-----------------|
| LOADING ZONE 1 | | | | | |
| Ruling Span | 1000 | 1000 | 1000 | 1000 | na |
| Tension NESC | 10256 | 13278 | 12802 | 14780 | na |
| Tension WIND | 10172 | 13056 | 12708 | 15043 | na |
| Tension ICE | 12809 | 15924 | 14514 | 17177 | na |
| Tension COMB | 18080 | 21712 | 19857 | 22028 | na |
| Sag NESC Ice | 33.92 | 26.93 | 28.11 | 28.59 | na |
| Sag Max Temp | 31.32 | 24.64 | 24.89 | 26.63 | na |
| Sag 6 PSF Wind | 29.89 | 22.91 | 23.09 | 25.66 | na |
| Sag XTM Wind | 34.85 | 28.07 | 30.49 | 30.43 | na |
| LOADING ZONE 2 | | | | | |
| Ruling Span | 1200 | 1200 | 1200 | 1200 | na |
| Tension NESC | 7959 | 11926 | 11605 | 11258 | na |
| Tension WIND | 8117 | 11995 | 11692 | 12098 | na |
| Tension ICE | 15820 | 20392 | 18620 | 19740 | na |
| Tension COMB | 11248 | 15346 | 14211 | 14890 | na |
| Sag NESC Ice | 53.83 | 40.30 | 42.43 | 46.01 | na |
| Sag Max Temp | 52.65 | 37.99 | 39.32 | 44.47 | na |
| Sag 6 PSF Wind | 51.04 | 35.97 | 37.24 | 43.17 | na |
| Sag XTM Wind | 54.17 | 40.96 | 44.77 | 47.20 | na |
| LOADING ZONE 3 | | | | | |
| Ruling Span | 1100 | 1100 | 1100 | 1100 | na |
| Tension NESC | 8373 | 11569 | 12347 | 11968 | na |
| Tension WIND | 8505 | 11619 | 12397 | 12701 | na |
| Tension ICE | 15820 | 19582 | 18260 | 19740 | na |
| Tension COMB | 15976 | 19670 | 18757 | 19823 | na |
| Sag NESC Ice | 44.00 | 34.83 | 34.14 | 37.28 | na |
| Sag Max Temp | 42.98 | 33.08 | 30.78 | 36.04 | na |
| Sag 6 PSF Wind | 41.41 | 31.14 | 28.84 | 34.83 | na |
| Sag XTM Wind | 44.37 | 35.40 | 36.44 | 38.52 | na |
| LOADING ZONE 4 | | | | | |
| Ruling Span | 900 | 1000 | 1000 | na | 1000 |
| Tension NESC | 5121 | 8132 | 7413 | na | 18501 |
| Tension WIND | 7433 | 11050 | 10023 | na | 19397 |
| Tension ICE | 15751 | 21000 | 18620 | na | 32422 |
| Tension COMB | 18080 | 23688 | 21261 | na | 35628 |
| Sag NESC Ice | 47.58 | 42.19 | 46.76 | na | 17.09 |
| Sag Max Temp | 46.97 | 41.33 | 46.43 | na | 18.18 |
| Sag 6 PSF Wind | 45.62 | 39.50 | 44.66 | na | 14.30 |
| Sag XTM Wind | 50.19 | 45.94 | 50.81 | na | 20.12 |

Work Order Account ::WW-1559-HA1-AC
 Client:.....:Alaska Energy Authority
 Project:.....:Copper Valley Intertie
 Feature:.....: Double Loop Galloping
 Item:.....: Teal 605 kcmil 30/19,LZ3
 By:.....: PED 8/11/93
 Check:.....: *JEH* 11/5/93

The following computations generate and evaluate galloping ellipses for double loop galloping. Based on REA 62-1 eqs.

Step 1 - Define system units to be used

Coordinate system center

$X_{cen} := 0\text{-ft}$ $Y_{cen} := 0\text{-ft}$

Select direction of wind

1 means wind to right, -1 means wind to left

$DIR := -1$

Step 2 - Define line characteristics

Following values at 1/2 inch radial ice 30 degrees F

| Tensions | Unit Weight | Diameter |
|----------------------------------|---|-----------------------------|
| $T_{ph} := 8159\text{-lb}$ | $w_{ph} := 1.869 \cdot \frac{\text{lb}}{\text{ft}}$ | $d_{ph} := 1.994\text{-in}$ |
| $T_{sw} := 0\text{-lb}$ | $w_{sw} := 0 \cdot \frac{\text{lb}}{\text{ft}}$ | $d_{sw} := 0\text{-in}$ |
| $RUL_{sp} := 1300\text{-ft}$ | $WIND := 6 \cdot \frac{\text{lb}}{\text{ft}^2}$ | |

Step 2a - Specify the number of wires on line by entering 1 (exists) or 0 (nada)

| | | |
|-----------|---|--------------|
| $LINE :=$ | 0 | Shieldwire 1 |
| | 0 | Shieldwire 2 |
| | 1 | Phase 1 |
| | 1 | Phase 2 |
| | 1 | Phase 3 |
| | 0 | Phase 4 |
| | 0 | Phase 5 |
| | 0 | Phase 6 |

Step 3 - Input coordinates of attachment points for phases and shieldwires

Note the coordinates are for either the end of the HLP, Vstring, or otherwise restrained conductor and for the point of insulator attachment for a tangent suspension assembly. Enter the coordinates relative to the chosen coordinate system center chosen in Step 1. Note that the Y dimension is arbitrary and can be altered to fit plot.

| | | | | |
|--------|---|--------|---|---|
| $X :=$ | $\begin{matrix} 0 \cdot \text{ft} \\ 0 \cdot \text{ft} \\ -15 \cdot \text{ft} \\ 0 \cdot \text{ft} \\ 15 \cdot \text{ft} \\ 0 \cdot \text{ft} \\ 0 \cdot \text{ft} \\ 0 \cdot \text{ft} \end{matrix}$ | $Y :=$ | $\begin{matrix} 0 \cdot \text{ft} \\ 0 \cdot \text{ft} \\ 90 \cdot \text{ft} \\ 90 \cdot \text{ft} \\ 90 \cdot \text{ft} \\ 0 \cdot \text{ft} \\ 0 \cdot \text{ft} \\ 0 \cdot \text{ft} \end{matrix}$ | <p>Shieldwire 1</p> <p>Shieldwire 2</p> <p>Phase 1</p> <p>Phase 2</p> <p>Phase 3</p> <p>Phase 4</p> <p>Phase 5</p> <p>Phase 6</p> |
|--------|---|--------|---|---|

Step 4 - Calculate ruling span sag for conductors and shieldwire

$$SAG_{ph} := \frac{T_{ph}}{w_{ph}} \cdot \left(\cosh \left(w_{ph} \cdot \frac{RUL_{sp}}{T_{ph} \cdot 2} \right) - 1 \right) \quad SAG_{ph} = 48.481 \cdot \text{ft}$$

$$SAG_{sw} := \frac{T_{sw}}{w_{sw}} \cdot \left(\cosh \left(w_{sw} \cdot \frac{RUL_{sp}}{T_{sw} \cdot 2} \right) - 1 \right) \quad SAG_{sw} = 0 \cdot \text{ft}$$

Step 5 - Calculate blowout angle of wires under wind

$$PHI_{ph} := DIR \cdot \text{atan} \left(\frac{WIND \cdot d_{ph}}{w_{ph}} \right) \quad PHI_{ph} = -28.077 \cdot \text{deg}$$

$$PHI_{sw} := DIR \cdot \text{atan} \left(\frac{WIND \cdot d_{sw}}{w_{sw}} \right) \quad PHI_{sw} = 0 \cdot \text{deg}$$

Step 6 - Calculate factor a in REA 62-1

$$a_{ph} := \sqrt{\left[\left(\frac{RUL_{sp}}{2} \right)^2 + SAG_{ph}^2 \right]} \quad a_{ph} = 651.805 \cdot \text{ft}$$

$$a_{sw} := \sqrt{\left[\left(\frac{RUL_{sp}}{2} \right)^2 + SAG_{sw}^2 \right]} \quad a_{sw} = 650 \cdot \text{ft}$$

Step 6 - Calculate the Double Loop Major Axis M

$$M_{ph} := 1 \cdot \text{ft} + \sqrt{\frac{3 \cdot a_{ph} \cdot \left(\frac{8 \cdot SAG_{ph}^2}{RUL_{sp} \cdot 3} + RUL_{sp} - 2 \cdot a_{ph} \right)}{8}} \quad M_{ph} = 18.2 \cdot \text{ft}$$

$$M_{sw} := 1 \cdot ft + \sqrt{\frac{3 \cdot a_{sw} \cdot \left(\frac{8 \cdot SAG_{sw}^2}{RUL_{sp} \cdot 3} + RUL_{sp} \right) \cdot ft}{8}}$$

Step 7 - Calculate the Double Loop distance B from ellipse focus to ellipse on major axis

$$\begin{aligned} B_{ph} &:= 0.20 \cdot M_{ph} & B_{ph} &= 3.64 \cdot ft \\ B_{sw} &:= 0.20 \cdot M_{sw} & B_{sw} &= 0.2 \cdot ft \end{aligned}$$

Step 8 - Calculate the Double Loop Minor Axis D

$$\begin{aligned} D_{ph} &:= 2 \cdot \sqrt{(M_{ph} - 1 \cdot ft) \cdot ft} & D_{ph} &= 8.295 \cdot ft \\ D_{sw} &:= 2 \cdot \sqrt{(M_{sw} - 1 \cdot ft) \cdot ft} & D_{sw} &= 0 \cdot ft \end{aligned}$$

Step 9 - Input insulator lengths. Shieldwire, V-Strings and post insulators L=0. Compute total length of insulator string and sag.

Input

$$L := \begin{bmatrix} 0 \cdot ft \\ 0 \cdot ft \\ 5 \cdot ft \\ 5 \cdot ft \\ 5 \cdot ft \\ 5 \cdot ft \\ 0 \cdot ft \\ 0 \cdot ft \\ 0 \cdot ft \end{bmatrix} \quad SAG := \begin{bmatrix} SAG_{sw} \\ SAG_{sw} \\ SAG_{ph} \\ SAG_{ph} \\ SAG_{ph} \\ SAG_{ph} \\ SAG_{ph} \\ SAG_{ph} \\ SAG_{ph} \end{bmatrix} \quad PHI := \begin{bmatrix} PHI_{sw} \\ PHI_{sw} \\ PHI_{sw} \\ PHI_{sw} \\ PHI_{sw} \\ PHI_{sw} \\ PHI_{sw} \\ PHI_{sw} \\ PHI_{sw} \end{bmatrix}$$

Compute length from supports to ellipse focus L

$$L := \overrightarrow{(L + (LINE \cdot SAG))} \quad L = \begin{bmatrix} 0 \\ 0 \\ 53.481 \\ 53.481 \\ 53.481 \\ 0 \\ 0 \\ 0 \end{bmatrix} \cdot ft$$

Step 10 - Compute the coordinates of the lissajous ellipse foci

$$PHI := \overrightarrow{(LINE \cdot PHI)}$$

$$X_f := \overrightarrow{(X + L \cdot \sin(PHI))} \quad Y_f := \overrightarrow{(Y - (L \cdot \cos(PHI)))}$$

$$\begin{bmatrix} 0 \end{bmatrix} \quad \begin{bmatrix} 0 \end{bmatrix}$$

$$X_f = \begin{bmatrix} -15 \\ 0 \\ 15 \\ 0 \\ 0 \\ 0 \\ 0 \end{bmatrix} \cdot \text{ft} \qquad Y_f = \begin{bmatrix} 36.519 \\ 36.519 \\ 36.519 \\ 0 \\ 0 \\ 0 \\ 0 \end{bmatrix} \cdot \text{ft}$$

Step 11 - A is the semi major axis, E the eccentricity of the ellipse

$$A_{sw} := \frac{M_{sw}}{2} \qquad E_{sw} := 1 - 2 \cdot \frac{B_{sw}}{M_{sw}}$$

$$A_{ph} := \frac{M_{ph}}{2} \qquad E_{ph} := 1 - 2 \cdot \frac{B_{ph}}{M_{ph}}$$

Step 12 - Express the polar equation for the lissajous ellipse as $r(A,E)$.

Define the number of angle increments N and the angle increments

$$N := 200 \qquad i := 0..N \qquad \theta_i := i \cdot 2 \cdot \frac{\pi}{N} \qquad k := 0 \cdot \text{ft} .. 65 \cdot \text{ft}$$

k defines centerline of structure for plot

Express the polar equation for an ellipse as a vector for each ellipse

$$r_{sw} := \left[A_{sw} \cdot \frac{(1 - E_{sw}^2)}{(1 - E_{sw} \cdot \cos(\theta))} \right] \qquad r_{ph} := \left[A_{ph} \cdot \frac{(1 - E_{ph}^2)}{(1 - E_{ph} \cdot \cos(\theta))} \right]$$

$$x_{sw} := \overrightarrow{(-r_{sw} \cdot \sin(\theta))} \qquad x_{ph} := \overrightarrow{(-r_{ph} \cdot \sin(\theta))}$$

$$y_{sw} := \overrightarrow{(r_{sw} \cdot \cos(\theta))} \qquad y_{ph} := \overrightarrow{(r_{ph} \cdot \cos(\theta))}$$

Now rotate and translate x,y to tilt ellipse through PHI/2

$$X_{sw} := \overrightarrow{\left(x_{sw} \cdot \cos\left(\frac{\text{PHI}_{sw}}{2}\right) + y_{sw} \cdot \sin\left(\frac{\text{PHI}_{sw}}{2}\right) \right)}$$

$$Y_{sw} := \overrightarrow{\left(-x_{sw} \cdot \sin\left(\frac{\text{PHI}_{sw}}{2}\right) + y_{sw} \cdot \cos\left(\frac{\text{PHI}_{sw}}{2}\right) \right)}$$

$$X_{ph} := \overrightarrow{\left(x_{ph} \cdot \cos\left(\frac{\text{PHI}_{ph}}{2}\right) + y_{ph} \cdot \sin\left(\frac{\text{PHI}_{ph}}{2}\right) \right)}$$

$$Y_{ph} := \overrightarrow{\left(-x_{ph} \cdot \sin\left(\frac{\text{PHI}_{ph}}{2}\right) + y_{ph} \cdot \cos\left(\frac{\text{PHI}_{ph}}{2}\right) \right)}$$

$$X_{sw0} := \overrightarrow{(X_{sw} + X_{f_{0,0}})}$$

$$X_{sw1} := \overrightarrow{(X_{sw} + X_{f_{1,0}})}$$

$$X_{ph1} := \overrightarrow{(X_{ph} + X_{f_{2,0}})}$$

$$X_{ph2} := \overrightarrow{(X_{ph} + X_{f_{3,0}})}$$

$$Y_{sw0} := \overrightarrow{(Y_{sw} + Y_{f_{0,0}})}$$

$$Y_{sw1} := \overrightarrow{(Y_{sw} + Y_{f_{1,0}})}$$

$$Y_{ph1} := \overrightarrow{(Y_{ph} + Y_{f_{2,0}})}$$

$$Y_{ph2} := \overrightarrow{(Y_{ph} + Y_{f_{3,0}})}$$

$$X_{ph3} := \overrightarrow{(X_{ph} + X_{f_{4,0}})}$$

$$X_{ph4} := \overrightarrow{(X_{ph} + X_{f_{5,0}})}$$

$$X_{ph5} := \overrightarrow{(X_{ph} + X_{f_{6,0}})}$$

$$X_{ph6} := \overrightarrow{(X_{ph} + X_{f_{7,0}})}$$


$$Y_{ph3} := \overrightarrow{(Y_{ph} + Y_{f_{4,0}})}$$

$$Y_{ph4} := \overrightarrow{(Y_{ph} + Y_{f_{5,0}})}$$

$$Y_{ph5} := \overrightarrow{(Y_{ph} + Y_{f_{6,0}})}$$

$$Y_{ph6} := \overrightarrow{(Y_{ph} + Y_{f_{7,0}})}$$

GRAPH OF GALLOPING ELLIPSES



21.0751

Blow Dove, xls

AEA COPPER VALLEY INTERTIE
 138 KV TRANSMISSION LINE
 CONDUCTOR BLOWOUT GUIDELINES
 Dove Conductor HF or XF construction
 PED 8/12/93

MODERATE WIND

ENTER UNIT WIND LOAD (PSF) 6 PSF
 ENTER CONDUCTOR DIAMETER 0.927 INCHES
 ENTER UNIT CONDUCTOR WEIGHT 0.766 LBS/FT
 CALC UNIT TRANSVERSE LOAD 0.4635 LBS/FT
 CALC BLOWOUT ANGLE 31.2 DEGREES
 ENTER NA FEET
 ENTER INSULATOR LENGTH 5.0 FEET
 ENTER STRUCTURE DEFLECTION 1.0 FEET

Note that numbers in italics are for input, linked to corresponding cells below on page 2.

| | LOADING ZONE 1 | | LOADING ZONE 2 | | LOADING ZONE 3 | | LOADING ZONE 4 | |
|-------|-----------------|------------|-----------------|------------|-----------------|------------|-----------------|------------|
| ENTER | STRUCTURE WIDTH | 34 FEET | STRUCTURE WIDTH | 36 FEET | STRUCTURE WIDTH | 36 FEET | STRUCTURE WIDTH | 38 FEET |
| ENTER | RULING SPAN - | 1000 | RULING SPAN - | 1200 | RULING SPAN - | 1100 | RULING SPAN - | 900 |
| ----- | | | | | | | | |
| ENTER | RS SAG WIND | 29.9 FEET | RS SAG WIND | 51.0 FEET | RS SAG WIND | 41.4 FEET | RS SAG WIND | 45.6 FEET |
| ENTER | MAXIMUM SPAN | 1200 FEET | MAXIMUM SPAN | 1400 FEET | MAXIMUM SPAN | 1300 FEET | MAXIMUM SPAN | 1100 FEET |
| CALC | MAX SPAN SAG | 43.0 FEET | MAX SPAN SAG | 69.5 FEET | MAX SPAN SAG | 57.8 FEET | MAX SPAN SAG | 68.1 FEET |
| CALC | ADD L1 | 48.0 FEET | ADD L1 | 74.5 FEET | ADD L1 | 62.8 FEET | ADD L1 | 73.1 FEET |
| CALC | BLOWOUT | 24.9 FEET | BLOWOUT | 38.6 FEET | BLOWOUT | 32.5 FEET | BLOWOUT | 37.9 FEET |
| ----- | | | | | | | | |
| CALC | INSULATOR SIDE | | INSULATOR SIDE | | INSULATOR SIDE | | INSULATOR SIDE | |
| CALC | CL-BLOWOUT | 42.9 FEET | CL-BLOWOUT | 57.6 FEET | CL-BLOWOUT | 51.5 FEET | CL-BLOWOUT | 57.9 FEET |
| ENTER | MARGIN | 10.0 FEET | MARGIN | 10.0 FEET | MARGIN | 10.0 FEET | MARGIN | 10.0 FEET |
| CALC | TOTAL WIDTH 1 | 52.9 FEET | TOTAL WIDTH 1 | 67.6 FEET | TOTAL WIDTH 1 | 61.5 FEET | TOTAL WIDTH 1 | 67.9 FEET |
| | ROW x 2 | 105.7 FEET | ROW x 2 | 135.1 FEET | ROW x 2 | 123.1 FEET | ROW x 2 | 135.7 FEET |

EXTREME WIND

ENTER UNIT WIND LOAD (PSF) 26 PSF
 ENTER CONDUCTOR DIAMETER 0.927 INCHES
 ENTER UNIT CONDUCTOR WEIGHT 0.766 LBS/FT
 CALC UNIT TRANSVERSE LOAD 2.009 LBS/FT
 CALC BLOWOUT ANGLE 69.1 DEGREES
 ENTER NA FEET
 ENTER INSULATOR LENGTH 5.0 FEET
 ENTER STRUCTURE DEFLECTION 4.0 FEET

| | LOADING ZONE 1 | | LOADING ZONE 2 | | LOADING ZONE 3 | | LOADING ZONE 4 | |
|-------|-----------------|------------|-----------------|------------|-----------------|------------|-----------------|------------|
| ENTER | STRUCTURE WIDTH | 34 FEET | STRUCTURE WIDTH | 36 FEET | STRUCTURE WIDTH | 36 FEET | STRUCTURE WIDTH | 38 FEET |
| ENTER | RULING SPAN - | 1000 | RULING SPAN - | 1200 | RULING SPAN - | 1100 | RULING SPAN - | 900 |
| ----- | | | | | | | | |
| ENTER | RS SAG WIND | 34.9 FEET | RS SAG WIND | 54.2 FEET | RS SAG WIND | 44.4 FEET | RS SAG WIND | 50.2 FEET |
| ENTER | MAXIMUM SPAN | 1200 FEET | MAXIMUM SPAN | 1400 FEET | MAXIMUM SPAN | 1300 FEET | MAXIMUM SPAN | 1100 FEET |
| CALC | MAX SPAN SAG | 50.2 FEET | MAX SPAN SAG | 73.7 FEET | MAX SPAN SAG | 62.0 FEET | MAX SPAN SAG | 75.0 FEET |
| CALC | ADD L1 | 55.2 FEET | ADD L1 | 78.7 FEET | ADD L1 | 67.0 FEET | ADD L1 | 80.0 FEET |
| CALC | BLOWOUT | 51.6 FEET | BLOWOUT | 73.6 FEET | BLOWOUT | 62.6 FEET | BLOWOUT | 74.7 FEET |
| ----- | | | | | | | | |
| CALC | INSULATOR SIDE | | INSULATOR SIDE | | INSULATOR SIDE | | INSULATOR SIDE | |
| CALC | CL-BLOWOUT | 72.6 FEET | CL-BLOWOUT | 95.6 FEET | CL-BLOWOUT | 84.6 FEET | CL-BLOWOUT | 97.7 FEET |
| ENTER | MARGIN | 0.0 FEET | MARGIN | 0.0 FEET | MARGIN | 0.0 FEET | MARGIN | 0.0 FEET |
| CALC | TOTAL WIDTH 1 | 72.6 FEET | TOTAL WIDTH 1 | 95.6 FEET | TOTAL WIDTH 1 | 84.6 FEET | TOTAL WIDTH 1 | 97.7 FEET |
| | ROW x 2 | 145.1 FEET | ROW x 2 | 191.1 FEET | ROW x 2 | 169.1 FEET | ROW x 2 | 195.5 FEET |

USE ONLY XTH WIND 40 PSF

AEA COPPER VALLEY INTERTIE
 138 KV TRANSMISSION LINE
 CONDUCTOR BLOWOUT GUIDELINES
 Teal SSAC Conductor HF or XF construction
 PED 8/12/93

MODERATE WIND

ENTER UNIT WIND LOAD (PSF) 6 PSF
 ENTER CONDUCTOR DIAMETER 0.994 INCHES
 ENTER UNIT CONDUCTOR WEIGHT 0.939 LBS/FT
 CALC UNIT TRANSVERSE LOAD 0.497 LBS/FT
 CALC BLOWOUT ANGLE 27.9 DEGREES
 ENTER NA FEET
 ENTER INSULATOR LENGTH 5.0 FEET
 ENTER STRUCTURE DEFLECTION 1.0 FEET

Note that numbers in italics are for input, linked to corresponding cells below on page 2.

| | | | | | | | | |
|-------|-----------------|-----------|-----------------|------------|-----------------|-----------|-----------------|------------|
| | LOADING ZONE 1 | | LOADING ZONE 2 | | LOADING ZONE 3 | | LOADING ZONE 4 | |
| | STRUCTURE WIDTH | 32 FEET | STRUCTURE WIDTH | 32 FEET | STRUCTURE WIDTH | 30 FEET | STRUCTURE WIDTH | 34 FEET |
| ENTER | RULING SPAN - | 1000 | RULING SPAN - | 1200 | RULING SPAN - | 1100 | RULING SPAN - | 1000 |
| ----- | | | | | | | | |
| ENTER | RS SAG WIND | 23.1 FEET | RS SAG WIND | 37.2 FEET | RS SAG WIND | 28.8 FEET | RS SAG WIND | 72.8 FEET |
| ENTER | MAXIMUM SPAN | 1200 FEET | MAXIMUM SPAN | 1400 FEET | MAXIMUM SPAN | 1300 FEET | MAXIMUM SPAN | 1200 FEET |
| CALC | MAX SPAN SAG | 33.2 FEET | MAX SPAN SAG | 50.7 FEET | MAX SPAN SAG | 40.3 FEET | MAX SPAN SAG | 104.8 FEET |
| CALC | ADD L1 | 38.2 FEET | ADD L1 | 55.7 FEET | ADD L1 | 45.3 FEET | ADD L1 | 109.8 FEET |
| CALC | BLOWOUT | 17.9 FEET | BLOWOUT | 26.1 FEET | BLOWOUT | 21.2 FEET | BLOWOUT | 51.4 FEET |
| | INSULATOR SIDE | | INSULATOR SIDE | | INSULATOR SIDE | | INSULATOR SIDE | |
| CALC | CL-BLOWOUT | 34.9 FEET | CL-BLOWOUT | 43.1 FEET | CL-BLOWOUT | 37.2 FEET | CL-BLOWOUT | 69.4 FEET |
| ENTER | MARGIN | 10.0 FEET | MARGIN | 10.0 FEET | MARGIN | 10.0 FEET | MARGIN | 10.0 FEET |
| CALC | TOTAL WIDTH 1 | 44.9 FEET | TOTAL WIDTH 1 | 53.1 FEET | TOTAL WIDTH 1 | 47.2 FEET | TOTAL WIDTH 1 | 79.4 FEET |
| | ROW x 2 | 89.8 FEET | ROW x 2 | 106.1 FEET | ROW x 2 | 94.4 FEET | ROW x 2 | 158.7 FEET |

EXTREME WIND

ENTER UNIT WIND LOAD (PSF) 26 PSF
 ENTER CONDUCTOR DIAMETER 0.994 INCHES
 ENTER UNIT CONDUCTOR WEIGHT 0.9395 LBS/FT
 CALC UNIT TRANSVERSE LOAD 2.154 LBS/FT
 CALC BLOWOUT ANGLE 66.4 DEGREES
 ENTER NA FEET
 ENTER INSULATOR LENGTH 5.0 FEET
 ENTER STRUCTURE DEFLECTION 4.0 FEET

| | | | | | | | | |
|-------|-----------------|------------|-----------------|------------|-----------------|------------|-----------------|------------|
| | LOADING ZONE 1 | | LOADING ZONE 2 | | LOADING ZONE 3 | | LOADING ZONE 4 | |
| | STRUCTURE WIDTH | 32 FEET | STRUCTURE WIDTH | 32 FEET | STRUCTURE WIDTH | 30 FEET | STRUCTURE WIDTH | 34 FEET |
| ENTER | RULING SPAN - | 1000 | RULING SPAN - | 1200 | RULING SPAN - | 1100 | RULING SPAN - | 1000 |
| ----- | | | | | | | | |
| ENTER | RS SAG WIND | 30.5 FEET | RS SAG WIND | 44.8 FEET | RS SAG WIND | 44.4 FEET | RS SAG WIND | 78.2 FEET |
| ENTER | MAXIMUM SPAN | 1200 FEET | MAXIMUM SPAN | 1400 FEET | MAXIMUM SPAN | 1300 FEET | MAXIMUM SPAN | 1200 FEET |
| CALC | MAX SPAN SAG | 43.9 FEET | MAX SPAN SAG | 60.9 FEET | MAX SPAN SAG | 62.0 FEET | MAX SPAN SAG | 112.6 FEET |
| CALC | ADD L1 | 48.9 FEET | ADD L1 | 65.9 FEET | ADD L1 | 67.0 FEET | ADD L1 | 117.6 FEET |
| CALC | BLOWOUT | 44.8 FEET | BLOWOUT | 60.4 FEET | BLOWOUT | 61.4 FEET | BLOWOUT | 107.8 FEET |
| | INSULATOR SIDE | | INSULATOR SIDE | | INSULATOR SIDE | | INSULATOR SIDE | |
| CALC | CL-BLOWOUT | 64.8 FEET | CL-BLOWOUT | 80.4 FEET | CL-BLOWOUT | 80.4 FEET | CL-BLOWOUT | 128.8 FEET |
| ENTER | MARGIN | 0.0 FEET | MARGIN | 0.0 FEET | MARGIN | 0.0 FEET | MARGIN | 0.0 FEET |
| CALC | TOTAL WIDTH 1 | 64.8 FEET | TOTAL WIDTH 1 | 80.4 FEET | TOTAL WIDTH 1 | 80.4 FEET | TOTAL WIDTH 1 | 128.8 FEET |
| | ROW x 2 | 129.7 FEET | ROW x 2 | 160.9 FEET | ROW x 2 | 160.8 FEET | ROW x 2 | 257.6 FEET |

USE ONLY XTM WIND 40 PSF

Blow 2, XLS

AEA COPPER VALLEY INTERTIE
 138 KV TRANSMISSION LINE
 CONDUCTOR BLOWOUT GUIDELINES
 T2 Linnet conductor HF or XF construction
 PED 8/12/93

MODERATE WIND

ENTER UNIT WIND LOAD (PSF) 6 PSF
 ENTER CONDUCTOR DIAMETER 1.18 INCHES
 ENTER UNIT CONDUCTOR WEIGHT 0.926 LBS/FT
 CALC UNIT TRANSVERSE LOAD 0.59 LBS/FT
 CALC BLOWOUT ANGLE 32.5 DEGREES
 ENTER NA FEET
 ENTER INSULATOR LENGTH 5.0 FEET
 ENTER STRUCTURE DEFLECTION 1.0 FEET

Note that numbers in italics are for input, linked to corresponding cells below on page 2.

| | | LOADING ZONE 1 | | LOADING ZONE 2 | | LOADING ZONE 3 | | T2 not appropriate for L24 LOADING ZONE 4 | |
|-------|---------------|-----------------|---------------|-----------------|---------------|-----------------|---------------|--|---------------|
| | | STRUCTURE WIDTH | RULING SPAN = | STRUCTURE WIDTH | RULING SPAN = | STRUCTURE WIDTH | RULING SPAN = | STRUCTURE WIDTH | RULING SPAN = |
| ENTER | | 28 FEET | 1000 | 30 FEET | 1200 | 32 FEET | 1100 | 0 FEET | 1000 |
| ENTER | RS SAG WIND | 25.7 FEET | | 43.2 FEET | | 34.8 FEET | | 0.0 FEET | |
| ENTER | MAXIMUM SPAN | 1200 FEET | | 1400 FEET | | 1300 FEET | | 1200 FEET | |
| CALC | MAX SPAN SAG | 37.0 FEET | | 58.8 FEET | | 48.6 FEET | | 0.0 FEET | |
| CALC | ADD L1 | 42.0 FEET | | 63.8 FEET | | 53.6 FEET | | 5.0 FEET | |
| CALC | BLOWOUT | 22.5 FEET | | 34.3 FEET | | 28.8 FEET | | 2.7 FEET | |
| | | INSULATOR SIDE | | INSULATOR SIDE | | INSULATOR SIDE | | INSULATOR SIDE | |
| CALC | CL-BLOWOUT | 37.5 FEET | | 50.3 FEET | | 45.8 FEET | | 3.7 FEET | |
| ENTER | MARGIN | 10.0 FEET | | 10.0 FEET | | 10.0 FEET | | 10.0 FEET | |
| CALC | TOTAL WIDTH 1 | 47.5 FEET | | 60.3 FEET | | 55.8 FEET | | 13.7 FEET | |
| | ROW x 2 | 95.1 FEET | | 120.5 FEET | | 111.7 FEET | | 27.4 FEET | |

EXTREME WIND

ENTER UNIT WIND LOAD (PSF) 26 PSF
 ENTER CONDUCTOR DIAMETER 1.18 INCHES
 ENTER UNIT CONDUCTOR WEIGHT 0.926 LBS/FT
 CALC UNIT TRANSVERSE LOAD 2.557 LBS/FT
 CALC BLOWOUT ANGLE 70.1 DEGREES
 ENTER NA FEET
 ENTER INSULATOR LENGTH 5.0 FEET
 ENTER STRUCTURE DEFLECTION 4.0 FEET

USE ONLY XTM WIND 40 PSF

| | | LOADING ZONE 1 | | LOADING ZONE 2 | | LOADING ZONE 3 | | USE ONLY XTM WIND 40 PSF LOADING ZONE 4 | |
|-------|---------------|-----------------|---------------|-----------------|---------------|-----------------|---------------|--|---------------|
| | | STRUCTURE WIDTH | RULING SPAN = | STRUCTURE WIDTH | RULING SPAN = | STRUCTURE WIDTH | RULING SPAN = | STRUCTURE WIDTH | RULING SPAN = |
| ENTER | | 28 FEET | 1000 | 30 FEET | 1200 | 32 FEET | 1100 | 0 FEET | 1000 |
| ENTER | RS SAG WIND | 30.4 FEET | | 47.2 FEET | | 38.5 FEET | | 78.2 FEET | |
| ENTER | MAXIMUM SPAN | 1200 FEET | | 1400 FEET | | 1300 FEET | | 1200 FEET | |
| CALC | MAX SPAN SAG | 43.8 FEET | | 64.2 FEET | | 53.8 FEET | | 112.6 FEET | |
| CALC | ADD L1 | 48.8 FEET | | 69.2 FEET | | 58.8 FEET | | 117.6 FEET | |
| CALC | BLOWOUT | 45.9 FEET | | 65.1 FEET | | 55.3 FEET | | 110.6 FEET | |
| | | INSULATOR SIDE | | INSULATOR SIDE | | INSULATOR SIDE | | INSULATOR SIDE | |
| CALC | CL-BLOWOUT | 63.9 FEET | | 84.1 FEET | | 75.3 FEET | | 114.6 FEET | |
| ENTER | MARGIN | 0.0 FEET | | 0.0 FEET | | 0.0 FEET | | 0.0 FEET | |
| CALC | TOTAL WIDTH 1 | 63.9 FEET | | 84.1 FEET | | 75.3 FEET | | 114.6 FEET | |
| | ROW x 2 | 127.8 FEET | | 168.2 FEET | | 150.6 FEET | | 229.2 FEET | |

AEA COPPER VALLEY INTERTIE
 138 KV TRANSMISSION LINE
 CONDUCTOR BLOWOUT GUIDELINES
 Dove Conductor HF or XF construction
 PED 8/12/93

MODERATE WIND

ENTER UNIT WIND LOAD (PSF) 6 PSF
 ENTER CONDUCTOR DIAMETER 0.927 INCHES
 ENTER UNIT CONDUCTOR WEIGHT 0.766 LBS/FT
 CALC UNIT TRANSVERSE LOAD 0.4635 LBS/FT
 CALC BLOWOUT ANGLE 31.2 DEGREES
 ENTER NA FEET
 ENTER INSULATOR LENGTH 5.0 FEET
 ENTER STRUCTURE DEFLECTION 1.0 FEET

Note that numbers in italics are for input, linked to corresponding cells below on page 2.

| | | | | | | | | |
|-------|-----------------|------------|-----------------|------------|-----------------|------------|-----------------|------------|
| | LOADING ZONE 1 | | LOADING ZONE 2 | | LOADING ZONE 3 | | LOADING ZONE 4 | |
| ENTER | STRUCTURE WIDTH | 34 FEET | STRUCTURE WIDTH | 36 FEET | STRUCTURE WIDTH | 36 FEET | STRUCTURE WIDTH | 38 FEET |
| | RULING SPAN = | 1000 | RULING SPAN = | 1200 | RULING SPAN = | 1100 | RULING SPAN = | 900 |
| ----- | | | | | | | | |
| ENTER | RS SAG WIND | 29.9 FEET | RS SAG WIND | 51.0 FEET | RS SAG WIND | 41.4 FEET | RS SAG WIND | 45.6 FEET |
| ENTER | MAXIMUM SPAN | 1425 FEET | MAXIMUM SPAN | 1300 FEET | MAXIMUM SPAN | 1325 FEET | MAXIMUM SPAN | 1015 FEET |
| CALC | MAX SPAN SAG | 60.7 FEET | MAX SPAN SAG | 59.9 FEET | MAX SPAN SAG | 60.1 FEET | MAX SPAN SAG | 58.0 FEET |
| CALC | ADD L1 | 65.7 FEET | ADD L1 | 64.9 FEET | ADD L1 | 65.1 FEET | ADD L1 | 63.0 FEET |
| CALC | BLOWOUT | 34.0 FEET | BLOWOUT | 33.6 FEET | BLOWOUT | 33.7 FEET | BLOWOUT | 32.6 FEET |
| | | | | | | | | |
| | INSULATOR SIDE | | INSULATOR SIDE | | INSULATOR SIDE | | INSULATOR SIDE | |
| CALC | CL-BLOWOUT | 52.0 FEET | CL-BLOWOUT | 52.6 FEET | CL-BLOWOUT | 52.7 FEET | CL-BLOWOUT | 52.6 FEET |
| ENTER | MARGIN | 10.0 FEET | MARGIN | 10.0 FEET | MARGIN | 10.0 FEET | MARGIN | 10.0 FEET |
| CALC | TOTAL WIDTH 1 | 62.0 FEET | TOTAL WIDTH 1 | 62.6 FEET | TOTAL WIDTH 1 | 62.7 FEET | TOTAL WIDTH 1 | 62.6 FEET |
| | ROW x 2 | 124.0 FEET | ROW x 2 | 125.2 FEET | ROW x 2 | 125.4 FEET | ROW x 2 | 125.3 FEET |

EXTREME WIND

ENTER UNIT WIND LOAD (PSF) 40 PSF
 ENTER CONDUCTOR DIAMETER 0.927 INCHES
 ENTER UNIT CONDUCTOR WEIGHT 0.766 LBS/FT
 CALC UNIT TRANSVERSE LOAD 3.090 LBS/FT
 CALC BLOWOUT ANGLE 76.1 DEGREES
 ENTER NA FEET
 ENTER INSULATOR LENGTH 5.0 FEET
 ENTER STRUCTURE DEFLECTION 4.0 FEET

USE ONLY XTM WIND 40 PSF

| | | | | | | | | |
|-------|-----------------|------------|-----------------|------------|-----------------|------------|-----------------|------------|
| | LOADING ZONE 1 | | LOADING ZONE 2 | | LOADING ZONE 3 | | LOADING ZONE 4 | |
| ENTER | STRUCTURE WIDTH | 34 FEET | STRUCTURE WIDTH | 36 FEET | STRUCTURE WIDTH | 36 FEET | STRUCTURE WIDTH | 38 FEET |
| | RULING SPAN = | 1000 | RULING SPAN = | 1200 | RULING SPAN = | 1100 | RULING SPAN = | 900 |
| ----- | | | | | | | | |
| ENTER | RS SAG WIND | 34.9 FEET | RS SAG WIND | 54.2 FEET | RS SAG WIND | 44.4 FEET | RS SAG WIND | 50.2 FEET |
| ENTER | MAXIMUM SPAN | 1060 FEET | MAXIMUM SPAN | 1010 FEET | MAXIMUM SPAN | 1025 FEET | MAXIMUM SPAN | 759 FEET |
| CALC | MAX SPAN SAG | 39.2 FEET | MAX SPAN SAG | 38.4 FEET | MAX SPAN SAG | 38.5 FEET | MAX SPAN SAG | 35.7 FEET |
| CALC | ADD L1 | 44.2 FEET | ADD L1 | 43.4 FEET | ADD L1 | 43.5 FEET | ADD L1 | 40.7 FEET |
| CALC | BLOWOUT | 42.9 FEET | BLOWOUT | 42.1 FEET | BLOWOUT | 42.2 FEET | BLOWOUT | 39.5 FEET |
| | | | | | | | | |
| | INSULATOR SIDE | | INSULATOR SIDE | | INSULATOR SIDE | | INSULATOR SIDE | |
| CALC | CL-BLOWOUT | 63.9 FEET | CL-BLOWOUT | 64.1 FEET | CL-BLOWOUT | 64.2 FEET | CL-BLOWOUT | 62.5 FEET |
| ENTER | MARGIN | 0.0 FEET | MARGIN | 0.0 FEET | MARGIN | 0.0 FEET | MARGIN | 0.0 FEET |
| CALC | TOTAL WIDTH 1 | 63.9 FEET | TOTAL WIDTH 1 | 64.1 FEET | TOTAL WIDTH 1 | 64.2 FEET | TOTAL WIDTH 1 | 62.5 FEET |
| | ROW x 2 | 127.7 FEET | ROW x 2 | 128.2 FEET | ROW x 2 | 128.5 FEET | ROW x 2 | 125.0 FEET |

AEA COPPER VALLEY INTERTIE
 138 KV TRANSMISSION LINE
 CONDUCTOR BLOWOUT GUIDELINES
 Teal Conductor HE or XF construction
 PED 8/12/93

MODERATE WIND

ENTER UNIT WIND LOAD (PSF) 6 PSF
 ENTER CONDUCTOR DIAMETER 0.994 INCHES
 ENTER UNIT CONDUCTOR WEIGHT 0.9395 LBS/FT
 CALC UNIT TRANSVERSE LOAD 0.497 LBS/FT
 CALC BLOWOUT ANGLE 27.9 DEGREES
 ENTER NA FEET
 ENTER INSULATOR LENGTH 5.0 FEET
 ENTER STRUCTURE DEFLECTION 1.0 FEET

Note that numbers in italics are for input, linked to corresponding cells below on page 2.

| | | | | | | | | |
|-------|-----------------|------------|-----------------|------------|-----------------|------------|-----------------|------------|
| | LOADING ZONE 1 | | LOADING ZONE 2 | | LOADING ZONE 3 | | LOADING ZONE 4 | |
| | STRUCTURE WIDTH | 30 FEET | STRUCTURE WIDTH | 32 FEET | STRUCTURE WIDTH | 32 FEET | STRUCTURE WIDTH | 32 FEET |
| ENTER | RULING SPAN - | 1000 | RULING SPAN - | 1200 | RULING SPAN - | 1100 | RULING SPAN - | 1000 |
| ----- | | | | | | | | |
| ENTER | RS SAG WIND | 22.9 FEET | RS SAG WIND | 36.0 FEET | RS SAG WIND | 43.7 FEET | RS SAG WIND | 39.5 FEET |
| ENTER | MAXIMUM SPAN | 1790 FEET | MAXIMUM SPAN | 1685 FEET | MAXIMUM SPAN | 1405 FEET | MAXIMUM SPAN | 1340 FEET |
| CALC | MAX SPAN SAG | 73.4 FEET | MAX SPAN SAG | 70.9 FEET | MAX SPAN SAG | 71.3 FEET | MAX SPAN SAG | 70.9 FEET |
| CALC | ADD LI | 78.4 FEET | ADD LI | 75.9 FEET | ADD LI | 76.3 FEET | ADD LI | 75.9 FEET |
| CALC | BLOWOUT | 36.7 FEET | BLOWOUT | 35.5 FEET | BLOWOUT | 35.7 FEET | BLOWOUT | 35.5 FEET |
| | INSULATOR SIDE | | INSULATOR SIDE | | INSULATOR SIDE | | INSULATOR SIDE | |
| CALC | CL-BLOWOUT | 52.7 FEET | CL-BLOWOUT | 52.5 FEET | CL-BLOWOUT | 52.7 FEET | CL-BLOWOUT | 52.5 FEET |
| ENTER | MARGIN | 10.0 FEET | MARGIN | 10.0 FEET | MARGIN | 10.0 FEET | MARGIN | 10.0 FEET |
| CALC | TOTAL WIDTH 1 | 62.7 FEET | TOTAL WIDTH 1 | 62.5 FEET | TOTAL WIDTH 1 | 62.7 FEET | TOTAL WIDTH 1 | 62.5 FEET |
| | ROW x 2 | 125.3 FEET | ROW x 2 | 125.0 FEET | ROW x 2 | 125.3 FEET | ROW x 2 | 125.0 FEET |

EXTREME WIND

ENTER UNIT WIND LOAD (PSF) 26 PSF
 ENTER CONDUCTOR DIAMETER 0.994 INCHES
 ENTER UNIT CONDUCTOR WEIGHT 0.9395 LBS/FT
 CALC UNIT TRANSVERSE LOAD 2.154 LBS/FT
 CALC BLOWOUT ANGLE 66.4 DEGREES
 ENTER NA FEET
 ENTER INSULATOR LENGTH 5.0 FEET
 ENTER STRUCTURE DEFLECTION 4.0 FEET

| | | | | | | | | |
|-------|-----------------|------------|-----------------|------------|-----------------|------------|-----------------|------------|
| | LOADING ZONE 1 | | LOADING ZONE 2 | | LOADING ZONE 3 | | LOADING ZONE 4 | |
| | STRUCTURE WIDTH | 30 FEET | STRUCTURE WIDTH | 32 FEET | STRUCTURE WIDTH | 32 FEET | STRUCTURE WIDTH | 32 FEET |
| ENTER | RULING SPAN - | 1000 | RULING SPAN - | 1200 | RULING SPAN - | 1100 | RULING SPAN - | 1000 |
| ----- | | | | | | | | |
| ENTER | RS SAG WIND | 28.1 FEET | RS SAG WIND | 41.0 FEET | RS SAG WIND | 35.4 FEET | RS SAG WIND | 45.9 FEET |
| ENTER | MAXIMUM SPAN | 1230 FEET | MAXIMUM SPAN | 1205 FEET | MAXIMUM SPAN | 1190 FEET | MAXIMUM SPAN | 950 FEET |
| CALC | MAX SPAN SAG | 42.5 FEET | MAX SPAN SAG | 41.3 FEET | MAX SPAN SAG | 41.4 FEET | MAX SPAN SAG | 41.5 FEET |
| CALC | ADD LI | 47.5 FEET | ADD LI | 46.3 FEET | ADD LI | 46.4 FEET | ADD LI | 46.5 FEET |
| CALC | BLOWOUT | 43.5 FEET | BLOWOUT | 42.4 FEET | BLOWOUT | 42.6 FEET | BLOWOUT | 42.6 FEET |
| | INSULATOR SIDE | | INSULATOR SIDE | | INSULATOR SIDE | | INSULATOR SIDE | |
| CALC | CL-BLOWOUT | 62.5 FEET | CL-BLOWOUT | 62.4 FEET | CL-BLOWOUT | 62.6 FEET | CL-BLOWOUT | 62.6 FEET |
| ENTER | MARGIN | 0.0 FEET | MARGIN | 0.0 FEET | MARGIN | 0.0 FEET | MARGIN | 0.0 FEET |
| CALC | TOTAL WIDTH 1 | 62.5 FEET | TOTAL WIDTH 1 | 62.4 FEET | TOTAL WIDTH 1 | 62.6 FEET | TOTAL WIDTH 1 | 62.6 FEET |
| | ROW x 2 | 125.0 FEET | ROW x 2 | 124.9 FEET | ROW x 2 | 125.1 FEET | ROW x 2 | 125.2 FEET |

AEA COPPER VALLEY INTERTIE
 138 KV TRANSMISSION LINE
 CONDUCTOR BLOWOUT GUIDELINES
 T2 Linnet conductor HF or XF construction
 PED 8/12/93

MODERATE WIND

ENTER UNIT WIND LOAD (PSF) 6 PSF
 ENTER CONDUCTOR DIAMETER 1.18 INCHES
 ENTER UNIT CONDUCTOR WEIGHT 0.926 LBS/FT
 CALC UNIT TRANSVERSE LOAD 0.59 LBS/FT
 CALC BLOWOUT ANGLE 32.5 DEGREES
 ENTER NA FEET
 ENTER INSULATOR LENGTH 5.0 FEET
 ENTER STRUCTURE DEFLECTION 1.0 FEET

Note that numbers in italics are for input, linked to corresponding cells below on page 2.

| | | | | | | | | |
|-------|-----------------|------------|-----------------|------------|-----------------|------------|----------------------------|-----------|
| | LOADING ZONE 1 | | LOADING ZONE 2 | | LOADING ZONE 3 | | T2 not appropriate for L24 | |
| ENTER | STRUCTURE WIDTH | 28 FEET | STRUCTURE WIDTH | 30 FEET | STRUCTURE WIDTH | 32 FEET | LOADING ZONE 4 | |
| | RULING SPAN = | 1000 | RULING SPAN = | 1200 | RULING SPAN = | 1100 | STRUCTURE WIDTH | |
| | ----- | | ----- | | ----- | | RULING SPAN = | |
| | | | | | | | 1000 | |
| ENTER | RS SAG WIND | 25.7 FEET | RS SAG WIND | 43.2 FEET | RS SAG WIND | 34.8 FEET | RS SAG WIND | 0.0 FEET |
| ENTER | MAXIMUM SPAN | 1590 FEET | MAXIMUM SPAN | 1450 FEET | MAXIMUM SPAN | 1455 FEET | MAXIMUM SPAN | 1200 FEET |
| CALC | MAX SPAN SAG | 64.9 FEET | MAX SPAN SAG | 63.0 FEET | MAX SPAN SAG | 60.9 FEET | MAX SPAN SAG | 0.0 FEET |
| CALC | ADD L1 | 69.9 FEET | ADD L1 | 68.0 FEET | ADD L1 | 65.9 FEET | ADD L1 | 5.0 FEET |
| CALC | BLOWOUT | 37.5 FEET | BLOWOUT | 36.6 FEET | BLOWOUT | 35.4 FEET | BLOWOUT | 2.7 FEET |
| | INSULATOR SIDE | | INSULATOR SIDE | | INSULATOR SIDE | | INSULATOR SIDE | |
| CALC | CL-BLOWOUT | 52.5 FEET | CL-BLOWOUT | 52.6 FEET | CL-BLOWOUT | 52.4 FEET | CL-BLOWOUT | 3.7 FEET |
| ENTER | MARGIN | 10.0 FEET | MARGIN | 10.0 FEET | MARGIN | 10.0 FEET | MARGIN | 10.0 FEET |
| CALC | TOTAL WIDTH 1 | 62.5 FEET | TOTAL WIDTH 1 | 62.6 FEET | TOTAL WIDTH 1 | 62.4 FEET | TOTAL WIDTH 1 | 13.7 FEET |
| | ROW x 2 | 125.1 FEET | ROW x 2 | 125.1 FEET | ROW x 2 | 124.9 FEET | ROW x 2 | 27.4 FEET |

EXTREME WIND

ENTER UNIT WIND LOAD (PSF) 26 PSF
 ENTER CONDUCTOR DIAMETER 1.18 INCHES
 ENTER UNIT CONDUCTOR WEIGHT 0.926 LBS/FT
 CALC UNIT TRANSVERSE LOAD 2.557 LBS/FT
 CALC BLOWOUT ANGLE 70.1 DEGREES
 ENTER NA FEET
 ENTER INSULATOR LENGTH 5.0 FEET
 ENTER STRUCTURE DEFLECTION 4.0 FEET

| | | | | | | | | |
|-------|-----------------|------------|-----------------|------------|-----------------|------------|--------------------------|------------|
| | LOADING ZONE 1 | | LOADING ZONE 2 | | LOADING ZONE 3 | | USE ONLY XTM WIND 40 PSF | |
| ENTER | STRUCTURE WIDTH | 28 FEET | STRUCTURE WIDTH | 30 FEET | STRUCTURE WIDTH | 32 FEET | LOADING ZONE 4 | |
| | RULING SPAN = | 1000 | RULING SPAN = | 1200 | RULING SPAN = | 1100 | STRUCTURE WIDTH | |
| | ----- | | ----- | | ----- | | RULING SPAN = | |
| | | | | | | | 1000 | |
| ENTER | RS SAG WIND | 30.4 FEET | RS SAG WIND | 47.2 FEET | RS SAG WIND | 38.5 FEET | RS SAG WIND | 78.2 FEET |
| ENTER | MAXIMUM SPAN | 1180 FEET | MAXIMUM SPAN | 1122 FEET | MAXIMUM SPAN | 1125 FEET | MAXIMUM SPAN | 855 FEET |
| CALC | MAX SPAN SAG | 42.4 FEET | MAX SPAN SAG | 41.3 FEET | MAX SPAN SAG | 40.3 FEET | MAX SPAN SAG | 57.2 FEET |
| CALC | ADD L1 | 47.4 FEET | ADD L1 | 46.3 FEET | ADD L1 | 45.3 FEET | ADD L1 | 62.2 FEET |
| CALC | BLOWOUT | 44.5 FEET | BLOWOUT | 43.5 FEET | BLOWOUT | 42.6 FEET | BLOWOUT | 58.5 FEET |
| | INSULATOR SIDE | | INSULATOR SIDE | | INSULATOR SIDE | | INSULATOR SIDE | |
| CALC | CL-BLOWOUT | 62.5 FEET | CL-BLOWOUT | 62.5 FEET | CL-BLOWOUT | 62.6 FEET | CL-BLOWOUT | 62.5 FEET |
| ENTER | MARGIN | 0.0 FEET | MARGIN | 0.0 FEET | MARGIN | 0.0 FEET | MARGIN | 0.0 FEET |
| CALC | TOTAL WIDTH 1 | 62.5 FEET | TOTAL WIDTH 1 | 62.5 FEET | TOTAL WIDTH 1 | 62.6 FEET | TOTAL WIDTH 1 | 62.5 FEET |
| | ROW x 2 | 125.1 FEET | ROW x 2 | 125.0 FEET | ROW x 2 | 125.2 FEET | ROW x 2 | 124.9 FEET |

AEA COPPER VALLEY INTERTIE
 138 KV TRANSMISSION LINE
 CONDUCTOR BLOWOUT GUIDELINES
 37 No 9 Alumoweld HF or XF construction
 PED 8/12/93

MODERATE WIND

ENTER UNIT WIND LOAD (PSF) 6 PSF
 ENTER CONDUCTOR DIAMETER 0.801 INCHES
 ENTER UNIT CONDUCTOR WEIGHT 1.108 LBS/FT
 CALC UNIT TRANSVERSE LOAD 0.4005 LBS/FT
 CALC BLOWOUT ANGLE 19.9 DEGREES
 ENTER NA FEET
 ENTER INSULATOR LENGTH 5.0 FEET
 ENTER STRUCTURE DEFLECTION 1.0 FEET

Note that numbers in italics are for input, linked to corresponding cells below on page 2.

| | | | | | | | | |
|-------|-----------------|----------------|-----------------|----------------|-----------------|----------------|-----------------|------------|
| | LOADING ZONE 1 | NOT APPLICABLE | LOADING ZONE 2 | NOT APPLICABLE | LOADING ZONE 3 | NOT APPLICABLE | LOADING ZONE 4 | |
| | STRUCTURE WIDTH | 32 FEET | STRUCTURE WIDTH | 32 FEET | STRUCTURE WIDTH | 32 FEET | STRUCTURE WIDTH | 30 FEET |
| ENTER | RULING SPAN - | 1000 | RULING SPAN - | 1200 | RULING SPAN - | 1100 | RULING SPAN - | 1000 |
| ----- | | | | | | | | |
| ENTER | RS SAG WIND | 29.9 FEET | RS SAG WIND | 51.0 FEET | RS SAG WIND | 41.4 FEET | RS SAG WIND | 14.3 FEET |
| ENTER | MAXIMUM SPAN | 1200 FEET | MAXIMUM SPAN | 1400 FEET | MAXIMUM SPAN | 1300 FEET | MAXIMUM SPAN | 2650 FEET |
| CALC | MAX SPAN SAG | 43.0 FEET | MAX SPAN SAG | 69.5 FEET | MAX SPAN SAG | 57.8 FEET | MAX SPAN SAG | 100.4 FEET |
| CALC | ADD L1 | 48.0 FEET | ADD L1 | 74.5 FEET | ADD L1 | 62.8 FEET | ADD L1 | 105.4 FEET |
| CALC | BLOWOUT | 16.3 FEET | BLOWOUT | 25.3 FEET | BLOWOUT | 21.4 FEET | BLOWOUT | 35.8 FEET |
| | INSULATOR SIDE | | INSULATOR SIDE | | INSULATOR SIDE | | INSULATOR SIDE | |
| CALC | CL-BLOWOUT | 33.3 FEET | CL-BLOWOUT | 42.3 FEET | CL-BLOWOUT | 38.4 FEET | CL-BLOWOUT | 51.8 FEET |
| ENTER | MARGIN | 10.0 FEET | MARGIN | 10.0 FEET | MARGIN | 10.0 FEET | MARGIN | 10.0 FEET |
| CALC | TOTAL WIDTH 1 | 43.3 FEET | TOTAL WIDTH 1 | 52.3 FEET | TOTAL WIDTH 1 | 48.4 FEET | TOTAL WIDTH 1 | 61.8 FEET |
| | ROW x 2 | NA FEET | ROW x 2 | NA FEET | ROW x 2 | NA FEET | ROW x 2 | 123.7 FEET |

EXTREME WIND

ENTER UNIT WIND LOAD (PSF) 40 PSF
 ENTER CONDUCTOR DIAMETER 0.801 INCHES
 ENTER UNIT CONDUCTOR WEIGHT 1.108 LBS/FT
 CALC UNIT TRANSVERSE LOAD 2.670 LBS/FT
 CALC BLOWOUT ANGLE 67.5 DEGREES
 ENTER NA FEET
 ENTER INSULATOR LENGTH 5.0 FEET
 ENTER STRUCTURE DEFLECTION 4.0 FEET

USE ONLY XTM WIND 40 PSF

| | | | | | | | | |
|-------|-----------------|----------------|-----------------|----------------|-----------------|----------------|-----------------|------------|
| | LOADING ZONE 1 | NOT APPLICABLE | LOADING ZONE 2 | NOT APPLICABLE | LOADING ZONE 3 | NOT APPLICABLE | LOADING ZONE 4 | |
| | STRUCTURE WIDTH | 32 FEET | STRUCTURE WIDTH | 32 FEET | STRUCTURE WIDTH | 32 FEET | STRUCTURE WIDTH | 30 FEET |
| ENTER | RULING SPAN - | 1000 | RULING SPAN - | 1200 | RULING SPAN - | 1100 | RULING SPAN - | 1000 |
| ----- | | | | | | | | |
| ENTER | RS SAG WIND | 34.9 FEET | RS SAG WIND | 54.2 FEET | RS SAG WIND | 44.4 FEET | RS SAG WIND | 20.1 FEET |
| ENTER | MAXIMUM SPAN | 1200 FEET | MAXIMUM SPAN | 1400 FEET | MAXIMUM SPAN | 1300 FEET | MAXIMUM SPAN | 1450 FEET |
| CALC | MAX SPAN SAG | 50.2 FEET | MAX SPAN SAG | 73.7 FEET | MAX SPAN SAG | 62.0 FEET | MAX SPAN SAG | 42.3 FEET |
| CALC | ADD L1 | 55.2 FEET | ADD L1 | 78.7 FEET | ADD L1 | 67.0 FEET | ADD L1 | 47.3 FEET |
| CALC | BLOWOUT | 51.0 FEET | BLOWOUT | 72.7 FEET | BLOWOUT | 61.9 FEET | BLOWOUT | 43.7 FEET |
| | INSULATOR SIDE | | INSULATOR SIDE | | INSULATOR SIDE | | INSULATOR SIDE | |
| CALC | CL-BLOWOUT | 71.0 FEET | CL-BLOWOUT | 92.7 FEET | CL-BLOWOUT | 81.9 FEET | CL-BLOWOUT | 62.7 FEET |
| ENTER | MARGIN | 0.0 FEET | MARGIN | 0.0 FEET | MARGIN | 0.0 FEET | MARGIN | 0.0 FEET |
| CALC | TOTAL WIDTH 1 | 71.0 FEET | TOTAL WIDTH 1 | 92.7 FEET | TOTAL WIDTH 1 | 81.9 FEET | TOTAL WIDTH 1 | 62.7 FEET |
| | ROW x 2 | NA FEET | ROW x 2 | NA FEET | ROW x 2 | NA FEET | ROW x 2 | 125.4 FEET |

only

Work Order Account :WW-1559-HA1-AC
 Client.....:ALASKA ENERGY AUTHORITY
 Project.....:SUTTON-GLENNALLEN 138kV INTERTIE
 Feature.....:Right of Way Width Computation
 Item:Hframe or Xframe Construction
 Calculated By/Date....:Paul Dorvel 7/21/93
 Checked By/Date.....:
 Approved By/Date

FIRST EXPRESS ROW WIDTH IN TERMS OF H (height of trees),w (width of ROW), delta (centerline to ROW edge distance), C (ground clearance), and P (percent slope). Solve equation symbolically.

$$H^2 - [(w - \delta)^2 + (C - (w - \delta) \cdot P)^2] \checkmark \quad \text{uphill side of right-of-way}$$

$$\left[\frac{1}{[2 \cdot (-1 - P^2)]} \cdot (-2 \cdot \delta - 2 \cdot C \cdot P - 2 \cdot P^2 \cdot \delta + 2 \cdot \sqrt{H^2 - C^2 + P^2 \cdot H^2}) \right]$$

$$\left[\frac{1}{[2 \cdot (-1 - P^2)]} \cdot (-2 \cdot \delta - 2 \cdot C \cdot P - 2 \cdot P^2 \cdot \delta - 2 \cdot \sqrt{H^2 - C^2 + P^2 \cdot H^2}) \right]$$

$$H1^2 - [(w1 - \delta)^2 + (C + P \cdot \delta + (w1 - \delta) \cdot P)^2] \checkmark \quad \text{downhill side of right-of-way}$$

$$\left[\frac{1}{[2 \cdot (-1 - P^2)]} \cdot (-2 \cdot \delta + 2 \cdot C \cdot P + 4 \cdot P^2 \cdot \delta + 2 \cdot \sqrt{-6 \cdot C \cdot P \cdot \delta - 9 \cdot P^2 \cdot \delta^2 + H1^2 - C^2 + P^2 \cdot H1^2}) \right]$$

$$\left[\frac{1}{[2 \cdot (-1 - P^2)]} \cdot (-2 \cdot \delta + 2 \cdot C \cdot P + 4 \cdot P^2 \cdot \delta - 2 \cdot \sqrt{-6 \cdot C \cdot P \cdot \delta - 9 \cdot P^2 \cdot \delta^2 + H1^2 - C^2 + P^2 \cdot H1^2}) \right]$$

Define variables
 W1 is downhill side, W2 is uphill side.

$i := 0, 1..6$ $k := 2, 3..9$ $\delta := 16 \cdot \text{ft}$
 $P_i := i \cdot 0.05$ $H_k := k \cdot 10 \cdot \text{ft}$ $C := 30 \cdot \text{ft}$

$$W1_{i,k} := \frac{1}{[2 \cdot [-1 - (P_i)^2]]} \cdot \left[-2 \cdot \delta + 2 \cdot C \cdot P_i + 4 \cdot (P_i)^2 \cdot \delta - 2 \cdot \sqrt{-6 \cdot C \cdot P_i \cdot \delta - 9 \cdot (P_i)^2 \cdot \delta^2 + (H_k)^2 - C^2 + (P_i)^2 \cdot (H_k)^2} \right] \checkmark$$

$$W2_{i,k} := \frac{1}{[2 \cdot [-1 - (P_i)^2]]} \cdot \left[-2 \cdot \delta - 2 \cdot C \cdot P_i - 2 \cdot (P_i)^2 \cdot \delta - 2 \cdot \sqrt{(H_k)^2 - C^2 + (P_i)^2 \cdot (H_k)^2} \right]$$

Set nonsensical solutions, i.e. imaginary, to 0

$$W1_{i,k} := \text{if} \left[(\text{Im}(W1_{i,k}) \neq 0 \cdot \text{ft}), 0 \cdot \text{ft}, W1_{i,k} \right]$$

$$W2_{i,k} := \text{if} \left[(\text{Im}(W2_{i,k}) \neq 0 \cdot \text{ft}), 0 \cdot \text{ft}, W2_{i,k} \right]$$

Combine matrices W1 and W2

$$WT := W1 + W2$$

$$WT := \text{augment}(P \cdot \text{ft}, WT)$$

Work Order Account :WW-1559-HA1-AC
 Client.....:ALASKA ENERGY AUTHORITY
 Project.....:SUTTON-GLENNALLEN 138kV INTERTIE
 Feature.....:Right of Way Width Computation
 Item:Single Pole Construction
 Calculated By/Date....:Paul Dorvel 7/21/93
 Checked By/Date.....:
 Approved By/Date

FIRST EXPRESS ROW WIDTH IN TERMS OF H (height of trees),w (width of ROW), delta (centerline to ROW edge distance), C (ground clearance), and P (percent slope). Solve equation symbolically.

$$H^2 - [(w - \delta)^2 + (C - (w - \delta) \cdot P)^2] \quad \text{uphill side of right-of-way}$$

$$\left[\frac{1}{[2 \cdot (-1 - P^2)]} \cdot (-2 \cdot \delta - 2 \cdot C \cdot P - 2 \cdot P^2 \cdot \delta + 2 \cdot \sqrt{H^2 - C^2 + P^2 \cdot H^2}) \right]$$

$$\left[\frac{1}{[2 \cdot (-1 - P^2)]} \cdot (-2 \cdot \delta - 2 \cdot C \cdot P - 2 \cdot P^2 \cdot \delta - 2 \cdot \sqrt{H^2 - C^2 + P^2 \cdot H^2}) \right]$$

$$H1^2 - [(w1 - \delta)^2 + (C + P \cdot \delta + (w1 - \delta) \cdot P)^2] \quad \text{downhill side of right-of-way}$$

$$\left[\frac{1}{[2 \cdot (-1 - P^2)]} \cdot (-2 \cdot \delta + 2 \cdot C \cdot P + 4 \cdot P^2 \cdot \delta + 2 \cdot \sqrt{-6 \cdot C \cdot P \cdot \delta - 9 \cdot P^2 \cdot \delta^2 + H1^2 - C^2 + P^2 \cdot H1^2}) \right]$$

$$\left[\frac{1}{[2 \cdot (-1 - P^2)]} \cdot (-2 \cdot \delta + 2 \cdot C \cdot P + 4 \cdot P^2 \cdot \delta - 2 \cdot \sqrt{-6 \cdot C \cdot P \cdot \delta - 9 \cdot P^2 \cdot \delta^2 + H1^2 - C^2 + P^2 \cdot H1^2}) \right]$$

Define variables
 W1 is downhill side, W2 is uphill side.

i := 0, 1.. 6 k := 2, 3.. 9 δ := 6-ft
 P_i := i · 0.05 H_k := k · 10-ft C := 30-ft

$$W1_{i,k} := \frac{1}{[2 \cdot [-1 - (P_i)^2]]} \cdot \left[-2 \cdot \delta + 2 \cdot C \cdot P_i + 4 \cdot (P_i)^2 \cdot \delta - 2 \cdot \sqrt{-6 \cdot C \cdot P_i \cdot \delta - 9 \cdot (P_i)^2 \cdot \delta^2 + (H_k)^2 - C^2 + (P_i)^2 \cdot (H_k)^2} \right]$$

$$W2_{i,k} := \frac{1}{[2 \cdot [-1 - (P_i)^2]]} \cdot \left[-2 \cdot \delta - 2 \cdot C \cdot P_i - 2 \cdot (P_i)^2 \cdot \delta - 2 \cdot \sqrt{(H_k)^2 - C^2 + (P_i)^2 \cdot (H_k)^2} \right]$$

Set nonsensical solutions, i.e. imaginary, to 0

$$W1_{i,k} := \text{if} \left[(\text{Im}(W1_{i,k}) \neq 0 \text{ ft}), 0 \text{ ft}, W1_{i,k} \right]$$

$$W2_{i,k} := \text{if} \left[(\text{Im}(W2_{i,k}) \neq 0 \text{ ft}), 0 \text{ ft}, W2_{i,k} \right]$$

Combine matrices W1 and W2

$$WT := W1 + W2$$

$$WT := \text{augment}(P \cdot \text{ft}, WT)$$

| | | H | | | | | | | | | | |
|------|------|----|----|----|-------|-------|-------|--------|--------|--------|--------|-----|
| P | | 40 | 50 | 60 | 70 | 80 | 90 | | | | | |
| WT = | 0 | 0 | 0 | 0 | 12 | 64.92 | 92 | 115.92 | 138.49 | 160.32 | 181.71 | }ft |
| | 0.05 | 0 | 0 | 0 | 8.99 | 63.84 | 91.22 | 115.26 | 137.89 | 159.76 | 181.15 | |
| | 0.1 | 0 | 0 | 0 | 11.94 | 62.66 | 90.26 | 114.34 | 136.95 | 158.79 | 180.14 | |
| | 0.15 | 0 | 0 | 0 | 14.8 | 61.42 | 89.12 | 113.16 | 135.7 | 157.44 | 178.69 | |
| | 0.2 | 0 | 0 | 0 | 17.54 | 60.13 | 87.83 | 111.76 | 134.15 | 155.74 | 176.84 | |
| | 0.25 | 0 | 0 | 0 | 20.12 | 58.81 | 86.42 | 110.15 | 132.35 | 153.73 | 174.61 | |
| | 0.3 | 0 | 0 | 0 | 22.51 | 57.49 | 84.9 | 108.38 | 130.31 | 151.43 | 172.06 | |

Work Order Account ...:WW-1559-HA1-AC
 Client.....:ALASKA ENERGY AUTHORITY
 Project.....:SUTTON-GLENNALLEN 138kV INTERTIE
 Feature.....:Right-of-Way Width for Maximum Span
 Item:Dove Loading Zone 1, XTM Wind, Xframe
 Calculated By/Date....:Paul Dorvel 7/21/93
 Checked By/Date.....: *PH* 11/5/93
 Approved By/Date

INPUT DATA FOR EVALUATION

$$LMAX := 1007\text{-ft} \quad dia := 0.927\text{-in} \quad weight := 0.766 \cdot \frac{\text{lb}}{\text{ft}} \quad L_{ins} := 5\text{-ft} \quad W := 17\text{-ft}$$

$$LRS := 1000\text{-ft} \quad SAGRS := 34.9\text{-ft} \quad PSF := 26 \cdot \frac{\text{lb}}{\text{ft}^2} \quad M := 0\text{-ft} \quad \delta := 1.0\text{-ft}$$

COMPUTE PHI THE BLOWOUT ANGLE

$$\Phi := \text{atan}\left(\frac{PSF \cdot dia}{weight}\right) \quad \Phi = 69\text{-deg}$$

DEVELOP AND SYMBOLICALLY SOLVE EXPRESSION IN TERMS OF H (ROW width), w (width of structure, between outside phases), delta (structure deflection), SAGRS (ruling span sag under wind), Li (insulator length), LMAX (maximum allowable span), LRS (ruling span), phi (blowout angle) and M (margin).

$$H - 2 \cdot \left[W + \delta + \left[SAGRS \cdot \left(\frac{LMAX}{LRS} \right)^2 + L_{ins} \right] \cdot \sin(\Phi) + M \right] \quad \text{expression}$$

$$2 \cdot W + 2 \cdot \delta + 2 \cdot \sin(\Phi) \cdot SAGRS \cdot \frac{LMAX^2}{LRS^2} + 2 \cdot \sin(\Phi) \cdot L_{ins} + 2 \cdot M \quad \text{solution}$$

Set H equal to expression and evaluate

$$H := 2 \cdot W + 2 \cdot \delta + 2 \cdot \sin(\Phi) \cdot SAGRS \cdot \frac{LMAX^2}{LRS^2} + 2 \cdot \sin(\Phi) \cdot L_{ins} + 2 \cdot M$$

H = 111 ft Required Right-of-Way Width Based on Conductor Blowout

CLIENT ALASKA ENERGY AUTHORITY
 PROJECT COPPER VALLEY INTERTIE FEASIBILITY STUDY
 FEATURE COND **TEAL** ZONE **1,3** XTM WIND
 ITEM **70** **CLASS** **1** RUL SPAN 1000
 WORK ORDER NUMBER : WW-1559-HA1-AC

BY/DATE PED 8/4/93
 CHECKED/DATE **SH** 11/5/93

| ENTER INPUT DATA BELOW | | INPUT VALUE | RANGE NAME |
|---|-------|-------------|---------------------|
| WOOD POLE DATA | | | |
| WOOD TYPE (DF,WRC,SYP,AYC) : | wrc | WOOD | TABLE2 |
| CLASS POLES (1,2,3,H1-H6) : | 1 | CLASS | 2 |
| POLE LENGTH (ft) : | 70 | LTOT | |
| EMBEDMENT L (ft) : | 10 | EMBPBR | |
| EMBEDMENT ADDER (ft) : | 3 | EMBADD | |
| LINE DESIGN DATA | | | |
| LINE ANGLE (deg) : | 0 | ANGLE | |
| RULING SPAN (ft) : | 1000 | RS | |
| UNIT WIND FORCE (psf) : | 26.00 | PSF | |
| RADIAL ICE (inches) : | 0.00 | ICE | |
| SAFETY FACTOR NOTE: IF SAFETY FACTOR NOT 1, THEN OCFs =1.0 | | | |
| WOOD POLE SAFETY FACTOR : | 1.00 | SF | |
| OVERLOAD CAPACITY FACTORS | | | |
| OCF TENSION : | 1.30 | OCFT | STEEL OCFS 1.10 |
| OCF WIND : | 1.30 | OCFW | WOOD OCFS 1.30 |
| OCF WEIGHT : | 1.30 | OCFWT | |
| PHASE CONDUCTOR DATA | | | |
| NUMBER PHASES : | 3 | NPHASE | |
| BARE DIAMETER (inches) : | 0.994 | PHDIAM | |
| UNIT WEIGHT (lb/ft) : | 0.939 | PHWT | |
| RULING SPAN TENSION (lb/ft) : | 0 | PHTEN | NO EFFECT, NO ANGLE |
| ASSEMBLY WT (lb/ft) : | 100 | PHWI | |
| SHIELDWIRE DATA | | | |
| NUMBER WIRES : | 0 | NSW | |
| BARE DIAMETER (inches) : | 0.000 | SWDIAM | |
| UNIT WEIGHT (lb/ft) : | 0.000 | SWWT | |
| RULING SPAN TENSION (lb/ft) : | 0 | SWTEN | |
| ASSEMBLY WT (lb/ft) : | 0 | SWWI | |

WOOD H-FRAME STRUCTURE ANALYSIS BASED ON REA 62-1 METHODS
 NEGATIVE OR ANOMALOUS RESULTS MAY INDICATE INCORRECT STRUCTURE DIMENSIONS

| ANALYSIS RESULTS | | | | |
|------------------|---|-------------------|-------------------|--------------------|
| STRUCTURE TYPE | MAXIMUM HORIZONTAL SPANS LIMITED BY POLE STRENGTH | | | |
| | CROSSARM LEVEL B | TOP OF XB LEVEL E | BOT OF XB LEVEL D | GROUNDLINE LEVEL A |
| H-FRAME 1 | NA | NA | NA | 794 |
| H-FRAME 2 | NO SW | 741 | 1944 | 3622 |
| H-FRAME 3 | NA | 796 | 1944 | 3622 |
| H-FRAME 4 | 977 | 1314 | 1944 | 3622 |
| H-FRAME 5 | NO SW | 741 | 8051 | 10582 |
| H-FRAME 6 | 977 | 1314 | 8051 | 10582 |

| STRUCTURE TYPE | MAXIMUM HORIZONTAL SPAN LIMITED BY CROSSBRACE | | | |
|----------------|---|------------------------|---------------------|---------------------|
| | L | L' | Pcr | U |
| H-FRAME 1 | NA | 16.0 pole separation | 130.6 K=1 | 60797 94048 |
| H-FRAME 2 | 829 | 16400 ultimate load | 14.77 wood xsection | 0.974 radius of gyr |
| H-FRAME 3 | 829 | 0 tension contribution | 374.1 457.1 | |
| H-FRAME 4 | 986 | 1333 for HF4 and HF6 | 37.3 47.2 | |
| H-FRAME 5 | 1418 | 8.4 for HF4 and HF6 | | |
| H-FRAME 6 | 1632 | | | |

WHF4 NOD

Alaska Energy Authority
Copper Valley Inter tie
Span Comparison

DIRECT EMBEDMENT
TYPE 4 IFRAME
BOXED NUMBERS
ARE QTY STRUCTURES IN
10 MILE SEGMENT
WOOD

INSIZ1
Insulator
5
ft

TOPLZ1
Top to Xmm
8
ft

ADOLZ1
Embed +
3
ft

PERLZ1
Embed %
10%

CLRZ1
Clearance
26.8
ft

ALLOWABLE SPANS BASED ON CLEARANCE/SAGS LOADING ZONE 1

| Ruling Span | Dove 558 ACSR 28/7 | Twp 605 ACSR 30/19 | Twp 605 SSAC 30/19 | T2 Umm 2x338 28/7 | Dove/GHS 558 ACSR 28/7 | Dove SD 558 SD |
|----------------|--------------------------|--------------------------|--------------------------|-------------------------|------------------------------|-------------------|
| | | | | | | |
| 800 | 21.89 | 18.12 | 19.30 | 18.38 | 18.89 | 19.56 |
| Lp | HORIZONTAL SPAN LIMITS | | | | | |
| 50 | 285 | 291 | 282 | 289 | 295 | 280 |
| 55 | 449 | 494 | 478 | 490 | 484 | 475 |
| 60 | 577 | 635 | 615 | 630 | 621 | 611 |
| 65 | 682 | 749 | 726 | 744 | 734 | 721 |
| 70 | 772 | 849 | 822 | 843 | 831 | 817 |
| 75 | 853 | 938 | 908 | 932 | 918 | 903 |
| 80 | 927 | 1019 | 987 | 1012 | 998 | 981 |
| 85 | 996 | 1094 | 1060 | 1087 | 1072 | 1053 |
| 900 | 27.04 | 22.35 | 23.86 | 23.23 | 22.25 | 23.39 |
| Lp | HORIZONTAL SPAN LIMITS | | | | | |
| 50 | 268 | 295 | 287 | 289 | 296 | 277 |
| 55 | 455 | 500 | 487 | 491 | 501 | 489 |
| 60 | 584 | 643 | 628 | 630 | 644 | 633 |
| 65 | 690 | 759 | 739 | 745 | 761 | 747 |
| 70 | 782 | 860 | 837 | 843 | 862 | 850 |
| 75 | 864 | 950 | 925 | 932 | 952 | 941 |
| 80 | 938 | 1032 | 1005 | 1012 | 1035 | 1025 |
| 85 | 1008 | 1108 | 1080 | 1087 | 1111 | 1100 |
| 1000 | 33.92 | 28.93 | 28.11 | 28.89 | 28.83 | 33.78 |
| Lp | HORIZONTAL SPAN LIMITS | | | | | |
| 50 | 266 | 299 | 292 | 290 | 305 | 287 |
| 55 | 451 | 500 | 485 | 491 | 517 | 502 |
| 60 | 580 | 643 | 628 | 630 | 644 | 633 |
| 65 | 685 | 759 | 739 | 745 | 761 | 747 |
| 70 | 776 | 860 | 837 | 843 | 862 | 850 |
| 75 | 857 | 950 | 925 | 932 | 952 | 941 |
| 80 | 931 | 1032 | 1005 | 1012 | 1035 | 1025 |
| 85 | 1000 | 1122 | 1098 | 1089 | 1146 | 1134 |
| 1100 | 43.31 | 31.87 | 32.93 | 32.28 | 32.23 | 43.13 |
| Lp | HORIZONTAL SPAN LIMITS | | | | | |
| 50 | 259 | 302 | 297 | 287 | 300 | 259 |
| 55 | 439 | 512 | 504 | 486 | 509 | 440 |
| 60 | 584 | 658 | 647 | 625 | 654 | 588 |
| 65 | 688 | 777 | 764 | 738 | 773 | 688 |
| 70 | 755 | 860 | 846 | 836 | 875 | 757 |
| 75 | 834 | 957 | 957 | 924 | 987 | 836 |
| 80 | 908 | 1057 | 1039 | 1004 | 1051 | 908 |
| 85 | 973 | 1134 | 1116 | 1078 | 1120 | 975 |
| 1200 | 53.89 | 37.16 | 38.87 | 44.35 | 41.55 | 53.48 |
| Lp | HORIZONTAL SPAN LIMITS | | | | | |
| 50 | 254 | 305 | 294 | 279 | 288 | 254 |
| 55 | 430 | 517 | 508 | 473 | 489 | 431 |
| 60 | 553 | 655 | 642 | 608 | 628 | 554 |
| 65 | 653 | 785 | 758 | 719 | 742 | 654 |
| 70 | 740 | 889 | 858 | 814 | 841 | 741 |
| 75 | 817 | 982 | 948 | 899 | 929 | 819 |
| 80 | 888 | 1087 | 1030 | 977 | 1009 | 890 |
| 85 | 954 | 1146 | 1107 | 1049 | 1084 | 955 |

CLIENT ALASKA ENERGY AUTHORITY
 PROJECT COPPER VALLEY INTERTIE FEASIBILITY STUDY
 FEATURE COND t2linnet ZONE 2 XTH WIND
 ITEM 70 CLASS h1 RUL SPAN 1000
 WORK ORDER NUMBER : WW-1559-HA1-AC

BY/DATE PED 8/4/93
 CHECKED/DATE *RTJ* 11/5/93

| ENTER INPUT DATA BELOW | | INPUT VALUE | RANGE NAME |
|---|---|-------------|---------------------------|
| WOOD POLE DATA | | | |
| WOOD TYPE (DF,WRC,SYP,AYC) | : | wrc | WOOD TABLE2 |
| CLASS POLES (1,2,3,H1-H6) | : | h1 | CLASS 3 |
| POLE LENGTH (ft) | : | 70 | LTOT |
| EMBEDMENT L (ft) | : | 0 | EMBPBR |
| EMBEDMENT ADDER (ft) | : | 6 | EMBADD |
| LINE DESIGN DATA | | | |
| LINE ANGLE (deg) | : | 0 | ANGLE |
| RULING SPAN (ft) | : | 1000 | RS |
| UNIT WIND FORCE (psf) | : | 26.00 | PSF |
| RADIAL ICE (inches) | : | 0.00 | ICE |
| SAFETY FACTOR NOTE: IF SAFETY FACTOR NOT 1, THEN OCFs =1.0 | | | |
| WOOD POLE SAFETY FACTOR | : | 1.00 | SF |
| OVERLOAD CAPACITY FACTORS | | | |
| OCF TENSION | : | 1.10 | OCFT STEEL OCFs 1.10 |
| OCF WIND | : | 1.10 | OCFW WOOD OCFs 1.30 |
| OCF WEIGHT | : | 1.10 | OCFWT |
| PHASE CONDUCTOR DATA | | | |
| NUMBER PHASES | : | 3 | NPHASE |
| BARE DIAMETER (inches) | : | 1.180 | PHDIAM |
| UNIT WEIGHT (lbf/ft) | : | 0.926 | PHWT |
| RULING SPAN TENSION (lbf) | : | 0 | PHTEN NO EFFECT, NO ANGLE |
| ASSEMBLY WT (lbf) | : | 100 | PHWI |
| SHIELDWIRE DATA | | | |
| NUMBER WIRES | : | 0 | NSW |
| BARE DIAMETER (inches) | : | 0.000 | SWDIAM |
| UNIT WEIGHT (lbf/ft) | : | 0.000 | SWWT |
| RULING SPAN TENSION (lbf) | : | 0 | SWTEN |
| ASSEMBLY WT (lbf) | : | 0 | SWWI |

WOOD H-FRAME STRUCTURE ANALYSIS BASED ON REA 62-1 METHODS
 NEGATIVE OR ANOMALOUS RESULTS MAY INDICATE INCORRECT STRUCTURE DIMENSIONS

| ANALYSIS RESULTS | | | | |
|------------------|---|-------------------|-------------------|--------------------|
| STRUCTURE TYPE | MAXIMUM HORIZONTAL SPANS LIMITED BY POLE STRENGTH | | | |
| | CROSSARM LEVEL B | TOP OF XB LEVEL E | BOT OF XB LEVEL D | GROUNDLINE LEVEL A |
| H-FRAME 1 | NA | NA | NA | 1040 |
| H-FRAME 2 | NO SW | 928 | 2151 | 4145 |
| H-FRAME 3 | NA | 978 | 2151 | 4145 |
| H-FRAME 4 | 1216 | 1633 | 2151 | 4145 |
| H-FRAME 5 | NO SW | 928 | 7167 | 9894 |
| H-FRAME 6 | 1216 | 1633 | 7167 | 9894 |

| STRUCTURE TYPE | MAXIMUM HORIZONTAL SPAN LIMITED BY CROSSBRACE | | <i>NOT APPLICABLE</i> | |
|----------------|---|------|-----------------------|------------------------|
| | L | L' | kl/r | Pcr |
| H-FRAME 1 | NA | NA | 16.0 pole separation | 10.6 unbraced length |
| H-FRAME 2 | 806 | 806 | 130.6 K=1 | 16400 ultimate load |
| H-FRAME 3 | 806 | 806 | 58967 91279 | 14.77 wood xsection |
| H-FRAME 4 | 954 | 954 | 0.974 radius of gyr | 0 tension contribution |
| H-FRAME 5 | 1374 | 1374 | 387.4 473.7 | 1220 for HF4 and HF6 |
| H-FRAME 6 | 1575 | 1575 | 38.6 48.9 | 8.4 for HF4 and HF6 |

8/11/93

PAGE 1

LOADING ZONE 1

LOAD COMPUTATIONS

C PROJECT COPPER VALLEY INTERTIE FEASIBILITY STUDY
 O CLIENT ALASKA ENERGY AUTHORITY
 D WORK ORDER .. WW-1559-HA1-AC
 E FEATURE LIGHT ANGLE STRUCTURE
 ITEM INTACT LOADS, LOADING ZONE 1, OCFs = 1.00
 BY PED 11-Aug-93
 CHECK *RD* 11/8/93

INPUT DATA SEE PAGE 4 FOR EQUATIONS AND REFERENCES

I NESC CONDITION = HEAVY (LIGHT MEDIUM HEAVY)
 I GO 95 CONDITION= HEAVY (LIGHT, HEAVY)
 I MATERIAL = STEEL (WOOD, STEEL, PSCON, CONC)
 I LINE ANGLE = 15 ANGLE DEGREES
 I YAWED WIND = NO (YES, NO: YES=REDUCE PSF BY COS^3 DUE ANGLE)
 I STRUCTURE TYPE = TAN (TAN=INTACT WIRES, SDE=SINGLE DEADEND)

| WIRE >>>>>>>>>> | 1 | 2 | 3 | 4 |
|--------------------------------|-----------|-----------|----------------|------------|
| I DESCRIPTION | DOVE ACSR | TEAL ACSR | T2 LINNET ACSR | TEAL SSAC |
| I DESCRIPTION | 556 26/7 | 605 30/19 | 2X336 26/7 | 605 30/19 |
| I BARE DIAMETER | 0.927 | 0.994 | 1.18 | 0.994 |
| I BARE WEIGHT | 0.766 | 0.939 | 0.926 | 0.939 |
| I WIRES/POSITION | 1 | 1 | 1 | 1 |
| I POSITIONS | 3 | 3 | 3 | 3 |
| I INSUL/HW WT | 75 | 75 | 75 | 75 |
| I WEIGHT OF MAN | 200 | 200 | 200 | 200 |
| I ECCENTRICITY | 0 | 0 | 0 | 0 |
| I NUMBER ECC | 0 | 0 | 0 | 0 |
| I TOP TO LOAD CTR | 5 | 5 | 5 | 5 |
| I TENSION - NESC | 10256 | 13278 | 14780 | 12802 |
| I TENSION - WIND | 10172 | 13056 | 15043 | 12708 |
| I TENSION - ICE | 12809 | 15924 | 17177 | 14514 |
| I TENSION - COMB XTR | 18080 | 21712 | 22028 | 19857 |
| I TENSION - CONSTR | 4000 | 5000 | 6000 | 6000 |
| I TENSION - GO 95 | 0 | 0 | 0 | 0 |
| I HORIZONTAL SPAN | 1100 | 1100 | 1100 | 1100 |
| I VERTICAL SPAN | 1300 | 1300 | 1300 | 1300 |
| I SNUB ANGLE FROM HORZ | 20 | 20 | 20 | 20 |
| I HS FACTOR ONE SIDE | 0.6 | 0.6 | 0.6 | 0.6 |
| I VS FACTOR ONE SIDE | 0.6 | 0.6 | 0.6 | 0.6 |
| I ANGLE FROM BISECTOR (X-AXIS) | 82.5 ANG1 | 82.5 ANG2 | -82.5 ANG3 | -82.5 ANG4 |

| VALUES FOR | TAN | | | |
|-------------------|-----|---|---|---|
| F HS FACTOR = | 1 | 1 | 1 | 1 |
| F VS FACTOR = | 1 | 1 | 1 | 1 |
| F TENSION FACTOR= | 2 | 2 | 2 | 2 |

LOADING CONDITIONS ASCE COMPUTATION DESIRED (YES, NO)= NO

| | ICE WIND SPEED | WIND FORCE | OCF | OCF | OCF |
|-----------------|----------------|------------|-------|----------|------|
| | IN | MPH | WIND | TENS | VERT |
| L I - NESC | 0.5 | 40 | 4.00 | 1.00 | 1.00 |
| I II - XTR WIND | 0.00 | 100 | 25.60 | 1.00 | 1.00 |
| I III - XTR ICE | 1.00 | 0 | 0.00 | 1.00 | 1.00 |
| I IV - COMB XTR | 1.70 | 20 | 1.40 | 1.00 | 1.00 |
| I V - CONST | 0.00 | 0 | 0.00 | 1.00 | 1.00 |
| L VI - GO 95 | 0.50 | 48.40 | 6.00 | SF= 1.25 | GR B |

MEYERBUK.XLS

Single Pole Buckling Check
 Alaska Energy Authority
 Copper Valley Intertie Study
 LOADING ZONE 1 T2 Linnet Deadend
 PED *ED* 11/5/93 9/14/93

Assumed K 1
 Assumed E steel 29000000 psi
 Assumed Guy Angle 45 deg
 Fraction of Unsupported L 0.6
 Number of Same Load Points 3
 Loading Zone 1 Deadend 90 deg
 Assumed Dead Load 6 k

| | | Input Loads in Kips no OCFs | | | Axial due | Total |
|-------|----------|-----------------------------|------|------|-----------|--------|
| | | Trans | Vert | Long | T,L | Axial |
| INPUT | NESC | 7.86 | 4.11 | 0 | 7.86 | 41.91 |
| INPUT | Xtm Wind | 6.69 | 1.58 | 0 | 6.69 | 30.81 |
| INPUT | Xtm Ice | 4.61 | 5.3 | 0 | 4.61 | 35.73 |
| INPUT | Xtm Comb | 33.46 | 9.95 | 0 | 33.46 | 136.23 |
| CALC | Max | 136.23 | | | | |

| | | | | | | | |
|----------|-------------------------|---------|---------|---------|---------|-----------------------|--|
| INPUT | <i>Meyers LD Series</i> | 9 | | | | input 1-10 | |
| INPUT | Embedment | DE | DE | DE | DE | DE direct embed | |
| INPUT | Top to Lowest Wire | 24 | 24 | 24 | 24 | | |
| INPUT | Pole Length | 70 | 80 | 90 | 100 | | |
| NO input | Top Dia | 10 | 10 | 10 | 10 | | |
| NO input | taper | 0.223 | 0.223 | 0.223 | 0.223 | | |
| CALC | Bottom Dia | 25.61 | 27.84 | 30.07 | 32.3 | | |
| CALC | Embed | 9 | 10 | 11 | 12 | | |
| CALC | L unSUP | 37 | 46 | 55 | 64 | Shaded area below | |
| CALC | Dist up to D | 22.2 | 27.6 | 33 | 38.4 | used to choose t for | |
| CALC | Dist down to D | 38.8 | 42.4 | 46 | 49.6 | old LD series design | |
| CALC | D | 18.6524 | 19.4552 | 20.258 | 21.0608 | No longer used | |
| CALC | Test 1 | FALSE | FALSE | FALSE | FALSE | is LD Class < 5 | |
| CALC | Test 2 | FALSE | FALSE | FALSE | FALSE | is LD Class 5-6 | |
| CALC | Test 3 | TRUE | TRUE | TRUE | TRUE | is LD Class 7-9 | |
| CALC | Test 4 | FALSE | FALSE | FALSE | FALSE | is LD Class 10 | |
| CALC | Test 5 | TRUE | TRUE | TRUE | FALSE | is dist fr top < 47.5 | |
| CALC | t | 0.25 | 0.25 | 0.25 | 0.25 | in | |
| CALC | Area | 14.4836 | 15.1070 | 15.7303 | 16.3537 | sq in | |
| CALC | Inertia | 601.24 | 682.26 | 770.26 | 865.51 | in 4 | |
| CALC | Radius of Gyr | 6.44 | 6.72 | 7.00 | 7.27 | in | |
| CALC | KI/r | 68.91 | 82.14 | 94.32 | 105.57 | | |
| CALC | Fa | 60 | 42 | 32 | 26 | ksi | |
| CALC | fa | 9 | 9 | 9 | 8 | ksi | |
| CALC | Safety Factor | 6.4 | 4.7 | 3.7 | 3.1 | | |
| INPUT | Required SF | 3 | 3 | 3 | 3 | 3 | |
| | | OK | OK | OK | OK | | |

Alaska Energy Authority
Copper Valley Inter tie
Span Comparison

TYPE XFRAME
BOXED NUMBERS
ARE QTY STRUCTURES IN
10 MILE SEGMENT

| INSLZ1 Insulator 5 ft | TOPLZ1 Top to Xarm 1 ft | ADDLZ1 Embed + -2 ft | PERLZ1 Embed % 0 | CLRLZ1 Clearance 28.6 ft |
|--------------------------------|----------------------------------|-------------------------------|------------------------|-----------------------------------|
|--------------------------------|----------------------------------|-------------------------------|------------------------|-----------------------------------|

ALLOWABLE SPANS BASED ON CLEARANCE/SAGS
LOADING ZONE 1

| Dove | Teal | Teal | T2 Linnet | Dove/EHS | Dove SD |
|----------|----------|----------|-----------|----------|---------|
| 558 ACSR | 605 ACSR | 605 SSAC | 2x338 | 558 ACSR | 558 SD |
| 28/7 | 30/19 | 30/19 | 28/7 | 28/7 | |

| INSLZ2 Insulator 5 ft | TOPLZ2 Top to Xarm 1 ft | ADDLZ2 Embed + -2 ft | PERLZ2 Embed % 0 |
|--------------------------------|----------------------------------|-------------------------------|------------------------|
|--------------------------------|----------------------------------|-------------------------------|------------------------|

ALLOWABLE SPANS BASED ON CLEARANCE/SAGS
LOADING ZONE 2

| Dove | Teal | Teal | T2 Linnet |
|----------|----------|----------|-----------|
| 558 ACSR | 605 ACSR | 605 SSAC | 2x338 |
| 28/7 | 30/19 | 30/19 | 28/7 |

800 Ruling Span Sage >>>>>>>>
Lp Le
50 50
55 55
60 60
65 65
70 70
75 75
80 80
85 85

900 Ruling Span Sage >>>>>>>>
Lp Le
50 50
55 55
60 60
65 65
70 70
75 75
80 80
85 85

1000 Ruling Span Sage >>>>>>>>
Lp Le
50 50
55 55
60 60
65 65
70 70
75 75
80 80
85 85

1100 Ruling Span Sage >>>>>>>>
Lp Le
50 50
55 55
60 60
65 65
70 70
75 75
80 80
85 85

1200 Ruling Span Sage >>>>>>>>
Lp Le
50 50
55 55
60 60
65 65
70 70
75 75
80 80
85 85

| | | | | | |
|-------|-------|-------|-------|-------|-------|
| 21.89 | 18.12 | 19.30 | 18.38 | 18.89 | 18.58 |
| 713 | 74 | 784 | 67 | 780 | 70 |
| 809 | 85 | 889 | 59 | 862 | 81 |
| 895 | 59 | 964 | 54 | 953 | 55 |
| 973 | 54 | 1070 | 49 | 1037 | 51 |
| 1048 | 50 | 1149 | 48 | 1114 | 47 |
| 1113 | 47 | 1224 | 43 | 1188 | 45 |
| 1177 | 45 | 1294 | 41 | 1254 | 42 |
| 1238 | 43 | 1360 | 39 | 1318 | 40 |
| 722 | 73 | 794 | 68 | 773 | 68 |
| 819 | 64 | 801 | 59 | 878 | 60 |
| 908 | 58 | 897 | 53 | 971 | 54 |
| 985 | 54 | 1084 | 49 | 1055 | 50 |
| 1058 | 50 | 1184 | 45 | 1134 | 47 |
| 1127 | 47 | 1240 | 43 | 1207 | 44 |
| 1192 | 44 | 1311 | 40 | 1277 | 41 |
| 1253 | 42 | 1378 | 38 | 1342 | 39 |
| 716 | 74 | 804 | 68 | 787 | 67 |
| 813 | 65 | 812 | 58 | 893 | 59 |
| 899 | 59 | 1009 | 52 | 987 | 53 |
| 977 | 54 | 1097 | 48 | 1074 | 49 |
| 1050 | 50 | 1178 | 45 | 1153 | 46 |
| 1118 | 47 | 1255 | 42 | 1228 | 43 |
| 1182 | 45 | 1327 | 40 | 1299 | 41 |
| 1243 | 42 | 1395 | 38 | 1365 | 39 |
| 897 | 76 | 813 | 65 | 800 | 66 |
| 791 | 67 | 922 | 57 | 907 | 58 |
| 875 | 60 | 1020 | 52 | 1003 | 53 |
| 951 | 55 | 1109 | 48 | 1091 | 48 |
| 1022 | 52 | 1192 | 44 | 1172 | 45 |
| 1088 | 49 | 1289 | 42 | 1248 | 42 |
| 1151 | 46 | 1342 | 39 | 1320 | 40 |
| 1210 | 44 | 1410 | 37 | 1386 | 38 |
| 883 | 77 | 821 | 64 | 783 | 67 |
| 775 | 68 | 932 | 57 | 899 | 59 |
| 857 | 62 | 1030 | 51 | 995 | 53 |
| 932 | 57 | 1121 | 47 | 1082 | 49 |
| 1002 | 53 | 1204 | 44 | 1182 | 45 |
| 1088 | 50 | 1282 | 41 | 1237 | 43 |
| 1128 | 47 | 1355 | 39 | 1308 | 40 |
| 1185 | 45 | 1425 | 37 | 1378 | 38 |

| | | | |
|-------|-------|-------|-------|
| 23.28 | 20.88 | 18.87 | 17.32 |
| 892 | 78 | 734 | 72 |
| 785 | 67 | 833 | 63 |
| 868 | 61 | 921 | 57 |
| 944 | 58 | 1001 | 53 |
| 1014 | 52 | 1078 | 49 |
| 1080 | 49 | 1148 | 46 |
| 1142 | 46 | 1211 | 44 |
| 1200 | 44 | 1273 | 41 |
| 708 | 75 | 750 | 70 |
| 801 | 66 | 851 | 62 |
| 885 | 60 | 941 | 56 |
| 963 | 55 | 1023 | 52 |
| 1034 | 51 | 1099 | 48 |
| 1101 | 48 | 1170 | 45 |
| 1185 | 45 | 1237 | 43 |
| 1224 | 43 | 1301 | 41 |
| 704 | 75 | 784 | 69 |
| 799 | 68 | 887 | 61 |
| 884 | 60 | 959 | 55 |
| 961 | 55 | 1042 | 51 |
| 1033 | 51 | 1120 | 47 |
| 1099 | 48 | 1192 | 44 |
| 1182 | 45 | 1261 | 42 |
| 1222 | 43 | 1328 | 40 |
| 892 | 78 | 777 | 68 |
| 785 | 67 | 881 | 60 |
| 868 | 61 | 975 | 54 |
| 944 | 58 | 1080 | 50 |
| 1014 | 52 | 1139 | 48 |
| 1080 | 49 | 1213 | 44 |
| 1142 | 46 | 1282 | 41 |
| 1200 | 44 | 1348 | 39 |
| 882 | 77 | 789 | 67 |
| 774 | 68 | 895 | 59 |
| 858 | 62 | 989 | 53 |
| 931 | 57 | 1078 | 49 |
| 1000 | 53 | 1158 | 46 |
| 1085 | 50 | 1231 | 43 |
| 1128 | 47 | 1301 | 41 |
| 1184 | 45 | 1368 | 39 |

COMPXF.XLS

Alaska Energy Authority
Copper Valley Intertie
Span Comparison

TYPE XFRAME
BOXED NUMBERS
ARE QTY STRUCTURES IN
10 MILE SEGMENT

CLRLZ2
Clearance
26.6
ft

INSLZ3
Insulator
5
ft

TOPLZ3
Top to Xarm
1
ft

ADDLZ3
Embed +
-2
ft

PERLZ3
Embed %
0

CLRLZ3
Clearance
32.8
ft

AGS

ALLOWABLE SPANS BASED ON CLEARANCE/SAGS
LOADING ZONE 3

| Dove/EHS | Dove SD |
|----------|---------|
| 558 ACSR | 558 SD |
| 26/7 | |

| 3719AW | Dove | Teal | Teal | T2 Linnet | Dove/EHS | Dove SD |
|--------|----------|----------|----------|-----------|----------|---------|
| | 558 ACSR | 605 ACSR | 605 SSAC | 2x336 | 558 ACSR | 558 SD |
| | 26/7 | 30/19 | 30/19 | 26/7 | 26/7 | |

| Span | Structure | AGS | 3719AW | Dove | Teal | Teal | T2 Linnet | Dove/EHS | Dove SD |
|------|-------------------------|-------|--------|-------|-------|-------|-----------|----------|---------|
| 800 | Ruling Span Sags >>>>>> | 23.98 | 19.97 | 13.31 | 23.17 | 20.67 | 18.89 | 17.14 | 19.81 |
| | Lp Le | | | | | | | | |
| | 50 50 | 681 | 77 | 747 | 71 | 734 | 72 | 556 | 95 |
| | 55 55 | 773 | 68 | 847 | 82 | 883 | 80 | 889 | 79 |
| | 60 60 | 855 | 62 | 937 | 58 | 1010 | 52 | 785 | 69 |
| | 65 65 | 930 | 57 | 1019 | 52 | 1122 | 47 | 851 | 82 |
| | 70 70 | 999 | 53 | 1095 | 48 | 1225 | 43 | 928 | 57 |
| | 75 75 | 1084 | 50 | 1168 | 45 | 1319 | 40 | 1000 | 53 |
| | 80 80 | 1125 | 47 | 1233 | 43 | 1408 | 38 | 1067 | 49 |
| | 85 85 | 1183 | 45 | 1296 | 41 | 1490 | 35 | 1130 | 47 |
| 900 | Ruling Span Sags >>>>>> | 28.06 | 28.88 | 15.91 | 28.22 | 24.88 | 23.07 | 22.32 | 26.87 |
| | Lp Le | | | | | | | | |
| | 50 50 | 697 | 78 | 723 | 73 | 755 | 70 | 567 | 93 |
| | 55 55 | 790 | 67 | 820 | 84 | 908 | 58 | 882 | 77 |
| | 60 60 | 874 | 60 | 907 | 58 | 1039 | 51 | 780 | 68 |
| | 65 65 | 950 | 56 | 988 | 54 | 1155 | 48 | 867 | 81 |
| | 70 70 | 1021 | 52 | 1060 | 50 | 1280 | 42 | 948 | 58 |
| | 75 75 | 1087 | 49 | 1126 | 47 | 1358 | 39 | 1019 | 52 |
| | 80 80 | 1150 | 46 | 1193 | 44 | 1448 | 38 | 1087 | 49 |
| | 85 85 | 1209 | 44 | 1254 | 42 | 1534 | 34 | 1152 | 46 |
| 1000 | Ruling Span Sags >>>>>> | 34.52 | 34.94 | 18.88 | 35.04 | 29.73 | 27.52 | 29.36 | 34.88 |
| | Lp Le | | | | | | | | |
| | 50 50 | 710 | 74 | 708 | 75 | 774 | 68 | 585 | 93 |
| | 55 55 | 808 | 68 | 801 | 68 | 931 | 57 | 880 | 78 |
| | 60 60 | 891 | 59 | 886 | 60 | 1085 | 50 | 778 | 68 |
| | 65 65 | 969 | 55 | 963 | 55 | 1184 | 45 | 865 | 81 |
| | 70 70 | 1041 | 51 | 1035 | 51 | 1292 | 41 | 944 | 56 |
| | 75 75 | 1108 | 48 | 1102 | 48 | 1392 | 38 | 1018 | 52 |
| | 80 80 | 1172 | 45 | 1165 | 45 | 1485 | 36 | 1084 | 49 |
| | 85 85 | 1232 | 43 | 1225 | 43 | 1573 | 34 | 1148 | 46 |
| 1100 | Ruling Span Sags >>>>>> | 40.42 | 43.83 | 21.82 | 44.00 | 34.83 | 34.14 | 37.28 | 43.83 |
| | Lp Le | | | | | | | | |
| | 50 50 | 722 | 73 | 693 | 76 | 792 | 67 | 555 | 95 |
| | 55 55 | 819 | 64 | 788 | 67 | 952 | 55 | 867 | 79 |
| | 60 60 | 908 | 58 | 870 | 61 | 1069 | 48 | 784 | 69 |
| | 65 65 | 985 | 54 | 948 | 58 | 1211 | 44 | 849 | 82 |
| | 70 70 | 1056 | 50 | 1016 | 52 | 1321 | 40 | 928 | 57 |
| | 75 75 | 1127 | 47 | 1062 | 49 | 1423 | 37 | 988 | 53 |
| | 80 80 | 1191 | 44 | 1144 | 48 | 1518 | 35 | 1084 | 50 |
| | 85 85 | 1252 | 42 | 1203 | 44 | 1608 | 33 | 1127 | 47 |
| 1200 | Ruling Span Sags >>>>>> | 48.0 | 53.63 | 24.73 | 53.88 | 40.26 | 42.53 | 46.05 | 53.88 |
| | Lp Le | | | | | | | | |
| | 50 50 | 718 | 74 | 684 | 77 | 808 | 65 | 547 | 97 |
| | 55 55 | 815 | 65 | 778 | 68 | 971 | 54 | 858 | 80 |
| | 60 60 | 901 | 59 | 858 | 62 | 1111 | 48 | 753 | 70 |
| | 65 65 | 980 | 54 | 933 | 57 | 1235 | 43 | 837 | 83 |
| | 70 70 | 1053 | 50 | 1002 | 53 | 1348 | 39 | 913 | 58 |
| | 75 75 | 1121 | 47 | 1067 | 49 | 1452 | 38 | 984 | 54 |
| | 80 80 | 1185 | 45 | 1128 | 47 | 1549 | 34 | 1049 | 50 |
| | 85 85 | 1248 | 42 | 1168 | 45 | 1640 | 32 | 1111 | 46 |

Alaska Energy Authority
Copper Valley Interlie
Span Comparison

TYPE XFRAME
BOXED NUMBERS
ARE QTY STRUCTURES IN
10 MILE SEGMENT

| | | | | |
|-----------|-------------|---------|---------|-----------|
| INSLZ4 | TOPLZ4 | ADDLZ4 | PERLZ4 | CLRLZ4 |
| Insulator | Top to Xaim | Embed + | Embed % | Clearance |
| 5 | 1 | -2 | 0 | 32.8 |
| ft | ft | ft | | ft |

ALLOWABLE SPANS BASED ON CLEARANCE/SAGS

LOADING ZONE 4

| | | 37#9AW | Dove | Teal | Teal | T2 Linnet | Dove/EHS | Dove SD | | | | | | | |
|------|--------------------------|----------|----------|----------|-------|-----------|----------|---------|----|------|----|-----|-----|-----|----|
| | | 558 ACSR | 805 ACSR | 805 SSAC | 2x338 | 558 ACSR | 558 SD | 558 SD | | | | | | | |
| | | 28/7 | 30/19 | 30/19 | 28/7 | 28/7 | | | | | | | | | |
| 600 | Ruling Span Sags >>>>>>> | 13.31 | 38.08 | 24.03 | 26.02 | 17.14 | 30.84 | 36.87 | | | | | | | |
| | Le | | | | | | | | | | | | | | |
| | 50 | 734 | 72 | 448 | ## | 548 | 97 | 525 | ## | 847 | 82 | 482 | 110 | 448 | ## |
| | 55 | 883 | 60 | 538 | 99 | 857 | 60 | 831 | 64 | 778 | 88 | 580 | 91 | 537 | 98 |
| | 60 | 1010 | 52 | 813 | 88 | 751 | 70 | 722 | 73 | 890 | 59 | 883 | 80 | 814 | 88 |
| | 65 | 1122 | 47 | 882 | 77 | 835 | 83 | 803 | 88 | 989 | 53 | 737 | 72 | 883 | 77 |
| | 70 | 1225 | 43 | 744 | 71 | 912 | 58 | 878 | 80 | 1079 | 49 | 805 | 88 | 745 | 71 |
| | 75 | 1319 | 40 | 801 | 88 | 982 | 54 | 944 | 58 | 1183 | 45 | 887 | 81 | 803 | 88 |
| | 80 | 1408 | 38 | 855 | 82 | 1048 | 50 | 1007 | 52 | 1240 | 43 | 925 | 57 | 858 | 82 |
| | 85 | 1490 | 35 | 905 | 58 | 1109 | 48 | 1088 | 50 | 1313 | 40 | 978 | 54 | 907 | 58 |
| 900 | Ruling Span Sags >>>>>>> | 15.81 | 47.68 | 32.62 | 35.73 | 22.32 | 40.91 | 47.43 | | | | | | | |
| | Le | | | | | | | | | | | | | | |
| | 50 | 755 | 70 | 437 | ## | 528 | ## | 504 | ## | 838 | 83 | 471 | 112 | 437 | ## |
| | 55 | 908 | 58 | 528 | ## | 835 | 83 | 808 | 87 | 787 | 89 | 588 | 93 | 528 | ## |
| | 60 | 1039 | 51 | 801 | 88 | 727 | 73 | 893 | 78 | 877 | 80 | 848 | 81 | 802 | 88 |
| | 65 | 1155 | 48 | 888 | 79 | 808 | 85 | 771 | 89 | 975 | 54 | 720 | 73 | 889 | 79 |
| | 70 | 1280 | 42 | 729 | 72 | 882 | 80 | 841 | 83 | 1084 | 50 | 788 | 87 | 730 | 72 |
| | 75 | 1358 | 39 | 785 | 87 | 950 | 58 | 908 | 58 | 1148 | 48 | 847 | 82 | 788 | 87 |
| | 80 | 1448 | 38 | 837 | 83 | 1013 | 52 | 988 | 55 | 1223 | 43 | 903 | 58 | 839 | 83 |
| | 85 | 1534 | 34 | 887 | 80 | 1073 | 48 | 1023 | 52 | 1295 | 41 | 958 | 55 | 888 | 58 |
| 1000 | Ruling Span Sags >>>>>>> | 18.88 | 61.18 | 42.18 | 46.76 | 29.38 | 62.99 | 69.99 | | | | | | | |
| | Le | | | | | | | | | | | | | | |
| | 50 | 774 | 88 | 428 | ## | 515 | ## | 489 | ## | 816 | 85 | 480 | 115 | 429 | ## |
| | 55 | 931 | 57 | 515 | ## | 820 | 85 | 589 | 90 | 743 | 71 | 553 | 95 | 515 | ## |
| | 60 | 1085 | 50 | 589 | 90 | 709 | 74 | 673 | 78 | 850 | 82 | 833 | 83 | 590 | 90 |
| | 65 | 1184 | 45 | 854 | 81 | 788 | 87 | 749 | 71 | 945 | 58 | 703 | 75 | 855 | 81 |
| | 70 | 1292 | 41 | 714 | 74 | 880 | 81 | 817 | 85 | 1031 | 51 | 787 | 89 | 715 | 74 |
| | 75 | 1392 | 38 | 789 | 89 | 928 | 57 | 880 | 80 | 1110 | 48 | 827 | 84 | 770 | 89 |
| | 80 | 1485 | 38 | 821 | 84 | 988 | 53 | 939 | 58 | 1185 | 45 | 882 | 80 | 822 | 84 |
| | 85 | 1573 | 34 | 889 | 81 | 1048 | 50 | 994 | 53 | 1254 | 42 | 934 | 57 | 870 | 81 |
| 1100 | Ruling Span Sags >>>>>>> | 21.82 | 76.39 | 53.00 | 59.89 | 37.28 | 88.82 | 78.17 | | | | | | | |
| | Le | | | | | | | | | | | | | | |
| | 50 | 792 | 87 | 421 | ## | 508 | ## | 478 | ## | 803 | 88 | 451 | 117 | 422 | ## |
| | 55 | 952 | 55 | 507 | ## | 808 | 87 | 572 | 92 | 725 | 73 | 542 | 97 | 507 | ## |
| | 60 | 1089 | 48 | 579 | 91 | 898 | 78 | 854 | 81 | 830 | 84 | 821 | 85 | 580 | 91 |
| | 65 | 1211 | 44 | 844 | 82 | 773 | 88 | 728 | 73 | 922 | 57 | 890 | 77 | 645 | 82 |
| | 70 | 1321 | 40 | 703 | 75 | 844 | 83 | 794 | 87 | 1008 | 52 | 753 | 70 | 704 | 75 |
| | 75 | 1423 | 37 | 757 | 70 | 909 | 58 | 855 | 82 | 1084 | 49 | 811 | 85 | 758 | 70 |
| | 80 | 1518 | 35 | 808 | 85 | 970 | 54 | 912 | 58 | 1158 | 48 | 885 | 81 | 809 | 85 |
| | 85 | 1608 | 33 | 855 | 82 | 1027 | 51 | 988 | 55 | 1225 | 43 | 916 | 58 | 857 | 82 |
| 1200 | Ruling Span Sags >>>>>>> | 24.73 | 83.28 | 65.31 | 74.61 | 46.05 | 81.82 | 83.02 | | | | | | | |
| | Le | | | | | | | | | | | | | | |
| | 50 | 808 | 85 | 418 | ## | 497 | ## | 465 | ## | 592 | 89 | 445 | 119 | 418 | ## |
| | 55 | 971 | 54 | 500 | ## | 598 | 88 | 580 | 94 | 712 | 74 | 535 | 99 | 501 | ## |
| | 60 | 1111 | 48 | 572 | 92 | 884 | 77 | 840 | 82 | 814 | 85 | 812 | 88 | 573 | 92 |
| | 65 | 1235 | 43 | 838 | 83 | 780 | 89 | 712 | 74 | 905 | 58 | 880 | 78 | 637 | 83 |
| | 70 | 1348 | 39 | 894 | 78 | 829 | 84 | 777 | 88 | 988 | 53 | 742 | 71 | 695 | 78 |
| | 75 | 1452 | 36 | 748 | 71 | 893 | 59 | 838 | 83 | 1084 | 50 | 789 | 88 | 749 | 71 |
| | 80 | 1549 | 34 | 798 | 88 | 953 | 55 | 892 | 59 | 1135 | 47 | 853 | 82 | 799 | 88 |
| | 85 | 1640 | 32 | 845 | 83 | 1009 | 52 | 945 | 58 | 1202 | 44 | 903 | 58 | 848 | 82 |

Work Order Account : WW-1559-HA1-AC
 Client : Alaska Energy Authority
 Project : Copper Valley Intertie
 Feature : T2Linnet 2*336 kcmil 26/ 7 ACSR, XTM WIND
 Item : Single Wood Pole Sizing and Optimization
 Calculated By/Date : PED
 Checked By/Date : *KY 11/5/83* *Swp T2 EX*
 Approved By/Date :

PROBLEM STATEMENT

Compute maximum spans due to pole moment capacity at groundline, maximum spans for given pole top dimensions and required ground clearance, and maximum span based on required vertical phase separation in midspan. Compare to determine most appropriate span and pole combinations.

SET special units

$$\text{kip} := 1000 \cdot \text{lb}$$

SET indices for arrays, i for rows and k for columns, for circumferences 6 feet from butt.

$$i := 1, 2, \dots, 14 \quad k := 1, 2, \dots, 5$$

INPUT transmission line data

Establish matrix of pole top dimensions, column 1 is X value of wire positions, column 2 is distance from pole top to phase, all in feet. Use +- numbers to indicate positions on opposite pole sides.

$$\text{DIST} = \begin{pmatrix} 6 & 5 \\ -6 & 12 \\ 6 & 19 \end{pmatrix} \text{ ft}$$

$$\text{CLR} := 27.8 \text{ ft} \quad \text{Clearance to grade}$$

$$\text{FSTRESSDF} := 8000 \cdot \frac{\text{lb}}{\text{in}^2}$$

$$\text{FSTRESSWRC} := 6000 \cdot \frac{\text{lb}}{\text{in}^2}$$

LOADING CONDITION IS [NESC, EXTREME WIND, EXTREME COMBINED]

$$\text{PSF} := 26 \cdot \frac{\text{lb}}{\text{ft}^2} \quad \text{wind pressure for loading condition}$$

$$\text{ICE} := 0.0 \text{ in} \quad \text{radial ice for loading condition}$$

$$\text{TENS} := 8226 \cdot \text{lb} \quad \text{loading condition tension for ruling span given}$$

$$\text{ANGLE} = 0 \text{ deg} \quad \text{line angle assumed}$$

$$\text{dia} := 1.18 \text{ in} \quad \text{bare wire diameter}$$

$$\text{weight} := 0.926 \cdot \frac{\text{lb}}{\text{ft}} \quad \text{bare wire unit weight}$$

$$\text{rulspan} := 400 \text{ ft} \quad \text{ruling span}$$

$$\text{sagsclr} := 4.65 \text{ ft} \quad \text{ruling span sag at maximum sag for clearance}$$

$$\text{inswgt} := 50 \cdot \text{lb} \quad \text{insulator weight}$$

$$\text{OCFW} := 1.3 \quad \text{overload capacity factor transverse wind}$$

OCFV := 1.3 overload capacity factor vertical load
 em1 := 0.10 embedment factor as percent of total pole length
 em2 := 2-ft embedment adder

COMPUTE INTERMEDIATE SINGLE VALUES

$$\begin{aligned} \text{DIAICE} &:= \text{dia} + 2 \cdot \text{ICE} & \text{DIAICE} &= 1.18 \cdot \text{in} \\ \text{WTICE} &:= \text{weight} + 0.311 \cdot (\text{DIAICE}^2 - \text{dia}^2) \cdot \frac{\text{lb}}{\text{in}^2 \cdot \text{ft}} & \text{WTICE} &= 0.926 \cdot \frac{\text{lb}}{\text{ft}} \\ \text{PC} &:= \text{DIAICE} \cdot \text{PSF} & \text{PC} &= 2.557 \cdot \frac{\text{lb}}{\text{ft}} \\ \text{MTEN} &:= \text{OCFT} \cdot 2 \cdot \text{TENS} \cdot \sin\left(\frac{\text{ANGLE}}{2}\right) & \text{MTEN} &= 0 \cdot \text{lb} \\ \text{VERTARM} &:= \sum_{l=0}^2 \text{DIST}_{l,0} & \text{VERTARM} &= 6 \cdot \text{ft} \end{aligned}$$

IMPORT associated files with ANSI 05.1 data on pole circumferences.

Note that WRCDIMS is associated with file WRCTABL.PRN and DFIRDIMS with file DFIRTABL.PRN in directory E:\AEA-CVEA. Suggest moving and reassociating when work is complete.

WRC := READPRN(WRCDIMS) DFIR := READPRN(DFIRDIMS)

should be 50.00 corrected

| | | | | | | | | | | | | | |
|--------------------|-----|------|------|------|------|------|---------------------|------|------|------|------|------|------|
| WRC ^T = | 0 | 23 | 25 | 27 | 29 | 31 | DFIR ^T = | 0 | 23 | 25 | 27 | 29 | 31 |
| | 60 | 46.5 | 50.5 | 53.5 | 56.5 | 59.5 | | 60 | 42 | 45 | 48 | 51 | 54 |
| | 65 | 48 | 51.5 | 55 | 58.5 | 61.5 | | 65 | 43.5 | 46.5 | 49.5 | 52.5 | 55.5 |
| | 70 | 49.5 | 53 | 56.5 | 60 | 63.5 | | 70 | 45 | 48 | 51 | 54 | 57 |
| | 75 | 51 | 54.5 | 58 | 61.5 | 65 | | 75 | 46 | 49 | 52.5 | 55.5 | 59 |
| | 80 | 52 | 56 | 59.5 | 63 | 67 | | 80 | 47 | 50.5 | 54 | 57 | 60 |
| | 85 | 53.5 | 57 | 61 | 64.5 | 68.5 | | 85 | 48 | 51.5 | 55 | 58.5 | 61.5 |
| | 90 | 54.5 | 58.5 | 62.5 | 66 | 70 | | 90 | 49 | 53 | 56 | 59.5 | 63 |
| | 95 | 0 | 59.5 | 63.5 | 67.5 | 71.5 | | 95 | 0 | 54 | 57 | 61 | 64.5 |
| | 100 | 0 | 61 | 65 | 69 | 72.5 | | 100 | 0 | 55 | 58.5 | 62 | 65.5 |
| | 105 | 0 | 62 | 66 | 70 | 74 | | 105 | 0 | 56 | 59.5 | 63 | 67 |
| | 110 | 0 | 63 | 67.5 | 71.5 | 75.5 | | 110 | 0 | 57 | 60.5 | 64.5 | 68 |
| | 115 | 0 | 64 | 68.5 | 72.5 | 76.5 | | 115 | 0 | 58 | 61.5 | 65.5 | 69 |
| | 120 | 0 | 65 | 69.5 | 74 | 78 | | 120 | 0 | 59 | 62.5 | 66.5 | 70 |
| 125 | 0 | 66 | 70.5 | 75 | 79 | 125 | 0 | 59.5 | 63.5 | 67.5 | 71 | | |

Table of circumferences of Western Red Cedar (WRC) or Douglas fir and Southern Yellow Pine (DFIR) poles per ANSI 05.1. Columns 1-5 correspond to classes 3, 2, 1, H1, H2 respectively. Column 0 is pole length, Row 0 is minimum top circumference, other data are minimum circumference at 6 feet above the butt in inches.

EXPRESS array of lengths, either DF or WRC matrices will do

$$L_i = (\text{WRC}^T)_{i,0} \cdot \text{ft} \quad \text{total pole length}$$

COMPUTE matrix of pole top diameters and diameters at 6 ft from butt.

$$dT\text{WRC}_{i,k} = \frac{(\text{WRC}^T)_{0,k} \cdot \text{in}}{\pi} \quad dT\text{DF}_{i,k} = \frac{(\text{DFIR}^T)_{0,k} \cdot \text{in}}{\pi}$$

$$d6\text{WRC}_{i,k} = \frac{(\text{WRC}^T)_{i,k} \cdot \text{in}}{\pi} \quad d6\text{DF}_{i,k} = \frac{(\text{DFIR}^T)_{i,k} \cdot \text{in}}{\pi}$$

$$\text{EMB}_i = L_i \cdot \text{em1} + \text{em2}$$

$$\text{LEXP}_i = L_i - \text{EMB}_i$$

COMPUTE GROUNDLINE POLE DIAMETERS

$$d\text{GLDF}_{i,k} = dT\text{DF}_{i,k} + \frac{d6\text{DF}_{i,k} - dT\text{DF}_{i,k}}{L_i - 6 \cdot \text{ft}} \cdot \text{LEXP}_i$$

$$d\text{GLWRC}_{i,k} = dT\text{WRC}_{i,k} + \frac{d6\text{WRC}_{i,k} - dT\text{WRC}_{i,k}}{L_i - 6 \cdot \text{ft}} \cdot \text{LEXP}_i$$

COMPUTE groundline moment capacity of poles

$$\text{MCAPDF}_{i,k} = \text{FSTRESSDF} \cdot \pi \cdot \frac{(d\text{GLDF}_{i,k})^3}{32}$$

$$\text{MCAPWRC}_{i,k} = \text{FSTRESSWRC} \cdot \pi \cdot \frac{(d\text{GLWRC}_{i,k})^3}{32}$$

COMPUTE moment arm for PT, total transverse load due wind

$$\text{MOMARM}_i = \frac{\left(3 \cdot L_i - \sum_{n=0}^2 \text{DIST}_{n,1} \right) \cdot \text{PC}}{3 \cdot \text{PC}}$$

PT := 3-PC

COMPUTE wind on pole contribution

$$\text{WPDF}_{i,k} = \frac{\text{PSF} \cdot (2 \cdot dT\text{DF}_{i,k} + d\text{GLDF}_{i,k}) \cdot (\text{LEXP}_i)^2}{6}$$

$$\text{WPWRC}_{i,k} = \frac{\text{PSF} \cdot (2 \cdot dT\text{WRC}_{i,k} + d\text{GLWRC}_{i,k}) \cdot (\text{LEXP}_i)^2}{6}$$

COMPUTE maximum horizontal spans based on groundline moment

$$\text{MAXHSDF}_{i,k} = \frac{\text{MCAPDF}_{i,k} - \text{WPDF}_{i,k} \cdot \text{OCFW} - \text{MTEN} \cdot \text{MOMARM}_i \cdot \text{OCFT}}{\text{PT} \cdot \text{MOMARM}_i \cdot \text{OCFW} + \text{WTICE} \cdot \text{VERTARM}_i \cdot \text{OCFV}}$$

$$\text{MAXHSWRC}_{i,k} = \frac{\text{MCAPWRC}_{i,k} - \text{WPWRC}_{i,k} \cdot \text{OCFW} - \text{MTEN} \cdot \text{MOMARM}_i \cdot \text{OCFT}}{\text{PT} \cdot \text{MOMARM}_i \cdot \text{OCFW} + \text{WTICE} \cdot \text{VERTARM}_i \cdot \text{OCFV}}$$

COMPUTE maximum spans based on pole length and ground clearance

$$\text{AVAILSAG}_i = \text{LEXP}_i - \text{DIST}_{2,1} - \text{CLR}$$

Available sag
subtracting
distance from pole
top to bottom phase
attachment and
clearance from
exposed length.

$$\text{MAXCLRSPAN}_{i,k} = \text{rulspan} \cdot \sqrt{\frac{\text{AVAILSAG}_i}{\text{sagrsclr}}}$$

COMPUTE maximum span based on vertical midspan separation and ice jump

$$\text{MIDSPANSEP} = 3.6 \text{ ft}$$

$$\text{SAGICE} = 6.35 \text{ ft}$$

$$\text{SAGNOICE} = 2.35 \text{ ft}$$

$$\text{ADDER} = 2.0 \text{ ft}$$

$$A = \text{DIST}_{2,1} - \text{DIST}_{0,1}$$

$$\text{MAXICESPAN} = \text{rulspan} \cdot \sqrt{\frac{\text{MIDSPANSEP} + \text{ADDER} - A}{\text{SAGNOICE} - \text{SAGICE}}}$$


$$\text{MAXICESPAN} = 580 \text{ ft}$$

PLOT curves of maximum HS versus length of pole, maximum span based on clearance, and maximum span based on vertical midspan separation. Select classes and range of heights desired. In following case all classes 3-H2 and lengths 60-85 feet are considered.

$$i = 1, 2, \dots, 6$$

$$k = 1, 2, \dots, 5$$

PLOT OF SPANS Western Red Cedar



| | 3 | 2 | 1 | H: | HV | |
|------------|---|-----|-----|-----|-----|-----|
| | 0 | 0 | 0 | 0 | 0 | 0 |
| 60 | 0 | 233 | 314 | 383 | 462 | 550 |
| 65 | 0 | 223 | 288 | 365 | 452 | 536 |
| 70 | 0 | 214 | 277 | 349 | 432 | 526 |
| | 0 | 207 | 267 | 336 | 415 | 505 |
| MAXHSWRC = | 0 | 193 | 259 | 325 | 401 | 500 |
| | 0 | 188 | 243 | 316 | 389 | 485 |
| | 0 | 177 | 237 | 308 | 379 | 471 |
| | 0 | -59 | 224 | 292 | 370 | 459 |
| | 0 | -62 | 220 | 286 | 362 | 437 |
| | 0 | -65 | 208 | 272 | 345 | 429 |
| | 0 | -68 | 197 | 267 | 339 | 421 |
| | 0 | -71 | 187 | 255 | 324 | 403 |
| | 0 | -74 | 178 | 243 | 320 | 397 |
| | 0 | -77 | 168 | 232 | 306 | 381 |

60%: 383 → 375
~~45/42~~ 536 → 525

| | |
|------|------|
| 0 | 423 |
| 578 | 699 |
| 802 | 893 |
| 976 | 1053 |
| 1124 | 1191 |
| 1254 | 1314 |
| 1372 | 1427 |
| 1480 | |

MAXCLRSPAN<1> =

MAXICESPAN = 580 · ft

Xframe Foundations

HP 10x57

Loading Zone

| |
|---|
| 1 |
|---|

Conductor

| |
|----------|
| T2Linnet |
|----------|

Vertical Load

| |
|------|
| 1.63 |
|------|

Extreme Wind Case

Transverse Load

| |
|------|
| 3.05 |
|------|

Extreme Wind Case

Wind on Structure

| |
|------|
| 28.2 |
|------|

Extreme Wind Case

| H,ft | X,ft | WOS,ft-k | M,ft-k | Wx1.1,k | C,kip | U,kip | Lc,ft | Lu,ft | Use L,ft |
|------|-------|----------|---------|---------|----------|----------|----------|----------|----------|
| 35 | 14.5 | 69.09 | 389.34 | 11.75 | 32.72603 | 18.625 | 17.27245 | 18.27778 | 19 |
| 40 | 18.25 | 90.24 | 456.24 | 12.2 | 31.09945 | 16.14658 | 16.91099 | 17.17626 | 18 |
| 45 | 22 | 114.21 | 525.96 | 12.65 | 30.23227 | 14.43636 | 16.71828 | 16.41616 | 17 |
| 50 | 25.75 | 141 | 598.5 | 13.1 | 29.79272 | 13.15874 | 16.6206 | 15.84833 | 17 |
| 55 | 29.5 | 170.61 | 673.86 | 13.55 | 29.61771 | 12.14873 | 16.58171 | 15.39944 | 17 |
| 60 | 33.25 | 203.04 | 752.04 | 14 | 29.61774 | 11.31579 | 16.58172 | 15.02924 | 17 |
| 65 | 37 | 238.29 | 833.04 | 14.45 | 29.73959 | 10.60608 | 16.6088 | 14.71381 | 17 |
| 70 | 40.75 | 276.36 | 916.86 | 14.9 | 29.94963 | 9.985583 | 16.65547 | 14.43804 | 17 |
| 75 | 44.5 | 317.25 | 1003.5 | 15.35 | 30.22556 | 9.431742 | 16.71679 | 14.19189 | 17 |
| 80 | 48.25 | 360.96 | 1092.96 | 15.8 | 30.55202 | 8.929016 | 16.78934 | 13.96845 | 17 |
| 85 | 52 | 407.49 | 1185.24 | 16.25 | 30.91808 | 8.466346 | 16.87068 | 13.76282 | 17 |
| 90 | 55.75 | 456.84 | 1280.34 | 16.7 | 31.31574 | 8.03565 | 16.95905 | 13.5714 | 17 |
| 95 | 59.5 | 509.01 | 1378.26 | 17.15 | 31.73903 | 7.630882 | 17.05312 | 13.3915 | 18 |
| 100 | 63.25 | 564 | 1479 | 17.6 | 32.1834 | 7.247431 | 17.15187 | 13.22108 | 18 |
| 105 | 67 | 621.81 | 1582.56 | 18.05 | 32.6453 | 6.881716 | 17.25451 | 13.05854 | 18 |
| 110 | 70.75 | 682.44 | 1688.94 | 18.5 | 33.12194 | 6.530919 | 17.36043 | 12.90263 | 18 |

Appendix C

SAMPLE COST ESTIMATING SHEETS

- Exhibit C-1 Sample Transmission Line Unit Cost Estimates, Least Cost Option, Route Alternative A (COSTMODX.xls)
- Exhibit C-2 Sample Structure Database File (DBSHF1.xls)
- Exhibit C-3 Material Unit Costs (UNITCOST.xls)
- Exhibit C-4 Insulator Assembly Costs (MATTEAL.xls)
- Exhibit C-5 Crew Cost Development (CREWS.xls)
- Exhibit C-6 Total Project Development Cost Estimates (SUMMARY.xls)
- Exhibit C-7 Cost Estimating Spreadsheet Organization
- Exhibit C-8 Substation Cost Estimates (SUBCOSTS.xls)
- *Exhibit C-9 Right-of-Way Clearing Cost Estimates (ROWTAB.xls)
- Exhibit C-10 Engineering Costs (DESGCOST.xls)
- *Exhibit C-11 Tabulation of Land Ownership (LANDOWN.xls)
- Exhibit C-12 Tabulation of Loading Zone Lengths (SEGTABL.xls)

* Not tailored to reflect latest route modifications 4-4A, 5A-5C, etc. Result: Route lengths different from other sheets by insignificant amount.

FILE: e:\ase-cvse\phase1\design\cost\costmod3.xls
 PROJ: COPPER VALLEY INTERIE FEASIBILITY STUDY
 PSA: WW-1559-HA1-AC

LEVEL OF ESTIMATE: Feasibility/Planning
 ESTIMATED: PED
 CHECKED: 12/12/93
 APPROVED:
 COSTS AS OF: 1993

| CRITERIA NAME: | Database Criteria Range Directly Below | | | | Route |
|----------------|--|--------------|------|-----------|-------|
| | Material | Option | Zone | Conductor | |
| SELECTION: | STEEL | opt1 | 3 | real | 0 |
| LENGTH: | 32.24 | DO NOT ALTER | | | |

| | | | | | | | | |
|-----------|------|------|------|------|------|------|------|------|
| BZone1 | 1.00 | 1.00 | 1.00 | 1.00 | 1.25 | 1.25 | 1.00 | 1.25 |
| BZone2 | 1.00 | 1.00 | 1.00 | 1.00 | 1.00 | 1.00 | 1.00 | 1.00 |
| BZone3 | 1.00 | 1.00 | 1.20 | 1.20 | 1.20 | 1.20 | 1.20 | 1.20 |
| BZone4 | 1.00 | 1.00 | 1.50 | 1.50 | 1.50 | 1.50 | 1.50 | 1.50 |
| BWinter | 1.20 | 1.20 | 1.25 | 1.25 | 1.25 | 1.25 | 1.25 | 1.25 |
| BSummer | 1.00 | 1.00 | 1.00 | 1.00 | 1.00 | 1.00 | 1.00 | 1.00 |
| BVariable | 0.00 | 0.00 | 0.00 | 0.05 | 0.05 | 0.15 | 0.05 | 0.00 |
| BFixed | 0.10 | 0.00 | 0.00 | 2.50 | 3.50 | 2.50 | 5.00 | 0.05 |

UNIT COST CREW PRODUCTIVITY (hours/unit) ENTER CREW. Hourly Rate below. Personnel above

| GROUP | No | Item | Description | Qty | Unit | Total Quantity | FOB Anchorage | CREW PRODUCTIVITY (hours/unit) ENTER CREW. Hourly Rate below. Personnel above | | | | | | | | UNIT COST Installation | EXTENDED Material | EXTENDED Installation | Subtotal | UMT MANHOURS | LOADED RATE |
|----------------|----------------|----------------------------|-----------------------|----------------|--------|----------------|---------------|---|------|------|------|------|-------|------|----------|------------------------|-------------------|-----------------------|----------|--------------|-------------|
| | | | | | | | | M1 | HEL1 | FP1 | FP2 | FDE1 | FDE1 | FR1 | HEL2 | | | | | | |
| B | 28 | FOUNDATIONS | Type | Depth/Len | Per/Sq | | | | | | | | | | | | | | | | |
| Hpile in 10x57 | 29 | Tangent | HPile1 | Permafrost | 20 | 0 | \$1,800 | 0.11 | 0.00 | 0.00 | 4.55 | | | | 0.07 | \$2,228 | \$0 | \$0 | \$0 | 0 | 0 |
| | 30 | Tangent | HPile2 | Glacial Till | 17 | 0 | \$1,300 | 0.11 | 0.00 | 0.00 | 4.38 | | | | 0.07 | \$2,148 | \$0 | \$0 | \$0 | 0 | 0 |
| 890 | 31 | Tangent | HPile3 | Muskeg | 25 | 0 | \$2,000 | 0.11 | 0.00 | 0.00 | 4.88 | | | | 0.07 | \$2,388 | \$0 | \$0 | \$0 | 0 | 0 |
| Cost per Ft | 32 | Tangent | HPile4 | Rock | 8 | 0 | \$1,750 | 0.11 | 0.00 | | | 7.02 | | 0.07 | \$3,073 | \$0 | \$0 | \$0 | 0 | 0 | |
| Pipe Pile | 33 | Tangent | Pipe | Muskeg/PF | 20 | 2 | \$2,200 | 0.11 | 0.00 | 0.00 | 4.55 | | | 0.07 | \$2,228 | \$248,400 | \$249,551 | \$495,951 | 19 | 118 | |
| 1110 | 34 | Tangent | Embed | Glacial Till | 10 | 2 | \$300 | 0.11 | 0.00 | | | | | 0.07 | \$3,909 | \$42,000 | \$54,7192 | \$589,192 | 37 | 106 | |
| Cost per Ft | 35 | Tangent | Embed | Rock | 8 | 2 | \$200 | 0.11 | 0.00 | | | 5.20 | | 0.07 | \$3,838 | \$5,800 | \$101,888 | \$107,488 | 34 | 108 | |
| 30"x0.25"t | 36 | Light Angle | HPile1 | Permafrost | 17 | 6 | \$1,300 | 0.11 | 0.00 | 0.00 | 4.38 | | | 0.07 | \$2,148 | \$9,520 | \$15,019 | \$24,539 | 18 | 119 | |
| Tan | 37 | Light Angle | HPile3 | Muskeg | 20 | 6 | \$1,800 | 0.11 | 0.00 | 0.00 | 4.55 | | | 0.07 | \$2,228 | \$11,200 | \$15,597 | \$26,797 | 19 | 118 | |
| 140 | 38 | Light Angle | HPile4 | Rock | 8 | 0 | \$1,750 | 0.11 | 0.00 | | | 7.02 | | 0.07 | \$2,228 | \$0 | \$0 | \$0 | 0 | 0 | |
| LA | 39 | Light Angle | Pipe | Muskeg | 20 | 3 | \$2,200 | 0.11 | 0.00 | 0.00 | 4.55 | | | 0.07 | \$3,073 | \$0 | \$0 | \$0 | 0 | 0 | |
| 6 | 40 | Light Angle | Embed | Glacial Till | 10 | 3 | \$300 | 0.11 | 0.00 | | | | | 0.07 | \$2,228 | \$2,700 | \$20,053 | \$22,753 | 37 | 90 | |
| MA | 41 | Light Angle | Embed | Rock | 8 | 3 | \$200 | 0.11 | 0.00 | | | 5.20 | | 0.07 | \$2,228 | \$400 | \$7,817 | \$8,217 | 34 | 114 | |
| 6 | 42 | Medium Angle | HPile1 | Permafrost | 20 | 6 | \$1,800 | 0.11 | 0.00 | 0.00 | 4.55 | | | 0.07 | \$3,909 | \$11,200 | \$25,468 | \$36,668 | 19 | 193 | |
| DE | 43 | Medium Angle | HPile3 | Muskeg | 23 | 6 | \$1,840 | 0.11 | 0.00 | 0.00 | 4.75 | | | 0.07 | \$2,311 | \$12,880 | \$16,175 | \$29,055 | 20 | 118 | |
| 11 | 44 | Medium Angle | HPile4 | Rock | 8 | 0 | \$1,750 | 0.11 | 0.00 | | | 7.02 | | 0.07 | \$3,073 | \$0 | \$0 | \$0 | 0 | 0 | |
| SSA | 45 | Medium Angle | Pipe | Muskeg | 23 | 3 | \$2,530 | 0.11 | 0.00 | 0.00 | 4.75 | | | 0.07 | \$2,311 | \$0 | \$0 | \$0 | 0 | 0 | |
| 0 | 46 | Medium Angle | Embed | Glacial Till | 10 | 3 | \$300 | 0.11 | 0.00 | | | 5.20 | | 0.07 | \$3,909 | \$2,700 | \$35,177 | \$37,877 | 37 | 106 | |
| | 47 | Medium Angle | Embed | Rock | 8 | 3 | \$200 | 0.11 | 0.00 | | | | 4.81 | 0.07 | \$3,638 | \$400 | \$7,278 | \$7,678 | 34 | 108 | |
| Geotech Info | 48 | Deadend/HA | HPile1 | Permafrost | 22 | 6 | \$1,700 | 0.11 | 0.00 | 0.00 | 4.88 | | | 0.07 | \$2,283 | \$22,880 | \$29,681 | \$52,581 | 19 | 118 | |
| from Unitcost | 49 | Deadend/HA | HPile3 | Muskeg | 25 | 6 | \$2,000 | 0.11 | 0.00 | 0.00 | 4.88 | | | 0.07 | \$2,388 | \$28,000 | \$30,754 | \$58,754 | 20 | 117 | |
| Glacial Till | 50 | Deadend/HA | HPile4 | Rock | 8 | 0 | \$1,750 | 0.11 | 0.00 | | | 7.02 | | 0.07 | \$3,073 | \$0 | \$0 | \$0 | 0 | 0 | |
| 50% | 51 | Deadend/HA | Pipe | Muskeg | 25 | 3 | \$2,750 | 0.11 | 0.00 | 0.00 | 4.88 | | | 0.07 | \$2,388 | \$0 | \$0 | \$0 | 0 | 0 | |
| Muskeg | 52 | Deadend/HA | Embed | Glacial Till | 10 | 3 | \$300 | 0.11 | 0.00 | | | 5.20 | | 0.07 | \$3,909 | \$5,100 | \$86,445 | \$71,545 | 37 | 106 | |
| 20% | 53 | Deadend/HA | Embed | Rock | 8 | 3 | \$200 | 0.11 | 0.00 | | | | 4.81 | 0.07 | \$3,638 | \$800 | \$10,914 | \$11,514 | 34 | 108 | |
| Permafrost | 54 | Pre-Auger Holes for Piling | | | | | \$500 | | | | | | | | \$13,500 | \$0 | \$13,500 | \$0 | 0 | 0 | |
| 20% | 55 | Concrete Cap SSA | Concrete | Rock Anchor | 2 | 00 | \$2,000 | 0.11 | 0.00 | 0.00 | 0.00 | 0.00 | 12.00 | 0.50 | \$6,491 | \$0 | \$0 | \$0 | 0 | 0 | |
| Rock | 56 | Pile Foundation Caps | | | 1 | 00 | \$150 | 0.00 | 0.00 | 5.00 | | | | | \$2,294 | \$4,050 | \$61,939 | \$65,989 | 20 | 115 | |
| 10% | 57 | Pile Splices | 1 per pile foundation | | 1 | 00 | \$100 | 0.00 | 0.00 | | 1.50 | | | | \$635 | \$13,900 | \$86,244 | \$102,144 | 6 | 106 | |
| | 58 | Pile Tip | | | 00 | 00 | \$50 | 0.00 | 0.00 | | | | | | \$0 | \$2,000 | \$0 | \$2,000 | 0 | 0 | |
| | 59 | Foundation UpH Tests | 1 | 10 foundations | lb | 11 | \$1,500 | | | | | | | | \$16,500 | \$0 | \$16,500 | \$0 | 0 | 0 | |
| 60 | | | | | | | | | | | | | | | | | \$58,058 | \$58,058 | Manhours | Helicopter | |
| 61 | Subtotal Hours | | | | | | | 241 | 100 | 540 | 3879 | 6370 | 1178 | 0 | 24 | | | | 11987 | 124 | |
| 62 | Subtotal | FOUNDATIONS | | | | | | | | | | | | | | \$449,530 | \$1,387,225 | \$1,836,755 | ok | | |

FILE: a:\base\cra\phase1\design\costs\costmod1.xls
 PROJ: COPPER VALLEY INERTIE FEASIBILITY STUDY
 PSA: WW-1559 HA1-AC

LEVEL OF ESTIMATE: Feasibility/Planning
 ESTIMATED: PED
 CHECKED:
 APPROVED:
 COSTS AS OF: 1993

| |
|----------|
| 12/12/93 |
| |
| |

Database Criteria Range Directly Below

CRITERIA NAME: Material Option Zone Conductor Route
 SELECTION: STEEL steel 250-300 D << INPUT, OPTION, CONDUCTOR AND ROUTE (A-D)
 LENGTH: 36.88 DO NOT ALTER

Note that input of Route here is linked to database file, other costmod.xls files, and summary.xls. Recalculate database file after changing route alternative.

| | | | | | | | | |
|-----------|------|------|------|------|------|------|------|------|
| CZone1 | 1.00 | 1.00 | 1.00 | 1.00 | 1.25 | 1.25 | 1.00 | 1.00 |
| CZone2 | 1.00 | 1.00 | 1.00 | 1.00 | 1.00 | 1.00 | 2.00 | 1.00 |
| CZone3 | 1.00 | 1.00 | 1.20 | 1.20 | 1.20 | 1.20 | 1.20 | 1.20 |
| CZone4 | 1.00 | 1.00 | 1.50 | 1.50 | 1.50 | 1.50 | 1.50 | 1.50 |
| CWinter | 1.20 | 1.20 | 1.25 | 1.25 | 1.25 | 1.25 | 1.25 | 1.25 |
| CSummer | 1.00 | 1.00 | 1.00 | 1.00 | 1.00 | 1.00 | 1.00 | 1.00 |
| CVariable | 0.00 | 0.00 | 0.05 | 0.20 | 0.05 | 0.00 | 0.00 | 0.00 |
| CFixed | 0.00 | 0.10 | 2.50 | 1.50 | 1.00 | 1.00 | 1.00 | 0.10 |

UNIT COST CREW PRODUCTIVITY (hours/unit) ENTER CREW, Hourly Rate below, Personnel above

| GROUP | No | Item | Description | Qty | Unit | Total Quantity | UNIT COST | | | | | | | | Installation | EXTENDED Material | EXTENDED Installation | Subtotal | UMT MANHOOURS | LOADED RATE | |
|----------------------------|-----|------------------------------|-----------------------|-----------|------|----------------|------------------------|------|------|------|------|------|------|------|--------------|-------------------|-----------------------|----------|---------------|-------------|------------|
| | | | | | | | Material FOB Anchorage | M1 | M2 | ANC1 | ANC2 | FP2 | ANC1 | SU1 | | | | | | | HEL2 |
| C | 83 | GUY ANCHOR ASSEMBLIES Length | | | | | | | | | | | | | | | | | | | |
| | 84 | Xframe Guy 1 | | | 0 | | \$223 | 0.00 | 0.10 | | | | 1.25 | | | \$361 | \$0 | \$0 | \$0 | 0 | 0 |
| | 85 | Xframe Guy 2 | | | 0 | | \$290 | 0.00 | 0.10 | | | | 1.25 | | | \$361 | \$0 | \$0 | \$0 | 0 | 0 |
| Hpile is 10x57 | 86 | Single Down Guy | 20k | | 45 | | \$111 | 0.00 | 0.10 | | | | 1.25 | | | \$361 | \$4,973 | \$16,250 | \$21,223 | 3 | 109 |
| Coat per Ft | 87 | Single Down Guy | 30k | | 0 | | \$158 | 0.00 | 0.10 | | | | 1.25 | | | \$361 | \$0 | \$0 | \$0 | 0 | 0 |
| | 88 | Single Down Guy | 35k | | 0 | | \$177 | 0.00 | 0.10 | | | | 1.25 | | | \$361 | \$0 | \$0 | \$0 | 0 | 0 |
| Tan | 89 | Single Down Guy | 40k | | 78 | | \$230 | 0.00 | 0.10 | | | | 1.25 | | | \$361 | \$18,374 | \$28,167 | \$46,541 | 3 | 109 |
| | 90 | Single Down Guy | 60k | | 0 | | \$512 | 0.00 | 0.10 | | | | 1.25 | | | \$361 | \$0 | \$0 | \$0 | 0 | 0 |
| | 175 | Single Down Guy | 60k | | 0 | | \$512 | 0.00 | 0.10 | | | | 1.25 | | | \$361 | \$0 | \$0 | \$0 | 0 | 0 |
| LA | 71 | Rockbolt Anchor | 25k | Rock | 6 | | \$48 | 0.00 | 0.10 | | 2.70 | | 1.00 | 0.10 | \$1,627 | \$216 | \$7,320 | \$7,536 | 11 | 149 | |
| | 72 | Rockbolt Anchor | 35k | Rock | 7 | | \$56 | 0.00 | 0.10 | | 2.90 | | 1.00 | 0.10 | \$1,703 | \$0 | \$0 | \$0 | 0 | 0 | |
| | 73 | Rockbolt Anchor | 45k | Rock | 8 | | \$64 | 0.00 | 0.10 | | 3.10 | | 1.00 | 0.10 | \$1,779 | \$0 | \$0 | \$0 | 0 | 0 | |
| MA | 74 | Rockbolt Anchor | 50k | Rock | 9 | | \$72 | 0.00 | 0.10 | | 3.30 | | 1.00 | 0.10 | \$1,856 | \$502 | \$14,475 | \$15,038 | 13 | 148 | |
| | 75 | Rockbolt Anchor | 60k | Rock | 10 | | \$80 | 0.00 | 0.10 | | 3.50 | | 1.00 | 0.10 | \$1,932 | \$0 | \$0 | \$0 | 0 | 0 | |
| DE | 76 | Hpile | 25k | Muskeg | 18 | | \$1,520 | 0.00 | 0.10 | | | 2.44 | 1.00 | 0.10 | \$1,628 | \$13,680 | \$14,651 | \$28,331 | 13 | 130 | |
| | 77 | Hpile | 35k | Muskeg | 22 | | \$1,840 | 0.00 | 0.10 | | | 2.63 | 1.00 | 0.10 | \$1,707 | \$0 | \$0 | \$0 | 0 | 0 | |
| SSA | 78 | Hpile | 45k | Muskeg | 25 | | \$2,100 | 0.00 | 0.10 | | | 2.81 | 1.00 | 0.10 | \$1,787 | \$0 | \$0 | \$0 | 0 | 0 | |
| | 79 | Hpile | 50k | Muskeg | 30 | | \$2,400 | 0.00 | 0.10 | | | 3.13 | 1.00 | 0.10 | \$1,919 | \$37,440 | \$29,934 | \$67,374 | 15 | 125 | |
| | 80 | Hpile | 60k | Muskeg | 33 | | \$2,800 | 0.00 | 0.10 | | | 3.31 | 1.00 | 0.10 | \$1,998 | \$0 | \$0 | \$0 | 0 | 0 | |
| Geotech Info from Unitcost | 81 | Log Anchor | 25k | Till | 5 | | \$100 | 0.00 | 0.10 | | 2.75 | | 1.00 | 0.10 | \$1,207 | \$3,150 | \$38,028 | \$41,178 | 8 | 145 | |
| Glacial Till | 82 | Log Anchor | 35k | Till | 7 | | \$150 | 0.00 | 0.10 | | 2.85 | | 1.00 | 0.10 | \$1,229 | \$0 | \$0 | \$0 | 0 | 0 | |
| 70% | 83 | Log Anchor | 45k | Till | 8 | | \$200 | 0.00 | 0.10 | | 2.90 | | 1.00 | 0.10 | \$1,241 | \$0 | \$0 | \$0 | 0 | 0 | |
| Muskeg | 84 | Log Anchor | 50k | Till | 9 | | \$250 | 0.00 | 0.10 | | 2.95 | | 1.00 | 0.10 | \$1,252 | \$13,650 | \$68,341 | \$81,991 | 9 | 144 | |
| 20% | 85 | Log Anchor | 60k | Till | 10 | | \$300 | 0.00 | 0.10 | | 3.00 | | 1.00 | 0.10 | \$1,263 | \$0 | \$0 | \$0 | 0 | 0 | |
| Permafrost | 86 | Anchor Tests | 1 every | 3 anchors | | 41 | \$700 | | | | | | | | \$28,700 | \$0 | \$28,700 | \$0 | 0 | 0 | |
| 0% | 87 | Anchor Tests | 1 every | 3 anchors | | 41 | \$700 | | | | | | | | \$28,700 | \$0 | \$28,700 | \$0 | 0 | 0 | |
| Rock | 88 | | | | | | | | | | | | | | | | | | | | |
| 10% | 89 | Subtotal Hours | | | | | 0 | 197 | 495 | 114 | 283 | 308 | 248 | 12 | | | | | | Manhouse | Helicopter |
| | 90 | | | | | | | | | | | | | | | | | | | 1642 | 12 |
| | 91 | | | | | | | | | | | | | | | | | | | | |
| | 92 | Subtotal | GUY ANCHOR ASSEMBLIES | | | | | | | | | | | | \$120,744 | \$217,165 | \$337,910 | \$0 | | | |

FILE: e:\one\cva\phase1\design\cost\costmod1.xls
 PRGJ: COPPER VALLEY INTERIE FEASIBILITY STUDY
 PSA: WW-1559-HA1-AC

LEVEL OF ESTIMATE: Feasibility/Planning

ESTIMATED: PED

CHECKED:

APPROVED:

COSTS AS OF: 1993

12/12/93

CRITERIA NAME: Database Criteria Range Directly Below
 SELECTION: Material: STEEL, Option: ah1, Zone: 1, Conductor: teal, Route: D
 LENGTH: 38.88, DO NOT ALTER
 Note that input of Route here is linked to database file, other costmod.xls file, and summary.xls. Recalculate database file after changing route alternative.

| | | | | | | | | |
|-----------|------|------|------|------|------|------|------|------|
| DZone1 | 1.00 | 1.00 | 1.00 | 1.00 | 1.25 | 1.25 | 1.00 | 0.00 |
| DZone2 | 1.00 | 1.00 | 1.00 | 1.00 | 1.00 | 1.00 | 1.00 | 0.00 |
| DZone3 | 1.00 | 1.00 | 1.20 | 1.20 | 1.20 | 1.20 | 1.20 | 1.20 |
| DZone4 | 1.00 | 1.00 | 1.50 | 1.50 | 1.50 | 1.50 | 1.50 | 1.50 |
| DWinter | 1.20 | 1.20 | 1.25 | 1.25 | 1.25 | 1.25 | 1.25 | 1.25 |
| DSummer | 1.00 | 1.00 | 1.00 | 1.00 | 1.00 | 1.00 | 1.00 | 1.00 |
| DVariable | 0.00 | 0.00 | 0.00 | 0.00 | 0.05 | 0.15 | 0.30 | 0.00 |
| DFixed | 0.10 | 0.10 | 0.00 | 0.50 | 1.50 | 1.00 | 1.00 | 1.00 |

UNIT COST CREW PRODUCTIVITY (hours/unit) ENTER CREW. Hourly Rate below. Personnel above

| GROUP | No | Item | Description | Qty | Unit | Total Quantity | Material | CREW PRODUCTIVITY (hours/unit) ENTER CREW. Hourly Rate below. Personnel above | | | | | | | | UNIT COST Installation | EXTENDED Material | EXTENDED Installation | Subtotal | UNT MANHOURS | LOADED RATE | | |
|-------|-----|--|-------------------------|-----|------|----------------|----------|---|------|------|------|------|------|------|------|------------------------|-------------------|-----------------------|-----------|--------------|-------------|------|--|
| | | | | | | | | FOR Anchorage | M1 | M2 | STR1 | ANC1 | CON3 | HEL1 | HEL1 | | | | | | | HEL2 | |
| D | 93 | STRUCTURE FRAMING, INSULATORS, GROUNDING | | | | | | | | | | | | | | | | | | | | | |
| | 94 | Hframe, Wood, Type 1, TH-10 Framing | | | 0 | | \$900 | 0.10 | 0.10 | 0.00 | | | | | | | \$163 | \$0 | \$0 | \$0 | 0 | 0 | |
| | 95 | Hframe, Wood, Type 4, TH-10V4X, Framing | | | 0 | | \$1,763 | 0.10 | 0.10 | 0.00 | | | | | | | \$163 | \$0 | \$0 | \$0 | 0 | 0 | |
| | 96 | Hframe, Steel, Type 4, Framing | | | 175 | | \$1,020 | 0.10 | 0.10 | 0.00 | | | | | | | \$163 | \$176,500 | \$26,576 | \$207,076 | 1 | 117 | |
| | 97 | Hframe, Steel, Type 4, Framing | | | 0 | | \$1,570 | 0.10 | 0.10 | 0.00 | | | | | | | \$0 | \$0 | \$0 | \$0 | 0 | 0 | |
| | 98 | | | | 0 | | \$800 | 0.10 | 0.10 | | | | | | | | \$163 | \$0 | \$0 | \$0 | 0 | 0 | |
| | 99 | Davit Arms, Single Steel Pole | 500 | lb | | | \$185 | | | | | | | | | | \$31 | \$2,970 | \$6,230 | \$9,200 | 0 | 105 | |
| | 100 | Structure Signs | | | 198 | | \$15 | | | 0.05 | | | | | | | \$126 | \$15,840 | \$24,922 | \$40,762 | 1 | 105 | |
| | 101 | Aerial Patrol Signs | | | 198 | | \$80 | | | 0.20 | | | | | | | \$0 | \$0 | \$0 | \$0 | 0 | 0 | |
| | 102 | | | | | | | | | | | | | | | | | | | | | | |
| | 103 | Tangent I-String | | | 350 | | \$212 | 0.10 | 0.10 | 0.20 | | | | | | | \$289 | \$74,200 | \$101,210 | \$175,410 | 3 | 111 | |
| | 104 | Tangent V-String | | | 175 | | \$377 | 0.10 | 0.10 | 0.30 | | | | | | | \$352 | \$65,989 | \$61,619 | \$127,607 | 3 | 110 | |
| | 105 | Tangent Inverted V-String | | | | | \$0 | 0.10 | 0.10 | 0.30 | | | | | | | \$352 | \$0 | \$0 | \$0 | 0 | 0 | |
| | 106 | Tangent Horizontal Vee | Pivoting Type | | 0 | | \$700 | 0.10 | 0.10 | 0.35 | | | | | | | \$364 | \$0 | \$0 | \$0 | 0 | 0 | |
| | 107 | Running Light Angle String | | | 15 | | \$326 | 0.10 | 0.10 | 0.30 | | | | | | | \$352 | \$4,886 | \$5,262 | \$10,108 | 3 | 110 | |
| | 108 | Running Medium Angle String | | | 15 | | \$691 | 0.10 | 0.10 | 0.30 | | | | | | | \$352 | \$10,211 | \$5,262 | \$15,493 | 3 | 110 | |
| | 109 | Deadend String without Jumper | | | 78 | | \$283 | 0.10 | 0.10 | 0.20 | | | 1.68 | | | | \$1,300 | \$22,050 | \$101,392 | \$123,442 | 14 | 94 | |
| | 110 | Jumper Support | | | 20 | | \$256 | 0.10 | 0.10 | 0.20 | | | 0.50 | | | | \$559 | \$5,120 | \$11,174 | \$16,294 | 0 | 100 | |
| | 111 | | | | | | | | | | | | | | | | \$0 | \$0 | \$0 | \$0 | 0 | 0 | |
| | 112 | Grounding Assembly | Hframe, Steel | | 175 | | \$30 | 0.10 | 0.10 | 0.50 | | | | | | | \$274 | \$5,250 | \$46,020 | \$53,270 | 2 | 114 | |
| | 113 | Grounding Assembly | Single Pole, Steel | | 0 | | \$15 | 0.10 | 0.10 | 0.50 | | | | | | | \$274 | \$0 | \$0 | \$0 | 0 | 0 | |
| | 114 | Grounding Assembly | Hframe, Wood | | 0 | | \$100 | 0.10 | 0.10 | 0.50 | | | | | | | \$274 | \$0 | \$0 | \$0 | 0 | 0 | |
| | 115 | Grounding Assembly | Single Pole, Wood | | 0 | | \$60 | 0.10 | 0.10 | 0.50 | | | | | | | \$274 | \$0 | \$0 | \$0 | 0 | 0 | |
| | 116 | Grounding Assembly | 3-Pole Structure, Steel | | 69 | | \$50 | 0.10 | 0.10 | 0.50 | | | | | | | \$274 | \$3,450 | \$16,933 | \$22,383 | 2 | 114 | |
| | 117 | | | | | | | | | | | | | | | | \$0 | \$0 | \$0 | \$0 | 0 | 0 | |
| | 118 | | | | | | | | | | | | | | | | | | | | | | |
| | 119 | | | | | | | | | | | | | | | | | | | | | | |
| | 120 | Subtotal Hours | | | | | | 643 | 856 | 1204 | 244 | 938 | 0 | 0 | 0 | | | | | | 3888 | 0 | |
| | 121 | | | | | | | | | | | | | | | | | | | | | | |
| | 122 | Subtotal FRAMING, etc. | | | | | | | | | | | | | | | | \$388,467 | \$412,641 | \$801,108 | ok | | |

FILE: e:\ee-cv\phase1\design\cost\costmod3.xls
 PROJ: COPPER VALLEY INTERTE FEASIBILITY STUDY
 PSA: WW-1559-NA1-AC

LEVEL OF ESTIMATE: Feasibility/Planning
 ESTIMATED: PED
 CHECKED:
 APPROVED:
 COSTS AS OF: 1993

| |
|----------|
| 12/12/93 |
| |
| |

| CRITERIA NAME: | Material | Option | Zone | Conductor | Route |
|----------------|----------|--------------|------|-----------|-------|
| SELECTION: | STEEL | sh1 | 200g | 1 | 1 |
| LENGTH: | 32.24 | DO NOT ALTER | | | |

| | | | | | | | | |
|-----------|------|------|------|------|------|------|------|------|
| CZone1 | 1.00 | 1.00 | 1.00 | 1.00 | 1.25 | 1.25 | 1.00 | 1.00 |
| CZone2 | 1.00 | 1.00 | 1.00 | 1.00 | 1.00 | 1.00 | 2.00 | 1.00 |
| CZone3 | 1.00 | 1.00 | 1.20 | 1.20 | 1.20 | 1.20 | 1.20 | 1.20 |
| CZone4 | 1.00 | 1.00 | 1.50 | 1.50 | 1.50 | 1.50 | 1.50 | 1.50 |
| CWinter | 1.20 | 1.20 | 1.25 | 1.25 | 1.25 | 1.25 | 1.25 | 1.25 |
| CSummer | 1.00 | 1.00 | 1.00 | 1.00 | 1.00 | 1.00 | 1.00 | 1.00 |
| CVariable | 0.00 | 0.00 | 0.05 | 0.20 | 0.05 | 0.00 | 0.00 | 0.00 |
| CFixed | 0.00 | 0.10 | 2.50 | 1.50 | 1.00 | 1.00 | 1.00 | 0.10 |

| GROUP | No | Item | Description | Qty | Unit | Total Quantity | UNIT COST | | | | | | | | | | UNIT COST | EXTENDED Material | EXTENDED Installation | Subtotal | UNIT MANHOURS | LOADED RATE |
|----------------------------|----|------------------------------|-----------------------|-----------|------|----------------|---------------|------|------|------|------|-----|------|------|----------|--------------|-----------|-------------------|-----------------------|----------|---------------|-------------|
| | | | | | | | FDB Anchorage | M1 | M2 | ANC1 | ANC2 | FP2 | ANC1 | SU1 | HEL2 | Installation | | | | | | |
| C | 83 | GUY ANCHOR ASSEMBLIES Length | | | | 0 | \$223 | 0.00 | 0.11 | | | | | 1.30 | | \$378 | \$0 | \$0 | \$0 | 0 | 0 | |
| | 84 | Xframe Guy 1 | | | | 0 | \$290 | 0.00 | 0.11 | | | | | 1.30 | | \$378 | \$0 | \$0 | \$0 | 0 | 0 | |
| | 85 | Xframe Guy 2 | | | | 0 | \$111 | 0.00 | 0.11 | | | | | 1.30 | | \$378 | \$0 | \$0 | \$0 | 0 | 0 | |
| | 86 | Single Down Guy | 20k | | 54 | \$158 | 0.00 | 0.11 | | | | | | 1.30 | | \$378 | \$5,988 | \$20,401 | \$26,389 | 3 | 109 | |
| | 87 | Single Down Guy | 30k | | 0 | \$158 | 0.00 | 0.11 | | | | | | 1.30 | | \$378 | \$0 | \$0 | \$0 | 0 | 0 | |
| | 88 | Single Down Guy | 35k | | 0 | \$177 | 0.00 | 0.11 | | | | | | 1.30 | | \$378 | \$0 | \$0 | \$0 | 0 | 0 | |
| | 89 | Single Down Guy | 40k | | 88 | \$238 | 0.00 | 0.11 | | | | | | 1.30 | | \$378 | \$15,547 | \$24,934 | \$40,481 | 3 | 109 | |
| | 90 | Single Down Guy | 60k | | 0 | \$512 | 0.00 | 0.11 | | | | | | 1.30 | | \$378 | \$0 | \$0 | \$0 | 0 | 0 | |
| LA | 71 | Rockbolt Anchor | 25k | Rock | 6 | \$48 | 0.00 | 0.11 | | 3.51 | | | 1.30 | 0.13 | \$2,095 | \$259 | \$11,315 | \$11,574 | 14 | 150 | | |
| | 72 | Rockbolt Anchor | 35k | Rock | 7 | \$56 | 0.00 | 0.11 | | 3.77 | | | 1.30 | 0.13 | \$2,195 | \$0 | \$0 | \$0 | 0 | 0 | | |
| MA | 73 | Rockbolt Anchor | 45k | Rock | 8 | \$64 | 0.00 | 0.11 | | 4.03 | | | 1.30 | 0.13 | \$2,294 | \$0 | \$0 | \$0 | 0 | 0 | | |
| | 74 | Rockbolt Anchor | 50k | Rock | 9 | \$72 | 0.00 | 0.11 | | 4.29 | | | 1.30 | 0.13 | \$2,393 | \$475 | \$15,794 | \$16,269 | 16 | 147 | | |
| DE | 75 | Rockbolt Anchor | 60k | Rock | 10 | \$80 | 0.00 | 0.11 | | 4.55 | | | 1.30 | 0.13 | \$2,492 | \$0 | \$0 | \$0 | 0 | 0 | | |
| | 76 | HPile | 25k | Muskeg | 19 | \$1,520 | 0.00 | 0.11 | | | 2.54 | | 1.30 | 0.13 | \$1,829 | \$32,832 | \$39,498 | \$72,328 | 14 | 135 | | |
| SSA | 77 | HPile | 35k | Muskeg | 22 | \$1,840 | 0.00 | 0.11 | | | 2.73 | | 1.30 | 0.13 | \$1,911 | \$0 | \$0 | \$0 | 0 | 0 | | |
| | 78 | HPile | 45k | Muskeg | 25 | \$2,100 | 0.00 | 0.11 | | | 2.93 | | 1.30 | 0.13 | \$1,994 | \$0 | \$0 | \$0 | 0 | 0 | | |
| | 79 | HPile | 50k | Muskeg | 30 | \$2,400 | 0.00 | 0.11 | | | 3.25 | | 1.30 | 0.13 | \$2,131 | \$63,380 | \$58,282 | \$119,622 | 16 | 130 | | |
| | 80 | HPile | 60k | Muskeg | 33 | \$2,800 | 0.00 | 0.11 | | | 3.45 | | 1.30 | 0.13 | \$2,214 | \$0 | \$0 | \$0 | 0 | 0 | | |
| Geotech Info from Unitcost | 81 | Log Anchor | 25k | T&I | 5 | \$100 | 0.00 | 0.11 | 3.58 | | | | 1.30 | 0.13 | \$1,550 | \$2,700 | \$41,848 | \$44,548 | 11 | 146 | | |
| Glacial T&I | 82 | Log Anchor | 35k | T&I | 7 | \$150 | 0.00 | 0.11 | 3.71 | | | | 1.30 | 0.13 | \$1,579 | \$0 | \$0 | \$0 | 0 | 0 | | |
| 50% | 83 | Log Anchor | 45k | T&I | 8 | \$200 | 0.00 | 0.11 | 3.77 | | | | 1.30 | 0.13 | \$1,593 | \$0 | \$0 | \$0 | 0 | 0 | | |
| Muskeg | 84 | Log Anchor | 50k | T&I | 9 | \$250 | 0.00 | 0.11 | 3.84 | | | | 1.30 | 0.13 | \$1,608 | \$8,250 | \$53,054 | \$61,304 | 11 | 145 | | |
| 20% | 85 | Log Anchor | 60k | T&I | 10 | \$300 | 0.00 | 0.11 | 3.90 | | | | 1.30 | 0.13 | \$1,622 | \$0 | \$0 | \$0 | 0 | 0 | | |
| Permafrost | 86 | Anchor Tests | 1 every | 3 anchors | | 40 | \$700 | | | | | | | | \$28,000 | \$0 | \$28,000 | \$28,000 | 0 | 0 | | |
| 20% | 87 | Anchor Tests | 1 every | 3 anchors | | 40 | \$700 | | | | | | | | \$28,000 | \$0 | \$28,000 | \$28,000 | 0 | 0 | | |
| Rock | 88 | Subtotal Hours | | | | | | | | | | | | | | | | | | | | |
| 10% | 89 | Subtotal Hours | | | | | | | | | | | | | | | | | | | | |
| 90 | 90 | Subtotal Hours | | | | | | | | | | | | | | | | | | | | |
| 91 | 91 | Subtotal Hours | | | | | | | | | | | | | | | | | | | | |
| 92 | 92 | Subtotal | GUY ANCHOR ASSEMBLIES | | | | | | | | | | | | | \$157,391 | \$263,103 | \$420,494 | ok | | | |
| | | | | | | | | | | | | | | | | | | | | Manhours | Helicopter | |
| | | | | | | | | | | | | | | | | | | | | 1979 | 18 | |

FILE: e:\ee-cv\phase1\design\cost\costmod3.xls
 PROJ: COPPER VALLEY INTERTE FEASIBILITY STUDY
 PSA: WW-1559-HA1-AC

LEVEL OF ESTIMATE: Feasibility/Planning
 ESTIMATED: PED
 CHECKED:
 APPROVED:
 COSTS AS OF: 1993

12/12/93

Database Criteria Range Directly Below
 CRITERIA NAME: Material Option Zone Conductor Route
 SELECTION: STEEL ah1 23 test test
 LENGTH: 32.24 DO NOT ALTER

| | | | | | | | | |
|-----------|------|------|------|------|------|------|------|------|
| DZone1 | 1.00 | 1.00 | 1.00 | 1.00 | 1.25 | 1.25 | 1.00 | 0.00 |
| DZone2 | 1.00 | 1.00 | 1.00 | 1.00 | 1.00 | 1.00 | 1.00 | 0.00 |
| DZone3 | 1.00 | 1.00 | 1.20 | 1.20 | 1.20 | 1.20 | 1.20 | 1.20 |
| DZone4 | 1.00 | 1.00 | 1.50 | 1.50 | 1.50 | 1.50 | 1.50 | 1.50 |
| DWriter | 1.20 | 1.20 | 1.25 | 1.25 | 1.25 | 1.25 | 1.25 | 1.25 |
| DSummer | 1.00 | 1.00 | 1.00 | 1.00 | 1.00 | 1.00 | 1.00 | 1.00 |
| DVariable | 0.00 | 0.00 | 0.00 | 0.00 | 0.05 | 0.15 | 0.30 | 0.00 |
| DFixed | 0.10 | 0.10 | 0.00 | 0.50 | 1.50 | 1.00 | 1.00 | 1.00 |

UNIT COST
 Material
 CREW PRODUCTIVITY (hours/unit) ENTER CREW. Hourly Rate below, Personnel above

| GROUP | No | Item | Description | Qty | Unit | Total Quantity | FOB Anchorage | CREW PRODUCTIVITY (hours/unit) ENTER CREW. Hourly Rate below, Personnel above | | | | | | | | | UNIT COST Installation | EXTENDED Material | EXTENDED Installation | Subtotal | UNIT MANHOURS | LOADED RATE |
|-------|-----|--|-------------------------|-----|------|----------------|---------------|---|------|------|------|------|------|------|------|-----------|------------------------|-------------------|-----------------------|----------|---------------|-------------|
| | | | | | | | | M1 | M2 | STR1 | ANC1 | CON3 | HEL1 | HEL1 | HEL2 | | | | | | | |
| D | 93 | STRUCTURE FRAMING, INSULATORS, GROUNDING | | | | 0 | \$900 | 0.11 | 0.11 | 0.00 | | | | | | \$174 | \$0 | \$0 | \$0 | 0 | 0 | |
| | 94 | Hframe, Wood, Type 1, 1H-10 Framing | | | | 0 | \$1,783 | 0.11 | 0.11 | 0.00 | | | | | | \$174 | \$0 | \$0 | \$0 | 0 | 0 | |
| | 95 | Hframe, Wood, Type 4, 1H-10V4X, Framing | | | | 140 | \$1,020 | 0.11 | 0.11 | 0.00 | | | | | | \$174 | \$142,800 | \$24,387 | \$167,187 | 1 | 117 | |
| | 96 | Hframe, Steel, Type 1, Framing | | | | 0 | \$1,570 | 0.11 | 0.11 | 0.00 | | | | | | \$174 | \$0 | \$0 | \$0 | 0 | 0 | |
| | 97 | Hframe, Steel, Type 4, Framing | | | | 0 | \$1,570 | 0.11 | 0.11 | 0.00 | | | | | | \$0 | \$0 | \$0 | \$0 | 0 | 0 | |
| | 98 | | | | | 0 | \$600 | 0.11 | 0.11 | | | | | | | \$174 | \$0 | \$0 | \$0 | 0 | 0 | |
| | 99 | Davit Arms, Single Steel Pole | 500 lb | | | 0 | \$15 | | | 0.05 | | | | | | \$31 | \$2,430 | \$5,098 | \$7,528 | 0 | 105 | |
| | 100 | Structure Sign | | | | 162 | \$80 | | | 0.20 | | | | | | \$126 | \$12,960 | \$20,330 | \$33,290 | 1 | 105 | |
| | 101 | Aerial Patrol Sign | | | | 162 | \$80 | | | 0.20 | | | | | | \$0 | \$0 | \$0 | \$0 | 0 | 0 | |
| | 102 | | | | | 280 | \$201 | 0.11 | 0.11 | 0.20 | | | | | | \$300 | \$56,207 | \$94,018 | \$140,224 | 3 | 111 | |
| | 103 | Tangent I-String | | | | 140 | \$395 | 0.11 | 0.11 | 0.30 | | | | | | \$363 | \$55,311 | \$50,819 | \$106,130 | 3 | 110 | |
| | 104 | Tangent V-String | | | | 0 | \$0 | 0.11 | 0.11 | 0.30 | | | | | | \$363 | \$0 | \$0 | \$0 | 0 | 0 | |
| | 105 | Tangent Inverted V-String | | | | 0 | \$700 | 0.11 | 0.11 | 0.35 | | | | | | \$394 | \$0 | \$0 | \$0 | 0 | 0 | |
| | 106 | Tangent Horizontal Vee | Pivoting Type | | | 18 | \$335 | 0.11 | 0.11 | 0.30 | | | | | | \$363 | \$6,025 | \$6,534 | \$12,559 | 3 | 110 | |
| | 107 | Running Light Angle String | | | | 18 | \$678 | 0.11 | 0.11 | 0.30 | | | | | | \$363 | \$12,164 | \$6,534 | \$18,698 | 3 | 110 | |
| | 108 | Running Medium Angle String | | | | 88 | \$299 | 0.11 | 0.11 | 0.20 | | 1.85 | | | | \$1,351 | \$19,714 | \$69,180 | \$108,894 | 14 | 94 | |
| | 109 | Deadend String without Jumper | | | | 10.5 | \$256 | 0.11 | 0.11 | 0.20 | | 0.50 | | | | \$570 | \$4,224 | \$9,398 | \$13,622 | 6 | 100 | |
| | 110 | Jumper Support | | | | 140 | \$30 | 0.11 | 0.11 | | | | | | | \$0 | \$0 | \$0 | \$0 | 0 | 0 | |
| | 111 | Grounding Assembly | Hframe, Steel | | | 0 | \$15 | 0.11 | 0.11 | 0.65 | | | | | | \$319 | \$4,200 | \$44,808 | \$48,808 | 3 | 114 | |
| | 112 | Grounding Assembly | Single Pole, Steel | | | 0 | \$100 | 0.11 | 0.11 | 0.65 | | | | | | \$319 | \$0 | \$0 | \$0 | 0 | 0 | |
| | 113 | Grounding Assembly | Hframe, Wood | | | 0 | \$80 | 0.11 | 0.11 | 0.65 | | | | | | \$319 | \$0 | \$0 | \$0 | 0 | 0 | |
| | 114 | Grounding Assembly | Single Pole, Wood | | | 89 | \$50 | 0.11 | 0.11 | 0.65 | | | | | | \$319 | \$3,450 | \$21,984 | \$25,434 | 3 | 114 | |
| | 115 | Grounding Assembly | 3-Pole Structure, Steel | | | 0 | | | | | | | | | | \$0 | \$0 | \$0 | \$0 | 0 | 0 | |
| | 116 | | | | | | | | | | | | | | | | | | | | | |
| | 117 | | | | | | | | | | | | | | | | | | | | | |
| | 118 | | | | | | | | | | | | | | | | | | | | | |
| | 119 | | | | | | | | | | | | | | | | | | | | | |
| | 120 | Subtotal Hours | | | | | | 568 | 757 | 995 | 272 | 822 | 0 | 0 | 0 | | | | | Manhours | Helicopter | |
| | 121 | | | | | | | | | | | | | | | | | | | 3414 | 0 | |
| | 122 | Subtotal | FRAMING, etc. | | | | | | | | | | | | | \$319,485 | \$362,946 | \$682,431 | \$682,431 | ok | | |

FILE: s:\www\cv\phase1\design\cost\costmod4.xls
 PROJ: COPPER VALLEY INTERTIE FEASIBILITY STUDY
 PSA: WW-1959-HA1-AC

LEVEL OF ESTIMATE: Feasibility/Planning

ESTIMATED: PED

12/12/93

CHECKED:

APPROVED:

COSTS AS OF: 1993

Database Criteria Range Directly Below
 CRITERIA NAME: Material Option Zone Conductor Route
 SELECTION: STEEL sHM 4 3799aw D
 LENGTH: 4 DO NOT ALTER

Unit Costs are normal times appropriate adjustment in table depending on type of structure, length of structure, loading zone, and expected winter or summer construction. Adder (hours) computed to give \$120/pick-up rate for given Zone miles.

| | Zone1 | Zone2 | Zone3 | Zone4 | Zone5 | Zone6 | Zone7 | Zone8 | Zone9 |
|---------|-------|-------|-------|-------|-------|-------|-------|-------|-------|
| Zone1 | 1.00 | 1.00 | 1.00 | 1.00 | 1.25 | 4.00 | 1.25 | 4.00 | 4.00 |
| Zone2 | 1.00 | 1.00 | 1.00 | 1.00 | 1.00 | 3.00 | 1.00 | 3.00 | 3.00 |
| Zone3 | 1.00 | 1.00 | 1.50 | 1.00 | 1.50 | 8.00 | 1.50 | 8.00 | 8.00 |
| Zone4 | 1.00 | 1.00 | 1.75 | 1.00 | 2.00 | 12.00 | 2.00 | 12.00 | 12.00 |
| Adder | | | | | | 0.03 | | 0.015 | 0.024 |
| Aframe | 3.00 | 1.00 | 3.00 | 1.00 | 0.00 | 1.00 | 0.00 | 1.50 | 1.50 |
| Height | 0.00 | 0.00 | 0.02 | 0.05 | 0.00 | 1.00 | 0.20 | 0.00 | 0.00 |
| 1.pole | 0.75 | 0.75 | 0.50 | 1.00 | 0.00 | 1.00 | 0.75 | 0.50 | 0.50 |
| 10.pole | 1.00 | 1.00 | 0.50 | 1.10 | 0.00 | 1.00 | 0.75 | 0.50 | 0.50 |
| 30.pole | 2.00 | 2.00 | 1.25 | 1.50 | 0.00 | 1.00 | 1.50 | 0.50 | 0.50 |
| hframe4 | 1.50 | 1.50 | 0.75 | 1.50 | 0.00 | 1.00 | 1.00 | 1.00 | 1.00 |
| hframe1 | 1.00 | 1.00 | 0.75 | 1.00 | 0.00 | 1.00 | 0.00 | 1.10 | 1.10 |
| xframe | 1.50 | 1.50 | 1.00 | 1.25 | 1.00 | 1.00 | 1.00 | 1.00 | 1.00 |
| Winter | 1.20 | 1.50 | 1.00 | 1.00 | 1.00 | 1.00 | 1.00 | 1.00 | 1.00 |
| Summer | 1.00 | 1.20 | 1.50 | 1.25 | 1.00 | 1.00 | 1.00 | 1.00 | 1.00 |
| Normal | 0.20 | 0.20 | 2.00 | 2.00 | 1.00 | 0.05 | 2.50 | 0.20 | 0.20 |

UNIT COST CREW PRODUCTIVITY (hours/unit) ENTER CREW, Hourly Rate below, Personnel above

| Material | 6 | 8 | 2 | 8 | 7 | 0 | 7 | 0 | 0 |
|-----------|-------|-------|-------|-------|-------|-------|-------|---------|---------|
| FOB | M1 | M2 | SU1 | STR1 | STR3 | HEL1 | STR2 | HEL2 | HEL3 |
| Anchorage | \$799 | \$834 | \$179 | \$629 | \$560 | \$581 | \$599 | \$7,947 | \$3,341 |

Note: structure data is extracted from Database in appropriate DBXXXX.xls file.

| GROUP | No | Item | Description | Qty | Unit Cost | EXTENDED | EXTENDED | SUBTOTAL | UNIT | LOADED | | | | | | | | | | | |
|---------------|----|------------------------------------|------------------------|----------|--------------|----------|--------------|----------|----------|--------|------|------|------|------|----------|-----------|-----------|-----------|-----------|-----|-----|
| | | | | | Installation | Material | Installation | | MANHOURS | RATE | | | | | | | | | | | |
| Extract Range | 1 | STRUCTURES | | | | | | | | | | | | | | | | | | | |
| | 2 | Tangent | steel Hframe4 65 LD-2 | 3 | 4055 | 0.30 | 0.30 | 2.69 | 3.15 | 0.00 | 0.41 | 5.60 | 0.00 | 0.49 | \$8,168 | \$8,110 | \$16,337 | \$24,446 | 68 | 121 | |
| | 3 | Tangent | steel Hframe4 70 LD-2 | 3 | 4468 | 0.30 | 0.30 | 2.71 | 3.20 | 0.00 | 0.41 | 5.80 | 0.00 | 0.49 | \$8,323 | \$13,403 | \$24,969 | \$38,372 | 69 | 120 | |
| | 4 | Tangent | steel Hframe4 80 LD-2 | 6 | 5103 | 0.30 | 0.30 | 2.75 | 3.30 | 0.00 | 0.41 | 6.20 | 0.00 | 0.49 | \$8,632 | \$30,617 | \$51,794 | \$82,411 | 73 | 118 | |
| | 5 | Tangent | steel Hframe4 90 LD-2 | 2 | 5992 | 0.30 | 0.30 | 2.79 | 3.40 | 0.00 | 0.41 | 6.60 | 0.00 | 0.49 | \$8,942 | \$11,984 | \$17,863 | \$29,866 | 76 | 117 | |
| | 6 | Tangent | steel Hframe4 100 LD-2 | 2 | 6637 | 0.30 | 0.30 | 2.83 | 3.50 | 0.00 | 0.41 | 7.00 | 0.00 | 0.49 | \$9,251 | \$13,274 | \$18,502 | \$31,776 | 80 | 116 | |
| | 7 | Light Angle | steel 30.Pole 80 LD-3 | 0 | 5785 | 0.40 | 0.40 | 4.42 | 3.10 | 0.00 | 0.41 | 7.90 | 0.00 | 0.65 | \$0 | \$0 | \$0 | \$0 | 0 | 0 | |
| | 8 | Light Angle | steel 30.Pole 85 LD-3 | 0 | 6434 | 0.40 | 0.40 | 4.44 | 3.15 | 0.00 | 0.41 | 8.10 | 0.00 | 0.65 | \$0 | \$0 | \$0 | \$0 | 0 | 0 | |
| | 9 | Light Angle | steel 30.Pole 75 LD-4 | 0 | 8535 | 0.40 | 0.40 | 4.48 | 3.25 | 0.00 | 0.41 | 8.50 | 0.00 | 0.65 | \$0 | \$0 | \$0 | \$0 | 0 | 0 | |
| | 10 | Light Angle | steel 30.Pole 85 LD-4 | 0 | 9705 | 0.40 | 0.40 | 4.52 | 3.35 | 0.00 | 0.41 | 8.90 | 0.00 | 0.65 | \$0 | \$0 | \$0 | \$0 | 0 | 0 | |
| | 11 | Light Angle | steel 30.Pole 95 LD-4 | 0 | 10829 | 0.40 | 0.40 | 4.58 | 3.45 | 0.00 | 0.41 | 9.30 | 0.00 | 0.65 | \$0 | \$0 | \$0 | \$0 | 0 | 0 | |
| | 12 | Medium Angle | steel 30.Pole 80 LD-6 | 0 | 7891 | 0.40 | 0.40 | 4.42 | 3.10 | 0.00 | 0.41 | 7.90 | 0.00 | 0.65 | \$0 | \$0 | \$0 | \$0 | 0 | 0 | |
| | 13 | Medium Angle | steel 30.Pole 85 LD-6 | 0 | 8622 | 0.40 | 0.40 | 4.44 | 3.15 | 0.00 | 0.41 | 8.10 | 0.00 | 0.65 | \$0 | \$0 | \$0 | \$0 | 0 | 0 | |
| | 14 | Medium Angle | steel 30.Pole 75 LD-8 | 1 | 10092 | 0.40 | 0.40 | 4.48 | 3.25 | 0.00 | 0.41 | 8.50 | 0.00 | 0.65 | \$10,984 | \$10,092 | \$10,984 | \$21,036 | 94 | 117 | |
| | 15 | Medium Angle | steel 30.Pole 85 LD-8 | 0 | 12003 | 0.40 | 0.40 | 4.52 | 3.35 | 0.00 | 0.41 | 8.90 | 0.00 | 0.65 | \$0 | \$0 | \$0 | \$0 | 0 | 0 | |
| | 16 | Medium Angle | steel 30.Pole 95 LD-8 | 0 | 13498 | 0.40 | 0.40 | 4.58 | 3.45 | 0.00 | 0.41 | 9.30 | 0.00 | 0.65 | \$0 | \$0 | \$0 | \$0 | 0 | 0 | |
| | 17 | Descend/HA | steel 30.Pole 80 LD-10 | 0 | 9622 | 0.40 | 0.40 | 4.42 | 3.10 | 0.00 | 0.41 | 7.90 | 0.00 | 0.65 | \$0 | \$0 | \$0 | \$0 | 0 | 0 | |
| | 18 | Descend/HA | steel 30.Pole 85 LD-10 | 0 | 10642 | 0.40 | 0.40 | 4.44 | 3.15 | 0.00 | 0.41 | 8.10 | 0.00 | 0.65 | \$0 | \$0 | \$0 | \$0 | 0 | 0 | |
| | 19 | Descend/HA | steel 30.Pole 75 LD-10 | 0 | 12330 | 0.40 | 0.40 | 4.48 | 3.25 | 0.00 | 0.41 | 8.50 | 0.00 | 0.65 | \$0 | \$0 | \$0 | \$0 | 0 | 0 | |
| | 20 | Descend/HA | steel 30.Pole 85 LD-10 | 0 | 18350 | 0.40 | 0.40 | 4.52 | 3.35 | 0.00 | 0.41 | 8.90 | 0.00 | 0.65 | \$0 | \$0 | \$0 | \$0 | 0 | 0 | |
| | 21 | Descend/HA | steel 30.Pole 95 LD-10 | 0 | 18152 | 0.40 | 0.40 | 4.58 | 3.45 | 0.00 | 0.41 | 9.30 | 0.00 | 0.65 | \$0 | \$0 | \$0 | \$0 | 0 | 0 | |
| | 22 | Self-Supporting | DX Aframe | 50 1E+04 | 9 | \$12,000 | 0.60 | 0.20 | 10.50 | 2.00 | 0.00 | 0.41 | 0.00 | 0.00 | 0.59 | \$5,982 | \$108,000 | \$53,835 | \$161,835 | 38 | 157 |
| | 23 | (Note quantity is 3 per structure) | | | | | | | | | | | | | | | | | | | |
| | 24 | | | | | | | | | | | | | | | | | | | | |
| | 25 | Subtotal Hours | | | 19 | | 42 | 54 | 280 | 425 | 0 | 10 | 711 | 0 | 13 | | | | | | |
| | 26 | | | | | | | | | | | | | | | | | | | | |
| | 27 | Subtotal | STRUCTURES | | | | | | | | | | | | | \$195,440 | \$194,305 | \$389,745 | | ok | |

| Manhours | Helicopter |
|----------|------------|
| 1541 | 23 |

FILE: e:\aaa-cv\phase1\design\costs\costmod4.xls
 PROJ: COPPER VALLEY INTERIE FEASIBILITY STUDY
 PSA: WW-1559-NA1-AC

LEVEL OF ESTIMATE: Feasibility/Planning

ESTIMATED: PED
 CHECKED:
 APPROVED:
 COSTS AS OF: 1993

12/12/93

CRITERIA NAME: Database Criteria Range Directly Below
 SELECTION: Material STEEL Option sh14 Zone 4 Conductor 3799aw Route D
 LENGTH: 4 DO NOT ALTER

| | | | | | | | | |
|-----------|------|------|------|------|------|------|------|------|
| BZone1 | 1.00 | 1.00 | 1.00 | 1.00 | 1.25 | 1.25 | 1.00 | 1.25 |
| BZone2 | 1.00 | 1.00 | 1.00 | 1.00 | 1.00 | 1.00 | 1.00 | 1.00 |
| BZone3 | 1.00 | 1.00 | 1.20 | 1.20 | 1.20 | 1.20 | 1.20 | 1.20 |
| BZone4 | 1.00 | 1.00 | 1.50 | 1.50 | 1.50 | 1.50 | 1.50 | 1.50 |
| BWinter | 1.20 | 1.20 | 1.25 | 1.25 | 1.25 | 1.25 | 1.25 | 1.25 |
| BSummer | 1.00 | 1.00 | 1.00 | 1.00 | 1.00 | 1.00 | 1.00 | 1.00 |
| BVariable | 0.00 | 0.00 | 0.00 | 0.05 | 0.05 | 0.15 | 0.05 | 0.00 |
| BFixed | 0.10 | 0.00 | 0.00 | 2.50 | 3.50 | 2.50 | 5.00 | 0.05 |

UNIT COST CREW PRODUCTIVITY (hours/unit) ENTER CREW Hourly Rate below, Personal above

| GROUP | No | Item | Description | Qty | Unit | Total Quantity | FOB Anchorage | CREW PRODUCTIVITY (hours/unit) ENTER CREW Hourly Rate below, Personal above | | | | | | | | UNIT COST \$179 | EXTENDED Material | EXTENDED Installation | Subtotal | UNIT MANHOURS | LOADED RATE |
|-------|----|----------------------------|-----------------------|-------------|-------------|----------------|---------------|---|------|------|------|------|------|-------|------|-----------------|-------------------|-----------------------|-----------|---------------|-------------|
| | | | | | | | | M1 | HEL1 | FP1 | FP2 | FDE1 | FDE1 | FRI | HEL2 | | | | | | |
| B | 28 | FOUNDATIONS | Type | Depth/Len | Per/Sr | | | | | | | | | | | | | | | | |
| | 29 | Tangent | HP#1 | Permafrost | 20 | 0 | \$1,600 | 0.10 | 0.00 | 0.00 | 5.25 | | | | 0.08 | \$2,552 | \$0 | \$0 | \$0 | 0 | 0 |
| | 30 | Tangent | HP#2 | Glacial TB | 17 | 0 | \$1,360 | 0.10 | 0.00 | 0.00 | 5.03 | | | | 0.08 | \$2,457 | \$0 | \$0 | \$0 | 0 | 0 |
| | 31 | Tangent | HP#3 | Muskeg | 25 | 0 | \$2,000 | 0.10 | 0.00 | 0.00 | 5.63 | | | | 0.08 | \$2,711 | \$0 | \$0 | \$0 | 0 | 0 |
| | 32 | Tangent | HP#4 | Rock | 8 | 0 | \$1,750 | 0.10 | 0.00 | | | | | 8.10 | 0.08 | \$3,527 | \$0 | \$0 | \$0 | 0 | 0 |
| | 33 | Tangent | Pipe | Muskeg/PF | 20 | 2 | \$2,200 | 0.10 | 0.00 | 0.00 | 5.25 | | | | 0.08 | \$2,552 | \$13,200 | \$15,315 | \$28,515 | 22 | 118 |
| | 34 | Tangent | Embed | Glacial TB | 10 | 2 | \$300 | 0.10 | 0.00 | | | 6.00 | | | 0.08 | \$4,491 | \$4,500 | \$67,371 | \$71,871 | 43 | 105 |
| | 35 | Tangent | Embed | Rock | 8 | 2 | \$200 | 0.10 | 0.00 | | | | 5.55 | | 0.08 | \$4,179 | \$1,600 | \$37,614 | \$39,414 | 39 | 106 |
| | 36 | Light Angle | HP#1 | Permafrost | 17 | 8 | \$1,360 | 0.10 | 0.00 | 0.00 | 5.03 | | | | 0.08 | \$2,457 | \$0 | \$0 | \$0 | 0 | 0 |
| | 37 | Light Angle | HP#3 | Muskeg | 20 | 8 | \$1,600 | 0.10 | 0.00 | 0.00 | 5.25 | | | | 0.08 | \$2,552 | \$0 | \$0 | \$0 | 0 | 0 |
| | 38 | Light angle | HP#4 | Rock | 8 | 0 | \$1,750 | 0.10 | 0.00 | | | | | 8.10 | 0.08 | \$2,552 | \$0 | \$0 | \$0 | 0 | 0 |
| | 39 | Light Angle | Pipe | Muskeg | 20 | 3 | \$2,200 | 0.10 | 0.00 | 0.00 | 5.25 | | | | 0.08 | \$3,527 | \$0 | \$0 | \$0 | 0 | 0 |
| | 40 | Light Angle | Embed | Glacial TB | 10 | 3 | \$300 | 0.10 | 0.00 | | | 6.00 | | | 0.08 | \$2,552 | \$0 | \$0 | \$0 | 0 | 0 |
| | 41 | Light Angle | Embed | Rock | 8 | 3 | \$200 | 0.10 | 0.00 | | | | 5.55 | | 0.08 | \$4,491 | \$0 | \$0 | \$0 | 0 | 0 |
| | 42 | Medium Angle | HP#1 | Permafrost | 20 | 8 | \$1,600 | 0.10 | 0.00 | 0.00 | 5.25 | | | | 0.08 | \$4,179 | \$0 | \$0 | \$0 | 0 | 0 |
| | 43 | Medium Angle | HP#3 | Muskeg | 23 | 9 | \$1,840 | 0.10 | 0.00 | 0.00 | 5.48 | | | | 0.08 | \$2,648 | \$1,840 | \$2,648 | \$4,488 | 23 | 118 |
| | 44 | Medium Angle | HP#4 | Rock | 8 | 0 | \$1,750 | 0.10 | 0.00 | | | | | 8.10 | 0.08 | \$2,527 | \$0 | \$0 | \$0 | 0 | 0 |
| | 45 | Medium Angle | Pipe | Muskeg | 23 | 3 | \$2,530 | 0.10 | 0.00 | 0.00 | 5.48 | | | | 0.08 | \$2,648 | \$0 | \$0 | \$0 | 0 | 0 |
| | 46 | Medium Angle | Embed | Glacial TB | 10 | 3 | \$300 | 0.10 | 0.00 | | | 6.00 | | | 0.08 | \$4,491 | \$600 | \$8,983 | \$9,583 | 43 | 105 |
| | 47 | Medium Angle | Embed | Rock | 8 | 3 | \$200 | 0.10 | 0.00 | | | | 5.55 | | 0.08 | \$4,179 | \$200 | \$4,179 | \$4,379 | 39 | 106 |
| | 48 | Deadend/HA | HP#1 | Permafrost | 22 | 8 | \$1,760 | 0.10 | 0.00 | 0.00 | 5.40 | | | | 0.08 | \$2,616 | \$0 | \$0 | \$0 | 0 | 0 |
| | 49 | Deadend/HA | HP#3 | Muskeg | 25 | 8 | \$2,000 | 0.10 | 0.00 | 0.00 | 5.63 | | | | 0.08 | \$2,711 | \$0 | \$0 | \$0 | 0 | 0 |
| | 50 | Deadend/HA | HP#4 | Rock | 8 | 0 | \$1,750 | 0.10 | 0.00 | | | | | 8.10 | 0.08 | \$3,527 | \$0 | \$0 | \$0 | 0 | 0 |
| | 51 | Deadend/HA | Pipe | Muskeg | 25 | 3 | \$2,750 | 0.10 | 0.00 | 0.00 | 5.63 | | | | 0.08 | \$2,711 | \$0 | \$0 | \$0 | 0 | 0 |
| | 52 | Deadend/HA | Embed | Glacial TB | 10 | 3 | \$300 | 0.10 | 0.00 | | | 6.00 | | | 0.08 | \$4,491 | \$0 | \$0 | \$0 | 0 | 0 |
| | 53 | Deadend/HA | Embed | Rock | 8 | 3 | \$200 | 0.10 | 0.00 | | | | 5.55 | | 0.08 | \$4,179 | \$0 | \$0 | \$0 | 0 | 0 |
| | 54 | Pre-Auger Holes for Piling | | | | | \$500 | | | | | | | | | \$0 | \$0 | \$0 | \$0 | 0 | 0 |
| | 55 | Concrete Cap SSA | Concrete | Rock Anchor | 2 | 18 | \$2,000 | 0.10 | 0.00 | 0.00 | 0.00 | 0.00 | 0.00 | 12.00 | 0.50 | \$6,486 | \$38,000 | \$116,751 | \$152,751 | 37 | 177 |
| | 56 | Pile Foundation Caps | | | 1 | 0.5 | \$150 | 0.00 | 0.00 | 5.00 | 0.00 | 0.00 | 0.00 | | | \$2,294 | \$75 | \$1,147 | \$1,222 | 20 | 115 |
| | 57 | Pile Splices | 1 per pile foundation | | 1 | 0.5 | \$100 | 0.00 | 0.00 | | 1.50 | | | | | \$635 | \$850 | \$4,127 | \$4,777 | 8 | 106 |
| | 58 | Pile Tips | | | 1 | 1 | \$50 | 0.00 | 0.00 | | | | | | | \$0 | \$50 | \$0 | \$50 | 0 | 0 |
| | 59 | Foundation Uplift Tests | 1 | 10 | foundations | 1 | \$1,500 | | | | | | | | | \$1,500 | \$0 | \$1,500 | \$1,500 | 0 | 0 |
| | 60 | | | | | | | | | | | | | | | | \$58,058 | \$58,058 | \$58,058 | Manhours | Helicopter |
| | 61 | Subtotal Hours | | | | | | 31 | 100 | 10 | 187 | 714 | 389 | 648 | 12 | | | | | 1947 | 112 |
| | 62 | Subtotal FOUNDATIONS | | | | | | | | | | | | | | | \$60,415 | \$316,192 | \$378,607 | | |

FILE: e:\aaa-cv\phase1\design\cost\costmod4.xls
 PROJ: COPPER VALLEY INTERTIE FEASIBILITY STUDY
 PSA: WW-1599-MA1-AC

LEVEL OF ESTIMATE: Feasibility/Planning
 ESTIMATED: PED
 CHECKED:
 APPROVED:
 COSTS AS OF: 1993

12/12/93

| CRITERIA NAME: | Database Criteria Range Directly Below | | | | Route |
|----------------|--|--------------|------|-----------|--------|
| | Material | Option | Zone | Conductor | |
| SELECTION: | STEEL | 4N4 | 4 | 379Saw | 0.D.01 |
| LENGTH: | 4 | DO NOT ALTER | | | |

| | | | | | | | | |
|-----------|------|------|------|------|------|------|------|-------|
| CZone1 | 1.00 | 1.00 | 1.00 | 1.00 | 1.25 | 1.25 | 1.00 | 1.00 |
| CZone2 | 1.00 | 1.00 | 1.00 | 1.00 | 1.00 | 1.00 | 2.00 | 1.00 |
| CZone3 | 1.00 | 1.00 | 1.20 | 1.20 | 1.20 | 1.20 | 1.20 | 1.20 |
| CZone4 | 1.00 | 1.00 | 1.50 | 1.50 | 1.50 | 1.50 | 1.50 | -1.50 |
| CWinter | 1.20 | 1.20 | 1.25 | 1.25 | 1.25 | 1.25 | 1.25 | 1.25 |
| CSummer | 1.00 | 1.00 | 1.00 | 1.00 | 1.00 | 1.00 | 1.00 | 1.00 |
| CVariable | 0.00 | 0.00 | 0.05 | 0.20 | 0.05 | 0.00 | 0.00 | 0.00 |
| CFixed | 0.00 | 0.10 | 2.50 | 1.50 | 1.00 | 1.00 | 1.00 | 0.10 |

UNIT COST Material
 CREW PRODUCTIVITY (hours/unit) ENTER CREW, Hourly Rate below, Personnel above

| GROUP | No | Item | Description | Qty | Unit | Total Quantity | UNIT COST | | | | | | | | UNIT COST Installation | EXTENDED Material | EXTENDED Installation | Subtotal | UNIT MANHOURS | LOADED RATE |
|----------------------------|----|-----------------------|-----------------------|-----|------|----------------|---|-------|-------|-------|-------|-------|-------|---------|------------------------|-------------------|-----------------------|----------|---------------|-------------|
| | | | | | | | CREW PRODUCTIVITY (hours/unit) ENTER CREW, Hourly Rate below, Personnel above | | | | | | | | | | | | | |
| | | | | | | | FOB Anchorage | 8 | 8 | 2 | 3 | 4 | 2 | 0 | | | | | | |
| | | | | | | | M1 | M2 | ANC1 | ANC2 | FP2 | ANC1 | SU1 | HEL2 | | | | | | |
| | | | | | | | \$799 | \$834 | \$222 | \$382 | \$423 | \$222 | \$179 | \$3.341 | | | | | | |
| C | 63 | GUY ANCHOR ASSEMBLIES | Length | | | 0 | \$223 | 0.00 | 0.10 | | | 1.50 | | | \$417 | \$0 | \$0 | \$0 | 0 | 0 |
| | 64 | Xtreme Guy 1 | | | | 0 | \$290 | 0.00 | 0.10 | | | 1.50 | | | \$417 | \$0 | \$0 | \$0 | 0 | 0 |
| | 65 | Xtreme Guy 2 | | | | 0 | \$111 | 0.00 | 0.10 | | | 1.50 | | | \$417 | \$0 | \$0 | \$0 | 0 | 0 |
| 880 | 66 | Single Down Guy | 20k | | 00 | 0 | \$158 | 0.00 | 0.10 | | | 1.50 | | | \$417 | \$946 | \$2,500 | \$3,446 | 4 | 110 |
| Cost per Ft | 67 | Single Down Guy | 30k | | 00 | 8 | \$177 | 0.00 | 0.10 | | | 1.50 | | | \$417 | \$0 | \$0 | \$0 | 0 | 0 |
| | 68 | Single Down Guy | 35k | | 00 | 0 | \$236 | 0.00 | 0.10 | | | 1.50 | | | \$417 | \$0 | \$0 | \$0 | 0 | 0 |
| Ten | 69 | Single Down Guy | 40k | | 00 | 0 | \$512 | 0.00 | 0.10 | | | 1.50 | | | \$417 | \$0 | \$0 | \$0 | 0 | 0 |
| 15 | 70 | Single Down Guy | 60k | | 00 | 0 | \$48 | 0.00 | 0.10 | | | 1.50 | | 0.15 | \$2,398 | \$0 | \$0 | \$0 | 0 | 0 |
| LA | 71 | Rockbolt Anchor | 25k Rock | 8 | 00 | 0 | \$56 | 0.00 | 0.10 | 4.05 | | 1.50 | | 0.15 | \$2,513 | \$101 | \$4,523 | \$4,624 | 17 | 149 |
| 0 | 72 | Rockbolt Anchor | 35k Rock | 7 | 00 | 2 | \$64 | 0.00 | 0.10 | 4.35 | | 1.50 | | 0.15 | \$2,627 | \$0 | \$0 | \$0 | 0 | 0 |
| MA | 73 | Rockbolt Anchor | 45k Rock | 8 | 00 | 0 | \$72 | 0.00 | 0.10 | 4.85 | | 1.50 | | 0.15 | \$2,742 | \$0 | \$0 | \$0 | 0 | 0 |
| 1 | 74 | Rockbolt Anchor | 50k Rock | 9 | 00 | 0 | \$80 | 0.00 | 0.10 | 4.95 | | 1.50 | | 0.15 | \$2,856 | \$0 | \$0 | \$0 | 0 | 0 |
| DE | 75 | Rockbolt Anchor | 60k Rock | 10 | 00 | 0 | \$1,520 | 0.00 | 0.10 | 5.25 | | 1.50 | | 0.15 | \$2,091 | \$0 | \$0 | \$0 | 0 | 0 |
| 0 | 76 | HP#e | 25k Muskeg | 19 | 00 | 1 | \$1,840 | 0.00 | 0.10 | | 2.93 | 1.50 | | 0.15 | \$2,186 | \$2,208 | \$2,823 | \$4,831 | 16 | 133 |
| SSA | 77 | HP#e | 35k Muskeg | 22 | 00 | 0 | \$2,160 | 0.00 | 0.10 | | 3.15 | 1.50 | | 0.15 | \$2,291 | \$0 | \$0 | \$0 | 0 | 0 |
| 9 | 78 | HP#e | 45k Muskeg | 25 | 00 | 0 | \$2,400 | 0.00 | 0.10 | | 3.38 | 1.50 | | 0.15 | \$2,440 | \$0 | \$0 | \$0 | 0 | 0 |
| | 79 | HP#e | 50k Muskeg | 30 | 00 | 0 | \$2,800 | 0.00 | 0.10 | | 3.75 | 1.50 | | 0.15 | \$2,535 | \$0 | \$0 | \$0 | 0 | 0 |
| Geotech Info from Unicoast | 80 | HP#e | 60k Muskeg | 33 | 00 | 0 | \$100 | 0.00 | 0.10 | | 3.98 | 1.50 | | 0.15 | \$1,769 | \$0 | \$0 | \$0 | 0 | 0 |
| | 81 | Log Anchor | 25k TH | 5 | 00 | 3 | \$150 | 0.00 | 0.10 | 4.13 | | 1.50 | | 0.15 | \$1,802 | \$450 | \$5,407 | \$5,857 | 12 | 146 |
| Glacial TH | 82 | Log Anchor | 35k TH | 7 | 00 | 0 | \$200 | 0.00 | 0.10 | 4.28 | | 1.50 | | 0.15 | \$1,819 | \$0 | \$0 | \$0 | 0 | 0 |
| 50% | 83 | Log Anchor | 45k TH | 8 | 00 | 0 | \$250 | 0.00 | 0.10 | 4.35 | | 1.50 | | 0.15 | \$1,836 | \$0 | \$0 | \$0 | 0 | 0 |
| Muskeg | 84 | Log Anchor | 50k TH | 9 | 00 | 0 | \$300 | 0.00 | 0.10 | 4.43 | | 1.50 | | 0.15 | \$1,852 | \$0 | \$0 | \$0 | 0 | 0 |
| 20% | 85 | Log Anchor | 60k TH | 10 | 00 | 0 | | | | | | 1.50 | | 0.15 | | | | | 0 | 0 |
| Permafrost | 86 | | | | | 2 | \$900 | | | | | | | | \$1,800 | \$0 | \$1,800 | | 0 | 0 |
| 0% | 87 | Anchor Tests | 1 every 3 anchors | | 00 | | | | | | | | | | | | | | Manhours | Helicopter |
| Rock | 88 | | | | | | | | | | | | | | | | | | 110 | 1 |
| 30% | 89 | Subtotal Hours | | | | | 0 | 10 | 26 | 23 | 15 | 18 | 18 | 1 | | | | | | |
| | 90 | | | | | | | | | | | | | | | | | | | |
| | 91 | | | | | | | | | | | | | | | | | | | |
| | 92 | Subtotal | GUY ANCHOR ASSEMBLIES | | | | | | | | | | | | \$5,504 | \$15,054 | \$20,558 | | | |

FILE: e:\ee-cv\phase1\design\cost\costmod4.xls
 PROJ: COPPER VALLEY INTERTIE FEASIBILITY STUDY
 PSA: WW-1559-HA1-AC

LEVEL OF ESTIMATE: Feasibility/Planning
 ESTIMATED: PED
 CHECKED:
 APPROVED:
 COSTS AS OF: 1993

12/12/93

CRITERIA NAME: Material Option Zone Conductor Route
 SELECTION: STEEL sh14 3799aw
 LENGTH: 4 DO NOT ALTER

| | | | | | | | | |
|-----------|------|------|------|------|------|------|------|------|
| DZone1 | 1.00 | 1.00 | 1.00 | 1.00 | 1.25 | 1.25 | 1.00 | 0.00 |
| DZone2 | 1.00 | 1.00 | 1.00 | 1.00 | 1.00 | 1.00 | 1.00 | 0.00 |
| DZone3 | 1.00 | 1.00 | 1.20 | 1.20 | 1.20 | 1.20 | 1.20 | 1.20 |
| DZone4 | 1.00 | 1.00 | 1.50 | 1.50 | 1.50 | 1.50 | 1.50 | 1.50 |
| DWire | 1.20 | 1.20 | 1.25 | 1.25 | 1.25 | 1.25 | 1.25 | 1.25 |
| DSummer | 1.00 | 1.00 | 1.00 | 1.00 | 1.00 | 1.00 | 1.00 | 1.00 |
| DVariable | 0.00 | 0.00 | 0.00 | 0.00 | 0.05 | 0.15 | 0.30 | 0.00 |
| DFixed | 0.10 | 0.10 | 0.00 | 0.50 | 1.50 | 1.00 | 1.00 | 1.00 |

UNIT COST Material CREW PRODUCTIVITY (hours/unit) ENTER CREW Hourly Rate below Personnel above

| GROUP | No | Item | Description | Qty | Unit | Total Quantity | FOB Anchorage | CREW PRODUCTIVITY (hours/unit) ENTER CREW Hourly Rate below Personnel above | | | | | | | | UNIT COST Installation | EXTENDED Material | EXTENDED Installation | Subtotal | UNIT MANNOURS | LOADED RATE |
|-------|-----|--|-------------------------|-----|------|----------------|---------------|---|-------|-------|-------|------|------|---------|----------|------------------------|-------------------|-----------------------|----------|---------------|-------------|
| | | | | | | | | M1 | M2 | STR1 | ANC1 | CON3 | HEL1 | HEL1 | HEL2 | | | | | | |
| | | | | | | | \$799 | \$834 | \$629 | \$222 | \$539 | | | \$3.341 | | | | | | | |
| 0 | 93 | STRUCTURE FRAMING, INSULATORS, GROUNDING | | | | | | | | | | | | | | | | | | | |
| | 94 | Hframe, Wood, Type 1, TH-10 Framing | | 0 | 00 | 0 | \$900 | 0.10 | 0.10 | 0.00 | | | | \$163 | \$0 | \$0 | \$0 | \$0 | 0 | 0 | 0 |
| | 95 | Hframe, Wood, Type 4, TH-10V4X, Framing | | 0 | 00 | 0 | \$1,763 | 0.10 | 0.10 | 0.00 | | | | \$163 | \$0 | \$0 | \$0 | \$0 | 0 | 0 | 0 |
| | 96 | Hframe, Steel, Type 1, Framing | | 0 | 00 | 0 | \$1,020 | 0.10 | 0.10 | 0.00 | | | | \$163 | \$0 | \$0 | \$0 | \$0 | 0 | 0 | 0 |
| | 97 | Hframe, Steel, Type 4, Framing | | 15 | 00 | 15 | \$1,570 | 0.10 | 0.10 | 0.00 | | | | \$163 | \$23,550 | \$2,450 | \$26,000 | \$0 | 1 | 117 | 0 |
| | 98 | | | | 00 | | | | | | | | | \$0 | \$0 | \$0 | \$0 | \$0 | 0 | 0 | 0 |
| | 99 | Dev't Arms, Single Steel Pole | 500 lb | 0 | 00 | 0 | \$600 | 0.10 | 0.10 | | | | | \$163 | \$0 | \$0 | \$0 | \$0 | 0 | 0 | 0 |
| | 100 | Structure Signs | | 18 | 00 | 18 | \$15 | | | 0.05 | | | | \$31 | \$285 | \$598 | \$883 | \$0 | 0 | 105 | 0 |
| | 101 | Aerial Patrol Signs | | 19 | 00 | 19 | \$90 | | | 0.20 | | | | \$126 | \$1,520 | \$2,391 | \$3,911 | \$0 | 1 | 105 | 0 |
| | 102 | | | | 00 | | | | | | | | | \$0 | \$0 | \$0 | \$0 | \$0 | 0 | 0 | 0 |
| | 103 | Tangent I-String | | 30 | 00 | 30 | \$163 | 0.10 | 0.10 | 0.20 | | | | \$269 | \$4,893 | \$8,675 | \$13,568 | \$0 | 3 | 111 | 0 |
| | 104 | Tangent V-String | | 15 | 00 | 15 | \$357 | 0.10 | 0.10 | 0.30 | | | | \$352 | \$5,282 | \$5,282 | \$10,643 | \$0 | 3 | 110 | 0 |
| | 105 | Tangent Inverted V-String | | | 00 | | \$0 | 0.10 | 0.10 | 0.30 | | | | \$352 | \$0 | \$0 | \$0 | \$0 | 0 | 0 | 0 |
| | 106 | Tangent Horizontal Vee | Photing Type | 0 | 00 | 0 | \$700 | 0.10 | 0.10 | 0.35 | | | | \$384 | \$0 | \$0 | \$0 | \$0 | 0 | 0 | 0 |
| | 107 | Running Light Angle String | | 0 | 00 | 0 | \$383 | 0.10 | 0.10 | 0.30 | | | | \$352 | \$0 | \$0 | \$0 | \$0 | 0 | 0 | 0 |
| | 108 | Running Medium Angle String | | 3 | 00 | 3 | \$710 | 0.10 | 0.10 | 0.30 | | | | \$352 | \$2,130 | \$1,056 | \$3,187 | \$0 | 3 | 110 | 0 |
| | 109 | Deadend String without Jumper | | 0 | 00 | 0 | \$857 | 0.10 | 0.10 | 0.20 | | 2.25 | | \$1,502 | \$0 | \$0 | \$0 | \$0 | 0 | 0 | 0 |
| | 110 | Jumper Support | | 0 | 00 | 0 | \$256 | 0.10 | 0.10 | 0.20 | | 0.50 | | \$559 | \$0 | \$0 | \$0 | \$0 | 0 | 0 | 0 |
| | 111 | | | | 00 | | | | | | | | | \$0 | \$0 | \$0 | \$0 | \$0 | 0 | 0 | 0 |
| | 112 | Grounding Assembly | Hframe, Steel | 15 | 00 | 15 | \$30 | 0.10 | 0.10 | 0.75 | | | | \$330 | \$450 | \$4,949 | \$5,399 | \$0 | 3 | 114 | 0 |
| | 113 | Grounding Assembly | Single Pole, Steel | 0 | 00 | 0 | \$15 | 0.10 | 0.10 | 0.75 | | | | \$330 | \$0 | \$0 | \$0 | \$0 | 0 | 0 | 0 |
| | 114 | Grounding Assembly | Hframe, Wood | 0 | 00 | 0 | \$100 | 0.10 | 0.10 | 0.75 | | | | \$330 | \$0 | \$0 | \$0 | \$0 | 0 | 0 | 0 |
| | 115 | Grounding Assembly | Single Pole, Wood | 0 | 00 | 0 | \$60 | 0.10 | 0.10 | 0.75 | | | | \$330 | \$0 | \$0 | \$0 | \$0 | 0 | 0 | 0 |
| | 116 | Grounding Assembly | 3-Pole Structure, Steel | 3 | 00 | 3 | \$50 | 0.10 | 0.10 | 0.75 | | | | \$330 | \$150 | \$990 | \$1,140 | \$0 | 3 | 114 | 0 |
| | 117 | | | | 00 | | | | | | | | | \$0 | \$0 | \$0 | \$0 | \$0 | 0 | 0 | 0 |
| | 118 | | | | | | | | | | | | | | | | | | | | |
| | 119 | | | | | | | | | | | | | | | | | | | | |
| | 120 | Subtotal Hours | | | | | | 48 | 65 | 97 | 27 | 0 | 0 | 0 | | | | | Manhours | Helicopter | |
| | 121 | | | | | | | | | | | | | | | | | | 237 | 0 | |
| | 122 | Subtotal FRAMING, etc. | | | | | | | | | | | | | \$38,340 | \$26,391 | \$64,731 | \$64,731 | ok | | |

FILE E:\AEA-CVEA\PHASE1\DESIGN\COSTS\dbhf1.xls
 WO ACCOUNT WW-1669-HA1-AC
 CLIENT ALASKA ENERGY AUTHORITY
 PROJECT COPPER VALLEY INTERTIE FEASIBILITY STUDY
 FEATURE STRUCTURE DATA CONSOLIDATION
 ITEM TYPES dbf1
 BY PED 9/17/93
 CHECK

DBSHF1.XLS

ROUTE D 4
 SPECIES DF

Angle Distribution by Loading Zone

| Order | LOADING ZONE | | | |
|-------|--------------|----|----|---|
| | 1 | 2 | 3 | 4 |
| DE | 13 | 12 | 10 | 0 |
| LA | 4 | 1 | 6 | 0 |
| MA | 4 | 2 | 6 | 2 |
| SSA | 0 | 0 | 0 | 3 |
| total | 21 | 16 | 21 | 6 |

35 The cells in table at left are named LZ?_LA,MA,DE,SS]Q
 10 where Q denotes quantity.

14
 3

Tangents computed as Zone length/avg span-total this table.

Route and Loading Zone lengths (MILES)

Data below linked to file SEGTABL.xls

| ROUTE | LOADING ZONE | | | |
|-------|--------------|-------|-------|------|
| | 1 | 2 | 3 | 4 |
| A | 26.52 | 60.87 | 37.37 | 9.27 |
| B | 42.70 | 61.03 | 26.08 | 4.00 |
| C | 37.99 | 61.03 | 33.39 | 4.00 |
| D | 36.88 | 60.87 | 32.24 | 4.00 |

Cells named LEN_ALT[A,B,C,D]_LZ[1,2,3,4]

totals
 134.03
 133.79
 136.41
 133.99

Tangent Height Distribution

Enter original data assumptions below.

| Height | LOADING ZONE | | | |
|--------|--------------|-----|-----|-----|
| | 1 | 2 | 3 | 4 |
| 1 | 10% | 5% | 10% | 10% |
| 2 | 20% | 16% | 20% | 20% |
| 3 | 40% | 60% | 40% | 40% |
| 4 | 15% | 16% | 15% | 15% |
| 5 | 15% | 5% | 15% | 15% |

The cells in table at left are named LZ?_TANO_[1-5]
 where Q denotes quantity, and 1-5 represent the height range.
 vary with construction option.

BASE >>

ok ok ok ok Test if = 100%

BASE HEIGHTS ARE TAKEN AS HEIGHT 3 FOR DISTRIBUTION PURPOSES

Base Height/Length of Tangent Structures

Data taken from XFSUMM, HFSUMM, SHFSUMM and 1PSUMM.xls

Option

below

| | 1 | | | |
|--------|------|----------|------|--------|
| | Dove | T2Linnet | Teal | |
| SHF1 | 76 | 70 | 75 | SHF1 |
| SHF4 | 80 | 75 | 85 | SHF4 |
| SSP | 80 | 75 | 75 | SSP |
| SWP | 65 | 60 | 66 | SWP |
| WHF1 | 75 | 70 | 75 | WHF1 |
| WHF4 | 85 | 80 | 75 | WHF4 |
| XFRAME | 65 | 60 | 60 | XFRAME |

| | 2 | | | |
|--------|------|----------|------|--------|
| | Dove | T2Linnet | Teal | |
| SHF1 | 80 | 80 | 70 | SHF1 |
| SHF4 | 80 | 80 | 75 | SHF4 |
| SSP | na | na | na | SSP |
| SWP | na | na | na | SWP |
| WHF1 | 70 | 60 | 60 | WHF1 |
| WHF4 | 75 | 65 | 75 | WHF4 |
| XFRAME | 85 | 80 | 75 | XFRAME |

| | 3 | | | |
|--------|------|----------|------|--------|
| | Dove | T2Linnet | Teal | |
| SHF1 | 76 | 75 | 70 | SHF1 |
| SHF4 | 80 | 80 | 80 | SHF4 |
| SSP | na | na | na | SSP |
| SWP | na | na | na | SWP |
| WHF1 | 75 | 65 | 75 | WHF1 |
| WHF4 | 80 | 65 | 75 | WHF4 |
| XFRAME | 80 | 75 | 70 | XFRAME |

| 37#9aw | 4 | |
|--------|------|------|
| | Dove | Teal |
| 1 | 2 | 3 |
| 70 | na | 75 |
| 80 | na | 75 |
| na | na | na |
| na | na | na |
| na | na | na |
| na | na | na |
| na | na | na |
| 65 | 85 | 80 |

FILE E:\AEA-CVEA\PHASE1\DESIGN\COSTS\ldbshf1.xls
 WW-1659-HA1-AC
 CLIENT ALASKA ENERGY AUTHORITY
 PROJECT COPPER VALLEY INTERTIE FEASIBILITY STUDY
 FEATURE STRUCTURE DATA CONSOLIDATION
 ITEM TYPES shf1
 BY PED 9/17/93
 CHECK

DBSHF1.XLS

Base Height/Length of Angle Structures
 Computed from table of Base Height/Length of Tangent Structures.

| Option below | 1 | | | SHF1 SHF4 SSP SWP WHF1 WHF4 XFRAME | 2 | | | SHF1 SHF4 SSP SWP WHF1 WHF4 XFRAME | 3 | | | SHF1 SHF4 SSP SWP WHF1 WHF4 XFRAME | 4 | | | equal to B LZ2 equal B-10, else B-5 equal B + 5 equal to B LZ2 equal B-10, else B-5 equal B |
|--------------|------|----------|------|--|------|----------|------|--|------|----------|------|--|--------|------|------|--|
| | Dove | T2Linnet | Teal | | Dove | T2Linnet | Teal | | Dove | T2Linnet | Teal | | 37#9AW | Dove | Teal | |
| | 1 | 2 | 3 | | 1 | 2 | 3 | | 1 | 2 | 3 | | 1 | 2 | 3 | |
| SHF1 | 75 | 70 | 75 | SHF1 | 80 | 60 | 70 | SHF1 | 75 | 75 | 70 | SHF1 | 70 | na | 75 | equal to B |
| SHF4 | 75 | 70 | 80 | SHF4 | 70 | 70 | 65 | SHF4 | 75 | 75 | 75 | SHF4 | 75 | na | 70 | LZ2 equal B-10, else B-5 |
| SSP | 70 | 65 | 70 | SSP | na | na | na | SSP | na | na | na | SSP | na | na | na | equal B + 5 |
| SWP | 80 | 75 | 80 | SWP | na | na | na | SWP | na | na | na | SWP | na | na | na | equal B + 5 |
| WHF1 | 75 | 70 | 75 | WHF1 | 70 | 60 | 60 | WHF1 | 75 | 65 | 75 | WHF1 | na | na | na | equal to B |
| WHF4 | 80 | 75 | 70 | WHF4 | 65 | 55 | 65 | WHF4 | 75 | 60 | 70 | WHF4 | na | na | na | LZ2 equal B-10, else B-5 |
| XFRAME | 65 | 80 | 60 | XFRAME | 65 | 80 | 75 | XFRAME | 80 | 75 | 70 | XFRAME | 65 | 65 | 80 | equal B |

| | |
|-------|-----|
| DECR1 | -15 |
| DECR2 | -10 |
| INCR1 | 10 |
| INCR2 | 20 |

Average Spans by Conductor, Construction Option, Loading Zone
 NA means an incompatibility, i.e. option or conductor not suitable or not considered for Loading Zone
 Data below linked to files XFSUMM.xls, HFSUMM.xls, 1PSUMM.xls, SHFSUMM.xls.

| Option | 1 | | | SHF1 SHF4 SSP SWP WHF1 WHF4 XFRAME | 2 | | | SHF1 SHF4 SSP SWP WHF1 WHF4 XFRAME | 3 | | | SHF1 SHF4 SSP SWP WHF1 WHF4 XFRAME | 4 | | | Linked to SHFSUMM.xls Linked to SHFSUMM.xls Linked to 1PSUMM.xls Linked to 1PSUMM.xls Linked to HFSUMM.xls Linked to HFSUMM.xls Linked to XFSUMM.xls |
|--------|------|----------|------|--|------|----------|------|--|------|----------|------|--|--------|------|------|--|
| | Dove | T2Linnet | Teal | | Dove | T2Linnet | Teal | | Dove | T2Linnet | Teal | | 37#9aw | Dove | Teal | |
| | 1 | 2 | 3 | | 1 | 2 | 3 | | 1 | 2 | 3 | | 1 | 2 | 3 | |
| SHF1 | 873 | 881 | 991 | SHF1 | 1035 | 899 | 1088 | SHF1 | 923 | 1060 | 1068 | SHF1 | 958 | na | 608 | Linked to SHFSUMM.xls |
| SHF4 | 844 | 840 | 1021 | SHF4 | 972 | 1037 | 1025 | SHF4 | 892 | 1036 | 984 | SHF4 | 1019 | na | 635 | Linked to SHFSUMM.xls |
| SSP | 720 | 720 | 720 | SSP | na | na | na | SSP | na | na | na | SSP | na | na | na | Linked to 1PSUMM.xls |
| SWP | 412 | 381 | 466 | SWP | na | na | na | SWP | na | na | na | SWP | na | na | na | Linked to 1PSUMM.xls |
| WHF1 | 873 | 891 | 991 | WHF1 | 954 | 899 | 894 | WHF1 | 923 | 878 | 1019 | WHF1 | na | na | na | Linked to HFSUMM.xls |
| WHF4 | 900 | 912 | 866 | WHF4 | 930 | 869 | 1025 | WHF4 | 892 | 908 | 1041 | WHF4 | na | na | na | Linked to HFSUMM.xls |
| XFRAME | 908 | 913 | 941 | XFRAME | 1085 | 1105 | 1088 | XFRAME | 981 | 977 | 967 | XFRAME | 888 | 815 | 911 | Linked to XFSUMM.xls |

Wood Pole Estimating Costs
 Data linked to UNITCOST.xls
 Prices include freight to Anchorage.

Western Red Cedar

| Order | CLASS | 40 | 45 | 50 | 55 | 60 | 65 | 70 | 75 | 80 | 85 |
|-------|-------|---------|---------|---------|---------|---------|---------|---------|---------|---------|---------|
| 1 | 2 | \$603 | \$685 | \$905 | \$1,015 | \$1,125 | \$1,290 | \$1,455 | \$1,510 | \$1,895 | \$2,005 |
| 2 | 1 | \$830 | \$740 | \$981 | \$1,132 | \$1,289 | \$1,448 | \$1,628 | \$1,781 | \$2,170 | \$2,304 |
| 3 | H1 | \$795 | \$960 | \$1,125 | \$1,414 | \$1,585 | \$1,775 | \$2,041 | \$2,256 | \$2,404 | \$2,555 |
| 4 | H2 | \$1,015 | \$1,153 | \$1,325 | \$1,547 | \$1,742 | \$1,946 | \$2,224 | \$2,453 | \$2,704 | \$2,950 |

Douglas Fir

| Order | CLASS | 40 | 45 | 50 | 55 | 60 | 65 | 70 | 75 | 80 | 85 |
|-------|-------|-------|---------|---------|---------|---------|---------|---------|---------|---------|---------|
| 1 | 2 | \$575 | \$630 | \$850 | \$933 | \$1,015 | \$1,235 | \$1,455 | \$1,565 | \$1,785 | \$2,005 |
| 2 | 1 | \$658 | \$685 | \$912 | \$1,050 | \$1,209 | \$1,401 | \$1,609 | \$1,807 | \$2,037 | \$2,288 |
| 3 | H1 | \$740 | \$850 | \$1,015 | \$1,218 | \$1,473 | \$1,651 | \$1,839 | \$2,039 | \$2,248 | \$2,445 |
| 4 | H2 | \$905 | \$1,060 | \$1,218 | \$1,401 | \$1,654 | \$1,852 | \$2,060 | \$2,303 | \$2,534 | \$2,776 |

FILE
 WO ACCOUNT
 CLIENT
 PROJECT
 FEATURE
 ITEM
 BY
 CHECK

E:\AEA-CVEA\PHASE1\DESIGN\COSTS\dbshf1.xls
 WW-1659-HA1-AC
 ALASKA ENERGY AUTHORITY
 COPPER VALLEY INTERTIE FEASIBILITY STUDY
 STRUCTURE DATA CONSOLIDATION
 TYPES shf1
 PED 9/17/93

DBSHF1.XLS

Steel Pole Estimating Costs
 Data linked to UNITCOST.xls
 Prices include freight to Anchorage.
 Based on Meyers LD Series

| LENGTH(ft) | LD-1 | LD-10 | LD-2 | LD-3 | LD-4 | LD-5 | LD-6 | LD-7 | LD-8 | LD-9 |
|------------|---------|---------|---------|---------|---------|---------|---------|---------|---------|---------|
| 40 | \$1,077 | \$1,948 | \$1,111 | \$1,168 | \$1,293 | \$1,313 | \$1,523 | \$1,724 | \$1,790 | \$1,846 |
| 45 | \$1,236 | \$2,280 | \$1,280 | \$1,337 | \$1,460 | \$1,524 | \$1,768 | \$2,000 | \$2,083 | \$2,167 |
| 50 | \$1,403 | \$2,826 | \$1,457 | \$1,526 | \$1,668 | \$1,744 | \$2,024 | \$2,292 | \$2,393 | \$2,485 |
| 55 | \$1,576 | \$2,991 | \$1,640 | \$1,724 | \$1,886 | \$1,976 | \$2,294 | \$2,597 | \$2,722 | \$2,830 |
| 60 | \$1,761 | \$3,207 | \$1,829 | \$1,928 | \$2,100 | \$2,206 | \$2,664 | \$2,902 | \$2,914 | \$3,034 |
| 65 | \$1,936 | \$3,614 | \$2,027 | \$2,145 | \$2,347 | \$2,473 | \$2,874 | \$3,110 | \$3,273 | \$3,418 |
| 70 | \$2,129 | \$4,022 | \$2,234 | \$2,369 | \$2,590 | \$2,739 | \$3,043 | \$3,443 | \$3,631 | \$3,799 |
| 75 | \$2,327 | \$4,443 | \$2,448 | \$2,600 | \$2,846 | \$3,014 | \$3,361 | \$3,790 | \$4,006 | \$4,197 |
| 80 | \$2,421 | \$4,882 | \$2,551 | \$2,719 | \$2,973 | \$3,158 | \$3,669 | \$4,150 | \$4,395 | \$4,613 |
| 85 | \$2,622 | \$5,117 | \$2,770 | \$2,961 | \$3,235 | \$3,442 | \$4,001 | \$4,524 | \$4,582 | \$4,817 |
| 90 | \$2,830 | \$5,673 | \$2,986 | \$3,210 | \$3,502 | \$3,736 | \$4,344 | \$4,886 | \$4,983 | \$5,294 |
| 95 | \$2,904 | \$6,061 | \$3,080 | \$3,308 | \$3,610 | \$3,859 | \$4,486 | \$5,068 | \$5,399 | \$5,712 |
| 100 | \$3,122 | \$6,542 | \$3,319 | \$3,570 | \$3,885 | \$4,158 | \$5,198 | \$5,464 | \$5,845 | \$6,176 |
| 105 | \$3,338 | \$7,062 | \$3,553 | \$3,829 | \$4,169 | \$4,468 | \$5,570 | \$5,873 | \$6,292 | \$6,656 |
| 110 | \$3,558 | \$7,577 | \$3,794 | \$4,097 | \$4,461 | \$4,789 | \$6,172 | \$6,295 | \$6,764 | \$7,151 |
| 115 | \$3,908 | \$8,413 | \$4,163 | \$4,509 | \$4,811 | \$5,537 | \$6,570 | \$6,878 | \$7,482 | \$7,930 |
| 120 | \$4,138 | \$8,974 | \$4,422 | \$4,795 | \$5,219 | \$5,936 | \$6,570 | \$7,426 | \$7,973 | \$8,464 |

Weights

| LENGTH(ft) | LD-1 | LD-10 | LD-2 | LD-3 | LD-4 | LD-5 | LD-6 | LD-7 | LD-8 | LD-9 |
|------------|------|-------|------|------|------|------|------|------|------|------|
| 40 | 892 | 1814 | 920 | 957 | 1048 | 1087 | 1261 | 1428 | 1482 | 1528 |
| 45 | 1024 | 1888 | 1060 | 1107 | 1209 | 1262 | 1464 | 1656 | 1725 | 1786 |
| 50 | 1162 | 2175 | 1207 | 1264 | 1381 | 1444 | 1678 | 1898 | 1982 | 2058 |
| 55 | 1304 | 2477 | 1358 | 1428 | 1561 | 1638 | 1900 | 2151 | 2254 | 2344 |
| 60 | 1450 | 2777 | 1515 | 1597 | 1739 | 1827 | 2123 | 2403 | 2523 | 2627 |
| 65 | 1603 | 3129 | 1679 | 1776 | 1944 | 2048 | 2380 | 2693 | 2834 | 2959 |
| 70 | 1763 | 3482 | 1850 | 1962 | 2145 | 2268 | 2636 | 2981 | 3144 | 3289 |
| 75 | 1927 | 3847 | 2027 | 2163 | 2358 | 2496 | 2901 | 3281 | 3468 | 3634 |
| 80 | 2096 | 4229 | 2208 | 2354 | 2574 | 2734 | 3177 | 3593 | 3805 | 3994 |
| 85 | 2270 | 4641 | 2398 | 2564 | 2801 | 2980 | 3464 | 3917 | 4158 | 4369 |
| 90 | 2450 | 5055 | 2594 | 2779 | 3032 | 3235 | 3761 | 4250 | 4520 | 4775 |
| 95 | 2634 | 5488 | 2794 | 3000 | 3274 | 3500 | 4069 | 4597 | 4897 | 5181 |
| 100 | 2832 | 5934 | 3010 | 3238 | 3524 | 3771 | 4386 | 4958 | 5302 | 5601 |
| 105 | 3026 | 6396 | 3223 | 3473 | 3781 | 4053 | 4713 | 5327 | 5707 | 6036 |
| 110 | 3225 | 6873 | 3441 | 3716 | 4048 | 4344 | 5052 | 5710 | 6126 | 6486 |
| 115 | 3543 | 7631 | 3776 | 4090 | 4454 | 5022 | 5598 | 6329 | 6786 | 7193 |
| 120 | 3753 | 8140 | 4011 | 4349 | 4734 | 5384 | 5959 | 6738 | 7232 | 7677 |

FILE
 WO ACCOUNT
 CLIENT
 PROJECT
 FEATURE
 ITEM
 BY
 CHECK

E:\AEA-CVEA\PHASE1\DESIGN\COSTS\vbshf1.xls
 WW-1650-HA1-AC
 ALASKA ENERGY AUTHORITY
 COPPER VALLEY INTERTIE FEASIBILITY STUDY
 STRUCTURE DATA CONSOLIDATION
 TYPES shf1
 PED 9/17/03

DBSHF1.XLS

XFRAME steel estimating costs. Data linked to UNITCOST.xls. Prices include freight to Anchorage.

| | 0 | LOADING ZONE/costs | | | | LOADING ZONE/weights | | | |
|----------|-----|--------------------|----------|----------|----------|----------------------|------|-------|-------|
| | | 1 | 2 | 3 | 4 | 1 | 2 | 3 | 4 |
| 37#9AW | 35 | na | na | na | \$5,009 | na | na | na | 3833 |
| 37#9AW | 40 | na | na | na | \$4,804 | na | na | na | 4003 |
| 37#9AW | 45 | na | na | na | \$5,009 | na | na | na | 4174 |
| 37#9AW | 50 | na | na | na | \$5,213 | na | na | na | 4344 |
| 37#9AW | 55 | na | na | na | \$5,328 | na | na | na | 4515 |
| 37#9AW | 60 | na | na | na | \$5,996 | na | na | na | 5081 |
| 37#9AW | 65 | na | na | na | \$6,256 | na | na | na | 5302 |
| 37#9AW | 70 | na | na | na | \$6,517 | na | na | na | 5523 |
| 37#9AW | 75 | na | na | na | \$7,994 | na | na | na | 6951 |
| 37#9AW | 80 | na | na | na | \$8,377 | na | na | na | 7284 |
| 37#9AW | 85 | na | na | na | \$8,758 | na | na | na | 7816 |
| 37#9AW | 90 | na | na | na | \$9,141 | na | na | na | 7949 |
| 37#9AW | 95 | na | na | na | \$9,524 | na | na | na | 8282 |
| 37#9AW | 100 | na | na | na | \$9,907 | na | na | na | 8615 |
| 37#9AW | 105 | na | na | na | \$12,978 | na | na | na | 11285 |
| Dove | 35 | \$4,568 | \$4,901 | \$4,568 | #VALUE! | 3807 | 4084 | 3807 | na |
| Dove | 40 | \$4,772 | \$5,105 | \$4,772 | #VALUE! | 3977 | 4254 | 3977 | na |
| Dove | 45 | \$4,976 | \$5,310 | \$4,976 | #VALUE! | 4147 | 4425 | 4147 | na |
| Dove | 50 | \$5,182 | \$5,422 | \$5,182 | #VALUE! | 4318 | 4595 | 4318 | na |
| Dove | 55 | \$5,296 | \$5,824 | \$5,296 | #VALUE! | 4488 | 4768 | 4488 | na |
| Dove | 60 | \$5,498 | \$6,824 | \$5,498 | #VALUE! | 4659 | 4938 | 4659 | na |
| Dove | 65 | \$6,226 | \$6,553 | \$6,226 | #VALUE! | 5276 | 5563 | 5276 | na |
| Dove | 70 | \$6,488 | \$6,813 | \$6,488 | #VALUE! | 5497 | 5774 | 5497 | na |
| Dove | 75 | \$6,576 | \$6,895 | \$6,576 | #VALUE! | 5718 | 5996 | 5718 | na |
| Dove | 80 | \$6,830 | \$8,065 | \$6,830 | #VALUE! | 5839 | 7635 | 7267 | na |
| Dove | 85 | \$8,729 | \$9,048 | \$8,729 | #VALUE! | 7690 | 7868 | 7690 | na |
| Dove | 90 | \$9,111 | \$9,431 | \$9,111 | #VALUE! | 7923 | 8201 | 7923 | na |
| Dove | 95 | \$9,494 | \$9,813 | \$9,494 | #VALUE! | 8256 | 8533 | 8256 | na |
| Dove | 100 | \$9,877 | \$10,198 | \$9,877 | #VALUE! | 8589 | 8866 | 8589 | na |
| Dove | 105 | \$10,260 | \$10,579 | \$10,260 | #VALUE! | 8922 | 9199 | 8922 | na |
| T2Linnet | 35 | \$4,875 | \$4,875 | \$4,875 | na | 3896 | 3896 | 3896 | na |
| T2Linnet | 40 | \$4,879 | \$4,879 | \$4,879 | na | 4066 | 4066 | 4066 | na |
| T2Linnet | 45 | \$5,083 | \$5,083 | \$5,083 | na | 4236 | 4236 | 4236 | na |
| T2Linnet | 50 | \$5,288 | \$5,288 | \$5,288 | na | 4407 | 4407 | 4407 | na |
| T2Linnet | 55 | \$5,401 | \$5,401 | \$5,401 | na | 4577 | 4577 | 4577 | na |
| T2Linnet | 60 | \$6,070 | \$6,070 | \$6,070 | na | 5144 | 5144 | 5144 | na |
| T2Linnet | 65 | \$6,331 | \$6,331 | \$6,331 | na | 5365 | 5365 | 5365 | na |
| T2Linnet | 70 | \$6,591 | \$6,591 | \$6,591 | na | 5586 | 5586 | 5586 | na |
| T2Linnet | 75 | \$8,065 | \$8,065 | \$8,065 | na | 7013 | 5807 | 7013 | na |
| T2Linnet | 80 | \$8,448 | \$8,448 | \$8,448 | na | 7348 | 7348 | 7348 | na |
| T2Linnet | 85 | \$8,903 | \$8,903 | \$8,386 | na | 7742 | 7742 | 8182 | na |
| T2Linnet | 90 | \$9,286 | \$9,286 | \$9,769 | na | 8075 | 8075 | 8495 | na |
| T2Linnet | 95 | \$9,669 | \$9,669 | \$10,152 | na | 8408 | 8408 | 8828 | na |
| T2Linnet | 100 | \$10,052 | \$10,052 | \$10,535 | na | 8741 | 8741 | 9181 | na |
| T2Linnet | 105 | \$10,435 | \$10,435 | \$13,806 | na | 9074 | 9074 | 11831 | na |
| Teal | 35 | \$4,417 | \$4,750 | \$4,750 | \$5,254 | 3881 | 3958 | 3958 | 4378 |
| Teal | 40 | \$4,621 | \$4,955 | \$4,955 | \$5,368 | 3851 | 4129 | 4129 | 4549 |
| Teal | 45 | \$4,826 | \$5,159 | \$5,159 | \$5,568 | 4022 | 4289 | 4289 | 4719 |
| Teal | 50 | \$5,030 | \$5,364 | \$5,364 | \$5,770 | 4182 | 4470 | 4470 | 4890 |
| Teal | 55 | \$5,148 | \$5,475 | \$5,475 | \$5,971 | 4383 | 4640 | 4640 | 5060 |
| Teal | 60 | \$5,349 | \$5,677 | \$5,677 | \$6,039 | 4533 | 4811 | 4811 | 5228 |
| Teal | 65 | \$6,077 | \$6,405 | \$6,405 | \$6,899 | 5150 | 5428 | 5428 | 5847 |
| Teal | 70 | \$6,338 | \$6,666 | \$6,842 | \$7,161 | 5371 | 5649 | 5629 | 6069 |
| Teal | 75 | \$6,431 | \$6,751 | \$6,941 | \$8,020 | 5582 | 5870 | 5870 | 7498 |
| Teal | 80 | \$8,202 | \$8,520 | \$8,520 | \$9,000 | 7132 | 7409 | 7409 | 7828 |

FILE
 WO ACCOUNT
 CLIENT
 PROJECT
 FEATURE
 ITEM
 BY
 CHECK

E:\AEA-CVE\PHASE1\DESIGN\COSTS\vbshf1.xls
 WW-1559-HA1-AC
 ALASKA ENERGY AUTHORITY
 COPPER VALLEY INTERTIE FEASIBILITY STUDY
 STRUCTURE DATA CONSOLIDATION
 TYPE# shf1
 PED 8/17/93

DBSHF1.XLS

| | | | | | | | | | |
|------|-----|----------|----------|----------|----------|------|------|------|-------|
| Teal | 85 | \$8,586 | \$8,803 | \$8,803 | \$9,388 | 7465 | 7742 | 7742 | 8182 |
| Teal | 90 | \$8,968 | \$9,286 | \$9,286 | \$9,769 | 7798 | 8075 | 8075 | 8495 |
| Teal | 95 | \$9,350 | \$9,669 | \$9,669 | \$10,152 | 8130 | 8408 | 8408 | 8828 |
| Teal | 100 | \$9,732 | \$10,052 | \$10,052 | \$10,535 | 8483 | 8741 | 8741 | 9161 |
| Teal | 105 | \$10,115 | \$10,435 | \$10,435 | \$13,608 | 8796 | 9074 | 9074 | 11831 |

Classes of Single Poles

| Option | SHF1 | 1 | | | 2 | | | 3 | | | 4 | | |
|---------|------|-------|-------|----------|-------|-------|----------|-------|-------|----------|-------|-------|--------|
| | | Teal | Dove | T2Linnet | Teal | Dove | T2Linnet | Teal | Dove | T2Linnet | Teal | Dove | 37#9AW |
| HFRAME1 | TAN | LD-2 | LD-1 | LD-2 | LD-2 | LD-2 | LD-2 | LD-2 | LD-1 | LD-3 | LD-2 | na | LD-3 |
| HFRAME1 | TAN | LD-2 | LD-1 | LD-2 | LD-2 | LD-2 | LD-2 | LD-2 | LD-1 | LD-3 | LD-2 | na | LD-3 |
| HFRAME1 | TAN | LD-2 | LD-1 | LD-2 | LD-2 | LD-2 | LD-2 | LD-2 | LD-1 | LD-3 | LD-2 | na | LD-3 |
| HFRAME1 | TAN | LD-2 | LD-1 | LD-2 | LD-2 | LD-2 | LD-2 | LD-2 | LD-1 | LD-3 | LD-2 | na | LD-3 |
| HFRAME1 | TAN | LD-2 | LD-1 | LD-2 | LD-2 | LD-2 | LD-2 | LD-2 | LD-1 | LD-3 | LD-2 | na | LD-3 |
| SSP | LA | LD-3 | LD-3 | LD-3 | LD-3 | LD-3 | LD-3 | LD-3 | LD-3 | LD-3 | LD-2 | LD-2 | LD-3 |
| SSP | LA | LD-3 | LD-3 | LD-3 | LD-3 | LD-3 | LD-3 | LD-3 | LD-3 | LD-3 | LD-2 | LD-2 | LD-3 |
| SSP | LA | LD-3 | LD-3 | LD-3 | LD-3 | LD-3 | LD-3 | LD-3 | LD-3 | LD-3 | LD-3 | LD-3 | LD-4 |
| SSP | LA | LD-3 | LD-3 | LD-3 | LD-3 | LD-3 | LD-3 | LD-3 | LD-3 | LD-3 | LD-3 | LD-3 | LD-4 |
| SSP | LA | LD-3 | LD-3 | LD-3 | LD-3 | LD-3 | LD-3 | LD-3 | LD-3 | LD-3 | LD-4 | LD-4 | LD-4 |
| SSP | MA | LD-2 | LD-2 | LD-2 | LD-1 | LD-2 | LD-2 | LD-2 | LD-1 | LD-2 | LD-3 | LD-4 | LD-4 |
| SSP | MA | LD-3 | LD-2 | LD-2 | LD-1 | LD-2 | LD-2 | LD-2 | LD-1 | LD-2 | LD-3 | LD-4 | LD-4 |
| SSP | MA | LD-3 | LD-2 | LD-2 | LD-2 | LD-3 | LD-2 | LD-3 | LD-2 | LD-3 | LD-4 | LD-4 | LD-6 |
| SSP | MA | LD-3 | LD-3 | LD-3 | LD-2 | LD-3 | LD-2 | LD-3 | LD-2 | LD-3 | LD-4 | LD-4 | LD-6 |
| SSP | MA | LD-3 | LD-3 | LD-3 | LD-2 | LD-3 | LD-2 | LD-3 | LD-3 | LD-3 | LD-5 | LD-5 | LD-6 |
| SSP | MA | LD-3 | LD-3 | LD-3 | LD-2 | LD-3 | LD-2 | LD-3 | LD-3 | LD-3 | LD-5 | LD-5 | LD-6 |
| SSP | DE | LD-9 | LD-9 | LD-9 | LD-8 | LD-9 | LD-7 | LD-9 | LD-9 | LD-9 | LD-9 | LD-9 | LD-10 |
| SSP | DE | LD-9 | LD-9 | LD-9 | LD-8 | LD-9 | LD-7 | LD-9 | LD-9 | LD-9 | LD-10 | LD-10 | LD-10 |
| SSP | DE | LD-10 | LD-10 | LD-10 | LD-9 | LD-9 | LD-7 | LD-10 | LD-10 | LD-10 | LD-10 | LD-10 | LD-10 |
| SSP | DE | LD-10 | LD-10 | LD-10 | LD-9 | LD-9 | LD-7 | LD-10 | LD-10 | LD-10 | LD-10 | LD-10 | LD-10 |
| SSP | DE | LD-10 | LD-10 | LD-10 | LD-10 | LD-10 | LD-7 | LD-10 | LD-10 | LD-10 | LD-10 | LD-10 | LD-10 |

FILE E:\AEA-CVEA\PHASE1\DESIGN\COSTS\vbshf1.xls
 WO ACCOUNT WW-1559-HA1-AC
 CLIENT ALASKA ENERGY AUTHORITY
 PROJECT COPPER VALLEY INTERTIE FEASIBILITY STUDY
 FEATURE STRUCTURE DATA CONSOLIDATION
 ITEM TYPES shf1
 BY PED 9/17/93
 CHECK

REMEMBER: RESET DATABASE EACH FILE
 START DATABASE ENTRIES FOR STRUCTURES

INPUT Option: shf1
 INPUT Zone: 1,2,3,4
 INPUT Conductor: Teal, Dove, T2LInnet, 37#9AW
 INPUT Application: TAN, LA, MA, DE
 INPUT Index: 1,2,3,4,5 used to selected structure heights
 FORM Type: xframe, hframe1, hframe4, 1g-pole, 3g-pole
 FORM Material: wood, steel
 FORM Lmin: Minimum length or height of structure based on structure dimensions and required ground clearance at structure.
 FORM Baselength: Base length/height of structure corresponding to Index 3
 FORM Length: Length of particular structure corresponding to index 1-5
 FORM If Baselength + DECR1 < Lmin, Lmin + (Index-1)*5
 FORM If Baselength + DECR1 > =Lmin, BL + DECR1, BL + DECR2, BL + INCR1, BL + INCR2
 FORM Class: structure class (I2,1,H1,H2 for Wood) and (LD-x for steel)
 FORM Quantity: number of structures depending on zone,option, etc.
 FORM Cost: unit cost taken from lookup table above.

| Option | Zone | Conductor | Application | Type | Material | Index | Lmin | Baselength | Length | Class | Quantity | Cost |
|--------|------|-----------|-------------|----------|----------|-------|------|------------|--------|-------|----------|-------|
| shf1 | 1 | teal | tan | Hframe1 | steel | 1 | 55 | 75 | 80 | LD-2 | 18 | 3659 |
| shf1 | 1 | teal | tan | Hframe1 | steel | 2 | 55 | 75 | 85 | LD-2 | 35 | 4055 |
| shf1 | 1 | teal | tan | Hframe1 | steel | 3 | 55 | 75 | 75 | LD-2 | 70 | 4895 |
| shf1 | 1 | teal | tan | Hframe1 | steel | 4 | 55 | 75 | 85 | LD-2 | 26 | 5639 |
| shf1 | 1 | teal | tan | Hframe1 | steel | 5 | 55 | 75 | 85 | LD-2 | 26 | 6161 |
| shf1 | 1 | teal | la | _3G.Pole | steel | 1 | 55 | 75 | 80 | LD-3 | 0 | 5785 |
| shf1 | 1 | teal | la | _3G.Pole | steel | 2 | 55 | 75 | 85 | LD-3 | 1 | 6434 |
| shf1 | 1 | teal | la | _3G.Pole | steel | 3 | 55 | 75 | 75 | LD-3 | 2 | 7799 |
| shf1 | 1 | teal | la | _3G.Pole | steel | 4 | 55 | 75 | 85 | LD-3 | 1 | 8884 |
| shf1 | 1 | teal | la | _3G.Pole | steel | 5 | 55 | 75 | 85 | LD-3 | 1 | 9923 |
| shf1 | 1 | teal | ma | _3G.Pole | steel | 1 | 55 | 75 | 80 | LD-2 | 0 | 5488 |
| shf1 | 1 | teal | ma | _3G.Pole | steel | 2 | 55 | 75 | 85 | LD-3 | 1 | 6434 |
| shf1 | 1 | teal | ma | _3G.Pole | steel | 3 | 55 | 75 | 75 | LD-3 | 2 | 7799 |
| shf1 | 1 | teal | ma | _3G.Pole | steel | 4 | 55 | 75 | 85 | LD-3 | 1 | 8884 |
| shf1 | 1 | teal | ma | _3G.Pole | steel | 5 | 55 | 75 | 85 | LD-3 | 1 | 9923 |
| shf1 | 1 | teal | de | _3G.Pole | steel | 1 | 55 | 75 | 80 | LD-9 | 1 | 9103 |
| shf1 | 1 | teal | de | _3G.Pole | steel | 2 | 55 | 75 | 85 | LD-8 | 3 | 10253 |
| shf1 | 1 | teal | de | _3G.Pole | steel | 3 | 55 | 75 | 75 | LD-10 | 5 | 13330 |
| shf1 | 1 | teal | de | _3G.Pole | steel | 4 | 55 | 75 | 85 | LD-10 | 2 | 15350 |
| shf1 | 1 | teal | de | _3G.Pole | steel | 5 | 55 | 75 | 85 | LD-10 | 2 | 18152 |
| shf1 | 1 | dove | tan | Hframe1 | steel | 1 | 55 | 75 | 80 | LD-1 | 20 | 3502 |
| shf1 | 1 | dove | tan | Hframe1 | steel | 2 | 55 | 75 | 85 | LD-1 | 40 | 3871 |
| shf1 | 1 | dove | tan | Hframe1 | steel | 3 | 55 | 75 | 75 | LD-1 | 81 | 4654 |
| shf1 | 1 | dove | tan | Hframe1 | steel | 4 | 55 | 75 | 85 | LD-1 | 30 | 5244 |
| shf1 | 1 | dove | tan | Hframe1 | steel | 5 | 55 | 75 | 85 | LD-1 | 30 | 5808 |
| shf1 | 1 | dove | la | _3G.Pole | steel | 1 | 55 | 75 | 80 | LD-3 | 0 | 5785 |
| shf1 | 1 | dove | la | _3G.Pole | steel | 2 | 55 | 75 | 85 | LD-3 | 1 | 6434 |
| shf1 | 1 | dove | la | _3G.Pole | steel | 3 | 55 | 75 | 75 | LD-3 | 2 | 7799 |
| shf1 | 1 | dove | la | _3G.Pole | steel | 4 | 55 | 75 | 85 | LD-3 | 1 | 8884 |
| shf1 | 1 | dove | la | _3G.Pole | steel | 5 | 55 | 75 | 85 | LD-3 | 1 | 9923 |
| shf1 | 1 | dove | ma | _3G.Pole | steel | 1 | 55 | 75 | 80 | LD-2 | 0 | 5488 |
| shf1 | 1 | dove | ma | _3G.Pole | steel | 2 | 55 | 75 | 85 | LD-2 | 1 | 6082 |
| shf1 | 1 | dove | ma | _3G.Pole | steel | 3 | 55 | 75 | 75 | LD-2 | 2 | 7343 |
| shf1 | 1 | dove | ma | _3G.Pole | steel | 4 | 55 | 75 | 85 | LD-3 | 1 | 8884 |
| shf1 | 1 | dove | ma | _3G.Pole | steel | 5 | 55 | 75 | 85 | LD-3 | 1 | 9923 |
| shf1 | 1 | dove | de | _3G.Pole | steel | 1 | 55 | 75 | 80 | LD-9 | 1 | 9103 |
| shf1 | 1 | dove | de | _3G.Pole | steel | 2 | 55 | 75 | 85 | LD-9 | 3 | 10253 |
| shf1 | 1 | dove | de | _3G.Pole | steel | 3 | 55 | 75 | 75 | LD-10 | 5 | 13330 |

FILE
 WO ACCOUNT
 CLIENT
 PROJECT
 FEATURE
 ITEM
 BY
 CHECK

E:\AEA-CVE\PHASE1\DESIGN\COSTS\dbshf1.xls
 WV-1669-HA1-AC
 ALASKA ENERGY AUTHORITY
 COPPER VALLEY INTERTIE FEASIBILITY STUDY
 STRUCTURE DATA CONSOLIDATION
 TYPES shf1
 PED 9/17/93

DBSHF1.XLS

| | | | | | | | | | | | | |
|------|---|----------|-----|----------|-------|---|----|----|-----|-------|-----|-------|
| shf1 | 1 | dove | de | _3G.Pole | steel | 4 | 55 | 75 | 85 | LD-10 | 2 | 16350 |
| shf1 | 1 | dove | de | _3G.Pole | steel | 5 | 55 | 75 | 95 | LD-10 | 2 | 18152 |
| shf1 | 1 | t2linnet | tan | Hframe1 | steel | 1 | 55 | 70 | 55 | LD-2 | 20 | 3280 |
| shf1 | 1 | t2linnet | tan | Hframe1 | steel | 2 | 55 | 70 | 60 | LD-2 | 40 | 3659 |
| shf1 | 1 | t2linnet | tan | Hframe1 | steel | 3 | 55 | 70 | 70 | LD-2 | 80 | 4488 |
| shf1 | 1 | t2linnet | tan | Hframe1 | steel | 4 | 55 | 70 | 80 | LD-2 | 30 | 5103 |
| shf1 | 1 | t2linnet | tan | Hframe1 | steel | 5 | 55 | 70 | 90 | LD-2 | 30 | 5992 |
| shf1 | 1 | t2linnet | la | _3G.Pole | steel | 1 | 55 | 70 | 55 | LD-3 | 0 | 5173 |
| shf1 | 1 | t2linnet | la | _3G.Pole | steel | 2 | 55 | 70 | 60 | LD-3 | 1 | 5785 |
| shf1 | 1 | t2linnet | la | _3G.Pole | steel | 3 | 55 | 70 | 70 | LD-3 | 2 | 7107 |
| shf1 | 1 | t2linnet | la | _3G.Pole | steel | 4 | 55 | 70 | 80 | LD-3 | 1 | 8157 |
| shf1 | 1 | t2linnet | la | _3G.Pole | steel | 5 | 55 | 70 | 90 | LD-3 | 1 | 9829 |
| shf1 | 1 | t2linnet | ma | _3G.Pole | steel | 1 | 55 | 70 | 55 | LD-2 | 0 | 4919 |
| shf1 | 1 | t2linnet | ma | _3G.Pole | steel | 2 | 55 | 70 | 60 | LD-2 | 1 | 5488 |
| shf1 | 1 | t2linnet | ma | _3G.Pole | steel | 3 | 55 | 70 | 70 | LD-3 | 2 | 7107 |
| shf1 | 1 | t2linnet | ma | _3G.Pole | steel | 4 | 55 | 70 | 80 | LD-3 | 1 | 8157 |
| shf1 | 1 | t2linnet | ma | _3G.Pole | steel | 5 | 55 | 70 | 90 | LD-3 | 1 | 9829 |
| shf1 | 1 | t2linnet | de | _3G.Pole | steel | 1 | 55 | 70 | 55 | LD-8 | 1 | 8491 |
| shf1 | 1 | t2linnet | de | _3G.Pole | steel | 2 | 55 | 70 | 60 | LD-8 | 3 | 9103 |
| shf1 | 1 | t2linnet | de | _3G.Pole | steel | 3 | 55 | 70 | 70 | LD-10 | 5 | 12085 |
| shf1 | 1 | t2linnet | de | _3G.Pole | steel | 4 | 55 | 70 | 80 | LD-10 | 2 | 13987 |
| shf1 | 1 | t2linnet | de | _3G.Pole | steel | 5 | 55 | 70 | 90 | LD-10 | 2 | 18719 |
| shf1 | 2 | teal | tan | Hframe1 | steel | 1 | 35 | 70 | 55 | LD-2 | 14 | 3280 |
| shf1 | 2 | teal | tan | Hframe1 | steel | 2 | 35 | 70 | 60 | LD-2 | 43 | 3659 |
| shf1 | 2 | teal | tan | Hframe1 | steel | 3 | 35 | 70 | 70 | LD-2 | 172 | 4488 |
| shf1 | 2 | teal | tan | Hframe1 | steel | 4 | 35 | 70 | 80 | LD-2 | 43 | 5103 |
| shf1 | 2 | teal | tan | Hframe1 | steel | 5 | 35 | 70 | 90 | LD-2 | 14 | 5992 |
| shf1 | 2 | teal | la | _3G.Pole | steel | 1 | 55 | 70 | 55 | LD-3 | 0 | 5173 |
| shf1 | 2 | teal | la | _3G.Pole | steel | 2 | 55 | 70 | 60 | LD-3 | 0 | 5785 |
| shf1 | 2 | teal | la | _3G.Pole | steel | 3 | 55 | 70 | 70 | LD-3 | 1 | 7107 |
| shf1 | 2 | teal | la | _3G.Pole | steel | 4 | 55 | 70 | 80 | LD-3 | 0 | 8157 |
| shf1 | 2 | teal | la | _3G.Pole | steel | 5 | 55 | 70 | 90 | LD-3 | 0 | 9829 |
| shf1 | 2 | teal | ma | _3G.Pole | steel | 1 | 55 | 70 | 55 | LD-1 | 0 | 4724 |
| shf1 | 2 | teal | ma | _3G.Pole | steel | 2 | 55 | 70 | 60 | LD-1 | 0 | 5253 |
| shf1 | 2 | teal | ma | _3G.Pole | steel | 3 | 55 | 70 | 70 | LD-2 | 1 | 6702 |
| shf1 | 2 | teal | ma | _3G.Pole | steel | 4 | 55 | 70 | 80 | LD-2 | 0 | 7654 |
| shf1 | 2 | teal | ma | _3G.Pole | steel | 5 | 55 | 70 | 90 | LD-2 | 0 | 8988 |
| shf1 | 2 | teal | de | _3G.Pole | steel | 1 | 55 | 70 | 55 | LD-8 | 1 | 8185 |
| shf1 | 2 | teal | de | _3G.Pole | steel | 2 | 55 | 70 | 60 | LD-8 | 2 | 8742 |
| shf1 | 2 | teal | de | _3G.Pole | steel | 3 | 55 | 70 | 70 | LD-8 | 7 | 11398 |
| shf1 | 2 | teal | de | _3G.Pole | steel | 4 | 55 | 70 | 80 | LD-8 | 2 | 13839 |
| shf1 | 2 | teal | de | _3G.Pole | steel | 5 | 55 | 70 | 90 | LD-10 | 1 | 18719 |
| shf1 | 2 | dove | tan | Hframe1 | steel | 1 | 35 | 80 | 65 | LD-2 | 15 | 4055 |
| shf1 | 2 | dove | tan | Hframe1 | steel | 2 | 35 | 80 | 70 | LD-2 | 44 | 4488 |
| shf1 | 2 | dove | tan | Hframe1 | steel | 3 | 35 | 80 | 80 | LD-2 | 177 | 5103 |
| shf1 | 2 | dove | tan | Hframe1 | steel | 4 | 35 | 80 | 90 | LD-2 | 44 | 5992 |
| shf1 | 2 | dove | tan | Hframe1 | steel | 5 | 35 | 80 | 100 | LD-2 | 15 | 6837 |
| shf1 | 2 | dove | la | _3G.Pole | steel | 1 | 55 | 80 | 65 | LD-3 | 0 | 6434 |
| shf1 | 2 | dove | la | _3G.Pole | steel | 2 | 55 | 80 | 70 | LD-3 | 0 | 7107 |
| shf1 | 2 | dove | la | _3G.Pole | steel | 3 | 55 | 80 | 80 | LD-3 | 1 | 8157 |
| shf1 | 2 | dove | la | _3G.Pole | steel | 4 | 55 | 80 | 90 | LD-3 | 0 | 8829 |
| shf1 | 2 | dove | la | _3G.Pole | steel | 5 | 55 | 80 | 100 | LD-3 | 0 | 10710 |
| shf1 | 2 | dove | ma | _3G.Pole | steel | 1 | 55 | 80 | 65 | LD-2 | 0 | 6082 |
| shf1 | 2 | dove | ma | _3G.Pole | steel | 2 | 55 | 80 | 70 | LD-2 | 0 | 6702 |
| shf1 | 2 | dove | ma | _3G.Pole | steel | 3 | 55 | 80 | 80 | LD-3 | 1 | 8157 |
| shf1 | 2 | dove | ma | _3G.Pole | steel | 4 | 55 | 80 | 90 | LD-3 | 0 | 8829 |
| shf1 | 2 | dove | ma | _3G.Pole | steel | 5 | 55 | 80 | 100 | LD-3 | 0 | 10710 |
| shf1 | 2 | dove | de | _3G.Pole | steel | 1 | 55 | 80 | 65 | LD-8 | 1 | 10253 |

FILE
 WO ACCOUNT
 CLIENT
 PROJECT
 FEATURE
 ITEM
 BY
 CHECK

E:\AEA-CVEA\PHASE1\DESIGN\COSTS\dbshf1.xls
 WW-1658-HA1-AC
 ALASKA ENERGY AUTHORITY
 COPPER VALLEY INTERTIE FEASIBILITY STUDY
 STRUCTURE DATA CONSOLIDATION
 TYPE6 shf1
 PED 9/17/83

D8SHF1.XLS

| | | | | | | | | | | | | |
|------|---|----------|-----|----------|-------|---|----|----|-----|-------|-----|-------|
| shf1 | 2 | dove | de | _3G.Pole | steel | 2 | 55 | 80 | 70 | LD-9 | 2 | 11398 |
| shf1 | 2 | dove | de | _3G.Pole | steel | 3 | 55 | 80 | 80 | LD-9 | 7 | 13839 |
| shf1 | 2 | dove | de | _3G.Pole | steel | 4 | 55 | 80 | 80 | LD-9 | 2 | 15793 |
| shf1 | 2 | dove | de | _3G.Pole | steel | 5 | 55 | 80 | 100 | LD-10 | 1 | 19827 |
| shf1 | 2 | t2linnet | tan | Hframe1 | steel | 1 | 35 | 60 | 45 | LD-2 | 17 | 2560 |
| shf1 | 2 | t2linnet | tan | Hframe1 | steel | 2 | 35 | 60 | 50 | LD-2 | 51 | 2915 |
| shf1 | 2 | t2linnet | tan | Hframe1 | steel | 3 | 35 | 60 | 60 | LD-2 | 206 | 3659 |
| shf1 | 2 | t2linnet | tan | Hframe1 | steel | 4 | 35 | 60 | 70 | LD-2 | 51 | 4468 |
| shf1 | 2 | t2linnet | tan | Hframe1 | steel | 5 | 35 | 60 | 80 | LD-2 | 17 | 5103 |
| shf1 | 2 | t2linnet | la | _3G.Pole | steel | 1 | 55 | 60 | 55 | LD-3 | 0 | 5173 |
| shf1 | 2 | t2linnet | la | _3G.Pole | steel | 2 | 55 | 60 | 60 | LD-3 | 0 | 5785 |
| shf1 | 2 | t2linnet | la | _3G.Pole | steel | 3 | 55 | 60 | 65 | LD-3 | 1 | 6434 |
| shf1 | 2 | t2linnet | la | _3G.Pole | steel | 4 | 55 | 60 | 70 | LD-3 | 0 | 7107 |
| shf1 | 2 | t2linnet | la | _3G.Pole | steel | 5 | 55 | 60 | 75 | LD-3 | 0 | 7799 |
| shf1 | 2 | t2linnet | ma | _3G.Pole | steel | 1 | 55 | 60 | 55 | LD-2 | 0 | 4919 |
| shf1 | 2 | t2linnet | ma | _3G.Pole | steel | 2 | 55 | 60 | 60 | LD-2 | 0 | 5488 |
| shf1 | 2 | t2linnet | ma | _3G.Pole | steel | 3 | 55 | 60 | 65 | LD-2 | 1 | 6082 |
| shf1 | 2 | t2linnet | ma | _3G.Pole | steel | 4 | 55 | 60 | 70 | LD-2 | 0 | 6702 |
| shf1 | 2 | t2linnet | ma | _3G.Pole | steel | 5 | 55 | 60 | 75 | LD-2 | 0 | 7343 |
| shf1 | 2 | t2linnet | de | _3G.Pole | steel | 1 | 55 | 60 | 55 | LD-7 | 1 | 7792 |
| shf1 | 2 | t2linnet | de | _3G.Pole | steel | 2 | 55 | 60 | 60 | LD-7 | 2 | 8705 |
| shf1 | 2 | t2linnet | de | _3G.Pole | steel | 3 | 55 | 60 | 65 | LD-7 | 7 | 9331 |
| shf1 | 2 | t2linnet | de | _3G.Pole | steel | 4 | 55 | 60 | 70 | LD-7 | 2 | 10329 |
| shf1 | 2 | t2linnet | de | _3G.Pole | steel | 5 | 55 | 60 | 75 | LD-7 | 1 | 11399 |
| shf1 | 3 | teal | tan | Hframe1 | steel | 1 | 55 | 70 | 55 | LD-2 | 14 | 3280 |
| shf1 | 3 | teal | tan | Hframe1 | steel | 2 | 55 | 70 | 60 | LD-2 | 28 | 3659 |
| shf1 | 3 | teal | tan | Hframe1 | steel | 3 | 55 | 70 | 70 | LD-2 | 55 | 4468 |
| shf1 | 3 | teal | tan | Hframe1 | steel | 4 | 55 | 70 | 80 | LD-2 | 21 | 5103 |
| shf1 | 3 | teal | tan | Hframe1 | steel | 5 | 55 | 70 | 80 | LD-2 | 21 | 5982 |
| shf1 | 3 | teal | la | _3G.Pole | steel | 1 | 55 | 70 | 55 | LD-3 | 1 | 5173 |
| shf1 | 3 | teal | la | _3G.Pole | steel | 2 | 55 | 70 | 60 | LD-3 | 1 | 5785 |
| shf1 | 3 | teal | la | _3G.Pole | steel | 3 | 55 | 70 | 70 | LD-3 | 2 | 7107 |
| shf1 | 3 | teal | la | _3G.Pole | steel | 4 | 55 | 70 | 80 | LD-3 | 1 | 8157 |
| shf1 | 3 | teal | la | _3G.Pole | steel | 5 | 55 | 70 | 90 | LD-3 | 1 | 9829 |
| shf1 | 3 | teal | ma | _3G.Pole | steel | 1 | 55 | 70 | 55 | LD-2 | 1 | 4919 |
| shf1 | 3 | teal | ma | _3G.Pole | steel | 2 | 55 | 70 | 60 | LD-2 | 1 | 5488 |
| shf1 | 3 | teal | ma | _3G.Pole | steel | 3 | 55 | 70 | 70 | LD-3 | 2 | 7107 |
| shf1 | 3 | teal | ma | _3G.Pole | steel | 4 | 55 | 70 | 80 | LD-3 | 1 | 8157 |
| shf1 | 3 | teal | ma | _3G.Pole | steel | 5 | 55 | 70 | 90 | LD-3 | 1 | 9829 |
| shf1 | 3 | teal | de | _3G.Pole | steel | 1 | 55 | 70 | 55 | LD-9 | 1 | 8481 |
| shf1 | 3 | teal | de | _3G.Pole | steel | 2 | 55 | 70 | 60 | LD-9 | 2 | 9103 |
| shf1 | 3 | teal | de | _3G.Pole | steel | 3 | 55 | 70 | 70 | LD-10 | 4 | 12085 |
| shf1 | 3 | teal | de | _3G.Pole | steel | 4 | 55 | 70 | 80 | LD-10 | 2 | 13987 |
| shf1 | 3 | teal | de | _3G.Pole | steel | 5 | 55 | 70 | 90 | LD-10 | 2 | 16719 |
| shf1 | 3 | dove | tan | Hframe1 | steel | 1 | 55 | 75 | 60 | LD-1 | 16 | 3502 |
| shf1 | 3 | dove | tan | Hframe1 | steel | 2 | 55 | 75 | 65 | LD-1 | 33 | 3871 |
| shf1 | 3 | dove | tan | Hframe1 | steel | 3 | 55 | 75 | 75 | LD-1 | 65 | 4654 |
| shf1 | 3 | dove | tan | Hframe1 | steel | 4 | 55 | 75 | 85 | LD-1 | 25 | 5244 |
| shf1 | 3 | dove | tan | Hframe1 | steel | 5 | 55 | 75 | 95 | LD-1 | 25 | 5808 |
| shf1 | 3 | dove | la | _3G.Pole | steel | 1 | 55 | 75 | 60 | LD-3 | 1 | 5785 |
| shf1 | 3 | dove | la | _3G.Pole | steel | 2 | 55 | 75 | 65 | LD-3 | 1 | 6434 |
| shf1 | 3 | dove | la | _3G.Pole | steel | 3 | 55 | 75 | 75 | LD-3 | 2 | 7799 |
| shf1 | 3 | dove | la | _3G.Pole | steel | 4 | 55 | 75 | 85 | LD-3 | 1 | 8884 |
| shf1 | 3 | dove | la | _3G.Pole | steel | 5 | 55 | 75 | 95 | LD-3 | 1 | 9923 |
| shf1 | 3 | dove | ma | _3G.Pole | steel | 1 | 55 | 75 | 60 | LD-1 | 1 | 5253 |
| shf1 | 3 | dove | ma | _3G.Pole | steel | 2 | 55 | 75 | 65 | LD-1 | 1 | 5807 |
| shf1 | 3 | dove | ma | _3G.Pole | steel | 3 | 55 | 75 | 75 | LD-2 | 2 | 7343 |
| shf1 | 3 | dove | ma | _3G.Pole | steel | 4 | 55 | 75 | 85 | LD-2 | 1 | 8309 |

FILE
 WO ACCOUNT
 CLIENT
 PROJECT
 FEATURE
 ITEM
 BY
 CHECK

E:\AEA-CVEA\PHASE1\DESIGN\COSTS\dbshf1.xls
 WW-1659-HA1-AC
 ALASKA ENERGY AUTHORITY
 COPPER VALLEY INTERTIE FEASIBILITY STUDY
 STRUCTURE DATA CONSOLIDATION
 TYPES shf1
 PED 9/17/93

D8SHF1.XLS

| | | | | | | | | | | | | |
|------|---|----------|-----|----------|-------|---|----|----|----|-------|----|-------|
| shf1 | 3 | dove | ma | _3G.Pole | steel | 5 | 55 | 75 | 95 | LD-3 | 1 | 9923 |
| shf1 | 3 | dove | de | _3G.Pole | steel | 1 | 55 | 75 | 80 | LD-9 | 1 | 9103 |
| shf1 | 3 | dove | de | _3G.Pole | steel | 2 | 55 | 75 | 85 | LD-9 | 2 | 10253 |
| shf1 | 3 | dove | de | _3G.Pole | steel | 3 | 55 | 75 | 75 | LD-8 | 4 | 12592 |
| shf1 | 3 | dove | de | _3G.Pole | steel | 4 | 55 | 75 | 85 | LD-10 | 2 | 15350 |
| shf1 | 3 | dove | de | _3G.Pole | steel | 5 | 55 | 75 | 95 | LD-10 | 2 | 18152 |
| shf1 | 3 | t2linnet | tan | Hframe1 | steel | 1 | 55 | 75 | 80 | LD-3 | 14 | 3857 |
| shf1 | 3 | t2linnet | tan | Hframe1 | steel | 2 | 55 | 75 | 85 | LD-3 | 28 | 4289 |
| shf1 | 3 | t2linnet | tan | Hframe1 | steel | 3 | 55 | 75 | 75 | LD-3 | 58 | 5199 |
| shf1 | 3 | t2linnet | tan | Hframe1 | steel | 4 | 55 | 75 | 85 | LD-3 | 21 | 5923 |
| shf1 | 3 | t2linnet | tan | Hframe1 | steel | 5 | 55 | 75 | 95 | LD-3 | 21 | 6615 |
| shf1 | 3 | t2linnet | la | _3G.Pole | steel | 1 | 55 | 75 | 80 | LD-3 | 1 | 5785 |
| shf1 | 3 | t2linnet | la | _3G.Pole | steel | 2 | 55 | 75 | 85 | LD-3 | 1 | 6434 |
| shf1 | 3 | t2linnet | la | _3G.Pole | steel | 3 | 55 | 75 | 75 | LD-3 | 2 | 7799 |
| shf1 | 3 | t2linnet | la | _3G.Pole | steel | 4 | 55 | 75 | 85 | LD-3 | 1 | 8884 |
| shf1 | 3 | t2linnet | la | _3G.Pole | steel | 5 | 55 | 75 | 95 | LD-3 | 1 | 9923 |
| shf1 | 3 | t2linnet | ma | _3G.Pole | steel | 1 | 55 | 75 | 80 | LD-2 | 1 | 5488 |
| shf1 | 3 | t2linnet | ma | _3G.Pole | steel | 2 | 55 | 75 | 85 | LD-3 | 1 | 6434 |
| shf1 | 3 | t2linnet | ma | _3G.Pole | steel | 3 | 55 | 75 | 75 | LD-3 | 2 | 7799 |
| shf1 | 3 | t2linnet | ma | _3G.Pole | steel | 4 | 55 | 75 | 85 | LD-3 | 1 | 8884 |
| shf1 | 3 | t2linnet | ma | _3G.Pole | steel | 5 | 55 | 75 | 95 | LD-3 | 1 | 9923 |
| shf1 | 3 | t2linnet | de | _3G.Pole | steel | 1 | 55 | 75 | 80 | LD-9 | 1 | 9103 |
| shf1 | 3 | t2linnet | de | _3G.Pole | steel | 2 | 55 | 75 | 85 | LD-9 | 2 | 10253 |
| shf1 | 3 | t2linnet | de | _3G.Pole | steel | 3 | 55 | 75 | 75 | LD-10 | 4 | 13330 |
| shf1 | 3 | t2linnet | de | _3G.Pole | steel | 4 | 55 | 75 | 85 | LD-10 | 2 | 15350 |
| shf1 | 3 | t2linnet | de | _3G.Pole | steel | 5 | 55 | 75 | 95 | LD-10 | 2 | 18152 |
| shf1 | 4 | teal | tan | Hframe1 | steel | 1 | 55 | 75 | 80 | LD-2 | 3 | 3659 |
| shf1 | 4 | teal | tan | Hframe1 | steel | 2 | 55 | 75 | 85 | LD-2 | 8 | 4055 |
| shf1 | 4 | teal | tan | Hframe1 | steel | 3 | 55 | 75 | 75 | LD-2 | 12 | 4895 |
| shf1 | 4 | teal | tan | Hframe1 | steel | 4 | 55 | 75 | 85 | LD-2 | 4 | 5539 |
| shf1 | 4 | teal | tan | Hframe1 | steel | 5 | 55 | 75 | 95 | LD-2 | 4 | 6181 |
| shf1 | 4 | teal | la | _3G.Pole | steel | 1 | 55 | 75 | 80 | LD-2 | 0 | 5488 |
| shf1 | 4 | teal | la | _3G.Pole | steel | 2 | 55 | 75 | 85 | LD-2 | 0 | 6082 |
| shf1 | 4 | teal | la | _3G.Pole | steel | 3 | 55 | 75 | 75 | LD-3 | 0 | 7799 |
| shf1 | 4 | teal | la | _3G.Pole | steel | 4 | 55 | 75 | 85 | LD-3 | 0 | 8884 |
| shf1 | 4 | teal | la | _3G.Pole | steel | 5 | 55 | 75 | 95 | LD-4 | 0 | 10829 |
| shf1 | 4 | teal | ma | _3G.Pole | steel | 1 | 55 | 75 | 80 | LD-3 | 0 | 5785 |
| shf1 | 4 | teal | ma | _3G.Pole | steel | 2 | 55 | 75 | 85 | LD-4 | 0 | 7042 |
| shf1 | 4 | teal | ma | _3G.Pole | steel | 3 | 55 | 75 | 75 | LD-4 | 1 | 8535 |
| shf1 | 4 | teal | ma | _3G.Pole | steel | 4 | 55 | 75 | 85 | LD-4 | 0 | 8705 |
| shf1 | 4 | teal | ma | _3G.Pole | steel | 5 | 55 | 75 | 95 | LD-5 | 0 | 11578 |
| shf1 | 4 | teal | de | _3G.Pole | steel | 1 | 55 | 75 | 80 | LD-9 | 0 | 9103 |
| shf1 | 4 | teal | de | _3G.Pole | steel | 2 | 55 | 75 | 85 | LD-10 | 0 | 10842 |
| shf1 | 4 | teal | de | _3G.Pole | steel | 3 | 55 | 75 | 75 | LD-10 | 0 | 13330 |
| shf1 | 4 | teal | de | _3G.Pole | steel | 4 | 55 | 75 | 85 | LD-10 | 0 | 15350 |
| shf1 | 4 | teal | de | _3G.Pole | steel | 5 | 55 | 75 | 95 | LD-10 | 0 | 18152 |
| shf1 | 4 | 37#9aw | tan | Hframe1 | steel | 1 | 55 | 70 | 55 | LD-3 | 2 | 3449 |
| shf1 | 4 | 37#9aw | tan | Hframe1 | steel | 2 | 55 | 70 | 80 | LD-3 | 3 | 3957 |
| shf1 | 4 | 37#9aw | tan | Hframe1 | steel | 3 | 55 | 70 | 70 | LD-3 | 7 | 4738 |
| shf1 | 4 | 37#9aw | tan | Hframe1 | steel | 4 | 55 | 70 | 80 | LD-3 | 3 | 5438 |
| shf1 | 4 | 37#9aw | tan | Hframe1 | steel | 5 | 55 | 70 | 90 | LD-3 | 3 | 6419 |
| shf1 | 4 | 37#9aw | la | _3G.Pole | steel | 1 | 55 | 70 | 55 | LD-3 | 0 | 5173 |
| shf1 | 4 | 37#9aw | la | _3G.Pole | steel | 2 | 55 | 70 | 60 | LD-3 | 0 | 5765 |
| shf1 | 4 | 37#9aw | la | _3G.Pole | steel | 3 | 55 | 70 | 70 | LD-4 | 0 | 7770 |
| shf1 | 4 | 37#9aw | la | _3G.Pole | steel | 4 | 55 | 70 | 80 | LD-4 | 0 | 8919 |
| shf1 | 4 | 37#9aw | la | _3G.Pole | steel | 5 | 55 | 70 | 90 | LD-4 | 0 | 10508 |
| shf1 | 4 | 37#9aw | ma | _3G.Pole | steel | 1 | 55 | 70 | 55 | LD-6 | 0 | 6883 |
| shf1 | 4 | 37#9aw | ma | _3G.Pole | steel | 2 | 55 | 70 | 60 | LD-6 | 0 | 7691 |

FILE
 WO ACCOUNT
 CLIENT
 PROJECT
 FEATURE
 ITEM
 BY
 CHECK

E:\AEA-CVEA\PHASE1\DESIGN\COSTS\dbshf1.xls
 WW-1558-HA1-AC
 ALASKA ENERGY AUTHORITY
 COPPER VALLEY INTERTIE FEASIBILITY STUDY
 STRUCTURE DATA CONSOLIDATION
 TYPES shf1
 PED 9/17/83

DBSHF1.XLS

| | | | | | | | | | | | | |
|------|---|--------|----|----------|-------|---|----|----|----|-------|---|-------|
| shf1 | 4 | 37#9aw | ma | _3G.Pole | steel | 3 | 55 | 70 | 70 | LD-8 | 1 | 9130 |
| shf1 | 4 | 37#9aw | ma | _3G.Pole | steel | 4 | 55 | 70 | 80 | LD-8 | 0 | 11008 |
| shf1 | 4 | 37#9aw | ma | _3G.Pole | steel | 5 | 55 | 70 | 80 | LD-8 | 0 | 13032 |
| shf1 | 4 | 37#8aw | de | _3G.Pole | steel | 1 | 55 | 70 | 55 | LD-10 | 0 | 8873 |
| shf1 | 4 | 37#9aw | de | _3G.Pole | steel | 2 | 55 | 70 | 60 | LD-10 | 0 | 9822 |
| shf1 | 4 | 37#9aw | de | _3G.Pole | steel | 3 | 55 | 70 | 70 | LD-10 | 0 | 12065 |
| shf1 | 4 | 37#9aw | de | _3G.Pole | steel | 4 | 55 | 70 | 80 | LD-10 | 0 | 13887 |
| shf1 | 4 | 37#9aw | de | _3G.Pole | steel | 5 | 55 | 70 | 90 | LD-10 | 0 | 16719 |

| | | | | | | | | | | | | | | | | | | | |
|----|--|--|---------------|---------|---------|---------|---------|---------|---------|---------|---------|---------|---------|---------|---------|---------|--|--|--|
| 1 | FILE | e:\aaa-cvealphase1\design\costs | | | | | | | | | | | | | | | | | |
| 2 | WORK ORDER ACCOUNT | WW-1559-HA1-AC | | | | | | | | | | | | | | | | | |
| 3 | CLIENT | ALASKA ENERGY AUTHORITY | | | | | | | | | | | | | | | | | |
| 4 | PROJECT | COPPER VALLEY INTERTIE FEASIBILITY STUDY | | | | | | | | | | | | | | | | | |
| 5 | FEATURE | Unit Costs - Materials | | | | | | | | | | | | | | | | | |
| 6 | BY | PED | 8/31/93 | updated | | | | | | | | | | | | | | | |
| 7 | CHECK | | | | | | | | | | | | | | | | | | |
| 9 | Enter "1" in column A if Distributor, Inspection, or Shipping Costs included in table, "0" if not. | | | | | | | | | | | | | | | | | | |
| 10 | A | STRUCTURES | | | | | | | | | | | | | | | | | |
| 11 | | | | | | | | | | | | | | | | | | | |
| 12 | | | | | | | | | | | | | | | | | | | |
| 13 | WOOD POLES | | | | | | | | | | | | | | | | | | |
| 14 | Type of Wood >>> | WRC | QUOTED PRICES | | | | | | | | | | | | | | | | |
| 15 | name | name | CLASS | 40 | 45 | 50 | 55 | 60 | 65 | 70 | 75 | 80 | 85 | 90 | | | | | |
| 16 | 0 | DISWPYN | 10% | DISTWP | 2 | \$525 | \$600 | \$800 | \$900 | \$1,000 | \$1,150 | \$1,300 | \$1,350 | \$1,700 | \$1,800 | \$1,950 | | | |
| 17 | 0 | INSPWYN | 25% | INSPWP | 1 | \$550 | \$650 | \$889 | \$1,008 | \$1,149 | \$1,294 | \$1,457 | \$1,598 | \$1,950 | \$2,072 | \$2,150 | | | |
| 18 | 1 | SHPPWYN | 10% | SHPPWP | H1 | \$700 | \$850 | \$1,000 | \$1,283 | \$1,418 | \$1,591 | \$1,833 | \$2,028 | \$2,183 | \$2,300 | \$2,400 | | | |
| 19 | | | | | H2 | \$900 | \$1,025 | \$1,182 | \$1,384 | \$1,561 | \$1,746 | \$1,999 | \$2,207 | \$2,435 | \$2,659 | \$2,800 | | | |
| 20 | | | | | | | | | | | | | | | | | | | |
| 21 | Source | ADJUSTED PRICES | | | | | | | | | | | | | | | | | |
| 22 | McFarland Cascade Pole | LENGTH (ft) | | | | | | | | | | | | | | | | | |
| 23 | costs in italics are RWB estimates | CLASS | 40 | 45 | 50 | 55 | 60 | 65 | 70 | 75 | 80 | 85 | 90 | | | | | | |
| 24 | based on interpolation | 2 | \$603 | \$685 | \$905 | \$1,015 | \$1,125 | \$1,290 | \$1,455 | \$1,510 | \$1,895 | \$2,005 | \$2,170 | | | | | | |
| 25 | | 1 | \$630 | \$740 | \$981 | \$1,132 | \$1,289 | \$1,448 | \$1,628 | \$1,781 | \$2,170 | \$2,304 | \$2,390 | | | | | | |
| 26 | | H1 | \$795 | \$960 | \$1,125 | \$1,414 | \$1,585 | \$1,775 | \$2,041 | \$2,258 | \$2,404 | \$2,555 | \$2,665 | | | | | | |
| 27 | | H2 | \$1,015 | \$1,153 | \$1,325 | \$1,547 | \$1,742 | \$1,946 | \$2,224 | \$2,453 | \$2,704 | \$2,950 | \$3,105 | | | | | | |
| 28 | | | | | | | | | | | | | | | | | | | |
| 29 | | | | | | | | | | | | | | | | | | | |
| 30 | Type of Wood >>> | DF | QUOTED PRICES | | | | | | | | | | | | | | | | |
| 31 | | | CLASS | 40 | 45 | 50 | 55 | 60 | 65 | 70 | 75 | 80 | 85 | 90 | | | | | |
| 32 | | | 2 | \$500 | \$550 | \$750 | \$825 | \$900 | \$1,100 | \$1,300 | \$1,400 | \$1,600 | \$1,800 | \$1,900 | | | | | |
| 33 | | | 1 | \$575 | \$600 | \$806 | \$932 | \$1,078 | \$1,251 | \$1,440 | \$1,620 | \$1,829 | \$2,057 | \$2,100 | | | | | |
| 34 | | | H1 | \$650 | \$750 | \$900 | \$1,083 | \$1,316 | \$1,478 | \$1,649 | \$1,831 | \$2,021 | \$2,200 | \$2,300 | | | | | |
| 35 | | | H2 | \$800 | \$941 | \$1,083 | \$1,251 | \$1,481 | \$1,661 | \$1,850 | \$2,071 | \$2,281 | \$2,501 | \$2,650 | | | | | |
| 36 | | | | | | | | | | | | | | | | | | | |
| 37 | ADJUSTED PRICES | | | | | | | | | | | | | | | | | | |
| 38 | LENGTH (ft) | | | | | | | | | | | | | | | | | | |
| 39 | | | CLASS | 40 | 45 | 50 | 55 | 60 | 65 | 70 | 75 | 80 | 85 | 90 | | | | | |
| 40 | | | 2 | \$575 | \$630 | \$850 | \$933 | \$1,015 | \$1,235 | \$1,455 | \$1,585 | \$1,785 | \$2,005 | \$2,115 | | | | | |
| 41 | | | 1 | \$658 | \$685 | \$912 | \$1,050 | \$1,209 | \$1,401 | \$1,609 | \$1,807 | \$2,037 | \$2,288 | \$2,335 | | | | | |
| 42 | | | H1 | \$740 | \$850 | \$1,015 | \$1,216 | \$1,473 | \$1,651 | \$1,839 | \$2,039 | \$2,248 | \$2,445 | \$2,555 | | | | | |
| 43 | | | H2 | \$905 | \$1,080 | \$1,216 | \$1,401 | \$1,654 | \$1,852 | \$2,060 | \$2,303 | \$2,534 | \$2,776 | \$2,940 | | | | | |
| 44 | | | | | | | | | | | | | | | | | | | |
| 45 | | | | | | | | | | | | | | | | | | | |
| 46 | STEEL POLES (Wood Pole Equivalents) | | | | | | | | | | | | | | | | | | |
| 47 | | | | | | | | | | | | | | | | | | | |
| 48 | Enter "1" in column A if Distributor, Shipping or other Costs included in prices, "0" if not. | | | | | | | | | | | | | | | | | | |
| 49 | name | name | | | | | | | | | | | | | | | | | |
| 50 | 0 | DISSPYN | 5% | DISTSP | | | | | | | | | | | | | | | |
| 51 | 1 | SHPPSPYN | 10% | SHPPSP | | | | | | | | | | | | | | | |
| 52 | 1 | PNTSPYN | 7% | PAINTSP | | | | | | | | | | | | | | | |
| 53 | 1 | GALSPYN | 12% | GALVSP | | | | | | | | | | | | | | | |
| 54 | WEIGHT (lbs) | | | | | | | | | | | | | | | | | | |
| 55 | Type of Steel >>> | Self-weathering | LENGTH(ft) | LD-1 | LD-10 | LD-2 | LD-3 | LD-4 | LD-5 | LD-6 | LD-7 | LD-8 | LD-9 | LD-9 | | | | | |
| 56 | | | 40 | 882 | 1614 | 920 | 957 | 1046 | 1087 | 1261 | 1428 | 1482 | 1528 | | | | | | |
| 57 | Source | Date | 8/31/93 | 45 | 1024 | 1988 | 1080 | 1107 | 1209 | 1262 | 1484 | 1658 | 1725 | 1786 | | | | | |
| 58 | X | MEYERS | | 50 | 1182 | 2175 | 1207 | 1284 | 1381 | 1444 | 1678 | 1898 | 1982 | 2058 | | | | | |
| 59 | | PSI | | 55 | 1304 | 2477 | 1358 | 1428 | 1561 | 1638 | 1900 | 2151 | 2254 | 2344 | | | | | |
| 60 | | VALMONT | | 60 | 1450 | 2777 | 1515 | 1597 | 1739 | 1827 | 2123 | 2403 | 2523 | 2627 | | | | | |
| 61 | | | | 65 | 1603 | 3129 | 1679 | 1776 | 1944 | 2048 | 2380 | 2693 | 2834 | 2959 | | | | | |
| 62 | | | Criteria | 70 | 1763 | 3482 | 1850 | 1982 | 2145 | 2288 | 2635 | 2981 | 3144 | 3289 | | | | | |

| | A | B | C | D | E | F | G | H | I | J | K | L | M | N | O | P | Q | R | S | T |
|-----|--------------------|--|--------|------|------|------|------|------|------|------|------|------|------|------|------|---|---|---|---|---|
| 1 | FILE | e:\cvs-cve\phase1\design\costs | | | | | | | | | | | | | | | | | | |
| 2 | WORK ORDER ACCOUNT | WW-1559-HA1-AC | | | | | | | | | | | | | | | | | | |
| 3 | CLIENT | ALASKA ENERGY AUTHORITY | | | | | | | | | | | | | | | | | | |
| 4 | PROJECT | COPPER VALLEY INTERTIE FEASIBILITY STUDY | | | | | | | | | | | | | | | | | | |
| 5 | FEATURE | Unit Costs - Materials | | | | | | | | | | | | | | | | | | |
| 6 | BY | PED 8/31/93 updated | | | | | | | | | | | | | | | | | | |
| 7 | CHECK | | | | | | | | | | | | | | | | | | | |
| 63 | Price/lb | Length | Weight | 75 | 1927 | 3847 | 2027 | 2153 | 2358 | 2496 | 2901 | 3281 | 3468 | 3634 | 3834 | | | | | |
| 64 | \$1.15 | SPPRC1 | 75 | 2500 | 80 | 2098 | 4229 | 2209 | 2354 | 2574 | 2734 | 3177 | 3593 | 3805 | 3994 | | | | | |
| 65 | \$1.10 | SPPRC2 | 90 | 4000 | 85 | 2270 | 4641 | 2398 | 2564 | 2801 | 2980 | 3464 | 3917 | 4156 | 4369 | | | | | |
| 66 | \$1.05 | SPPRC3 | 105 | 5000 | 90 | 2450 | 5055 | 2594 | 2779 | 3032 | 3235 | 3781 | 4250 | 4520 | 4775 | | | | | |
| 67 | | | | | 95 | 2634 | 5488 | 2794 | 3000 | 3274 | 3500 | 4069 | 4597 | 4897 | 5181 | | | | | |
| 68 | | | | | 100 | 2832 | 5934 | 3010 | 3238 | 3524 | 3771 | 4385 | 4958 | 5302 | 5601 | | | | | |
| 69 | | | | | 105 | 3028 | 6396 | 3223 | 3473 | 3781 | 4053 | 4713 | 5327 | 5707 | 6036 | | | | | |
| 70 | | | | | 110 | 3225 | 6873 | 3441 | 3716 | 4046 | 4344 | 5052 | 5710 | 6126 | 6486 | | | | | |
| 71 | | | | | 115 | 3543 | 7631 | 3776 | 4090 | 4454 | 5022 | 5598 | 6329 | 6786 | 7193 | | | | | |
| 72 | | | | | 120 | 3753 | 8140 | 4011 | 4349 | 4734 | 5384 | 5959 | 6736 | 7232 | 7677 | | | | | |
| 73 | | Wood Pole Class Equiv >> | | | 1 | | | H1 | H2 | H3 | H4 | H5 | H6 | | | | | | | |
| 74 | | | | | | | | | | | | | | | | | | | | |
| 75 | | | | | | | | | | | | | | | | | | | | |
| 76 | | | | | | | | | | | | | | | | | | | | |
| 77 | | | | | | | | | | | | | | | | | | | | |
| 78 | | | | | | | | | | | | | | | | | | | | |
| 79 | | | | | | | | | | | | | | | | | | | | |
| 80 | | | | | | | | | | | | | | | | | | | | |
| 81 | | | | | | | | | | | | | | | | | | | | |
| 82 | | | | | | | | | | | | | | | | | | | | |
| 83 | | | | | | | | | | | | | | | | | | | | |
| 84 | | | | | | | | | | | | | | | | | | | | |
| 85 | | | | | | | | | | | | | | | | | | | | |
| 86 | | | | | | | | | | | | | | | | | | | | |
| 87 | | | | | | | | | | | | | | | | | | | | |
| 88 | | | | | | | | | | | | | | | | | | | | |
| 89 | | | | | | | | | | | | | | | | | | | | |
| 90 | | | | | | | | | | | | | | | | | | | | |
| 91 | | | | | | | | | | | | | | | | | | | | |
| 92 | | | | | | | | | | | | | | | | | | | | |
| 93 | | | | | | | | | | | | | | | | | | | | |
| 94 | | | | | | | | | | | | | | | | | | | | |
| 95 | | | | | | | | | | | | | | | | | | | | |
| 96 | | | | | | | | | | | | | | | | | | | | |
| 97 | | | | | | | | | | | | | | | | | | | | |
| 98 | | | | | | | | | | | | | | | | | | | | |
| 99 | | | | | | | | | | | | | | | | | | | | |
| 100 | | | | | | | | | | | | | | | | | | | | |
| 101 | | | | | | | | | | | | | | | | | | | | |
| 102 | | | | | | | | | | | | | | | | | | | | |
| 103 | | | | | | | | | | | | | | | | | | | | |
| 104 | | | | | | | | | | | | | | | | | | | | |
| 105 | | | | | | | | | | | | | | | | | | | | |
| 106 | | | | | | | | | | | | | | | | | | | | |
| 107 | | | | | | | | | | | | | | | | | | | | |
| 108 | | | | | | | | | | | | | | | | | | | | |
| 109 | | | | | | | | | | | | | | | | | | | | |
| 110 | | | | | | | | | | | | | | | | | | | | |
| 111 | | | | | | | | | | | | | | | | | | | | |
| 112 | | | | | | | | | | | | | | | | | | | | |
| 113 | | | | | | | | | | | | | | | | | | | | |
| 114 | | | | | | | | | | | | | | | | | | | | |
| 115 | | | | | | | | | | | | | | | | | | | | |
| 116 | | | | | | | | | | | | | | | | | | | | |

| | A | B | C | D | E | F | G | H | I | J | K | L | M | N | O | P | Q | R | S | T | |
|-----|---|--------------------|----|------|--|---|---|---|---|---|----|------|---|---|---|---|---|---|---|---|--|
| 1 | | FILE | | | e:\ee-cva\phase1\design\costs | | | | | | | | | | | | | | | | |
| 2 | | WORK ORDER ACCOUNT | | | WW-1559-HA1-AC | | | | | | | | | | | | | | | | |
| 3 | | CLIENT | | | ALASKA ENERGY AUTHORITY | | | | | | | | | | | | | | | | |
| 4 | | PROJECT | | | COPPER VALLEY INTERTIE FEASIBILITY STUDY | | | | | | | | | | | | | | | | |
| 5 | | FEATURE | | | Unit Costs - Materials | | | | | | | | | | | | | | | | |
| 6 | | BY | | | PED 8/31/93 updated | | | | | | | | | | | | | | | | |
| 7 | | CHECK | | | | | | | | | | | | | | | | | | | |
| 117 | | | V= | 3000 | | | | | | | R= | 11.0 | | | | | | | | | |
| 118 | | | L= | 3000 | | | | | | | | | | | | | | | | | |
| 119 | | | R= | 4.5 | | | | | | | | | | | | | | | | | |
| 120 | | | | | Note that index moment above is resultant of point loads times structure height. | | | | | | | | | | | | | | | | |
| 121 | | | | | | | | | | | | | | | | | | | | | |
| 122 | | | | | | | | | | | | | | | | | | | | | |
| 123 | | | | | | | | | | | | | | | | | | | | | |
| 124 | | | | | | | | | | | | | | | | | | | | | |
| 125 | | | | | | | | | | | | | | | | | | | | | |
| 126 | | | | | | | | | | | | | | | | | | | | | |
| 127 | | | | | | | | | | | | | | | | | | | | | |
| 128 | | | | | | | | | | | | | | | | | | | | | |
| 129 | | | | | | | | | | | | | | | | | | | | | |
| 130 | | | | | | | | | | | | | | | | | | | | | |
| 131 | | | | | | | | | | | | | | | | | | | | | |
| 132 | | | | | | | | | | | | | | | | | | | | | |
| 133 | | | | | | | | | | | | | | | | | | | | | |
| 134 | | | | | | | | | | | | | | | | | | | | | |
| 135 | | | | | | | | | | | | | | | | | | | | | |
| 136 | | | | | | | | | | | | | | | | | | | | | |
| 137 | | | | | | | | | | | | | | | | | | | | | |
| 138 | | | | | | | | | | | | | | | | | | | | | |
| 139 | | | | | | | | | | | | | | | | | | | | | |
| 140 | | | | | | | | | | | | | | | | | | | | | |
| 141 | | | | | | | | | | | | | | | | | | | | | |
| 142 | | | | | | | | | | | | | | | | | | | | | |
| 143 | | | | | | | | | | | | | | | | | | | | | |
| 144 | | | | | | | | | | | | | | | | | | | | | |
| 145 | | | | | | | | | | | | | | | | | | | | | |
| 146 | | | | | | | | | | | | | | | | | | | | | |
| 147 | | | | | | | | | | | | | | | | | | | | | |
| 148 | | | | | | | | | | | | | | | | | | | | | |
| 149 | | | | | | | | | | | | | | | | | | | | | |
| 150 | | | | | | | | | | | | | | | | | | | | | |
| 151 | | | | | | | | | | | | | | | | | | | | | |
| 152 | | | | | | | | | | | | | | | | | | | | | |
| 153 | | | | | | | | | | | | | | | | | | | | | |
| 154 | | | | | | | | | | | | | | | | | | | | | |
| 155 | | | | | | | | | | | | | | | | | | | | | |
| 156 | | | | | | | | | | | | | | | | | | | | | |
| 157 | | | | | | | | | | | | | | | | | | | | | |
| 158 | | | | | | | | | | | | | | | | | | | | | |
| 159 | | | | | | | | | | | | | | | | | | | | | |
| 160 | | | | | | | | | | | | | | | | | | | | | |
| 161 | | | | | | | | | | | | | | | | | | | | | |
| 162 | | | | | | | | | | | | | | | | | | | | | |
| 163 | | | | | | | | | | | | | | | | | | | | | |
| 164 | | | | | | | | | | | | | | | | | | | | | |
| 165 | | | | | | | | | | | | | | | | | | | | | |
| 166 | | | | | | | | | | | | | | | | | | | | | |
| 167 | | | | | | | | | | | | | | | | | | | | | |
| 168 | | | | | | | | | | | | | | | | | | | | | |
| 169 | | | | | | | | | | | | | | | | | | | | | |
| 170 | | | | | | | | | | | | | | | | | | | | | |

| | A | B | C | D | E | F | G | H | I | J | K | L | M | N | O | P | Q | R | S | T | |
|-----|------------------------------|---------|-----|--------|--|-----|-------|------------------|-----|-------|------|------|-------|------------------|-------|----------|----------|----------|----------|---|--|
| 1 | FILE | | | | e:\aaa-oveal\phase1\design\coste | | | | | | | | | | | | | | | | |
| 2 | WORK ORDER ACCOUNT | | | | WW-1559-HA1-AC | | | | | | | | | | | | | | | | |
| 3 | CLIENT | | | | ALASKA ENERGY AUTHORITY | | | | | | | | | | | | | | | | |
| 4 | PROJECT | | | | COPPER VALLEY INTERTIE FEASIBILITY STUDY | | | | | | | | | | | | | | | | |
| 5 | FEATURE | | | | Unit Costs - Materials | | | | | | | | | | | | | | | | |
| 6 | BY | | | | PED 8/31/93 updated | | | | | | | | | | | | | | | | |
| 7 | CHECK | | | | | | | | | | | | | | | | | | | | |
| 171 | | | | | | | | 105 | | 8922 | | 9074 | | 11348 | | na | | | | | |
| 172 | | | | | | | | | | | | | | | | | | | | | |
| 173 | | | | | 4 | 35 | 13390 | na | | 14980 | 4378 | na | na | na | 16480 | 3833 | | | | | |
| 174 | | | | | | 40 | | na | | 4549 | | | | | | 4003 | | | | | |
| 175 | | | | | | 45 | | na | | 4718 | | | | | | 4174 | | | | | |
| 176 | | | | | | 50 | | na | | 4890 | | | | | | 4344 | | | | | |
| 177 | | | | | | 55 | | na | | 5060 | | | | | | 4515 | | | | | |
| 178 | | | | | | 60 | | na | | 5020 | | | | | | 5081 | | | | | |
| 179 | | | | | | 65 | | na | | 5847 | | | | | | 5302 | | | | | |
| 180 | | | | | | 70 | | na | | 6089 | | | | | | 5523 | | | | | |
| 181 | | | | | | 75 | | na | | 7496 | | | | | | 6951 | | | | | |
| 182 | | | | | | 80 | | na | | 7828 | | | | | | 7284 | | | | | |
| 183 | | | | | | 85 | | na | | 8162 | | | | | | 7616 | | | | | |
| 184 | | | | | | 90 | | na | | 8495 | | | | | | 7949 | | | | | |
| 185 | | | | | | 85 | | na | | 8828 | | | | | | 8282 | | | | | |
| 186 | | | | | | 100 | | na | | 9161 | | | | | | 8615 | | | | | |
| 187 | | | | | | 105 | | na | | 11831 | | | | | | 11285 | | | | | |
| 188 | | | | | | | | | | | | | | | | | | | | | |
| 189 | X-frame Weights for Intertie | | | | | | | | | | | | | | | | | | | | |
| 190 | | | | | | | | | | | | | | | | | | | | | |
| 191 | | | | | | | | | | | | | | | | | | | | | |
| 192 | 1 | DISXFYX | 10% | DISTXF | | | | Conductor Height | 1 | | | | | Conductor Height | 1 | | | | | | |
| 193 | 1 | SHPXFYX | 10% | SHIPXF | | | | | 2 | 3 | 4 | | | | 2 | 3 | 4 | | | | |
| 194 | | | | | | | | Dove | 35 | 3807 | 4084 | 3807 | na | Dove | 35 | \$4,588 | \$4,901 | \$4,588 | #VALUE! | | |
| 195 | | | | | | | | | 40 | 3977 | 4254 | 3977 | na | | 40 | \$4,772 | \$5,105 | \$4,772 | #VALUE! | | |
| 196 | | | | | | | | | 45 | 4147 | 4425 | 4147 | na | | 45 | \$4,976 | \$5,310 | \$4,976 | #VALUE! | | |
| 197 | | | | | | | | | 50 | 4318 | 4595 | 4318 | na | | 50 | \$5,182 | \$5,422 | \$5,182 | #VALUE! | | |
| 198 | | | | | | | | | 55 | 4488 | 4766 | 4488 | na | | 55 | \$5,296 | \$5,824 | \$5,296 | #VALUE! | | |
| 199 | | | | | | | | | 60 | 4659 | 4836 | 4659 | na | | 60 | \$5,498 | \$5,824 | \$5,498 | #VALUE! | | |
| 200 | | | | | | | | | 65 | 5276 | 5553 | 5276 | na | | 65 | \$6,226 | \$6,553 | \$6,226 | #VALUE! | | |
| 201 | | | | | | | | | 70 | 5497 | 5774 | 5497 | na | | 70 | \$6,486 | \$6,813 | \$6,486 | #VALUE! | | |
| 202 | | | | | | | | | 75 | 5718 | 5996 | 5718 | na | | 75 | \$6,576 | \$6,895 | \$6,576 | #VALUE! | | |
| 203 | | | | | | | | | 80 | 5939 | 7535 | 7257 | na | | 80 | \$6,830 | \$8,865 | \$8,346 | #VALUE! | | |
| 204 | | | | | | | | | 85 | 7590 | 7868 | 7590 | na | | 85 | \$8,729 | \$9,048 | \$8,729 | #VALUE! | | |
| 205 | | | | | | | | | 90 | 7923 | 8201 | 7923 | na | | 90 | \$9,111 | \$9,431 | \$9,111 | #VALUE! | | |
| 206 | | | | | | | | | 95 | 8258 | 8533 | 8258 | na | | 95 | \$9,494 | \$9,813 | \$9,494 | #VALUE! | | |
| 207 | | | | | | | | | 100 | 8589 | 8866 | 8589 | na | | 100 | \$9,877 | \$10,196 | \$9,877 | #VALUE! | | |
| 208 | | | | | | | | | 105 | 8922 | 9199 | 8922 | na | | 105 | \$10,280 | \$10,579 | \$10,280 | #VALUE! | | |
| 209 | | | | | | | | | | | | | | | | | | | | | |
| 210 | | | | | | | | Teal | 35 | 3881 | 3958 | 3958 | 4378 | Teal | 35 | \$4,417 | \$4,750 | \$4,750 | \$5,254 | | |
| 211 | | | | | | | | | 40 | 3851 | 4129 | 4129 | 4549 | | 40 | \$4,821 | \$4,955 | \$4,955 | \$5,368 | | |
| 212 | | | | | | | | | 45 | 4022 | 4299 | 4299 | 4719 | | 45 | \$4,826 | \$5,159 | \$5,159 | \$5,588 | | |
| 213 | | | | | | | | | 50 | 4192 | 4470 | 4470 | 4890 | | 50 | \$5,030 | \$5,364 | \$5,364 | \$5,770 | | |
| 214 | | | | | | | | | 55 | 4363 | 4640 | 4640 | 5080 | | 55 | \$5,148 | \$5,475 | \$5,475 | \$5,971 | | |
| 215 | | | | | | | | | 60 | 4533 | 4811 | 4811 | 5628 | | 60 | \$5,349 | \$5,677 | \$5,677 | \$6,839 | | |
| 216 | | | | | | | | | 65 | 5150 | 5428 | 5428 | 5847 | | 65 | \$6,077 | \$6,405 | \$6,405 | \$6,899 | | |
| 217 | | | | | | | | | 70 | 5371 | 5649 | 5629 | 6089 | | 70 | \$6,338 | \$6,666 | \$6,642 | \$7,181 | | |
| 218 | | | | | | | | | 75 | 5592 | 5870 | 5870 | 7496 | | 75 | \$6,431 | \$6,751 | \$6,751 | \$8,820 | | |
| 219 | | | | | | | | | 80 | 7132 | 7409 | 7409 | 7828 | | 80 | \$8,202 | \$8,520 | \$8,520 | \$9,000 | | |
| 220 | | | | | | | | | 85 | 7465 | 7742 | 7742 | 8182 | | 85 | \$8,585 | \$8,903 | \$8,903 | \$9,386 | | |
| 221 | | | | | | | | | 90 | 7798 | 8075 | 8075 | 8495 | | 90 | \$8,968 | \$9,286 | \$9,286 | \$9,769 | | |
| 222 | | | | | | | | | 95 | 8130 | 8408 | 8408 | 8828 | | 95 | \$9,350 | \$9,669 | \$9,669 | \$10,152 | | |
| 223 | | | | | | | | | 100 | 8463 | 8741 | 8741 | 9161 | | 100 | \$9,732 | \$10,052 | \$10,052 | \$10,535 | | |
| 224 | | | | | | | | | 105 | 8796 | 9074 | 9074 | 11831 | | 105 | \$10,115 | \$10,435 | \$10,435 | \$13,806 | | |

| A | B | C | D | E | F | G | H | I | J | K | L | M | N | O | P | Q | R | S | T |
|-----|--------------------|---------------------------|---|--|---|----------|----------|-------|-------|----------|-------|-------|----------|-------|----------|----------|----------|----|----------|
| 1 | FILE | | | s:\aee-cve\phase1\design\costs | | | | | | | | | | | | | | | |
| 2 | WORK ORDER ACCOUNT | | | WW-1559-HA1-AC | | | | | | | | | | | | | | | |
| 3 | CLIENT | | | ALASKA ENERGY AUTHORITY | | | | | | | | | | | | | | | |
| 4 | PROJECT | | | COPPER VALLEY INTERTIE FEASIBILITY STUDY | | | | | | | | | | | | | | | |
| 5 | FEATURE | | | Unit Costs - Materials | | | | | | | | | | | | | | | |
| 6 | BY | | | PED 8/31/93 updated | | | | | | | | | | | | | | | |
| 7 | CHECK | | | | | | | | | | | | | | | | | | |
| 225 | | | | | | | | | | | | | | | | | | | |
| 226 | | | | | | T2Linnet | 35 | 3898 | 3898 | 3898 | na | | T2Linnet | 35 | \$4,875 | \$4,875 | \$4,875 | na | |
| 227 | | | | | | | 40 | 4088 | 4088 | 4088 | na | | | 40 | \$4,879 | \$4,879 | \$4,879 | na | |
| 228 | | | | | | | 45 | 4238 | 4238 | 4238 | na | | | 45 | \$5,083 | \$5,083 | \$5,083 | na | |
| 229 | | | | | | | 50 | 4407 | 4407 | 4407 | na | | | 50 | \$5,288 | \$5,288 | \$5,288 | na | |
| 230 | | | | | | | 55 | 4577 | 4577 | 4577 | na | | | 55 | \$5,401 | \$5,401 | \$5,401 | na | |
| 231 | | | | | | | 60 | 5144 | 5144 | 5144 | na | | | 60 | \$8,070 | \$8,070 | \$8,070 | na | |
| 232 | | | | | | | 65 | 5385 | 5385 | 5385 | na | | | 65 | \$8,331 | \$8,331 | \$8,331 | na | |
| 233 | | | | | | | 70 | 5588 | 5588 | 5588 | na | | | 70 | \$8,591 | \$8,591 | \$8,591 | na | |
| 234 | | | | | | | 75 | 7013 | 5807 | 7013 | na | | | 75 | \$8,085 | \$8,078 | \$8,085 | na | |
| 235 | | | | | | | 80 | 7348 | 7348 | 7348 | na | | | 80 | \$8,448 | \$8,448 | \$8,448 | na | |
| 236 | | | | | | | 85 | 7742 | 7742 | 8182 | na | | | 85 | \$8,903 | \$8,903 | \$9,388 | na | |
| 237 | | | | | | | 90 | 8075 | 8075 | 8495 | na | | | 90 | \$9,288 | \$9,288 | \$9,789 | na | |
| 238 | | | | | | | 95 | 8408 | 8408 | 8828 | na | | | 95 | \$9,889 | \$9,889 | \$10,152 | na | |
| 239 | | | | | | | 100 | 8741 | 8741 | 9181 | na | | | 100 | \$10,052 | \$10,052 | \$10,535 | na | |
| 240 | | | | | | | 105 | 9074 | 9074 | 11831 | na | | | 105 | \$10,435 | \$10,435 | \$13,808 | na | |
| 241 | | | | | | | | | | | | | | | | | | | |
| 242 | | | | | | 37#9AW | 35 | na | na | na | 3833 | | 37#9AW | 35 | na | na | na | na | \$5,009 |
| 243 | | | | | | | 40 | na | na | na | 4003 | | | 40 | na | na | na | na | \$4,804 |
| 244 | | | | | | | 45 | na | na | na | 4174 | | | 45 | na | na | na | na | \$5,009 |
| 245 | | | | | | | 50 | na | na | na | 4344 | | | 50 | na | na | na | na | \$5,213 |
| 246 | | | | | | | 55 | na | na | na | 4515 | | | 55 | na | na | na | na | \$5,328 |
| 247 | | | | | | | 60 | na | na | na | 5081 | | | 60 | na | na | na | na | \$5,998 |
| 248 | | | | | | | 65 | na | na | na | 5302 | | | 65 | na | na | na | na | \$8,258 |
| 249 | | | | | | | 70 | na | na | na | 5523 | | | 70 | na | na | na | na | \$8,517 |
| 250 | | | | | | | 75 | na | na | na | 6951 | | | 75 | na | na | na | na | \$7,994 |
| 251 | | | | | | | 80 | na | na | na | 7284 | | | 80 | na | na | na | na | \$8,377 |
| 252 | | | | | | | 85 | na | na | na | 7818 | | | 85 | na | na | na | na | \$8,758 |
| 253 | | | | | | | 90 | na | na | na | 7949 | | | 90 | na | na | na | na | \$9,141 |
| 254 | | | | | | | 95 | na | na | na | 8282 | | | 95 | na | na | na | na | \$9,524 |
| 255 | | | | | | | 100 | na | na | na | 8815 | | | 100 | na | na | na | na | \$9,907 |
| 256 | | | | | | | 105 | na | na | na | 11285 | | | 105 | na | na | na | na | \$12,978 |
| 257 | | | | | | | | | | | | | | | | | | | |
| 258 | B | INSULATOR ASSEMBLY | | | | | | | | | | | | | | | | | |
| 259 | | | | | | 1 | 1 | 1 | 2 | 2 | 2 | 3 | 3 | 3 | 4 | 4 | 4 | | |
| 260 | | | | | | Dove | T2Linnet | Teal | Dove | T2Linnet | Teal | Dove | T2Linnet | Teal | 37#9AW | Dove | Teal | | |
| 261 | TANGENT | I-String | | | | \$212 | \$109 | \$212 | \$192 | \$109 | \$192 | \$201 | \$118 | \$201 | \$183 | \$201 | \$201 | | |
| 262 | TANGENT | V-String | | | | \$377 | \$275 | \$377 | \$377 | \$275 | \$377 | \$395 | \$293 | \$395 | \$357 | \$395 | \$385 | | |
| 263 | TANGENT | Inverted V-String | | | | | | | | | | | | | | | | | |
| 264 | TANGENT | Horz-Vee | | | | \$700 | \$700 | \$700 | \$700 | \$700 | \$700 | \$700 | \$700 | \$700 | \$700 | \$700 | \$700 | | |
| 265 | LA | Running Angle, Bracket | | | | \$328 | \$243 | \$328 | \$383 | \$300 | \$383 | \$335 | \$317 | \$335 | \$383 | \$400 | \$400 | | |
| 266 | MA | Running Angle, No Bracket | | | | \$881 | \$288 | \$881 | \$881 | \$288 | \$881 | \$878 | \$381 | \$878 | \$710 | \$695 | \$695 | | |
| 267 | DE | No Jumper | | | | \$283 | \$322 | \$283 | \$283 | \$258 | \$283 | \$299 | \$312 | \$299 | \$857 | \$299 | \$299 | | |
| 268 | DE | With Jumper | | | | \$539 | \$578 | \$539 | \$539 | \$512 | \$539 | \$588 | \$599 | \$588 | \$944 | \$588 | \$588 | | |
| 269 | | | | | | | | | | | | | | | | | | | |
| 270 | | | | | | | | | | | | | | | | | | | |
| 271 | | | | | | | | | | | | | | | | | | | |
| 272 | | | | | | | | | | | | | | | | | | | |
| 273 | | | | | | | | | | | | | | | | | | | |
| 274 | | | | | | | | | | | | | | | | | | | |
| 275 | | | | | | | | | | | | | | | | | | | |
| 276 | | | | | | | | | | | | | | | | | | | |
| 277 | | | | | | | | | | | | | | | | | | | |
| 278 | C | BRACING | | | | | | | | | | | | | | | | | |

| | A | B | C | D | E | F | G | H | I | J | K | L | M | N | O | P | Q | R | S | T |
|-----|----------------------|--|--------|-----------|---------|---------|-----------|-------------------------|------------------------------|----------|---------|---------|-------|---|---|---|---|---|---|---|
| 1 | FILE | e:\ee-cvea\phase1\design\costs | | | | | | | | | | | | | | | | | | |
| 2 | WORK ORDER ACCOUNT | WW-1559-HA1-AC | | | | | | | | | | | | | | | | | | |
| 3 | CLIENT | ALASKA ENERGY AUTHORITY | | | | | | | | | | | | | | | | | | |
| 4 | PROJECT | COPPER VALLEY INTERTIE FEASIBILITY STUDY | | | | | | | | | | | | | | | | | | |
| 5 | FEATURE | Unit Costs - Materials | | | | | | | | | | | | | | | | | | |
| 6 | BY | PED 8/31/93 updated | | | | | | | | | | | | | | | | | | |
| 7 | CHECK | | | | | | | | | | | | | | | | | | | |
| 279 | | | | | | | | | | | | | | | | | | | | |
| 280 | Hframe, Type 1 | TH-10 >>>>> | | | \$600 | | WOOD | | | | | | | | | | | | | |
| 281 | 0 Xbrace | | | | 0 | | Xbrace | 2056-16 | \$250 | 2096-16 | \$350 | 2094-16 | \$300 | | | | | | | |
| 282 | 0 Vbrace | | | | 0 | | Xbrace | 2077-16 | \$275 | 2096A-16 | \$375 | | | | | | | | | |
| 283 | 0 Crosstie | | | | 0 | | Xbrace | 2086-16 | \$300 | 2096b-16 | \$400 | | | | | | | | | |
| 284 | 1 Xarm | | | 600 | 600 | | | | | | | | | | | | | | | |
| 285 | | | | | | | | | | | | | | | | | | | | |
| 286 | Hframe, Type 4 | TH-10V4X >>>>> | | | \$1,175 | | V-brace | 2025-11 | \$50 | | | | | | | | | | | |
| 287 | 1 Xbrace | HB 2094 | 400 | 400 | | | V-brace | 2038-11 | \$80 | | | | | | | | | | | |
| 288 | 4 Braces | | 75 | 300 | | | | | | | | | | | | | | | | |
| 289 | 1 Crosstie | | 75 | 75 | | | Xarm 1 | 4-5/8x9-3/8,36" | | 510 | | | | | | | | | | |
| 290 | 1 Xarm | 3-1/8x9' | 400 | 400 | | | Xarm 2 | 4-5/8x9-5/8,32" | | 475 | | | | | | | | | | |
| 291 | | | | | | | | | | | | | | | | | | | | |
| 292 | Steel Hframe, Type 1 | | | | | | | | | | | | | | | | | | | |
| 293 | 0 Xbrace | | 0 | | | | | | | | | | | | | | | | | |
| 294 | \$1.20 Xarm | | 525 lb | | \$630 | | Zone2 | | | | | | | | | | | | | |
| 295 | \$1.20 Xarm | | 850 lb | | \$1,020 | | Others | | | | | | | | | | | | | |
| 296 | Steel Hframe, Type 4 | | | | | | | | | | | | | | | | | | | |
| 297 | \$1.00 Xbrace | | 540 lb | | \$540 | | | | | | | | | | | | | | | |
| 298 | \$1.20 Xarm | | 525 lb | | \$630 | | | | | | | | | | | | | | | |
| 299 | \$100 Braces | | 4 ea | | \$400 | | | | | | | | | | | | | | | |
| 300 | | | | | \$1,570 | | All Zones | | | | | | | | | | | | | |
| 301 | | | | | | | | | | | | | | | | | | | | |
| 302 | | | | | | | | | | | | | | | | | | | | |
| 303 | | | | | | | | | | | | | | | | | | | | |
| 304 | D FOUNDATIONS | | | | | | | | | | | | | | | | | | | |
| 305 | | | | | | | | | | | | | | | | | | | | |
| 306 | | | | | | | | | | | | | | | | | | | | |
| 307 | Xframe | Type 1 | Hpile | 10x57 | cost/ft | \$80 | | Estimated Material Cost | | | | | | | | | | | | |
| 308 | | | 1 | 2 | 3 | 4 | | 1 | 2 | 3 | 4 | | | | | | | | | |
| 309 | | Teal | 17 | 17 | 17 | 19 | | Teal | \$1,360 | \$1,360 | \$1,360 | \$1,520 | | | | | | | | |
| 310 | | Dove | 16 | 17 | 17 | 18 | | Dove | \$1,280 | \$1,360 | \$1,380 | \$1,440 | | | | | | | | |
| 311 | | T2Linnet | 17 | 18 | 18 | na | | T2Linnet | \$1,360 | \$1,440 | \$1,440 | na | | | | | | | | |
| 312 | | 37#9AW | na | na | na | 18 | | 37#9AW | na | na | na | \$1,440 | | | | | | | | |
| 313 | | pile lengths do not vary appreciably with structure height | | | | | | | | | | | | | | | | | | |
| 314 | | | | | | | | | | | | | | | | | | | | |
| 315 | | | | | | | | | | | | | | | | | | | | |
| 316 | Hframe | Pipe Pile | Pipe | 30"x1/4"t | cost/ft | \$110 | lbs/ft | 79.90 | Assumptions for Geotechnical | | | | | | | | | | | |
| 317 | Zone 2 | H | L | Cost | | | | | 1 | 2 | 3 | 4 | | | | | | | | |
| 318 | | 50 | 15.5 | \$1,705 | | | | Glacial Till | 70% | 10% | 50% | 50% | | | | | | | | |
| 319 | | 55 | 16.0 | \$1,780 | | | | Muskeg | 20% | 10% | 20% | 20% | | | | | | | | |
| 320 | | 80 | 16.5 | \$1,815 | | | | Permafrost | 0% | 80% | 20% | 0% | | | | | | | | |
| 321 | | 85 | 17.0 | \$1,870 | | | | Rock | 10% | 0% | 10% | 30% | | | | | | | | |
| 322 | | 70 | 17.0 | \$1,870 | | | | | | | | | | | | | | | | |
| 323 | | 75 | 17.5 | \$1,925 | | | | | | | | | | | | | | | | |
| 324 | | 80 | 18.0 | \$1,980 | | | | | | | | | | | | | | | | |
| 325 | | 85 | 18.5 | \$2,035 | | | | | | | | | | | | | | | | |
| 326 | | 90 | 19.0 | \$2,090 | | | | | | | | | | | | | | | | |
| 327 | | 85 | 19.5 | \$2,145 | | | | | | | | | | | | | | | | |
| 328 | | | | | | | | | | | | | | | | | | | | |
| 329 | 3G-Pole | Hpile | 2x17' | 10x57 | 34 | \$2,720 | per pole | | | | | | | | | | | | | |
| 330 | Zone 2 | battered | | | | | | | | | | | | | | | | | | |
| 331 | | | | | | | | | | | | | | | | | | | | |
| 332 | | | | | | | | | | | | | | | | | | | | |

| A | B | C | D | E | F | G | H | I | J | K | L | M | N | O | P | Q | R | S | T |
|-----|--------------------|-----------------------|-----|--|---------------|---------|------------------------------------|-------|----|---------|----------|---|---|---|---|---|---|---|---|
| 1 | FILE | | | e:\aaa-cv\phase1\design\costs | | | | | | | | | | | | | | | |
| 2 | WORK ORDER ACCOUNT | | | WW-1559-HA1-AC | | | | | | | | | | | | | | | |
| 3 | CLIENT | | | ALASKA ENERGY AUTHORITY | | | | | | | | | | | | | | | |
| 4 | PROJECT | | | COPPER VALLEY INTERTIE FEASIBILITY STUDY | | | | | | | | | | | | | | | |
| 5 | FEATURE | | | Unit Costs - Materials | | | | | | | | | | | | | | | |
| 6 | BY | | | PED | 8/31/93 | updated | | | | | | | | | | | | | |
| 7 | CHECK | | | | | | | | | | | | | | | | | | |
| 333 | | | | | | | | | | | | | | | | | | | |
| 334 | | | | | | | | | | | | | | | | | | | |
| 335 | | | | | | | | | | | | | | | | | | | |
| 336 | | | | | | | | | | | | | | | | | | | |
| 337 | | | | | | | | | | | | | | | | | | | |
| 338 | | | | | | | | | | | | | | | | | | | |
| 339 | | | | | | | | | | | | | | | | | | | |
| 340 | | | | | | | | | | | | | | | | | | | |
| 341 | | | | | | | | | | | | | | | | | | | |
| 342 | | | | | | | | | | | | | | | | | | | |
| 343 | | | | | | | | | | | | | | | | | | | |
| 344 | | | | | | | | | | | | | | | | | | | |
| 345 | | | | | | | | | | | | | | | | | | | |
| 346 | | | | | | | | | | | | | | | | | | | |
| 347 | | | | | | | | | | | | | | | | | | | |
| 348 | | | | | | | | | | | | | | | | | | | |
| 349 | | | | | | | | | | | | | | | | | | | |
| 350 | | | | | | | | | | | | | | | | | | | |
| 351 | | | | | | | | | | | | | | | | | | | |
| 352 | | | | | | | | | | | | | | | | | | | |
| 353 | | | | | | | | | | | | | | | | | | | |
| 354 | | | | | | | | | | | | | | | | | | | |
| 355 | | | | | | | | | | | | | | | | | | | |
| 356 | | | | | | | | | | | | | | | | | | | |
| 357 | | | | | | | | | | | | | | | | | | | |
| 358 | | | | | | | | | | | | | | | | | | | |
| 359 | | | | | | | | | | | | | | | | | | | |
| 360 | | | | | | | | | | | | | | | | | | | |
| 361 | E | GUY ANCHOR ASSEMBLIES | | | | | | | | | | | | | | | | | |
| 362 | | | | | | | | | | | | | | | | | | | |
| 363 | 1 | DISANYN | 10% | DISTANCH | | | | | | | | | | | | | | | |
| 364 | 1 | SHPANYN | 10% | SHIPANCH | | | | | | | | | | | | | | | |
| 365 | | | | | | | | | | | | | | | | | | | |
| 366 | | GUY S | | | | | | | | | | | | | | | | | |
| 367 | | | | | | | | | | | | | | | | | | | |
| 368 | | | | Quote | Adjusted | | | | | | | | | | | | | | |
| 369 | | Xframe Guy Assembly 1 | | \$222.78 | \$222.78 | | | | | | | | | | | | | | |
| 370 | | Xframe Guy Assembly 2 | | \$290.41 | \$290.41 | | | | | | | | | | | | | | |
| 371 | | Single Down Guy 20k | | \$110.51 | \$110.51 | | | | | | | | | | | | | | |
| 372 | | Single Down Guy 30k | | \$157.60 | \$157.60 | | | | | | | | | | | | | | |
| 373 | | Single Down Guy 35k | | \$176.88 | \$176.88 | | | | | | | | | | | | | | |
| 374 | | Single Down Guy 40k | | \$235.58 | \$235.58 | | | | | | | | | | | | | | |
| 375 | | Single Down Guy 60k | | \$511.87 | \$511.87 | | | | | | | | | | | | | | |
| 376 | | | | | | | | | | | | | | | | | | | |
| 377 | | ANCHORS | | | | | | | | | | | | | | | | | |
| 378 | | | | | | | | | | | | | | | | | | | |
| 379 | | GLACIAL TILL | | Length | Material Cost | | MUSKEG/PF | | | Cost/ft | | | | | | | | | |
| 380 | | 20k Anchor Plate | | | \$40 | | 20k Anchor Hpile | 10x57 | 17 | \$80 | | | | | | | | | |
| 381 | | 30k Anchor Plate | | | \$60 | | 30k Anchor Hpile | 10x57 | 21 | | | | | | | | | | |
| 382 | | 40k Anchor Plate | | | \$80 | | 40k Anchor Hpile | 10x57 | 25 | | | | | | | | | | |
| 383 | | 50k Anchor Plate | | | \$100 | | 50k Anchor Hpile | 10x57 | 30 | | | | | | | | | | |
| 384 | | 25k Anchor Log | | | \$100 | | assumes L = 8' + Tload/(4.5 + 0.5) | | | | | | | | | | | | |
| 385 | | 35k Anchor Log | | | \$150 | | | | | Fixed | Variable | | | | | | | | |
| 386 | | 45k Anchor Log | | | \$200 | | ROCK | | | \$0 | \$8 | | | | | | | | |

| A | B | C | D | E | F | G | H | I | J | K | L | M | N | O | P | Q | R | S | T |
|-----|--------------------|--|----------|-----------|---------------|--------|--|-----------|--------|--------------|----------|------------------|----------|--------|---------|---|---|---|------|
| 1 | FILE | a:\ee-cvea\phase1\design\costs | | | | | | | | | | | | | | | | | |
| 2 | WORK ORDER ACCOUNT | WW-1558-HA1-AC | | | | | | | | | | | | | | | | | |
| 3 | CLIENT | ALASKA ENERGY AUTHORITY | | | | | | | | | | | | | | | | | |
| 4 | PROJECT | COPPER VALLEY INTERTIE FEASIBILITY STUDY | | | | | | | | | | | | | | | | | |
| 5 | FEATURE | Unit Costs - Materials | | | | | | | | | | | | | | | | | |
| 6 | BY | PED 8/31/93 updated | | | | | | | | | | | | | | | | | |
| 7 | CHECK | | | | | | | | | | | | | | | | | | |
| 387 | 50k Anchor | Log | | | \$250 | | 25k Anchor | Rock bolt | 8 | ft | | | | | | | | | \$48 |
| 388 | 60k Anchor | Log | | | \$300 | | 35k Anchor | Rock bolt | 7 | ft | | | | | | | | | \$58 |
| 389 | 25k Anchor | HPile | 10x57 | 18 | \$1,520 | | 45k Anchor | Rock bolt | 8 | ft | | | | | | | | | \$84 |
| 390 | 35k Anchor | HPile | 10x57 | 23 | \$1,840 | | 50k Anchor | Rock bolt | 8 | ft | | | | | | | | | \$72 |
| 391 | 45k Anchor | HPile | 10x57 | 27 | \$2,160 | | 60k Anchor Bolt Rock bo | 10 | ft | | | | | | | | | | \$80 |
| 392 | 50k Anchor | HPile | 10x57 | 30 | \$2,400 | | assumes 75 ksi working bond stress grout to rock | | | | | | | | | | | | |
| 393 | 60k Anchor | HPile | 10x57 | 35 | \$2,800 | | assumes 9.5 k/ft load developed. | | | | | | | | | | | | |
| 394 | | | | | | | | | | | | | | | | | | | |
| 395 | | | | | | | | | | | | | | | | | | | |
| 396 | | | | | | | | | | | | | | | | | | | |
| 397 | F | CONDUCTOR | | | | | | | | | | | | | | | | | |
| 398 | | | | | | | | | | | | | | | | | | | |
| 399 | 1 | DISCONYN | 10% | DISTCOND | | | | | | | | | | | | | | | |
| 400 | 1 | SHPCONYN | 10% | SHIPCOND | | | | | | | | | | | | | | | |
| 401 | 0 | NONSPYN | 2.80% | NONSPEC | | | | | | | | | | | | | | | |
| 402 | | | | | | unit | Alum | CABLEC | ALUM | ACPC | ADJUST | CONDUCTOR FINISH | | | | | | | |
| 403 | | 558 kcmil | ACSR | Dove | Standard | wt/ft | wt/ft | \$/lb | ESCAL | \$/lb | MFG\$/LB | \$/lb | name | SPEC | NONSPEC | | | | |
| 404 | | 605 kcmil | ACSR | Teal | Standard | 0.788 | 0.525 | 1.039 | 10% | 0.96 | 0.350339 | \$0.92 | DOVE | \$0.92 | \$0.95 | | | | |
| 405 | | 2x838 kcmil | ACSR/T2 | T2/Linnet | Standard | 0.939 | 0.572 | 1.152 | | 0.919 | 0.421535 | \$0.97 | TEAL | \$0.97 | \$1.00 | | | | |
| 406 | | 558 kcmil | ASCR/ehs | Dove | HS CORE | 0.928 | 0.634 | 1.188 | | 0.884 | 0.454454 | \$1.03 | T2LINNET | \$1.03 | \$1.05 | | | | |
| 407 | | 605 kcmil | ASCR/ehs | Teal | HS CORE | 0.788 | 0.525 | 1.081 | | 0.898 | 0.388339 | \$0.98 | DOVEEHS | \$0.98 | \$0.98 | | | | |
| 408 | | 605 kcmil | SSAC | Teal | SSAC | 0.939 | 0.572 | 1.194 | | 0.981 | 0.463535 | \$1.02 | TEALEHS | \$1.02 | \$1.04 | | | | |
| 409 | | 37#9AW NA | AW | Alumoweld | Alumoweld | 1.108 | NA | 1.325 | | 1.125 | 0.827535 | \$1.18 | TEALSSAC | \$1.18 | \$1.21 | | | | |
| 410 | | | | | | | | | | | | | | | | | | | |
| 411 | | | | | | \$/lb | | \$/lb | | | | | | | | | | | |
| 412 | | | | | 1893 AL INGOT | \$0.58 | EST FUT | AL INGOT | \$0.85 | 85-0.58/0.58 | | 18.07% | | | | | | | |
| 413 | | | | | ST CORE | \$0.40 | EST FUT | ST | \$0.40 | | | | | | | | | | |
| 414 | | | | | | | | | | | | | | | | | | | |
| 415 | | | | | | | | | | | | | | | | | | | |
| 416 | | | | | | | | | | | | | | | | | | | |

Alaska Energy Authority
 Copper Valley Intertie
 Insulator Assembly Material - TEAL Conductor
 PED 8/18/93

REV

1/6/94

| | | Estimating Data | | | | | |
|------------------|--------------------|------------------|--------------------|-----|-----|----------|----------|
| Loading Zone 1 | | Average Span | 900 ft | | | | |
| | | Zone Length | 26.55 mi | | | | |
| | | Total Structures | 156 | | | | |
| 75% | Tangent I String | Qty/Str | 2 | | | \$212.00 | |
| 107 | Anchor Shackle | 25k | AND AS-25 | 1 | 214 | \$3.45 | \$3.45 |
| | Insulator | 12.5k RTL, YC-B | OB 511007-1201 | 1 | 214 | \$89.00 | \$89.00 |
| | Suspension Clamp | 30k | AND HAS-182-S | 1 | 214 | \$13.35 | \$13.35 |
| | Armor Rod | Teal | PRE AR 0137 | 1 | 214 | \$59.94 | \$59.94 |
| | Vibration Damper | Teal/AR | FARGO 60710-12 | 1 | 214 | \$26.00 | \$26.00 |
| Tangent V-String | | Qty/Str | 1 | | | \$377.08 | |
| | Extension Link | 12",25k | AND HOO 30L | 2 | 214 | \$21.20 | \$42.40 |
| | Anchor Shackle | 25k | AND AS-25 | 2 | 214 | \$3.45 | \$6.90 |
| | Insulator | 12.5k RTL, YC-B | OB 511007-1201 | 2 | 214 | \$89.00 | \$178.00 |
| | Socket Y Clevis | 30k | AND SYC 30 | 2 | 214 | \$8.28 | \$16.56 |
| | Yoke Plate | 30k | AND YPD-30-15238-2 | 1 | 107 | \$26.57 | \$26.57 |
| | Y Clevis | 30k | AND YCS-16-90 | 1 | 107 | \$7.36 | \$7.36 |
| | Suspension Clamp | 30k | AND HAS-182-S | 1 | 107 | \$13.35 | \$13.35 |
| | Armor Rod | Teal | PRE AR 0137 | 1 | 107 | \$59.94 | \$59.94 |
| | Vibration Damper | Teal/AR | FARGO 60710-12 | 1 | 107 | \$26.00 | \$26.00 |
| 15% | LA Structure | Qty/Str | 3 | | | \$325.74 | |
| 21 | Swinging Bracket | Heavy, 3ft | HB 2848-F | 1 | 64 | \$134.00 | \$134.00 |
| | Anchor Shackle | 25k | AND AS-25 | 1 | 64 | \$3.45 | \$3.45 |
| | Insulator | 12.5k RTL, YC-B | OB 511007-1201 | 1 | 64 | \$89.00 | \$89.00 |
| | Suspension Clamp | 30k | AND HAS-182-S | 1 | 64 | \$13.35 | \$13.35 |
| | Armor Rod | Teal | PRE AR 0137 | 1 | 64 | \$59.94 | \$59.94 |
| | Vibration Damper | Teal/AR | FARGO 60710-12 | 1 | 64 | \$26.00 | \$26.00 |
| 10% | MA Structure | Qty/Str | 3 | | | \$680.76 | |
| 14 | Swinging Bracket | Heavy, 2ft | HB 2848-A | 1 | 43 | \$102.00 | \$102.00 |
| | Anchor Shackle | 50k | AND AS-50 | 1 | 43 | \$5.40 | \$5.40 |
| | Insulator | 25k RTL, YC-B | OB 513007-1201 | 1 | 43 | \$168.00 | \$168.00 |
| | Double AGS | 40k | PRE AGS-5826 | 1 | 43 | \$167.08 | \$167.08 |
| | Yoke Plate | 40k | PRE YP 5909 | 1 | 43 | \$165.03 | \$165.03 |
| | Socket Clevis | 50k | PRE SC-5329 | 1 | 43 | \$47.25 | \$47.25 |
| | Vibration Damper | | FARGO 60710-12 | 1 | 43 | \$26.00 | \$26.00 |
| | Deadend | Qty/Str | 6 | | | \$538.70 | \$282.70 |
| 13 | Anchor Shackle | 50k | AND AS-50 | 1 | 78 | \$5.40 | \$5.40 |
| | Insulator | 25k RTL, YC-B | OB 513008-1201 | 1 | 78 | \$182.00 | \$182.00 |
| | HL Socket -YClevis | 50k | AND HSYC-50 | 1 | 78 | \$21.88 | \$21.88 |
| | Comp DE w Term | Teal | FARGO A 0312-29 | 1 | 78 | \$45.00 | \$45.00 |
| | Jumper Post | | OB 522008-1102 | 0.0 | 0 | \$256.00 | \$0.00 |
| | Suspension Clamp | Teal | AND TSC-106 | 1 | 39 | \$4.83 | \$2.42 |
| 156 | Vibration Damper | | FARGO 60710-12 | 1 | 78 | \$26.00 | \$26.00 |

Estimating