



December 2024 Copper Basin Outages 10 Outages



■ Operator error ■ Equipment failure ■ Construction ■ Material or equipment fault/failure


During this period one generation unit at the Glennallen Diesel plant tripped offline twice due to an intermittent mechanical issue causing two different load shed events. We continue to work on a resolution.

November 2024 Copper Basin Outages 3 Outages




■ Unknown Cause ■ Wind/trees in ROW ■ Construction

October 2024 Copper Basin Outages 5 Outages




■ Trees (non-weather related) ■ Material or equipment fault/failure ■ Animals/birds ■ Public or Members

September 2024 Copper Basin Outages 4 Outages




■ Animals/birds ■ Public or Members ■ Trees (non-weather related) ■ Wind/trees outside ROW

August 2024 Copper Basin Outages 14 Outages




- Material or equipment fault/failure
- Trees (non-weather related)
- CVEA caused
- Public or Members
- Maintenance
- Animals/birds
- Wind/trees outside ROW
- Unknown Cause

July 2024 Copper Basin Outages 6 Outages




- Material or equipment fault/failure
- Wind/trees outside ROW
- Trees (non-weather related)
- Unknown

June 2024 Copper Basin Outages 7 Outages




■ Material or equipment fault/failure ■ Construction ■ Wind/trees outside ROW

May 2024 Copper Basin Outages 7 Outages




■ Construction ■ Trees (non-weather related)
■ Material or equipment fault/failure ■ Animals/birds
■ Snow/ice/sleet/frost (not trees)

April 2024 Copper Basin Outages 5 Outages




■ Trees (non-weather related) ■ Maintenance
■ Wind/trees outside ROW ■ Material or equipment fault/failure

March 2024 Copper Basin Outages 4 Outages



■ Unknown Cause ■ CVEA caused
■ Material or equipment fault/failure ■ Wind (not trees)

February 2024 Copper Basin Outages 10 Outages



January 2024 Copper Basin Outages 15 Outages

