
November 2025 Copper Basin Outages 7 Outages




Public or Members

Unknown Cause


■ Snow/ice/sleet/frost (not trees)

No Outages in October 2025 in the Copper Basin


September 2025 Copper Basin Outages 3 Outages




August 2025 Copper Basin Outages 8 Outages




July 2025 Copper Basin Outages 10 Outages



June 2025 Copper Basin Outages 7 Outages




May 2025 Copper Basin Outages 3 Outages




Date	Cause
5/2/2025	Tree on line, removed, closed cutout
5/12/2025	Scheduled outage to replace pole at R63-12
5/19/2025	Unknown reason for open fuse AT G187-5, refused

April 2025 Copper Basin Outages 6 Outages



Date	Cause
4/2/2025	Squirrel blew cutout, refused
4/9/2025	Replaced dead end bells
4/13/2025	Tree on wire at E5-8, removed tree and closed F2421/31A, outside ROW
4/14/2025	Phase off insulator, replaced insulator
4/16/2025	Down wire span, wire rehung
4/27/2025	Bad elbow on transformer, replaced


March 2025 Copper Basin Outages 8 Outage



- Material or equipment fault/failure
- Trees (non-weather related)

- Animals/birds
- Unknown Cause

February 2025 Copper Basin Outages 1 Outage



January 2025 Copper Basin Outages 22 Outages

